



Craig W. Silverstein
craig.silverstein@marchcounsel.com
202.640.2111

May 16, 2024

VIA ETARIFF/ELECTRONIC FILING

The Honorable Debbie-Anne A. Reese
Acting Secretary, Office of the Secretary
Federal Energy Regulatory Commission
888 First Street, NE
Washington, DC 20426

Re: *Golden Spread Electric Cooperative, Inc.*
Docket No. ER24-____-000
Proposed Open Access Transmission Tariff Revisions
Order No. 2023/2023-A Compliance – Attachments M, N, O and P
Filing Type Code: 80

Dear Acting Secretary Reese:

Pursuant to the directives of the Federal Energy Regulatory Commission (“FERC” or “Commission”) in Order No. 2023 and 2023-A,¹ and its October 25, 2023 order extending compliance deadlines,² Golden Spread Electric Cooperative, Inc. (“Golden Spread”) hereby submits for filing its compliance filing to include the following revised Attachments to Golden Spread’s Open Access Transmission Tariff (“OATT” or “Tariff”):

- Attachment M, Standard Large Generator Interconnection Procedures (“LGIP”);
- Attachment N, Standard Large Generator Interconnection Agreement (“LGIA”);
- Attachment O, Small Generator Interconnection Procedures (“SGIP”); and
- Attachment P, Small Generator Interconnection Agreement (“SGIA”).

Golden Spread submits this filing in accordance with sections 205 and 206 of the Federal Power Act (“FPA”)³ and Part 35 of the Commission’s regulations.⁴

¹ *Improvements to Generator Interconnection Procs. & Agreements*, Order No. 2023, 88 Fed. Reg. 61,014 (Sept. 6, 2023), 184 FERC ¶ 61,054 (2023), Order No. 2023-A, 89 Fed. Reg. 27,006 (Apr. 16, 2024), 186 FERC ¶ 61,199, P 667 (2024).

² *Improvements to Generator Interconnection Procs. & Agreements*, Order on Motions and Addressing Limited Arguments Raised on Rehearing and Setting Aside Prior Order, in Part, 185 FERC ¶ 61,063 (2023).

³ 16 U.S.C. §§ 824d and 824e.

⁴ 18 C.F.R. Part 35.

The Honorable Debbie-Anne A. Reese
May 16, 2024
Page 2

Except as discussed below, Golden Spread's revised Attachments M, N, O, and P will incorporate without modification the Commission's *pro forma* language with respect to the LGIP, LGIA, SGIP and SGIA that is mandated by Order Nos. 2023 and 2023-A. Golden Spread requests an effective date of May 17, 2024, the day after this compliance filing was submitted.

In support of its compliance filing, Golden Spread states as follows:

I. COMMUNICATIONS

All communications and service related to this filing should be directed to the following individuals:

Shane McMinn
Director of Power Delivery
Michael Johnson
Power Delivery Services
Golden Spread Electric Cooperative, Inc.
Post Office Box 9898
Amarillo, Texas 79105-5898
(806) 379-7766 (telephone)
(806) 374-2922 (facsimile)
shane@gsec.coop
mjohnson@gsec.coop

* Craig Silverstein
March Counsel LLC
2001 L Street, NW
Suite 500
Washington DC 20036
(202) 640-2100 (Phone)
craig.silverstein@marchcounsel.com

II. DESCRIPTION OF GOLDEN SPREAD AND ITS TARIFF

Golden Spread is a non-profit electric generation and transmission cooperative organized under the Texas Electric Cooperative Corporation Act. Golden Spread's main corporate purpose is to supply cost effective and reliable wholesale electric power and energy to its sixteen Member cooperatives. Golden Spread supplies wholesale power to its sixteen Member cooperatives in the Southwest Power Pool ("SPP") and the Electric Reliability Council of Texas. Golden Spread's members provide electric service to about 318,000 retail electric meters serving member consumers located in the Panhandle, South Plains, and Edward Plateau regions of Texas, an area covering 24 percent of the state, and in the Panhandle of Oklahoma and in small portions of Southwestern Kansas and Southeastern Colorado.

On June 18, 1987, the Commission determined that Golden Spread was a public utility subject to the Commission's jurisdiction and accepted Golden Spread's initial rates to provide wholesale full requirements service to its member systems pursuant to Section 205 of the FPA. On April 24, 2012, the Commission accepted Golden Spread's OATT for filing.⁵ Concurrent with that acceptance and in subsequent orders, Golden Spread was granted a waiver of standards of conduct and the obligation to operate an open-access same-time information system

⁵ *Golden Spread Elec. Coop., Inc.*, 139 FERC ¶ 61,067 (2012).

The Honorable Debbie-Anne A. Reese
May 16, 2024
Page 3

("OASIS").⁶ Golden Spread's limited owned facilities within the Eastern Interconnection⁷ are comprised of facilities that Golden Spread has financed and/or constructed (as needed) on behalf of its requesting members ("Special Facilities") that are used to supply the loads of the specific member participating in what is referred to as "Rider A" of Golden Spread's requirements wholesale power contract with its member. Due to the discrete nature of its facilities, all transmission service purchased or requested on the Golden Spread system under its OATT has been point-to-point service; there are no network integration transmission service customers and Part III of the Tariff has been eliminated. Golden Spread's transmission system is fully embedded in other balancing authority areas; Golden Spread does not provide any balancing authority area services. Golden Spread has one generator interconnection customer and no generator interconnection requests in its queue.

III. DESCRIPTION OF THE COMPLIANCE FILING

A. *Pro Forma* Edits

In the instant filing Golden Spread proposes changes to Attachments M, N, O, and P of its OATT to implement the changes directed by Order Nos. 2023 and 2023-A. Golden Spread is proposing to implement each substantive change set forth in Order Nos. 2023 and 2023-A without modification. Because such changes are described in considerable detail within the Final Rule and in the interests of brevity, Golden Spread will not repeat the purpose of each such change in this filing. Below, Golden Spread provides a narrative of aspects of its generator interconnection procedures and agreements that are specific to its OATT and relevant to the instant compliance filing.

B. LGIP Section 3.3.2 – Process for Surplus Interconnection Service

In conjunction with its Order No. 845 compliance filings, Golden Spread proposed, and the Commission accepted, a Process for Surplus Interconnection Service.⁸ Golden Spread proposes to retain this provision.

C. LGIP Section 3.4.1 – Cluster Request Window

Order No. 2023 provides that each Transmission Provider will establish the start date of its initial Cluster Request Window.⁹ The *pro forma* LGIP includes a placeholder for each

⁶ *Black Hills Power, Inc., et al.*, 135 FERC ¶ 61,058, P 48 (2011), *aff'd Golden Spread Elec. Coop., Inc.*, Docket No. ER11-3404-002 (Jan. 24, 2014) (unpublished letter order).

⁷ Golden Spread also owns non-jurisdictional facilities located in the Electric Reliability Council of Texas which are subject to its interconnection and transmission regulations and protocols.

⁸ Three orders were issued: Order on Compliance, *Golden Spread Elec. Coop., Inc.*, 169 FERC ¶ 61,141 (2019); Order on Compliance, *Golden Spread Elec. Coop., Inc.*, 171 FERC ¶ 61,027 (2020), *Golden Spread Elec. Coop., Inc.*, Docket No. ER19-1900-004 (November 4, 2020)(unpublished letter order). The Process Surplus Interconnection Service was accepted at 171 FERC ¶ 61,027 at P 20.

⁹ Order No. 2023 at P 223.

The Honorable Debbie-Anne A. Reese
May 16, 2024
Page 4

Transmission Provider to provide the number of calendar days after conclusion of the transition study process when it will begin the first standard cluster study process.

Golden Spread proposes 180 calendar days after the conclusion transition process set forth in Section 5.1 of the LGIP (Procedures for Transitioning to the Cluster Study Process). This proposal reflects Golden Spread's best estimate of how long it would take for projects that participate in the transitional cluster study to execute LGIAs, and it accounts for Golden Spread's limited resources. Once Golden Spread completes the LGIA processes for the projects that participate in the Transitional Cluster Study, it will then turn resources towards the Initial Cluster Study process.

The *pro forma* LGIP also requires Transmission Providers to establish an annual open date for all successive Cluster Request Windows after the initial Cluster Request Window in LGIP Section 3.4.1. Golden Spread proposes February 1, which it anticipates will align with its annual load forecasting and will allow Golden Spread to use up-to-date system data when conducting Cluster Studies.

D. LGIP Section 3.5.2.3 – Interconnection Facilities Studies Processing Time

LGIP Section 3.5.2.3, as revised by Order Nos. 2023 and 2023-A, requires each Transmission Provider to provide a list of its Interconnection Facilities Studies processing timelines (in subsections (B) and (C)). Golden Spread proposes to retain the timelines currently in its Attachment M, which are “90 days with a cost variance of 20% or 180 days with a cost variance of 10%.” The Commission accepted these timelines as part of Golden Spread's Order No. 845 compliance.¹⁰

E. LGIP Section 3.8 – Contingent Facilities

Pro forma Section 3.8 of the LGIP requires each Transmission Provider to post “a method for identifying the Contingent Facilities to be provided to Interconnection Customer at the conclusion of the Cluster Study and included in Interconnection Customer's Large Generator Interconnection Agreement.”

Golden Spread's LGIP currently includes Section 3.8 (Identification of Contingent Facilities), Section 3.8.1 (Method for Identifying Contingent Facilities), Section 3.8.2 (Estimates Available for Contingent Facilities), and Section 3.8.3 (Inclusion of Contingent Facilities in LGIA), all of which were first inserted to comply with Order No. 845. The Commission accepted all such sections detailing Golden Spread's identification of Contingent Facilities in two orders on compliance.¹¹ With the exception of changing references to the System Impact Study to the Cluster Study, Golden Spread does not propose to make any changes to such sections in this instant filing.

¹⁰ 169 FERC ¶ 61,141 (2019).

¹¹ 169 FERC ¶ 61,141 (2019); 171 FERC ¶ 61,027 (2020).

The Honorable Debbie-Anne A. Reese
May 16, 2024
Page 5

F. LGIP Section 4.2.1 – Network Upgrade Cost Allocation Method

Order No. 2023 requires Transmission Providers to allocate network upgrade costs based on a proportional impact method,¹² and LGIP Section 4.2.1(1)(b) includes a placeholder for Transmission Providers to include a description of how costs for each facility type designated as a network upgrade will be allocated using its proportional impact method. Golden Spread proposes the following language:

The proportional impact of such Network Upgrades shall be calculated as follows: All transmission lines and transformers identified as Network Upgrades shall be allocated using distribution factor or similar analysis. Voltage support related Network Upgrades shall be allocated using a voltage impact analysis which will identify each Generating Facility's contribution to the voltage violation. Network Upgrades associated with upgrading existing breakers due to short circuit current exceeding breaker capability shall be allocated proportionally based on the short circuit current contribution of each request.

Golden Spread notes that it modeled this language on the corresponding provision proposed by Duke Energy Carolinas, LLC on behalf of Duke Energy Florida, LLC ("DEF"), to comply with Order No. 2023.¹³ DEF's proposed language was accepted by the Commission on March 21, 2024.¹⁴

G. LGIP Section 4.4.3.1

Because Golden Spread does not use fuel-based dispatch assumptions in Interconnection Studies, consistent with the directives in Order No. 2023, it does not include Section 4.4.3.1 in its LGIP.

H. Definition of Permissible Technological Advancement and LGIP Section 4.4.6 – Technological Change Procedures

The Commission previously directed Transmission Providers to insert a definition of "Permissible Technological Advancement" in its LGIP. Golden Spread's proposes to retain the definition that is currently in its Attachment M:

Permissible Technological Advancement shall mean a new, upgraded, updated or improved technology that an Interconnection Customer intends to utilize in the design, construction or operation

¹² Order No. 2023 at P 453; *see also id.* at PP 454-467.

¹³ Duke Energy Florida, LLC – Compliance Filing Containing Revisions to Attachment J to Joint OATT (LGIP/LGIA), Docket No. ER24-679-000 (Dec. 15, 2023), at 3-4.

¹⁴ *Duke Energy Carolinas, LLC, et al.* 186 FERC ¶ 61,200, P 31 (2024).

The Honorable Debbie-Anne A. Reese
May 16, 2024
Page 6

of generation or transmission facilities but does not (a) include a change in the generation technology or fuel type or (b) constitute a Material Modification.

As noted in Order No. 2023 (at P 1682), Section 4.4.6 includes each Transmission Provider's definition of its technological change procedures.

Golden Spread included both its definition of Permissible Technological Advancement and its existing technological change procedures in Section 4.4.6 of the LGIP in revisions made in compliance with Order No. 845. The Commission accepted both Golden Spread's definition of Permissible Technological Advancement and Golden Spread's description of such procedures in a series of orders on compliance accepting its Order No. 845 compliance filings.¹⁵ Golden Spread does not propose to make any substantive changes to such definition or description of procedures in this instant filing.

I. LGIP 13.3 – Obligation for Study Costs

The Commission directs each Transmission Provider to include a description of how the costs of any clustered interconnection study will be allocated. Specifically, Order No. 2023 states that “between 10% and 50% of study costs must be allocated on a per capita basis, with the remainder (between 90% and 50%) allocated pro rata by MW.”¹⁶

Consistent with the Commission's directive, Golden Spread proposes the following allocation:

Transmission Provider shall determine each Interconnection Customer's share of the costs of the Cluster Study by allocating: (1) fifty percent (50%) of the applicable study costs to Interconnection Customers on a *per capita* basis based on number of Interconnection Requests included in the applicable Cluster; and (2) fifty percent (50%) of the applicable study costs to Interconnection Customers on a *pro-rata* basis based on requested megawatts included in the applicable Cluster. The Interconnection Facilities Study portion of the Definitive Interconnection Study Process is an individual study and costs for each Interconnection Facilities Study are directly assigned to the Interconnection Customer associated with such study.

J. Qualifying Regulatory Limitations

Order No. 2023 requires Transmission Providers to “define regulatory limitations relevant to their service territory, to publicly post the definition, and to provide a narrative

¹⁵ See fn. 8, *supra*.

¹⁶ Order No. 2023 at P 416.

The Honorable Debbie-Anne A. Reese
May 16, 2024
Page 7

description of how they define regulatory limitations as part of their compliance filing.”¹⁷ Golden Spread’ proposes to adopt the following definition:

A Qualifying Regulatory Limitation is a federal, state, local, or Tribal law or process that prohibits Interconnection Customer from obtaining exclusive Site Control within the time frame detailed in Golden Spread’s LGIP for an interconnection request proposing to interconnect to Golden Spread’s transmission system. A Qualifying Regulatory Limitation may not be due to the fault or undue delay of Interconnection Customer, nor does expense or impracticality qualify.

This proposed definition is applicable to lands managed by entities or entity types that fall within Golden Spread’s service area, and Golden Spread will post the definition in a Business Practice on its transmission web page.¹⁸

K. Generating Facility Acreage Requirements

Order No. 2023 requires Transmission Providers to publicly post minimum acreage for each generating facility technology-type, including requirements for hybrid generating facilities.¹⁹ Golden Spread will post its minimum acreage for each generating facility type in a Business Practice on its transmission web page.

L. Non-Substantive Changes

In the course of preparing its compliance filing, Golden Spread found minor instances in which its generation interconnection agreements and procedures deviated from the *pro forma* Tariff. These deviations were non-substantive and are reflected in the redline versions of Attachments M, N, O and P included with this filing. Golden Spread respectfully submits that changes to conform its Tariff to as closely as possible follow the *pro forma* Tariff are just and reasonable and should be accepted as part of this compliance filing.

IV. EFFECTIVE DATE

Golden Spread respectfully requests that the Commission accept the revisions to its Attachments M, N, O, and P in its Tariff effective as of May 17, 2024. The requested effective date is consistent with the Commission’s guidance in Order No. 2023-A.²⁰

¹⁷ *Id.* at P 607.

¹⁸ As noted above, Golden Spread does not operate an OASIS.

¹⁹ *Id.* at P 595.

²⁰ Order No. 2023-A at P 669 (confirming that transmission providers may propose effective dates in their compliance filings that align with their existing queue processing dates and clarifying that “the Commission will consider, and may grant, requests from transmission providers for an effective date that predates the Commission’s order on their compliance filing, on a case-by-case basis.”).

The Honorable Debbie-Anne A. Reese
May 16, 2024
Page 8

V. ADDITIONAL INFORMATION

The following documents are included with this filing in addition XML-formatted data required by Order No. 714 for eTariff submission:

Attachments A1 through A4 – Clean Versions of the LGIA, LGIP, SGIA and SGIP.

Attachments B1 through B4 – Redlined Versions of the LGIA, LGIP, SGIA and SGIP.

VI. CONCLUSION

WHEREFORE, for the foregoing reasons, Golden Spread respectfully requests that the Commission accept Golden Spread's proposed Tariff revisions in compliance with Order Nos. 2023 and 2023-A. Please direct any questions or comments regarding this filing to the undersigned counsel.

Respectfully submitted,

/s/ Craig W. Silverstein

Craig Silverstein
March Counsel LLC
2001 L Street, NW
Suite 500
Washington DC 20036
(202) 640-2100 (Phone)
craig.silverstein@marchcounsel.com

*Counsel for
Golden Spread Electric Cooperative, Inc.*

Attachments

CERTIFICATE OF SERVICE

I hereby certify that I have served this day copies of the foregoing to be sent via electronic or first-class mail in accordance with Rule 2010 of the Commission Rules of Practice and Procedure.

Dated at Washington, D.C., this 16th day of May, 2024.

/s/ Craig W. Silverstein

ATTACHMENT M

STANDARD LARGE GENERATOR

INTERCONNECTION PROCEDURES (LGIP)

Standard Large Generator

Interconnection Procedures (LGIP)

(Applicable to Generating Facilities that exceed 20 MW)

TABLE OF CONTENTS

	Page No.
Section 1. Definitions.....	- 1 -
Section 2. Scope and Application.....	- 13 -
2.1 Application of Standard Large Generator Interconnection Procedures.....	- 13 -
2.2 Comparability.....	- 14 -
2.3 Base Case Data.....	- 14 -
2.4 No Applicability to Transmission Service.....	- 14 -
Section 3. Interconnection Requests.....	- 15 -
3.1 Interconnection Requests.....	- 15 -
3.2 Identification of Types of Interconnection Services.....	- 17 -
3.3 Utilization of Surplus Interconnection Service.....	- 20 -
3.4 Valid Interconnection Request.....	- 22 -
3.5. OASIS Posting.	- 28 -
3.6 Coordination with Affected Systems.	- 36 -
3.7 Withdrawal.....	- 37 -
3.8 Identification of Contingent Facilities.....	- 50 -
3.9 Penalties for Failure to Meet Study Deadlines.	- 52 -
Section 4. Interconnection Request Evaluation Process.....	- 54 -
4.1 Queue Position.	- 55 -
4.2. General Study Process.	- 55 -
4.3 Transferability of Queue Position.	- 57 -
4.4 Modifications.	- 57 -
Section 5. Procedures for Interconnection Requests Submitted Prior to Effective Date of the Cluster Study Revisions.....	- 61 -
5.1 Procedures for Transitioning to the Cluster Study Process.....	- 61 -
5.2 New Transmission Provider.....	- 67 -
Section 6. Interconnection Information Access.....	- 68 -
6.1 Publicly Posted Interconnection Information.	- 68 -
Section 7. Cluster Study.....	- 69 -
7.1 Cluster Study Agreement.....	- 69 -
7.2 Execution of Cluster Study Agreement.....	- 69 -

- 7.3 Scope of Cluster Study. - 69 -
- 7.4 Cluster Study Procedures..... - 71 -
- 7.5 Cluster Study Restudies..... - 72 -
- Section 8. Interconnection Facilities Study..... - 75 -
 - 8.1 Interconnection Facilities Study Agreement. - 75 -
 - 8.2 Scope of Interconnection Facilities Study. - 76 -
 - 8.3 Interconnection Facilities Study Procedures. - 76 -
 - 8.4 Meeting with Transmission Provider. - 78 -
 - 8.5 Restudy. - 78 -
- Section 9. Affected System Study. - 78 -
 - 9.1 Applicability..... - 78 -
 - 9.2 Response to Notifications. - 78 -
 - 9.3 Affected System Queue Position. - 79 -
 - 9.4 Affected System Study Agreement/Multiparty Affected System
Study Agreement..... - 80 -
 - 9.5 Execution of Affected System Study Agreement/Multiparty Affected
System Study Agreement. - 80 -
 - 9.6 Scope of Affected System Study..... - 81 -
 - 9.7 Affected System Study Procedures. - 82 -
 - 9.8 Meeting with Transmission Provider. - 83 -
 - 9.9 Affected System Cost Allocation..... - 83 -
 - 9.10 Tender of Affected Systems Facilities Construction
Agreement/Multiparty Affected System Facilities Construction
Agreement..... - 84 -
 - 9.11 Restudy. - 84 -
- Section 10. Optional Interconnection Study - 84 -
 - 10.1 Optional Interconnection Study Agreement. - 84 -
 - 10.2 Scope of Optional Interconnection Study..... - 85 -
 - 10.3 Optional Interconnection Study Procedures. - 86 -
- Section 11. Standard Large Generator Interconnection Agreement (LGIA).. - 86 -
 - 11.1 Tender. - 86 -
 - 11.2 Negotiation..... - 87 -
 - 11.3 Execution and Filing..... - 88 -
 - 11.4 Commencement of Interconnection Activities. - 89 -
- Section 12. Construction of Transmission Provider’s Interconnection Facilities
and Network Upgrades - 90 -
 - 12.1 Schedule..... - 90 -
 - 12.2 Construction Sequencing. - 90 -
- Section 13. Miscellaneous..... - 92 -
 - 13.1 Confidentiality..... - 92 -
 - 13.2 Delegation of Responsibility..... - 97 -
 - 13.3 Obligation for Study Costs. - 97 -
 - 13.4 Third Parties Conducting Studies..... - 98 -

13.5 Disputes. - 99 -
13.6 Local Furnishing Bonds..... - 102 -
13.7 Engineering & Procurement ('E&P') Agreement..... - 103 -

Appendix 1 – Interconnection Request for a Large Generating Facility

Appendix 2 – Cluster Study Agreement

Appendix 3 – Interconnection Facilities Study Agreement

Appendix 4 – Optional Interconnection Study Agreement

Appendix 5 – Standard Large Generator Interconnection Agreement

Appendix 6 – Interconnection Procedures for a Wind Generating Plant

Appendix 7 – Transitional Cluster Study Agreement

Appendix 8 – Transitional Serial Interconnection Facilities Study Agreement

Appendix 9 – Two-Party Affected System Study Agreement

Appendix 10 – Multiparty Affected System Study Agreement

Appendix 11 – Two-Party Affected System Facilities Construction Agreement

Appendix 12 – Multiparty Affected System Facilities Construction Agreement

Section 1. Definitions

Adverse System Impact shall mean the negative effects due to technical or operational limits on conductors or equipment being exceeded that may compromise the safety and reliability of the electric system.

Affected System shall mean an electric system other than Transmission Provider's Transmission System that may be affected by the proposed interconnection.

Affected System Facilities Construction Agreement shall mean the agreement contained in Appendix 11 to this LGIP that is made between Transmission Provider and Affected System Interconnection Customer to facilitate the construction of and to set forth cost responsibility for necessary Affected System Network Upgrades on Transmission Provider's Transmission System.

Affected System Interconnection Customer shall mean any entity that submits an interconnection request for a generating facility to a transmission system other than Transmission Provider's Transmission System that may cause the need for Affected System Network Upgrades on Transmission Provider's Transmission System.

Affected System Network Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Transmission System required to accommodate Affected System Interconnection Customer's proposed interconnection to a transmission system other than Transmission Provider's Transmission System.

Affected System Operator shall mean the entity that operates an Affected System.

Affected System Queue Position shall mean the queue position of an Affected System Interconnection Customer in Transmission Provider's interconnection queue relative to Transmission Provider's Interconnection Customers' Queue Positions.

Affected System Study shall mean the evaluation of Affected System Interconnection Customers' proposed interconnection(s) to a transmission system other than Transmission Provider's Transmission System that have an impact on Transmission Provider's Transmission System, as described in Section 9 of this LGIP.

Affected System Study Agreement shall mean the agreement contained in Appendix 9 to this LGIP that is made between Transmission Provider and Affected System Interconnection Customer to conduct an Affected System Study pursuant to Section 9 of this LGIP.

Affected System Study Report shall mean the report issued following completion of an Affected System Study pursuant to Section 9.7 of this LGIP.

Affiliate shall mean, with respect to a corporation, partnership or other entity, each such other corporation, partnership or other entity that directly or indirectly, through one or more intermediaries, controls, is controlled by, or is under common control with, such corporation, partnership or other entity.

Ancillary Services shall mean those services that are necessary to support the transmission of capacity and energy from resources to loads while maintaining reliable operation of Transmission Provider's Transmission System in accordance with Good Utility Practice.

Applicable Laws and Regulations shall mean all duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Applicable Reliability Standards shall mean the requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Balancing Authority shall mean an entity that integrates resource plans ahead of time, maintains demand and resource balance within a Balancing Authority Area, and supports interconnection frequency in real time.

Balancing Authority Area shall mean the collection of generation, transmission, and loads within the metered boundaries of the Balancing Authority. The Balancing Authority maintains load-resource balance within this area.

Base Case shall mean the base case power flow, short circuit, and stability data bases used for the Interconnection Studies by Transmission Provider or Interconnection Customer.

Breach shall mean the failure of a Party to perform or observe any material term or condition of the Standard Large Generator Interconnection Agreement.

Breaching Party shall mean a Party that is in Breach of the Standard Large Generator Interconnection Agreement.

Business Day shall mean Monday through Friday, excluding Federal Holidays.

Calendar Day shall mean any day including Saturday, Sunday or a Federal Holiday.

Cluster shall mean a group of one or more Interconnection Requests that are studied together for the purpose of conducting a Cluster Study.

Cluster Request Window shall mean the time period set forth in Section 3.4.1 of this LGIP.

Cluster Restudy shall mean a restudy of a Cluster Study conducted pursuant to Section 7.5 of this LGIP.

Cluster Restudy Report shall mean the report issued following completion of a Cluster Restudy pursuant to Section 7.5 of this LGIP.

Cluster Restudy Report Meeting shall mean the meeting held to discuss the results of a Cluster Restudy pursuant to Section 7.5 of this LGIP.

Cluster Study shall mean the evaluation of one or more Interconnection Requests within a Cluster as described in Section 7 of this LGIP.

Cluster Study Agreement shall mean the agreement contained in Appendix 2 to this LGIP for conducting the Cluster Study.

Cluster Study Process shall mean the following processes, conducted in sequence: the Cluster Request Window; the Customer Engagement Window and Scoping Meetings therein; the Cluster Study; any needed Cluster Restudies; and the Interconnection Facilities Study.

Cluster Study Report shall mean the report issued following completion of a Cluster Study pursuant to Section 7 of this LGIP.

Cluster Study Report Meeting shall mean the meeting held to discuss the results of a Cluster Study pursuant to Section 7 of this LGIP.

Clustering shall mean the process whereby one or more Interconnection Requests are studied together, instead of serially, as described in Section 7 of this LGIP.

Commercial Operation shall mean the status of a Generating Facility that has commenced generating electricity for sale, excluding electricity generated during Trial Operation.

Commercial Operation Date of a unit shall mean the date on which the Generating Facility commences Commercial Operation as agreed to by the Parties pursuant to Appendix E to the Standard Large Generator Interconnection Agreement.

Commercial Readiness Deposit shall mean a deposit paid as set forth in Sections 3.4.2, 7.5, and 8.1 of this LGIP.

Confidential Information shall mean any confidential, proprietary or trade secret information of a plan, specification, pattern, procedure, design, device, list, concept, policy or compilation relating to the present or planned business of a Party, which is

designated as confidential by the Party supplying the information, whether conveyed orally, electronically, in writing, through inspection, or otherwise.

Contingent Facilities shall mean those unbuilt Interconnection Facilities and Network Upgrades upon which the Interconnection Request's costs, timing, and study findings are dependent, and if delayed or not built, could cause a need for restudies of the Interconnection Request or a reassessment of the Interconnection Facilities and/or Network Upgrades and/or costs and timing.

Customer Engagement Window shall mean the time period set forth in Section 3.4.5 of this LGIP.

Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 17 of the Standard Large Generator Interconnection Agreement.

Dispute Resolution shall mean the procedure for resolution of a dispute between the Parties in which they will first attempt to resolve the dispute on an informal basis.

Distribution System shall mean Transmission Provider's facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which distribution systems operate differ among areas.

Distribution Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Generating Facility and render the transmission service necessary to effect Interconnection Customer's wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Effective Date shall mean the date on which the Standard Large Generator Interconnection Agreement becomes effective upon execution by the Parties subject to acceptance by FERC, or if filed unexecuted, upon the date specified by FERC.

Electric Reliability Organization shall mean the North American Electric Reliability Corporation (NERC) or its successor organization.

Emergency Condition shall mean a condition or situation: (1) that in the judgment of the Party making the claim is imminently likely to endanger life or property; or (2) that, in the case of a Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to Transmission Provider's Transmission System, Transmission Provider's Interconnection Facilities or the electric systems of others to which Transmission Provider's Transmission System is directly connected; or (3) that, in the case of

Interconnection Customer, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Generating Facility or Interconnection Customer's Interconnection Facilities. System restoration and black start shall be considered Emergency Conditions; provided that Interconnection Customer is not obligated by the Standard Large Generator Interconnection Agreement to possess black start capability.

Energy Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to connect its Generating Facility to Transmission Provider's Transmission System to be eligible to deliver the Generating Facility's electric output using the existing firm or nonfirm capacity of Transmission Provider's Transmission System on an as available basis. Energy Resource Interconnection Service in and of itself does not convey transmission service.

Engineering & Procurement (E&P) Agreement shall mean an agreement that authorizes Transmission Provider to begin engineering and procurement of long lead-time items necessary for the establishment of the interconnection in order to advance the implementation of the Interconnection Request.

Environmental Law shall mean Applicable Laws or Regulations relating to pollution or protection of the environment or natural resources.

Federal Power Act shall mean the Federal Power Act, as amended, 16 U.S.C. §§ 791a et seq.

FERC shall mean the Federal Energy Regulatory Commission (Commission) or its successor.

Force Majeure shall mean any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, breakage or accident to machinery or equipment, any order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, or any other cause beyond a Party's control. A Force Majeure event does not include acts of negligence or intentional wrongdoing by the Party claiming Force Majeure.

Generating Facility shall mean Interconnection Customer's device(s) for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer's Interconnection Facilities.

Generating Facility Capacity shall mean the net capacity of the Generating Facility or the aggregate net capacity of the Generating Facility where it includes more than one device for the production and/or storage for later injection of electricity.

Good Utility Practice shall mean any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Governmental Authority shall mean any federal, state, local or other governmental regulatory or administrative agency, court, commission, department, board, or other governmental subdivision, legislature, rulemaking board, tribunal, or other governmental authority having jurisdiction over the Parties, their respective facilities, or the respective services they provide, and exercising or entitled to exercise any administrative, executive, police, or taxing authority or power; provided, however, that such term does not include Interconnection Customer, Transmission Provider, or any Affiliate thereof.

Hazardous Substances shall mean any chemicals, materials or substances defined as or included in the definition of “hazardous substances,” “hazardous wastes,” “hazardous materials,” “hazardous constituents,” “restricted hazardous materials,” “extremely hazardous substances,” “toxic substances,” “radioactive substances,” “contaminants,” “pollutants,” “toxic pollutants” or words of similar meaning and regulatory effect under any applicable Environmental Law, or any other chemical, material or substance, exposure to which is prohibited, limited or regulated by any applicable Environmental Law.

Initial Synchronization Date shall mean the date upon which the Generating Facility is initially synchronized and upon which Trial Operation begins.

In-Service Date shall mean the date upon which Interconnection Customer reasonably expects it will be ready to begin use of Transmission Provider’s Interconnection Facilities to obtain back feed power.

Interconnection Customer shall mean any entity, including Transmission Provider, Transmission Owner or any of the Affiliates or subsidiaries of either, that proposes to interconnect its Generating Facility with Transmission Provider’s Transmission System.

Interconnection Customer’s Interconnection Facilities shall mean all facilities and equipment, as identified in Appendix A of the Standard Large Generator Interconnection Agreement, that are located between the Generating Facility and the

Point of Change of Ownership, including any modification, addition, or upgrades to such facilities and equipment necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Customer's Interconnection Facilities are sole use facilities.

Interconnection Facilities shall mean Transmission Provider's Interconnection Facilities and Interconnection Customer's Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Interconnection Facilities Study shall mean a study conducted by Transmission Provider or a third party consultant for Interconnection Customer to determine a list of facilities (including Transmission Provider's Interconnection Facilities and Network Upgrades as identified in the Cluster Study), the cost of those facilities, and the time required to interconnect the Generating Facility with Transmission Provider's Transmission System. The scope of the study is defined in Section 8 of this LGIP.

Interconnection Facilities Study Agreement shall mean the form of agreement contained in Appendix 3 of this LGIP for conducting the Interconnection Facilities Study.

Interconnection Facilities Study Report shall mean the report issued following completion of an Interconnection Facilities Study pursuant to Section 8 of this LGIP.

Interconnection Request shall mean an Interconnection Customer's request, in the form of Appendix 1 to this LGIP, in accordance with the Tariff, to interconnect a new Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Generating Facility that is interconnected with Transmission Provider's Transmission System.

Interconnection Service shall mean the service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling it to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Standard Large Generator Interconnection Agreement and, if applicable, Transmission Provider's Tariff.

Interconnection Study shall mean any of the following studies: the Cluster Study, the Cluster Restudy, the Surplus Interconnection Service Study, the

Interconnection Facilities Study, the Affected System Study, Optional Interconnection Study, and Material Modification assessment, described in this LGIP.

IRS shall mean the Internal Revenue Service.

Joint Operating Committee shall be a group made up of representatives from Interconnection Customers and Transmission Provider to coordinate operating and technical considerations of Interconnection Service.

Large Generating Facility shall mean a Generating Facility having a Generating Facility Capacity of more than 20 MW.

LGIA Deposit shall mean the deposit Interconnection Customer submits when returning the executed LGIA, or within ten (10) Business Days of requesting that the LGIA be filed unexecuted at the Commission, in accordance with Section 11.3 of this LGIP.

Loss shall mean any and all losses relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's performance, or non-performance of its obligations under the Standard Large Generator Interconnection Agreement on behalf of the Indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the Indemnifying Party.

Material Modification shall mean those modifications that have a material impact on the cost or timing of any Interconnection Request with an equal or later Queue Position.

Metering Equipment shall mean all metering equipment installed or to be installed at the Generating Facility pursuant to the Standard Large Generator Interconnection Agreement at the metering points, including but not limited to instrument transformers, MWh-meters, data acquisition equipment, transducers, remote terminal unit, communications equipment, phone lines, and fiber optics.

Multiparty Affected System Facilities Construction Agreement shall mean the agreement contained in Appendix 12 to this LGIP that is made among Transmission Provider and multiple Affected System Interconnection Customers to facilitate the construction of and to set forth cost responsibility for necessary Affected System Network Upgrades on Transmission Provider's Transmission System.

Multiparty Affected System Study Agreement shall mean the agreement contained in Appendix 10 to this LGIP that is made among Transmission Provider and multiple Affected System Interconnection Customers to conduct an Affected System Study pursuant to Section 9 of this LGIP.

Network Resource shall mean any designated generating resource owned, purchased, or leased by a Network Customer under the Network Integration Transmission Service Tariff. Network Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Network Customer's Network Load on a non-interruptible basis.

Network Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to integrate its Large Generating Facility with Transmission Provider's Transmission System (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an RTO or ISO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service in and of itself does not convey transmission service.

Network Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Transmission System required at or beyond the point at which the Interconnection Facilities connect to Transmission Provider's Transmission System to accommodate the interconnection of the Large Generating Facility to Transmission Provider's Transmission System.

Notice of Dispute shall mean a written notice of a dispute or claim that arises out of or in connection with the Standard Large Generator Interconnection Agreement or its performance.

Optional Interconnection Study shall mean a sensitivity analysis based on assumptions specified by Interconnection Customer in the Optional Interconnection Study Agreement.

Optional Interconnection Study Agreement shall mean the form of agreement contained in Appendix 4 of this LGIP for conducting the Optional Interconnection Study.

Party or Parties shall mean Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Permissible Technological Advancement shall mean a new, upgraded, updated or improved technology that an Interconnection Customer intends to utilize in the design, construction or operation of generation or transmission facilities but does not (a) include a change in the generation technology or fuel type or (b) constitute a Material Modification.

Point of Change of Ownership shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where

Interconnection Customer's Interconnection Facilities connect to Transmission Provider's Interconnection Facilities.

Point of Interconnection shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where the Interconnection Facilities connect to Transmission Provider's Transmission System.

Proportional Impact Method shall mean a technical analysis conducted by Transmission Provider to determine the degree to which each Generating Facility in the Cluster Study contributes to the need for a specific System Network Upgrade.

Provisional Interconnection Service shall mean Interconnection Service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling that Transmission System to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Provisional Large Generator Interconnection Agreement and, if applicable, the Tariff.

Provisional Large Generator Interconnection Agreement shall mean the interconnection agreement for Provisional Interconnection Service established between Transmission Provider and/or Transmission Owner and Interconnection Customer. This agreement shall take the form of the Standard Large Generator Interconnection Agreement, modified for provisional purposes.

Queue Position shall mean the order of a valid Interconnection Request, relative to all other pending valid Interconnection Requests, established pursuant to Section 4.1 of this LGIP.

Reasonable Efforts shall mean, with respect to an action required to be attempted or taken by a Party under the Standard Large Generator Interconnection Agreement, efforts that are timely and consistent with Good Utility Practice and are otherwise substantially equivalent to those a Party would use to protect its own interests.

Scoping Meeting shall mean the meeting between representatives of Interconnection Customer(s) and Transmission Provider conducted for the purpose of discussing the proposed Interconnection Request and any alternative interconnection options, exchanging information including any transmission data and earlier study evaluations that would be reasonably expected to impact such interconnection options, refining information and models provided by Interconnection Customer(s), discussing the Cluster Study materials posted to OASIS pursuant to Section 3.5 of this LGIP, and analyzing such information.

Site Control shall mean the exclusive land right to develop, construct, operate, and maintain the Generating Facility over the term of expected operation of the

Generating Facility. Site Control may be demonstrated by documentation establishing: (1) ownership of, a leasehold interest in, or a right to develop a site of sufficient size to construct and operate the Generating Facility; (2) an option to purchase or acquire a leasehold site of sufficient size to construct and operate the Generating Facility; or (3) any other documentation that clearly demonstrates the right of Interconnection Customer to exclusively occupy a site of sufficient size to construct and operate the Generating Facility. Transmission Provider will maintain acreage requirements for each Generating Facility type on its OASIS or public website.

Small Generating Facility shall mean a Generating Facility that has a Generating Facility Capacity of no more than 20 MW.

Stand Alone Network Upgrades shall mean Network Upgrades that are not part of an Affected System that Interconnection Customer may construct without affecting day-to-day operations of the Transmission System during their construction. Both Transmission Provider and Interconnection Customer must agree as to what constitutes Stand Alone Network Upgrades and identify them in Appendix A to the Standard Large Generator Interconnection Agreement. If Transmission Provider and Interconnection Customer disagree about whether a particular Network Upgrade is a Stand Alone Network Upgrade, Transmission Provider must provide Interconnection Customer a written technical explanation outlining why Transmission Provider does not consider the Network Upgrade to be a Stand Alone Network Upgrade within fifteen (15) Business Days of its determination.

Standard Large Generator Interconnection Agreement (LGIA) shall mean the form of interconnection agreement applicable to an Interconnection Request pertaining to a Large Generating Facility that is included in Transmission Provider's Tariff.

Standard Large Generator Interconnection Procedures (LGIP) shall mean the interconnection procedures applicable to an Interconnection Request pertaining to a Large Generating Facility that are included in Transmission Provider's Tariff.

Substation Network Upgrades shall mean Network Upgrades that are required at the substation located at the Point of Interconnection.

Surplus Interconnection Service shall mean any unneeded portion of Interconnection Service established in a Standard Large Generator Interconnection Agreement, such that if Surplus Interconnection Service is utilized, the total amount of Interconnection Service at the Point of Interconnection would remain the same.

System Network Upgrades shall mean Network Upgrades that are required beyond the substation located at the Point of Interconnection.

System Protection Facilities shall mean the equipment, including necessary protection signal communications equipment, required to protect (1) Transmission Provider's Transmission System from faults or other electrical disturbances occurring at the Generating Facility and (2) the Generating Facility from faults or other electrical system disturbances occurring on Transmission Provider's Transmission System or on other delivery systems or other generating systems to which Transmission Provider's Transmission System is directly connected.

Tariff shall mean Transmission Provider's Tariff through which open access transmission service and Interconnection Service are offered, as filed with FERC, and as amended or supplemented from time to time, or any successor tariff.

Transitional Cluster Study shall mean an Interconnection Study evaluating a Cluster of Interconnection Requests during the transition to the Cluster Study Process, as set forth in Section 5.1.1.2 of this LGIP.

Transitional Cluster Study Agreement shall mean the agreement contained in Appendix 7 to this LGIP that is made between Transmission Provider and Interconnection Customer to conduct a Transitional Cluster Study pursuant to Section 5.1.1.2 of this LGIP.

Transitional Cluster Study Report shall mean the report issued following completion of a Transitional Cluster Study pursuant to Section 5.1.1.2 of this LGIP.

Transitional Serial Interconnection Facilities Study shall mean an Interconnection Facilities Study evaluating an Interconnection Request on a serial basis during the transition to the Cluster Study Process, as set forth in Section 5.1.1.1 of this LGIP.

Transitional Serial Interconnection Facilities Study Agreement shall mean the agreement contained in Appendix 8 to this LGIP that is made between Transmission Provider and Interconnection Customer to conduct a Transitional Serial Interconnection Facilities Study pursuant to Section 5.1.1.1 of this LGIP.

Transitional Serial Interconnection Facilities Study Report shall mean the report issued following completion of a Transitional Serial Interconnection Facilities Study pursuant to Section 5.1.1.1 of this LGIP.

Transitional Withdrawal Penalty shall mean the penalty assessed by Transmission Provider to Interconnection Customer that has entered the Transitional Cluster Study or Transitional Serial Interconnection Facilities Study and chooses to withdraw or is deemed withdrawn from Transmission Provider's interconnection queue or whose Generating Facility does not otherwise reach Commercial Operation. The

calculation of the Transitional Withdrawal Penalty is set forth in Sections 5.1.1.1 and 5.1.1.2 of this LGIP.

Transmission Owner shall mean an entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Standard Large Generator Interconnection Agreement to the extent necessary.

Transmission Provider shall mean the public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission Provider's Interconnection Facilities shall mean all facilities and equipment owned, controlled, or operated by Transmission Provider from the Point of Change of Ownership to the Point of Interconnection as identified in Appendix A to the Standard Large Generator Interconnection Agreement, including any modifications, additions or upgrades to such facilities and equipment. Transmission Provider's Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Transmission System shall mean the facilities owned, controlled or operated by Transmission Provider or Transmission Owner that are used to provide transmission service under the Tariff.

Trial Operation shall mean the period during which Interconnection Customer is engaged in on-site test operations and commissioning of the Generating Facility prior to Commercial Operation.

Withdrawal Penalty shall mean the penalty assessed by Transmission Provider to an Interconnection Customer that chooses to withdraw or is deemed withdrawn from Transmission Provider's interconnection queue or whose Generating Facility does not otherwise reach Commercial Operation. The calculation of the Withdrawal Penalty is set forth in Section 3.7.1 of this LGIP.

Section 2. Scope and Application

2.1 Application of Standard Large Generator Interconnection Procedures. Sections 2 through 13 of this LGIP apply to processing an Interconnection Request pertaining to a Large Generating Facility.

2.2 Comparability.

Transmission Provider shall receive, process and analyze all Interconnection Requests in a timely manner as set forth in this LGIP. Transmission Provider shall process and analyze Interconnection Requests from all Interconnection Customers comparably, regardless of whether the Generating Facilities are owned by Transmission Provider, its subsidiaries or Affiliates or others.

2.3 Base Case Data.

Transmission Provider shall maintain base power flow, short circuit and stability databases, including all underlying assumptions, and contingency list on either its OASIS site or a password-protected website, subject to confidentiality provisions in LGIP Section 13.1. In addition, Transmission Provider shall maintain network models and underlying assumptions on either its OASIS site or a password-protected website. Such network models and underlying assumptions should reasonably represent those used during the most recent Interconnection Study and be representative of current system conditions. If Transmission Provider posts this information on a password-protected website, a link to the information must be provided on Transmission Provider's OASIS site. Transmission Provider is permitted to require that Interconnection Customers, OASIS site users and password-protected website users sign a confidentiality agreement before the release of commercially sensitive information or Critical Energy Infrastructure Information in the Base Case data. Such databases and lists, hereinafter referred to as Base Cases, shall include all (1) generation projects and (2) transmission projects, including merchant transmission projects that are proposed for the Transmission System for which a transmission expansion plan has been submitted and approved by the applicable authority.

2.4 No Applicability to Transmission Service.

Nothing in this LGIP shall constitute a request for transmission service or confer upon an Interconnection Customer any right to receive transmission service.

Section 3. Interconnection Requests

3.1 Interconnection Requests.

3.1.1 Study Deposits.

3.1.1.1 Study Deposit. Interconnection Customer shall submit to Transmission Provider, during a Cluster Request Window, an Interconnection Request in the form of Appendix 1 to this LGIP, a non-refundable application fee of \$5,000, and a refundable study deposit of:

(a) \$35,000 plus \$1,000 per MW for Interconnection Requests < 80 MW; or

(b) \$150,000 for Interconnection Requests \geq 80 MW < 200 MW; or

(c) \$250,000 for Interconnection Requests \geq 200 MW.

Transmission Provider shall apply the study deposit toward the cost of the Cluster Study Process.

3.1.2 Submission.

Interconnection Customer shall submit a separate Interconnection Request for each site. Where multiple Generating Facilities share a site, Interconnection Customer(s) may submit separate Interconnection Requests or a single Interconnection Request. An Interconnection Request to evaluate one site at two different voltage levels shall be treated as two Interconnection Requests.

At Interconnection Customer's option, Transmission Provider and Interconnection Customer will identify alternative Point(s) of Interconnection and configurations at a Scoping Meeting within the Customer Engagement Window to evaluate in this process and attempt to eliminate alternatives in a reasonable fashion given resources and information available. Interconnection Customer will select the definitive Point of Interconnection to be studied no later than the execution of the Cluster Study Agreement. For purposes of clustering Interconnection Requests, Transmission Provider may propose changes to the requested Point of Interconnection to facilitate efficient interconnection of Interconnection Customers at common Point(s) of Interconnection. Transmission Provider shall notify Interconnection Customers in writing of any intended changes to the requested Point of Interconnection within the Customer Engagement Window, and the Point of Interconnection shall only change upon mutual agreement.

Transmission Provider shall have a process in place to consider requests for Interconnection Service below the Generating Facility Capacity. These requests for Interconnection Service shall be studied at the level of Interconnection Service requested for purposes of Interconnection Facilities, Network Upgrades, and associated costs, but may be subject to other studies at the full Generating Facility Capacity to ensure safety and reliability of the system, with the study costs borne by Interconnection Customer. If after the additional studies are complete, Transmission Provider determines that additional Network Upgrades are necessary, then Transmission Provider must: (1) specify which additional Network Upgrade costs are based on which studies; and (2) provide a detailed explanation of why the additional Network Upgrades are necessary. Any Interconnection Facility and/or Network Upgrade costs required for safety and reliability also would be borne by Interconnection Customer. Interconnection Customers may be subject to additional control technologies as well as testing and validation of those technologies consistent with Article 6 of the LGIA. The necessary control technologies and protection systems shall be established in Appendix C of that executed, or requested to be filed unexecuted, LGIA.

Transmission Provider shall have a process in place to study Generating Facilities that include at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect the proposed charging behavior of the Generating Facility as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions. If Transmission Provider finds Interconnection Customer's requested operating assumptions conflict with Good Utility Practice, Transmission Provider must provide Interconnection Customer an explanation in writing of why the submitted operating assumptions are insufficient or inappropriate by no later than thirty (30) Calendar Days before the end of the Customer Engagement Window and allow Interconnection Customer to revise and resubmit requested operating assumptions one time at least ten (10) Calendar Days prior to the end of the Customer Engagement Window. Transmission Provider shall study these requests for Interconnection Service, with the study costs borne by Interconnection Customer, using the submitted operating assumptions for purposes of Interconnection Facilities, Network Upgrades, and associated costs. These requests for Interconnection Service also may be subject to other studies at the full Generating Facility Capacity to ensure safety and reliability of the system, with the study costs borne by Interconnection Customer. Interconnection Customer's Generating Facility may be subject to additional control technologies as well as testing and validation of such additional control technologies consistent with Article 6 of the LGIA. The necessary control technologies and protection systems shall be set forth in Appendix C of Interconnection Customer's LGIA.

3.2 Identification of Types of Interconnection Services.

At the time the Interconnection Request is submitted, Interconnection Customer must request either Energy Resource Interconnection Service or Network Resource Interconnection Service, as described; provided, however, any Interconnection Customer requesting Network Resource Interconnection Service may also request that it be concurrently studied for

Energy Resource Interconnection Service, up to the point when an Interconnection Facilities Study Agreement is executed. Interconnection Customer may then elect to proceed with Network Resource Interconnection Service or to proceed under a lower level of interconnection service to the extent that only certain upgrades will be completed.

3.2.1 Energy Resource Interconnection Service.

3.2.1.1 The Product. Energy Resource Interconnection Service allows Interconnection Customer to connect the Large Generating Facility to the Transmission System and be eligible to deliver the Large Generating Facility's output using the existing firm or non-firm capacity of the Transmission System on an "as available" basis. Energy Resource Interconnection Service does not in and of itself convey any right to deliver electricity to any specific customer or Point of Delivery.

3.2.1.2 The Study. The study consists of short circuit/fault duty, steady state (thermal and voltage) and stability analyses. The short circuit/fault duty analysis would identify direct Interconnection Facilities required and the Network Upgrades necessary to address short circuit issues associated with the Interconnection Facilities. The stability and steady state studies would identify necessary upgrades to allow full output of the proposed Large Generating Facility, except for Generating Facilities that include at least one electric storage resource that request to use operating assumptions pursuant to Section 3.1.2, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions, and would also identify the maximum allowed output, at the time the study is performed, of

the interconnecting Large Generating Facility without requiring additional Network Upgrades.

3.2.2 Network Resource Interconnection Service.

3.2.2.1 The Product. Transmission Provider must conduct the necessary studies and construct the Network Upgrades needed to integrate the Large Generating Facility (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an ISO or RTO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service allows Interconnection Customer's Large Generating Facility to be designated as a Network Resource, up to the Large Generating Facility's full output, on the same basis as existing Network Resources interconnected to Transmission Provider's Transmission System, and to be studied as a Network Resource on the assumption that such a designation will occur.

3.2.2.2 The Study. The Interconnection Study for Network Resource Interconnection Service shall assure that Interconnection Customer's Large Generating Facility meets the requirements for Network Resource Interconnection Service and as a general matter, that such Large Generating Facility's interconnection is also studied with Transmission Provider's Transmission System at peak load, under a variety of severely stressed conditions, to determine whether, with the Large Generating Facility at full output, except for Generating Facilities that include at least one electric storage resource that request to use, and for which Transmission Provider approves, operating assumptions pursuant to Section 3.1.2, the aggregate of generation in the local area can be delivered to the aggregate of load on Transmission Provider's

Transmission System, consistent with Transmission Provider's reliability criteria and procedures. This approach assumes that some portion of existing Network Resources are displaced by the output of Interconnection Customer's Large Generating Facility. Network Resource Interconnection Service in and of itself does not convey any right to deliver electricity to any specific customer or Point of Delivery. Transmission Provider may also study the Transmission System under non-peak load conditions. However, upon request by Interconnection Customer, Transmission Provider must explain in writing to Interconnection Customer why the study of non-peak load conditions is required for reliability purposes.

3.3 Utilization of Surplus Interconnection Service.

Transmission Provider must provide a process that allows an Interconnection Customer to utilize or transfer Surplus Interconnection Service at an existing Point of Interconnection. The original Interconnection Customer or one of its affiliates shall have priority to utilize Surplus Interconnection Service. If the existing Interconnection Customer or one of its affiliates does not exercise its priority, then that service may be made available to other potential Interconnection Customers.

3.3.1 Surplus Interconnection Service Requests.

Surplus Interconnection Service requests may be made by the existing Interconnection Customer or one of its affiliates or may be submitted once Interconnection Customer has executed the LGIA or requested that the LGIA be filed unexecuted. Surplus Interconnection Service requests also may be made by another Interconnection Customer. Transmission Provider shall provide a process for evaluating Interconnection Requests for Surplus Interconnection Service. Studies for Surplus Interconnection Service shall consist of reactive power, short circuit/fault duty, stability analyses, and any other appropriate studies. Steady-state (thermal/voltage) analyses may be performed as necessary to ensure that all required reliability conditions are studied. If the Surplus

Interconnection Service was not studied under off-peak conditions, off-peak steady state analyses shall be performed to the required level necessary to demonstrate reliable operation of the Surplus Interconnection Service. If the original system impact study report or Cluster Study Report is not available for the Surplus Interconnection Service, both off-peak and peak analysis may need to be performed for the existing Generating Facility associated with the request for Surplus Interconnection Service. The reactive power, short circuit/fault duty, stability, and steady-state analyses for Surplus Interconnection Service will identify any additional Interconnection Facilities and/or Network Upgrades necessary.

Transmission Provider shall study Surplus Interconnection Service requests for a Generating Facility that includes at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect the proposed charging behavior of the Generating Facility as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions.

3.3.2 Process for Surplus Interconnection Service

A request for Surplus Interconnection Service may be initiated by transmitting information to the Transmission Provider specifying the Large Generator Interconnection for which such service is requested, and that the request be treated pursuant to Section 3.3 of the LGIP. The cover transmittal should also indicate whether or not the request is related to service provided to the original Interconnection Customer or its affiliate's Large Generator Interconnection.

Should the Transmission Provider receive a request for Surplus Interconnection Service at a Point of Interconnection from a third party relating to an existing Large Generator Interconnection, the original Interconnection Customer or its affiliates shall have priority. Transmission Provider will notify the original Interconnection Customer of any competing request, and that original Interconnection Customer will have ten (10) days to exercise its priority rights. The prospective Interconnection Customer with the competing request will be notified within ten (10) days of any exercise of priority rights. Failure to exercise priority rights by the original Interconnection Customer will result in all excess capacity available through Surplus Interconnection Service being

released to other potential Interconnection Customers for a period up to one hundred and eighty (180) days.

Nothing in this Section 3.3.2 should be construed as limiting the right of the original Large Generator Interconnection Customer to either release all claims to priority on a permanent basis or to transfer its priority right to Surplus Interconnection Service to a third party.

Once the priority right of the original Interconnection Customer or its affiliates has been properly exercised, waived (either expressly or through the expiration of the ten (10) day window set out above), released or transferred, the request for Surplus Interconnection Service shall be studied pursuant to the criteria set forth in Section 3.3.1. The timeline and requirements for the study process shall be as follows:

1. The surplus Interconnection Customer must execute an appropriate study agreement and provide a study deposit in the amount of \$10,000 within five (5) Business Days after execution of the agreement.
2. The \$10,000 deposit will be applied to the actual cost of all studies referenced in Section 3.3.1. Any difference in actual cost will be paid by, or refunded to, the surplus Interconnection Customer.
3. In the event that the Transmission Provider and Interconnection Customer cannot agree upon the study agreement, the agreement may be filed on an unexecuted basis with the Commission.
4. Studies performed under Section 3.3.1 shall be completed outside the interconnection study queue set out in Section 3 to the LGIP, and completed within sixty (60) calendar days after execution of a study agreement and receipt of the study deposit.
5. Results of all studies required under Section 3.3.1 shall be communicated to the potential Interconnection Customer as soon as practicable.

Surplus Interconnection Service shall be documented in an agreement between the original Interconnection Customer, surplus Interconnection Customer and Transmission Provider and shall be executed prior to the commencement of service. All agreements shall be filed in accordance with the Commission's regulations governing service agreements under the Transmission Provider's Tariff.

3.4 Valid Interconnection Request.

3.4.1 Cluster Request Window.

Transmission Provider shall accept Interconnection Requests during a forty-five (45) Calendar Day period (the Cluster Request

Window). The initial Cluster Request Window shall open for Interconnection Requests beginning one hundred eighty (180) Calendar Days after the conclusion of the transition process set out in Section 5.1 of this LGIP and successive Cluster Request Windows shall open annually every February 1 thereafter.

3.4.2 Initiating an Interconnection Request.

An Interconnection Customer seeking to join a Cluster shall submit its Interconnection Request to Transmission Provider within, and no later than the close of, the Cluster Request Window. Interconnection Requests submitted outside of the Cluster Request Window will not be considered. To initiate an Interconnection Request, Interconnection Customer must submit all of the following:

- (i) Applicable study deposit amount, pursuant to Section 3.1.1.1 of this LGIP,
- (ii) A completed application in the form of Appendix 1,
- (iii) Demonstration of no less than ninety percent (90%) Site Control or (1) a signed affidavit from an officer of the company indicating that Site Control is unobtainable due to regulatory limitations as such term is defined by Transmission Provider; and (2) documentation sufficiently describing and explaining the source and effects of such regulatory limitations, including a description of any conditions that must be met to satisfy the regulatory limitations and the anticipated time by which Interconnection Customer expects to satisfy the regulatory requirements and (3) a deposit in lieu of Site Control of \$10,000 per MW, subject to a minimum of \$500,000 and a maximum of \$2,000,000. Interconnection Requests from multiple Interconnection Customers for multiple Generating Facilities that share a site must include a contract or other agreement that allows for shared land use,
- (iv) Generating Facility Capacity (MW) (and requested Interconnection Service level if the requested Interconnection Service is less than the Generating Facility Capacity),

(v) If applicable, (1) the requested operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) to be used by Transmission Provider that reflect the proposed charging behavior of the Generating Facility that includes at least one electric storage resource, and (2) a description of any control technologies (software and/or hardware) that will limit the operation of the Generating Facility to the operating assumptions submitted by Interconnection Customer,

(vi) A Commercial Readiness Deposit equal to two times the study deposit described in Section 3.1.1.1 of this LGIP in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider. This Commercial Readiness Deposit is refunded to Interconnection Customer according to Section 3.7 of this LGIP,

(vii) A Point of Interconnection, and

(viii) Whether the Interconnection Request shall be studied for Network Resource Interconnection Service or for Energy Resource Interconnection Service, consistent with Section 3.2 of this LGIP.

An Interconnection Customer that submits a deposit in lieu of Site Control due to demonstrated regulatory limitations must demonstrate that it is taking identifiable steps to secure the necessary regulatory approvals from the applicable federal, state, and/or tribal entities before execution of the Cluster Study Agreement. Such deposit will be held by Transmission Provider until Interconnection Customer provides the required Site Control demonstration for its point in the Cluster Study Process. Interconnection Customers facing qualifying regulatory limitations must demonstrate one hundred percent (100%) Site Control within one hundred eighty (180) Calendar Days of the effective date of the LGIA.

Interconnection Customer shall promptly inform Transmission Provider of any material change to Interconnection Customer's demonstration of Site Control under Section 3.4.2(iii) of this LGIP. If Transmission Provider determines, based on Interconnection Customer's information, that Interconnection Customer no longer

satisfies the Site Control requirement, Transmission Provider shall give Interconnection Customer ten (10) Business Days to demonstrate satisfaction with the applicable requirement subject to Transmission Provider's approval. Absent such, Transmission Provider shall deem the Interconnection Request withdrawn pursuant to Section 3.7 of this LGIP.

The expected In-Service Date of the new Large Generating Facility or increase in capacity of the existing Generating Facility shall be no more than the process window for the regional expansion planning period (or in the absence of a regional planning process, the process window for Transmission Provider's expansion planning period) not to exceed seven (7) years from the date the Interconnection Request is received by Transmission Provider, unless Interconnection Customer demonstrates that engineering, permitting and construction of the new Large Generating Facility or increase in capacity of the existing Generating Facility will take longer than the regional expansion planning period. The In-Service Date may succeed the date the Interconnection Request is received by Transmission Provider by a period up to ten (10) years, or longer where Interconnection Customer and Transmission Provider agree, such agreement not to be unreasonably withheld.

3.4.3 Acknowledgment of Interconnection Request.

Transmission Provider shall acknowledge receipt of the Interconnection Request within five (5) Business Days of receipt of the request and attach a copy of the received Interconnection Request to the acknowledgement.

3.4.4 Deficiencies in Interconnection Request.

An Interconnection Request will not be considered to be a valid request until all items in Section 3.4.2 of this LGIP have been received by Transmission Provider during the Cluster Request Window. If an Interconnection Request fails to meet the requirements set forth in Section 3.4.2 of this LGIP, Transmission Provider shall notify Interconnection Customer within five (5) Business Days of receipt of the initial Interconnection Request of the reasons for such failure and that the Interconnection Request does

not constitute a valid request. Interconnection Customer shall provide Transmission Provider the additional requested information needed to constitute a valid request within ten (10) Business Days after receipt of such notice but no later than the close of the Cluster Request Window. At any time, if Transmission Provider finds that the technical data provided by Interconnection Customer is incomplete or contains errors, Interconnection Customer and Transmission Provider shall work expeditiously and in good faith to remedy such issues. In the event that Interconnection Customer fails to comply with this Section 3.4.4 of this LGIP, Transmission Provider shall deem the Interconnection Request withdrawn (without the cure period provided under Section 3.7 of this LGIP), the application fee is forfeited to Transmission Provider, and the study deposit and Commercial Readiness Deposit shall be returned to Interconnection Customer.

3.4.5 Customer Engagement Window.

Upon the close of each Cluster Request Window, Transmission Provider shall open a sixty (60) Calendar Day period (Customer Engagement Window). During the Customer Engagement Window, Transmission Provider shall hold a Scoping Meeting with all interested Interconnection Customers. Notwithstanding the preceding requirements and upon written consent of all Interconnection Customers within the Cluster, Transmission Provider may shorten the Customer Engagement Window and begin the Cluster Study. Within ten (10) Business Days of the opening of the Customer Engagement Window, Transmission Provider shall post on its OASIS a list of Interconnection Requests for that Cluster. The list shall identify, for each anonymized Interconnection Request: (1) the requested amount of Interconnection Service; (2) the location by county and state; (3) the station or transmission line or lines where the interconnection will be made; (4) the projected In-Service Date; (5) the type of Interconnection Service requested; and (6) the type of Generating Facility or Facilities to be constructed, including fuel types, such as coal, natural gas, solar, or wind. Transmission Provider must ensure that project information is anonymized and does not reveal the identity or commercial information of Interconnection Customers with submitted requests. During the

Customer Engagement Window, Transmission Provider shall provide to Interconnection Customer a non-binding updated good faith estimate of the cost and timeframe for completing the cluster Study and a Cluster Study Agreement to be executed prior to the close of the Customer Engagement Window.

At the end of the Customer Engagement Window, all Interconnection Requests deemed valid that have executed a Cluster Study Agreement in the form of Appendix 2 to this LGIP shall be included in the Cluster Study. Any Interconnection Requests for which Interconnection Customer has not executed a Cluster Study Agreement shall be deemed withdrawn (without the cure period provided under Section 3.7 of this LGIP) by Transmission Provider, the application fee shall be forfeited to Transmission Provider, and Transmission Provider shall return the study deposit and Commercial Readiness Deposit to Interconnection Customer. Immediately following the Customer Engagement Window, Transmission Provider shall initiate the Cluster Study described in Section 7 of this LGIP.

3.4.6 Cluster Study Scoping Meeting.

During the Customer Engagement Window, Transmission Provider shall hold a Scoping Meeting with all Interconnection Customers whose valid Interconnection Requests were received in that Cluster Request Window.

The purpose of the Cluster Study Scoping Meeting shall be to discuss alternative interconnection options, to exchange information including any transmission data and earlier study evaluations that would reasonably be expected to impact such interconnection options, to discuss the Cluster Study materials posted to OASIS pursuant to Section 3.5 of this LGIP, if applicable, and to analyze such information. Transmission Provider and Interconnection Customer(s) will bring to the meeting such technical data, including, but not limited to: (i) general facility loadings, (ii) general instability issues, (iii) general short circuit issues, (iv) general

voltage issues, and (v) general reliability issues as may be reasonably required to accomplish the purpose of the meeting. Transmission Provider and Interconnection Customer(s) will also bring to the meeting personnel and other resources as may be reasonably required to accomplish the purpose of the meeting in the time allocated for the meeting. On the basis of the meeting, Interconnection Customer(s) shall designate its Point of Interconnection. The duration of the meeting shall be sufficient to accomplish its purpose. If the Cluster Study Scoping Meeting consists of more than one Interconnection Customer, Transmission Provider shall issue, no later than fifteen (15) Business Days after the commencement of the Customer Engagement Window, and Interconnection Customer shall execute a non-disclosure agreement prior to a group Cluster Study Scoping Meeting, which will provide for confidentiality of identifying information or commercially sensitive information pertaining to any other Interconnection Customers.

3.5. OASIS Posting.

3.5.1 OASIS Posting.

Transmission Provider will maintain on its OASIS a list of all Interconnection Requests. The list will identify, for each Interconnection Request: (i) the maximum summer and winter megawatt electrical output; (ii) the location by county and state; (iii) the station or transmission line or lines where the interconnection will be made; (iv) the projected In-Service Date; (v) the status of the Interconnection Request, including Queue Position; (vi) the type of Interconnection Service being requested; (vii) the availability of any studies related to the Interconnection Request; (viii) the date of the Interconnection Request; (ix) the type of Generating Facility to be constructed; and (x) for Interconnection Requests that have not resulted in a completed interconnection, an explanation as to why it was not completed. Except in the case of an Affiliate, the list will not disclose the identity of Interconnection Customer until Interconnection Customer executes an LGIA or requests that Transmission Provider file an unexecuted LGIA with FERC. Before holding a Scoping Meeting with its Affiliate, Transmission Provider

shall post on OASIS an advance notice of its intent to do so. Transmission Provider shall post to its OASIS site any deviations from the study timelines set forth herein. Interconnection Study reports and Optional Interconnection Study reports shall be posted to Transmission Provider's OASIS site subsequent to the meeting between Interconnection Customer and Transmission Provider to discuss the applicable study results. Transmission Provider shall also post any known deviations in the Large Generating Facility's In-Service Date.

3.5.2 Requirement to Post Interconnection Study Metrics.

Transmission Provider will maintain on its OASIS or its website summary statistics related to processing Interconnection Studies pursuant to Interconnection Requests, updated quarterly. If Transmission Provider posts this information on its website, a link to the information must be provided on Transmission Provider's OASIS site. For each calendar quarter, Transmission Provider must calculate and post the information detailed in Sections 3.5.2.1 through 3.5.2.4 of this LGIP.

3.5.2.1 Interconnection Cluster Study Processing Time.

(A) Number of Interconnection Requests that had Cluster Studies completed within Transmission Provider's coordinated region during the reporting quarter,

(B) Number of Interconnection Requests that had Cluster Studies completed within Transmission Provider's coordinated region during the reporting quarter that were completed more than one hundred fifty (150) Calendar Days after the close of the Customer Engagement Window,

(C) At the end of the reporting quarter, the number of active valid Interconnection Requests with ongoing incomplete Cluster Studies where such Interconnection Requests had executed a Cluster Study Agreement received by Transmission Provider more than one hundred fifty (150) Calendar Days before the reporting quarter end,

(D) Mean time (in days), Cluster Studies completed within Transmission Provider's coordinated region during the reporting quarter, from the commencement of the Cluster Study to the date when Transmission Provider provided the completed Cluster Study Report to Interconnection Customer,

(E) Mean time (in days), Cluster Studies were completed within Transmission Provider's coordinated region during the reporting quarter, from the close of the Cluster Request Window to the date when Transmission Provider provided the completed Cluster Study Report to Interconnection Customer,

(F) Percentage of Cluster Studies exceeding one hundred fifty (150) Calendar Days to complete this reporting quarter, calculated as the sum of Section 3.5.2.1(B) plus Section 3.5.2.1(C) divided by the sum of Section 3.5.2.1(A) plus Section 3.5.2.1(C) of this LGIP.

3.5.2.2 Cluster Restudies Processing Time.

(A) Number of Interconnection Requests that had Cluster Restudies completed within Transmission

Provider's coordinated region during the reporting quarter,

(B) Number of Interconnection Requests that had Cluster Restudies completed within Transmission Provider's coordinated region during the reporting quarter that were completed more than one hundred fifty (150) Calendar Days after Transmission Provider notifies Interconnection Customers in the Cluster that a Cluster Restudy is required pursuant to Section 7.5(4) of this LGIP,

(C) At the end of the reporting quarter, the number of active valid Interconnection Requests with ongoing incomplete Cluster Restudies where Transmission Provider notified Interconnection Customers in the Cluster that a Cluster Restudy is required pursuant to Section 7.5(4) of this LGIP more than one hundred fifty (150) Calendar Days before the reporting quarter end,

(D) Mean time (in days), Cluster Restudies completed within Transmission Provider's coordinated region during the reporting quarter, from the date when Transmission Provider notifies Interconnection Customers in the Cluster that a Cluster Restudy is required pursuant to Section 7.5(4) of this LGIP to the date when Transmission Provider provided the completed Cluster Restudy Report to Interconnection Customer,

(E) Mean time (in days), Cluster Restudies completed within Transmission Provider's coordinated region during the reporting quarter, from the close of the Cluster Request Window to the date when

Transmission Provider provided the completed Cluster Restudy Report to Interconnection Customer,

(F) Percentage of Cluster Restudies exceeding one hundred fifty (150) Calendar Days to complete this reporting quarter, calculated as the sum of Section 3.5.2.2(B) plus Section 3.5.2.2(C) divided by the sum of Section 3.5.2.2(A) plus Section 3.5.2.2(C) of this LGIP.

3.5.2.3 Interconnection Facilities Studies Processing Time.

(A) Number of Interconnection Requests that had Interconnection Facilities Studies that are completed within Transmission Provider's coordinated region during the reporting quarter,

(B) Number of Interconnection Requests that had Interconnection Facilities Studies that are completed within Transmission Provider's coordinated region during the reporting quarter that were completed more than 90 days with a cost variance of 20% or 180 days with a cost variance of 10% after receipt by Transmission Provider of Interconnection Customer's executed Interconnection Facilities Study Agreement,

(C) At the end of the reporting quarter, the number of active valid Interconnection Service requests with ongoing incomplete Interconnection Facilities Studies where such Interconnection Requests had executed Interconnection Facilities Studies Agreement received by Transmission Provider more than 90 days with a cost variance of 20% or 180 days with a cost variance of 10% before the reporting quarter end,

(D) Mean time (in days), for Interconnection Facilities Studies completed within Transmission Provider's coordinated region during the reporting quarter, calculated from the date when Transmission Provider received the executed Interconnection Facilities Study Agreement to the date when Transmission Provider provided the completed Interconnection Facilities Study to Interconnection Customer,

(E) Mean time (in days), Interconnection Facilities Studies completed within Transmission Provider's coordinated region during the reporting quarter, from the close of the Cluster Request Window to the date when Transmission Provider provided the completed Interconnection Facilities Study to Interconnection Customer,

(F) Percentage of delayed Interconnection Facilities Studies this reporting quarter, calculated as the sum of Section 3.5.2.3(B) plus Section 3.5.2.3(C) divided by the sum of Section 3.5.2.3(A) plus Section 3.5.2.3(C) of this LGIP.

3.5.2.4 Interconnection Service Requests Withdrawn from Interconnection Queue.

(A) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue during the reporting quarter,

(B) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue during the reporting quarter before completion of any Interconnection Studies or execution of any Interconnection Study agreements,

(C) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue during the reporting quarter before completion of a Cluster Study,

(D) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue during the reporting quarter before completion of an Interconnection Facilities Study,

(E) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue after completion of an Interconnection Facilities Study but before execution of an LGIA or Interconnection Customer requests the filing of an unexecuted, new LGIA,

(F) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue after execution of an LGIA or Interconnection Customer requests the filing of an unexecuted, new LGIA

(G) Mean time (in days), for all withdrawn Interconnection Requests, from the date when the request was determined to be valid to when Transmission Provider received the request to withdraw from the queue.

3.5.3

Transmission Provider is required to post on OASIS or its website the measures in Section 3.5.2.1(A) through Section 3.5.2.4(G) for each calendar quarter within thirty (30) Calendar Days of the end of

the calendar quarter. Transmission Provider will keep the quarterly measures posted on OASIS or its website for three (3) calendar years with the first required report to be in the first quarter of 2020. If Transmission Provider retains this information on its website, a link to the information must be provided on Transmission Provider's OASIS site.

3.5.4

In the event that any of the values calculated in Sections 3.5.2.1(E), 3.5.2.2(E) or 3.5.2.3(E) exceeds twenty-five percent (25%) for two (2) consecutive calendar quarters, Transmission Provider will have to comply with the measures below for the next four (4) consecutive calendar quarters and must continue reporting this information until Transmission Provider reports four (4) consecutive calendar quarters without the values calculated in Sections 3.5.2.1(E), 3.5.2.2(E) or 3.5.2.3(E) exceeding twenty-five percent (25%) for two (2) consecutive calendar quarters:

(i) Transmission Provider must submit a report to the Commission describing the reason for each Cluster Study, Cluster Restudy, or individual Interconnection Facilities Study pursuant to one or more Interconnection Request(s) that exceeded its deadline (i.e., 150, 90 or 180 Calendar Days) for completion. Transmission Provider must describe the reasons for each study delay and any steps taken to remedy these specific issues and, if applicable, prevent such delays in the future. The report must be filed at the Commission within forty-five (45) Calendar Days of the end of the calendar quarter.

(ii) Transmission Provider shall aggregate the total number of employee-hours and third party consultant hours expended towards Interconnection Studies within its coordinated region that quarter and post on OASIS or its website. If Transmission Provider posts this information on its website, a link to the information must be provided on Transmission Provider's OASIS site. This information is to be posted

within thirty (30) Calendar Days of the end of the calendar quarter.

3.6 Coordination with Affected Systems.

Transmission Provider will coordinate the conduct of any studies required to determine the impact of the Interconnection Request on Affected Systems with Affected System Operators. Interconnection Customer will cooperate with Transmission Provider and Affected System Operator in all matters related to the conduct of studies and the determination of modifications to Affected Systems.

A Transmission Provider whose system may be impacted by a proposed interconnection on another transmission provider's transmission system shall cooperate with transmission provider with whom interconnection has been requested in all matters related to the conduct of studies and the determination of modifications to Transmission Provider's Transmission System.

3.6.1 Initial Notification.

Transmission Provider must notify Affected System Operator of a potential Affected System impact caused by an Interconnection Request within ten (10) Business Days of the completion of the Cluster Study.

At the time of initial notification, Transmission Provider must provide Interconnection Customer with a list of potential Affected Systems, along with relevant contact information.

3.6.2 Notification of Cluster Restudy.

Transmission Provider must notify Affected System Operator of a Cluster Restudy concurrently with its notification of such Cluster Restudy to Interconnection Customers.

3.6.3 Notification of Cluster Restudy Completion.

Upon the completion of Transmission Provider's Cluster Restudy, Transmission Provider will notify Affected System Operator of a

potential Affected System impact caused by an Interconnection Request within ten (10) Business Days of the completion of the Cluster Restudy, regardless of whether that potential Affected System impact was previously identified. At the time of the notification of the completion of the Cluster Restudy to the Affected System Operator, Transmission Provider must provide Interconnection Customer with a list of potential Affected System Operators, along with relevant contact information.

3.7 Withdrawal.

Interconnection Customer may withdraw its Interconnection Request at any time by written notice of such withdrawal to Transmission Provider. In addition, if Interconnection Customer fails to adhere to all requirements of this LGIP, except as provided in Section 13.5 (Disputes), Transmission Provider shall deem the Interconnection Request to be withdrawn and shall provide written notice to Interconnection Customer of the deemed withdrawal and an explanation of the reasons for such deemed withdrawal. Upon receipt of such written notice, Interconnection Customer shall have fifteen (15) Business Days in which to either respond with information or actions that cures the deficiency or to notify Transmission Provider of its intent to pursue Dispute Resolution.

Withdrawal shall result in the loss of Interconnection Customer's Queue Position. If an Interconnection Customer disputes the withdrawal and loss of its Queue Position, then during Dispute Resolution, Interconnection Customer's Interconnection Request is eliminated from the queue until such time that the outcome of Dispute Resolution would restore its Queue Position. An Interconnection Customer that withdraws or is deemed to have withdrawn its Interconnection Request shall pay to Transmission Provider all costs that Transmission Provider prudently incurs with respect to that Interconnection Request prior to Transmission Provider's receipt of notice described above. Interconnection Customer must pay all monies due to Transmission Provider before it is allowed to obtain any Interconnection Study data or results.

If Interconnection Customer withdraws its Interconnection Request or is deemed withdrawn by Transmission Provider under Section 3.7 of this

LGIP, Transmission Provider shall (i) update the OASIS Queue Position posting; (ii) impose the Withdrawal Penalty described in Section 3.7.1 of this LGIP; and (iii) refund to Interconnection Customer any portion of the refundable portion of Interconnection Customer's study deposit that exceeds the costs that Transmission Provider has incurred, including interest calculated in accordance with Section 35.19a(a)(2) of FERC's regulations. Transmission Provider shall also refund any portion of the Commercial Readiness Deposit not applied to the Withdrawal Penalty and, if applicable, the deposit in lieu of site control. In the event of such withdrawal, Transmission Provider, subject to the confidentiality provisions of Section 13.1 of this LGIP, shall provide, at Interconnection Customer's request, all information that Transmission Provider developed for any completed study conducted up to the date of withdrawal of the Interconnection Request.

3.7.1 Withdrawal Penalty.

Interconnection Customer shall be subject to a Withdrawal Penalty if it withdraws its Interconnection Request or is deemed withdrawn, or the Generating Facility does not otherwise reach Commercial Operation unless: (1) the withdrawal does not have a material impact on the cost or timing of any Interconnection Request in the same Cluster; (2) Interconnection Customer withdraws after receiving Interconnection Customer's most recent Cluster Restudy Report and the Network Upgrade costs assigned to the Interconnection Request identified in that report have increased by more than twenty-five percent (25%) compared to costs identified in Interconnection Customer's preceding Cluster Study Report or Cluster Restudy Report; or (3) Interconnection Customer withdraws after receiving Interconnection Customer's Interconnection Facilities Study Report and the Network Upgrade costs assigned to the Interconnection Request identified in that report have increased by more than one hundred percent (100%) compared to costs identified in the Cluster Study Report or Cluster Restudy Report.

3.7.1.1 Calculation of the Withdrawal Penalty.

If Interconnection Customer withdraws its Interconnection Request or is deemed withdrawn

prior to the commencement of the initial Cluster Study, Interconnection Customer shall not be subject to a Withdrawal Penalty. If Interconnection Customer withdraws, is deemed withdrawn, or otherwise does not reach Commercial Operation at any point after the commencement of the initial Cluster Study, that Interconnection Customer's Withdrawal Penalty will be the greater of: (1) Interconnection Customer's study deposit required under Section 3.1.1.1 of this LGIP; or (2) as follows in (a)–(d):

(a) If Interconnection Customer withdraws or is deemed withdrawn during the Cluster Study or after receipt of a Cluster Study Report, but prior to commencement of the Cluster Restudy or Interconnection Facilities Study if no Cluster Restudy is required, Interconnection Customer shall be charged two (2) times its actual allocated cost of all studies performed for Interconnection Customers in the Cluster up until that point in the Interconnection Study process.

(b) If Interconnection Customer withdraws or is deemed withdrawn during the Cluster Restudy or after receipt of any applicable restudy reports issued pursuant to Section 7.5 of this LGIP, but prior to commencement of the Interconnection Facilities Study, Interconnection Customer shall be charged five percent (5%) its estimated Network Upgrade costs.

(c) If Interconnection Customer withdraws or is deemed withdrawn during the Interconnection Facilities Study, after receipt of the Interconnection Facilities Study Report issued pursuant to Section 8.3 of this LGIP, or after

receipt of the draft LGIA but before Interconnection Customer has executed an LGIA or has requested that its LGIA be filed unexecuted, and has satisfied the other requirements described in Section 11.3 of this LGIP (i.e., Site Control demonstration, LGIA Deposit, reasonable evidence of one or more milestones in the development of the Generating Facility), Interconnection Customer shall be charged ten percent (10%) its estimated Network Upgrade costs.

(d) If Interconnection Customer has executed an LGIA or has requested that its LGIA be filed unexecuted and has satisfied the other requirements described in Section 11.3 of this LGIP (i.e., Site Control demonstration, LGIA Deposit, reasonable evidence of one or more milestones in the development of the Generating Facility) and subsequently withdraws its Interconnection Request or if Interconnection Customer's Generating Facility otherwise does not reach Commercial Operation, that Interconnection Customer's Withdrawal Penalty shall be twenty percent (20%) its estimated Network Upgrade costs.

3.7.1.2 Distribution of the Withdrawal Penalty.

3.7.1.2.1 Initial Distribution of Withdrawal Penalties Prior to Assessment of Network Upgrade Costs Previously Shared with Withdrawn Interconnection Customers in the Same Cluster.

For a single Cluster, Transmission Provider shall hold all Withdrawal Penalty funds until all Interconnection Customers in that Cluster have either: (1) withdrawn

or been deemed withdrawn; (2) executed an LGIA; or (3) requested an LGIA to be filed unexecuted. Any Withdrawal Penalty funds collected from the Cluster shall first be used to fund studies conducted under the Cluster Study Process for Interconnection Customers in the same Cluster that have executed the LGIA or requested the LGIA to be filed unexecuted. Next, after the Withdrawal Penalty funds are applied to relevant study costs in the same Cluster, Transmission Provider will apply the remaining Withdrawal Penalty funds to reduce net increases, for Interconnection Customers in the same Cluster, in Interconnection Customers' Network Upgrade cost assignment and associated financial security requirements under Article 11.5 of the pro forma LGIA attributable to the impacts of withdrawn Interconnection Customers that shared an obligation with the remaining Interconnection Customers to fund a Network Upgrade, as described in more detail in Sections 3.7.1.2.3 and 3.7.1.2.4. The total amount of funds used to fund these studies under the Cluster Study Process or those applied to any net increases in Network Upgrade costs for Interconnection Customers in the same Cluster shall not exceed the total amount of Withdrawal Penalty funds collected from the Cluster.

Withdrawal Penalty funds shall first be applied as a refund to invoiced study costs for Interconnection Customers in the same Cluster that did not withdraw within thirty (30) Calendar Days of such Interconnection Customers executing their LGIA or requesting to have their LGIA filed unexecuted. Distribution of Withdrawal Penalty funds within one specific Cluster for study costs shall not exceed the total actual Cluster Study Process costs for the Cluster. Withdrawal Penalty funds applied to study costs shall be allocated within the same Cluster to Interconnection Customers in a manner consistent with Transmission Provider's method in Section 13.3 of this LGIP for

allocating the costs of Interconnection Studies conducted on a clustered basis. Transmission Provider shall post the balance of Withdrawal Penalty funds held by Transmission Provider but not yet dispersed on its OASIS site and update this posting on a quarterly basis.

If an Interconnection Customer withdraws after it executes, or requests the unexecuted filing of, its LGIA, Transmission Provider shall first apply such Interconnection Customer's Withdrawal Penalty funds to any restudy costs required due to Interconnection Customer's withdrawal as a credit to as-yet-to be invoiced study costs to be charged to the remaining Interconnection Customers in the same Cluster in a manner consistent with Transmission Provider's method in Section 13.3 of this LGIP for allocating the costs of Interconnection Studies conducted on a clustered basis. Distribution of the Withdrawal Penalty funds for such restudy costs shall not exceed the total actual restudy costs.

3.7.1.2.2 Assessment of Network Upgrade Costs Previously Shared with Withdrawn Interconnection Customers in the Same Cluster.

If Withdrawal Penalty funds remain for the same Cluster after the Withdrawal Penalty funds are applied to relevant study costs, Transmission Provider will determine if the withdrawn Interconnection Customers, at any point in the Cluster Study Process, shared cost assignment for one or more Network Upgrades with any remaining Interconnection Customers in the same Cluster based on the Cluster Study Report, Cluster Restudy Report(s), Interconnection Facilities Study Report, and any subsequent issued restudy report issued for the Cluster.

In Section 3.7.1.2 of this LGIP, shared cost assignments for Network Upgrades refers to the cost of Network Upgrades still needed for the same Cluster for which an Interconnection Customer, prior to withdrawing its Interconnection Request, shared the obligation to fund along with Interconnection Customers that have executed an LGIA, or requested the LGIA to be filed unexecuted.

If Transmission Provider's assessment determines that there are no shared cost assignments for any Network Upgrades in the same Cluster for the withdrawn Interconnection Customer, or determines that the withdrawn Interconnection Customer's withdrawal did not cause a net increase in the shared cost assignment for any remaining Interconnection Customers' Network Upgrade(s) in the same Cluster, Transmission Provider will return any remaining Withdrawal Penalty funds to the withdrawn Interconnection Customer(s). Such remaining Withdrawal Penalty funds will be returned to withdrawn Interconnection Customers based on the proportion of each withdrawn Interconnection Customer's contribution to the total amount of Withdrawal Penalty funds collected for the Cluster (i.e., the total amount before the initial disbursement required under Section 3.7.1.2.1 of this LGIP). Transmission Provider must make such disbursement within sixty (60) Calendar Days of the date on which all Interconnection Customers in the same Cluster have either: (1) withdrawn or been deemed withdrawn; (2) executed an LGIA; or (3) requested an LGIA to be filed unexecuted. For the withdrawn Interconnection Customers that Transmission Provider determines have caused a net increase in the shared cost assignment for one or more Network Upgrade(s) in the same Cluster under Section 3.7.1.2.3(a) of this LGIP, Transmission Provider will determine each such withdrawn Interconnection Customers' Withdrawal Penalty funds remaining

balance that will be applied toward net increases in Network Upgrade shared costs calculated under Sections 3.7.1.2.3(a) and 3.7.1.2.3(b) of this LGIP based on each such withdrawn Interconnection Customer's proportional contribution to the total amount of Withdrawal Penalty funds collected for the same Cluster (i.e., the total amount before the initial disbursement requirement under Section 3.7.1.2.1 of this LGIP).

If Transmission Provider's assessment determines that there are shared cost assignments for Network Upgrades in the same Cluster, Transmission Provider will calculate the remaining Interconnection Customers' net increase in cost assignment for Network Upgrades due to a shared cost assignment for Network Upgrades with the withdrawn Interconnection Customer and distribute Withdrawal Penalty funds as described in Section 3.7.1.2.3, depending on whether the withdrawal occurred before the withdrawing Interconnection Customer executed the LGIA (or filed unexecuted), as described in Section 3.7.1.2.3(a) of this LGIP, or after such execution (or filing unexecuted) of an LGIA, as described in Section 3.7.1.2.3(b) of this LGIP.

As discussed in Section 3.7.1.2.4 of this LGIP, Transmission Provider will amend executed (or filed unexecuted) LGIAs of the remaining Interconnection Customers in the same Cluster to apply the remaining Withdrawal Penalty funds to reduce net increases in Interconnection Customers' Network Upgrade cost assignment and associated financial security requirements under Article 11.5 of the pro forma LGIA attributable to the impacts of withdrawn Interconnection Customers on Interconnection Customers remaining in the same Cluster that had a

shared cost assignment for Network Upgrades with the withdrawn Interconnection Customers.

3.7.1.2.3 Impact Calculations.

3.7.1.2.3(a) Impact Calculation for Withdrawals During the Cluster Study Process.

If an Interconnection Customer withdraws before it executes, or requests the unexecuted filing of, its LGIA, Transmission Provider will distribute in the following manner the Withdrawal Penalty funds to reduce the Network Upgrade cost impact on the remaining Interconnection Customers in the same Cluster who had a shared cost assignment for a Network Upgrade with the withdrawn Interconnection Customer.

To calculate the reduction in the remaining Interconnection Customers' net increase in Network Upgrade costs and associated financial security requirements under Article 11.5 of the pro forma LGIA, Transmission Provider will determine the financial impact of a withdrawing Interconnection Customer on other Interconnection Customers in the same Cluster that shared an obligation to fund the same Network Upgrade(s). Transmission Provider shall calculate this financial impact once all Interconnection Customers in the same Cluster either: (1) have withdrawn or have been deemed withdrawn; (2) executed an LGIA; or (3) request an LGIA to be filed unexecuted. Transmission Provider will perform the financial impact calculation using the following steps.

First, Transmission Provider must determine which withdrawn Interconnection Customers shared an obligation to fund Network Upgrades with Interconnection Customers from the same Cluster that have LGIAs that are executed or have been requested to be filed unexecuted. Next, Transmission Provider shall perform the calculation of the financial impact of a withdrawal on another Interconnection Request in the same Cluster by performing a comparison of the Network Upgrade cost estimates between each of the following:

- (1) Cluster Study phase to Cluster Restudy phase (if Cluster Restudy was necessary);
- (2) Cluster Restudy phase to Interconnection Facilities Study phase (if a Cluster Restudy was necessary);
- (3) Cluster Study phase to Interconnection Facilities Study phase (if no Cluster Restudy was performed);
- (4) Interconnection Facilities Study phase to any subsequent restudy that was performed before the execution or filing of an unexecuted LGIA;
- (5) the restudy to the executed, or filed unexecuted, LGIA (if a restudy was performed after the Interconnection Facilities Study phase and before the execution or filing of an unexecuted LGIA).

If, based on the above calculations, Transmission Provider determines:

(i) that the costs assigned to an Interconnection Customer in the same Cluster for Network Upgrades that a withdrawn Interconnection Customer shared cost assignment for increased between any two studies, and

(ii) after the impacted Interconnection Customer's LGIA was executed or filed unexecuted, Interconnection Customer's cost assignment for the relevant Network Upgrade is greater than it was prior to the withdrawal of Interconnection Customer in the same Cluster that shared cost assignment for the Network Upgrade,

then Transmission Provider shall apply the withdrawn Interconnection Customer's Withdrawal Penalty funds that has not already been applied to study costs in the amount of the financial impact by reducing, in the same Cluster, the remaining Interconnection Customer's Network Upgrade costs and associated financial security requirements under Article 11.5 of the pro forma LGIA.

If Transmission Provider determines that more than one Interconnection Customer in the same Cluster was financially impacted by the same withdrawn Interconnection Customer, Transmission Provider will apply the relevant withdrawn Interconnection Customer's Withdrawal Penalty funds that has not already been applied to study costs to reduce the financial impact to each Interconnection Customer based on each Interconnection Customer's proportional share of the financial impact, as determined by either the Proportional Impact Method if it is a System Network Upgrade or on a per capita basis if it is a Substation Network Upgrade, as described under Section 4.2.1 of this LGIP.

3.7.1.2.3(b) Impact Calculation for Withdrawals in the Same Cluster After the Cluster Study Process.

If an Interconnection Customer withdraws after it executes, or requests the unexecuted filing of, its LGIA, Transmission Provider will distribute in the following manner the remaining Withdrawal Penalty funds to reduce the Network Upgrade cost impact on the remaining Interconnection Customers in the same Cluster who had a shared cost assignment with the withdrawn Interconnection Customer for one or more Network Upgrades.

Transmission Provider will determine the financial impact on the remaining Interconnection Customers in the same Cluster within thirty (30) Calendar Days after the withdrawal occurs. Transmission Provider will determine that financial impact by comparing the Network Upgrade cost funding obligations Interconnection Customers shared with the withdrawn Interconnection Customer before the withdrawal of Interconnection Customer and after the withdrawal of Interconnection Customer. If that comparison indicates an increase in Network Upgrade costs for an Interconnection Customer, Transmission Provider shall apply the withdrawn Interconnection Customer's Withdrawal Penalty funds to the increased costs each impacted Interconnection Customer in the same Cluster experienced associated with such Network Upgrade(s) in proportion to each Interconnection Customer's increased cost assignment, as determined by Transmission Provider.

3.7.1.2.4 Amending LGIA to Apply Reductions to Interconnection Customer's Assigned Network Upgrade Costs and Associated Financial Security

Requirement with Respect to Withdrawals in the Same Cluster.

Within thirty (30) Calendar Days of all Interconnection Customers in the same Cluster having: (1) withdrawn or been deemed withdrawn; (2) executed an LGIA; or (3) requested an LGIA to be filed unexecuted, Transmission Provider must perform the calculations described in Section 3.7.1.2.3(a) of this LGIP and provide such Interconnection Customers with an amended LGIA that provides the reduction in Network Upgrade cost assignment and associated reduction to Interconnection Customer's financial security requirements, under Article 11.5 of the pro forma LGIA, due from Interconnection Customer to Transmission Provider.

Where an Interconnection Customer executes the LGIA (or requests the filing of an unexecuted LGIA) and is later withdrawn or its LGIA is terminated, Transmission Provider must, within thirty (30) Calendar Days of such withdrawal or termination, perform the calculations described in Section 3.7.1.2.3(b) of this LGIP and provide such Interconnection Customers in the same Cluster with an amended LGIA that provides the reduction in Network Upgrade cost assignment and associated reduction to Interconnection Customer's financial security requirements, under Article 11.5 of the pro forma LGIA, due from Interconnection Customer to Transmission Provider.

Any repayment by Transmission Provider to Interconnection Customer under Article 11.4 of the pro forma LGIA of amounts advanced for Network Upgrades after the Generating Facility achieves Commercial Operation shall be limited to Interconnection Customer's total amount of Network

Upgrade costs paid and associated financial security provided to Transmission Provider under Article 11.5 of the pro forma LGIA.

3.7.1.2.5

Final Distribution of Withdrawal Penalty Funds.

If Withdrawal Penalty funds remain for the Cluster after the Withdrawal Penalty funds are applied to relevant study costs and net increases in shared cost assignments for Network Upgrades to remaining Interconnection Customers, Transmission Provider will return any remaining Withdrawal Penalty funds to the withdrawn Interconnection Customers in the same Cluster net of the amount of each withdrawn Interconnection Customer's Withdrawal Penalty funds applied to study costs and net increases in shared cost assignments for Network Upgrades to remaining Interconnection Customers.

3.8 Identification of Contingent Facilities.

Transmission Provider shall post in this section a method for identifying the Contingent Facilities to be provided to Interconnection Customer at the conclusion of the Cluster Study and included in Interconnection Customer's Large Generator Interconnection Agreement. The method shall be sufficiently transparent to determine why a specific Contingent Facility was identified and how it relates to the Interconnection Request. Transmission Provider shall also provide, upon request of Interconnection Customer, the estimated Interconnection Facility and/or Network Upgrade costs and estimated in-service completion time of each identified Contingent Facility when this information is readily available and not commercially sensitive.

3.8 Identification of Contingent Facilities. The Cluster Study shall identify any Contingent Facilities that may impact the results of the Cluster Study and explain how each Contingent Facility was identified and how it relates to the Interconnection Request.

3.8.1 Method for Identifying Contingent Facilities

The following process, outlined below, is to be followed by Transmission

Provider to identify Contingent Facilities, if any, upon which the Interconnection Customer's costs, timing, and study findings are dependent. Any Contingent Facilities that are identified will be provided to Interconnection Customer within the LGIP Interconnection Cluster Study.

- i) During each Cluster Study, Transmission Provider will review higher queued interconnection requests to determine whether any of the request(s) have unbuilt Interconnection Facilities and/or Network Upgrades that may be necessary to provide the Interconnection Customer's requested interconnection. Such unbuilt facilities and/or upgrades will be noted as potential Contingent Facilities and used in various impact studies (as described in Section 3.8.1.ii).
- ii) Near completion of the Cluster Study, the Transmission Provider will finalize the list of Contingent Facilities by removing each previously identified potential Contingent Facility and, if applicable, any Affected System facility modifications from the study cases, and perform steady state, short circuit, voltage stability, and/or transient stability analyses to determine if the Transmission System is unable to demonstrate acceptable system performance. Acceptable system performance, as used in this context for purposes of identifying Contingent Facilities, is determined during the analysis by meeting the performance requirements outlined in Table 1 of NERC standard TPL-001-4. The studied system shall remain stable, cascading and uncontrolled islanding shall not occur and applicable facility ratings shall not be exceeded during pre and post contingency for all study cases/seasonal models. Acceptable system performance shall also mean that system operating limits shall not be exceeded for all pre and post contingency scenarios and the system must demonstrate compliance with the "SPP 2019 TPL-001-4 Planning Assessment Scope" (or its annual successor), which requires pre-contingency voltage between .95 and 1.05 per unit of nominal, post-contingency voltage between .90 and 1.05 per unit of nominal, no post-contingency voltage deviation greater than .10 per unit, and no transmission lines/ conductors are overloaded (greater than 100% of the modeled line rating) during pre and post-contingency scenarios.
- iii) If the Transmission System fails to demonstrate acceptable system performance (based on the analysis performed for each potential Contingent Facility as described in Section 3.8.1.ii), the potential contingent facility will be confirmed as a Contingent Facility. Potential contingent facilities that are associated with communications, protection, and automation systems necessary for

the operation of the Generating Facility or associated with delivery of its output, are also deemed Contingent Facilities.

- iv) In the Cluster Study report, Transmission Provider will list each Contingent Facility and why it was identified as such.

3.8.2. Estimates Available for Contingent Facilities. Upon request of the Interconnection Customer, the Transmission Provider shall provide the estimated costs of Interconnection Facilities and/or Network Upgrades and estimated in-service completion times of each Contingent Facility identified in the Cluster Study performed pursuant to Section 7.3 of the LGIP, if, and to the extent, Transmission Provider determines such information is readily available and not commercially sensitive.

3.8.3 Inclusion of Contingent Facilities in LGIA. Any Contingent Facilities identified for Interconnection Customer at the conclusion of a Cluster Study, performed pursuant to Section 7.3 of this LGIP, will subsequently be included in such Interconnection Customer's Large Generator Interconnection Agreement, to the extent they are still applicable.

3.9 Penalties for Failure to Meet Study Deadlines.

(1) Transmission Provider shall be subject to a penalty if it fails to complete a Cluster Study, Cluster Restudy, Interconnection Facilities Study, or Affected Systems Study by the applicable deadline set forth in this LGIP. Transmission Provider must pay the penalty for each late Cluster Study, Cluster Restudy, and Interconnection Facilities Study on a pro rata basis per Interconnection Request to all Interconnection Customer(s) included in the relevant study that did not withdraw, or were not deemed withdrawn, from Transmission Provider's interconnection queue before the missed study deadline, in proportion to each Interconnection Customer's final study cost. Transmission Provider must pay the penalty for a late Affected Systems Study on a pro rata basis per interconnection request to all Affected System Interconnection Customer(s) included in the relevant Affected System Study that did not withdraw, or were not deemed withdrawn, from the host transmission provider's interconnection queue before the missed study deadline, in proportion to each Interconnection Customer's final study cost. The study delay penalty for each late study shall be distributed no later than forty-five (45) Calendar Days after the late study has been completed.

(2) For penalties assessed in accordance with this Section, the penalty amount will be equal to: \$1,000 per Business Day for delays of Cluster Studies beyond the applicable deadline set forth in this LGIP; \$2,000 per Business Day for delays of Cluster Restudies beyond the applicable deadline set forth in this LGIP; \$2,000 per Business Day for delays of Affected System Studies beyond the applicable deadline set forth in this LGIP; and \$2,500 per Business Day for delays of Interconnection Facilities Studies beyond the applicable deadline set forth in this LGIP. The total amount of a penalty assessed under this Section shall not exceed: (a) one hundred percent (100%) of the initial study deposit(s) received for all of the Interconnection Requests in the Cluster for Cluster Studies and Cluster Restudies; (b) one hundred percent (100%) of the initial study deposit received for the single Interconnection Request in the study for Interconnection Facilities Studies; and (c) one hundred percent (100%) of the study deposit(s) that Transmission Provider collects for conducting the Affected System Study.

(3) Transmission Provider may appeal to the Commission any penalties imposed under this Section. Any such appeal must be filed no later than forty-five (45) Calendar Days after the late study has been completed. While an appeal to the Commission is pending, Transmission Provider shall remain liable for the penalty, but need not distribute the penalty until forty-five (45) Calendar Days after (1) the deadline for filing a rehearing request has ended, if no requests for rehearing of the appeal have been filed, or (2) the date that any requests for rehearing of the Commission's decision on the appeal are no longer pending before the Commission. The Commission may excuse Transmission Provider from penalties under this Section for good cause.

(4) No penalty will be assessed under this Section where a study is delayed by ten (10) Business Days or less. If the study is delayed by more than ten (10) Business Days, the penalty amount will be calculated from the first Business Day Transmission Provider misses the applicable study deadline.

(5) If (a) Transmission Provider needs to extend the deadline for a particular study subject to penalties under this Section and (b) all Interconnection Customers or Affected System Interconnection Customers included in the relevant study mutually agree to such an extension, the deadline for that study shall be extended thirty (30) Business Days from the original deadline. In such a scenario, no penalty will be assessed for Transmission Provider missing the original deadline.

(6) No penalties shall be assessed until the third Cluster Study cycle (including any Transitional Cluster Study cycle, but not Transitional Serial Interconnection Facilities Studies) after the Commission-approved effective date of Transmission Provider's filing made in compliance with the Final Rule in Docket No. RM22-14-000.

(7) Transmission Provider must maintain on its OASIS or its public website summary statistics related to penalties assessed under this Section, updated quarterly. For each calendar quarter, Transmission Provider must calculate and post (1) the total amount of penalties assessed under this Section during the previous reporting quarter and (2) the highest penalty assessed under this Section paid to a single Interconnection Customer or Affected System Interconnection Customer during the previous reporting quarter. Transmission Provider must post on its OASIS or its website these penalty amounts for each calendar quarter within thirty (30) Calendar Days of the end of the calendar quarter. Transmission Provider must maintain the quarterly measures posted on its OASIS or its website for three (3) calendar years with the first required posting to be the third Cluster Study cycle (including any Transitional Cluster Study cycle, but not Transitional Serial Interconnection Facilities Studies) after Transmission Provider transitions to the Cluster Study Process.

Section 4. Interconnection Request Evaluation Process.

an Interconnection Customer has submitted a valid Interconnection Request pursuant to Section 3.4 of this LGIP, such Interconnection Request shall become part of Transmission Provider's interconnection queue for further processing pursuant to the following procedures.

4.1 Queue Position.

4.1.1 Assignment of Queue Position.

Transmission Provider shall assign a Queue Position as follows: the Queue Position within the queue shall be assigned based upon the date and time of receipt of all items required pursuant to the provisions of Section 3.4 of this LGIP. All Interconnection Requests submitted and validated in a single Cluster Request Window shall be considered equally queued.

4.1.2 Higher Queue Position.

A higher Queue Position assigned to an Interconnection Request is one that has been placed “earlier” in the queue in relation to another Interconnection Request that is assigned a lower Queue Position. All requests studied in a single Cluster shall be considered equally queued. Interconnection Customers that are part of Clusters initiated earlier in time than an instant queue shall be considered to have a higher Queue Position than Interconnection Customers that are part of Clusters initiated later than an instant queue.

4.2. General Study Process.

Interconnection Studies performed within the Cluster Study Process shall be conducted in such a manner to ensure the efficient implementation of the applicable regional transmission expansion plan in light of the Transmission System’s capabilities at the time of each study and consistent with Good Utility Practice.

Transmission Provider may use subgroups in the Cluster Study Process. In all instances in which Transmission Provider elects to use subgroups in the Cluster Study Process, Transmission Provider must publish the criteria used to define and determine subgroups on its OASIS or public website.

4.2.1 Cost Allocation for Interconnection Facilities and Network Upgrades.

(1) For Network Upgrades identified in Cluster Studies, Transmission Provider shall calculate each Interconnection Customer's share of the costs as follows:

(a) Substation Network Upgrades, including all switching stations, shall be allocated first per capita to Interconnection Facilities interconnecting to the substation at the same voltage level, and then per capita to each Generating Facility sharing the Interconnection Facility.

(b) System Network Upgrades shall be allocated based on the proportional impact of each individual Generating Facility in the Cluster Study on the need for a specific System Network Upgrade. The proportional impact of such Network Upgrades shall be calculated as follows: All transmission lines and transformers identified as Network Upgrades shall be allocated using distribution factor or similar analysis. Voltage support related Network Upgrades shall be allocated using a voltage impact analysis which will identify each Generating Facility's contribution to the voltage violation. Network Upgrades associated with upgrading existing breakers due to short circuit current exceeding breaker capability shall be allocated proportionally based on the short circuit current contribution of each request.

(c) An Interconnection Customer that funds Substation Network Upgrades and/or System Network Upgrades shall be entitled to transmission credits as provided in Article 11.4 of the LGIA.

(2) The costs of any needed Interconnection Facilities identified in the Cluster Study Process will be directly assigned to Interconnection Customer(s) using such facilities. Where Interconnection Customers in the Cluster agree to share

Interconnection Facilities, the cost of such Interconnection Facilities shall be allocated based on the number of Generating Facilities sharing use of such Interconnection Facilities on a per capita basis (i.e., on a per Generating Facility basis), unless Parties mutually agree to a different cost sharing arrangement.

4.3 Transferability of Queue Position.

An Interconnection Customer may transfer its Queue Position to another entity only if such entity acquires the specific Generating Facility identified in the Interconnection Request and the Point of Interconnection does not change.

4.4 Modifications.

Interconnection Customer shall submit to Transmission Provider, in writing, modifications to any information provided in the Interconnection Request. Interconnection Customer shall retain its Queue Position if the modifications are in accordance with Sections 4.4.1, 4.4.2, or 4.4.5 of this LGIP, or are determined not to be Material Modifications pursuant to Section 4.4.3 of this LGIP.

Notwithstanding the above, during the course of the Interconnection Studies, either Interconnection Customer or Transmission Provider may identify changes to the planned interconnection that may improve the costs and benefits (including reliability) of the interconnection, and the ability of the proposed change to accommodate the Interconnection Request. To the extent the identified changes are acceptable to Transmission Provider and Interconnection Customer, such acceptance not to be unreasonably withheld, Transmission Provider shall modify the Point of Interconnection prior to return of the executed Cluster Study Agreement, and Interconnection Customer shall retain its Queue Position.

4.4.1 Prior to the return of the executed Cluster Study Agreement to Transmission Provider, modifications permitted under this Section shall include specifically: (a) a decrease of up to sixty percent (60%) of electrical output (MW) of the proposed project, through either (1) a decrease in plant size or (2) a decrease in Interconnection

Service level (consistent with the process described in Section 3.1 of this LGIP) accomplished by applying Transmission Provider-approved injection-limiting equipment; (b) modifying the technical parameters associated with the Large Generating Facility technology or the Large Generating Facility step-up transformer impedance characteristics; and (c) modifying the interconnection configuration. For plant increases, the incremental increase in plant output will go in the next Cluster Request Window for the purposes of cost allocation and study analysis.

4.4.2 Prior to the return of the executed Interconnection Facilities Study Agreement to Transmission Provider, the modifications permitted under this Section shall include specifically: (a) additional fifteen percent (15%) decrease of electrical output of the proposed project through either (1) a decrease in plant size (MW) or (2) a decrease in Interconnection Service level (consistent with the process described in Section 3.1) accomplished by applying Transmission Provider-approved injection-limiting equipment; (b) Large Generating Facility technical parameters associated with modifications to Large Generating Facility technology and transformer impedances; provided, however, the incremental costs associated with those modifications are the responsibility of the requesting Interconnection Customer; and (c) a Permissible Technological Advancement for the Large Generating Facility after the submission of the Interconnection Request. Section 4.4.6 of this LGIP specifies a separate technological change procedure including the requisite information and process that will be followed to assess whether Interconnection Customer's proposed technological advancement under Section 4.4.2(c) of this LGIP is a Material Modification. Section 1 of this LGIP contains a definition of Permissible Technological Advancement.

4.4.3 Prior to making any modification other than those specifically permitted by Sections 4.4.1, 4.4.2, and 4.4.5 of this LGIP, Interconnection Customer may first request that Transmission Provider evaluate whether such modification is a Material Modification. In response to Interconnection Customer's request, Transmission Provider shall evaluate the proposed modifications

prior to making them and inform Interconnection Customer in writing of whether the modifications would constitute a Material Modification. Any change to the Point of Interconnection, except those deemed acceptable under Sections 3.1.2 or 4.4 of this LGIP or so allowed elsewhere, shall constitute a Material Modification. Interconnection Customer may then withdraw the proposed modification or proceed with a new Interconnection Request for such modification. Transmission Provider shall study the addition of a Generating Facility that includes at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect the proposed charging behavior of the Generating Facility as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions.

4.4.3.1 Section Omitted.

- 4.4.4 Upon receipt of Interconnection Customer's request for modification permitted under this Section 4.4 of this LGIP, Transmission Provider shall commence and perform any necessary additional studies as soon as practicable, but in no event shall Transmission Provider commence such studies later than thirty (30) Calendar Days after receiving notice of Interconnection Customer's request. Any additional studies resulting from such modification shall be done at Interconnection Customer's cost. Any such request for modification of the Interconnection Request must be accompanied by any resulting updates to the models described in Attachment A to Appendix 1 of this LGIP.
- 4.4.5 Extensions of less than three (3) cumulative years in the Commercial Operation Date of the Large Generating Facility to which the Interconnection Request relates are not material and should be handled through construction sequencing. For purposes of this section, the Commercial Operation Date reflected in the initial Interconnection Request shall be used to calculate the permissible

extension prior to Interconnection Customer executing an LGIA or requesting that the LGIA be filed unexecuted. After an LGIA is executed or requested to be filed unexecuted, the Commercial Operation Date reflected in the LGIA shall be used to calculate the permissible extension. Such cumulative extensions may not exceed three years including both extensions requested after execution of the LGIA by Interconnection Customer or the filing of an unexecuted LGIA by Transmission Provider and those requested prior to execution of the LGIA by Interconnection Customer or the filing of an unexecuted LGIA by Transmission Provider.

4.4.6 Technological Change Procedure. In accordance with Section 4.4.2, at any time prior to the execution of the Interconnection Facilities Study Agreement the Interconnection Customer may submit a request if it seeks to incorporate technological advancements into its proposed Large Generating Facility. The technological advancement request should include an analysis and other supporting information to explain how it affects its original Interconnection Request, including a demonstration that (i) the technological advancement request will result in equal to or better than the electrical performance expected prior to the technology change, and (ii) would not cause any reliability standard criteria (including any applicable TPL or PRC standards), short circuit capability limits, steady-state thermal and voltage limits, or dynamic system stability and response impacts. If the Transmission Provider determines that additional studies are needed to evaluate whether a technological advancement is a material modification, a deposit in the amount of \$10,000 will be required to reimburse the Transmission Provider for the time and effort needed to complete the study. The Transmission Provider shall describe to the Interconnection Customer any costs incurred to conduct any necessary additional studies, provide its costs to the Interconnection Customer, and either refund any overage or charge for any shortage for costs that exceed the deposit amount. If it is determined that the technological advancement request does not change the specifications for the Large Generating Facility submitted by the Interconnection Customer to the Transmission Provider, the request shall be deemed a Permissible Technological Advancement and no further action shall be required. If the study results changes the submitted specifications, the request to change the Large Generating Facility's technology shall be deemed a Material Modification in

accordance with Section 4.4.3. The Transmission Provider will make a determination regarding the proposed technological advancement request and provide a written explanation within thirty (30) days of receiving the request.

Section 5. Procedures for Interconnection Requests Submitted Prior to Effective Date of the Cluster Study Revisions

5.1 Procedures for Transitioning to the Cluster Study Process.

5.1.1 Any Interconnection Customer assigned a Queue Position as of thirty (30) Calendar Days after May 16, 2024 (the filing date of this LGIP) shall retain that Queue Position subject to the requirements in Sections 5.1.1.1 and 5.1.1.2 of this LGIP. Any Interconnection Customer that fails to meet these requirements shall have its Interconnection Request deemed withdrawn by Transmission Provider pursuant to Section 3.7 of this LGIP. In such case, Transmission Provider shall not assess Interconnection Customer any Withdrawal Penalty.

Any Interconnection Customer that has received a final Interconnection Facilities Study Report before the commencement of the studies under the transition process set forth in this Section shall be tendered an LGIA pursuant to Section 11 of this LGIP, and shall not be required to enter this transition process.

5.1.1.1 Transitional Serial Study.

An Interconnection Customer that has been tendered an Interconnection Facilities Study Agreement as of thirty (30) Calendar Days after May 16, 2024 (the filing date of this LGIP) may opt to proceed with an Interconnection Facilities Study. Transmission Provider shall tender each eligible Interconnection Customer a Transitional Serial Interconnection Facilities Study Agreement, in the form of Appendix 8 to this LGIP, no later than the Commission-approved effective date of this LGIP. Transmission Provider

shall proceed with the Interconnection Facilities Study, provided that Interconnection Customer: (1) meets each of the following requirements; and (2) executes the Transitional Serial Interconnection Facilities Study Agreement within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP. If an eligible Interconnection Customer does not meet these requirements, its Interconnection Request shall be deemed withdrawn without penalty. Transmission Provider must commence the Transitional Serial Interconnection Facilities Study at the conclusion of this sixty (60) Calendar Day period. Transitional Serial Interconnection Facilities Study costs shall be allocated according to the method described in Section 13.3 of this LGIP.

All of the following must be included when an Interconnection Customer returns the Transitional Serial Interconnection Facilities Study Agreement:

(1) A deposit equal to one hundred percent (100%) of the costs identified for Transmission Provider's Interconnection Facilities and Network Upgrades in Interconnection Customer's system impact study report. If Interconnection Customer does not withdraw, the deposit shall be trued up to actual costs once they are known and applied to future construction costs described in Interconnection Customer's eventual LGIA. Any amounts in excess of the actual construction costs shall be returned to Interconnection Customer within thirty (30) Calendar Days of the issuance of a final invoice for construction costs, in accordance with Article 12.2 of the pro forma LGIA. If Interconnection Customer withdraws or otherwise does not reach Commercial Operation, Transmission Provider shall refund the remaining deposit after the final invoice for study costs and Transitional Withdrawal Penalty is settled. The deposit shall be in

the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider, where cash deposits shall be treated according to Section 3.7 of this LGIP.

(2) Exclusive Site Control for 100% of the proposed Generating Facility.

Transmission Provider shall conduct each Transitional Serial Interconnection Facilities Study and issue the associated Transitional Serial Interconnection Facilities Study Report within one hundred fifty (150) Calendar Days of the Commission-approved effective date of this LGIP.

After Transmission Provider issues each Transitional Interconnection Facilities Study Report, Interconnection Customer shall proceed pursuant to Section 11 of this LGIP. If Interconnection Customer withdraws its Interconnection Request or if Interconnection Customer's Generating Facility otherwise does not reach Commercial Operation, a Transitional Withdrawal Penalty shall be imposed on Interconnection Customer equal to nine (9) times Interconnection Customer's total study cost incurred since entering Transmission Provider's interconnection queue (including the cost of studies conducted under Section 5 of this LGIP).

5.1.1.2

Transitional Cluster Study.

An Interconnection Customer with an assigned Queue Position as of thirty (30) Calendar Days after May 16, 2024 (the filing date of this LGIP) may opt to proceed with a Transitional Cluster Study. Transmission Provider shall tender each eligible Interconnection

Customer a Transitional Cluster Study Agreement, in the form of Appendix 7 to this LGIP, no later than the Commission-approved effective date of this LGIP. Transmission Provider shall proceed with the Transitional Cluster Study that includes each Interconnection Customer that: (1) meets each of the following requirements listed as (1)–(3) in this section; and (2) executes the Transitional Cluster Study Agreement within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP. All Interconnection Requests that enter the Transitional Cluster Study shall be considered to have an equal Queue Position that is lower than Interconnection Customer(s) proceeding with Transitional Serial Interconnection Facilities Study. If an eligible Interconnection Customer does not meet these requirements, its Interconnection Request shall be deemed withdrawn without penalty. Transmission Provider must commence the Transitional Cluster Study at the conclusion of this sixty (60) Calendar Day period. All identified Transmission Provider's Interconnection Facilities and Network Upgrade costs shall be allocated according to Section 4.2.1 of this LGIP. Transitional Cluster Study costs shall be allocated according to the method described in Section 13.3 of this LGIP.

Interconnection Customer may make a one-time extension to its requested Commercial Operation Date upon entry into the Transitional Cluster Study, where any such extension shall not result in a Commercial Operation Date later than December 31, 2027.

All of the following must be included when an Interconnection Customer returns the Transitional Cluster Study Agreement:

(1) A selection of either Energy Resource Interconnection Service or Network Resource Interconnection Service.

(2) A deposit of five million dollars (\$5,000,000) in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider, where cash deposits will be treated according to Section 3.7 of this LGIP. If Interconnection Customer does not withdraw, the deposit shall be reconciled with and applied towards future construction costs described in the LGIA. Any amounts in excess of the actual construction costs shall be returned to Interconnection Customer within thirty (30) Calendar Days of the issuance of a final invoice for construction costs, in accordance with Article 12.2 of the pro forma LGIA. If Interconnection Customer withdraws or otherwise does not reach Commercial Operation, Transmission Provider must refund the remaining deposit once the final invoice for study costs and Transitional Withdrawal Penalty is settled.

(3) Exclusive Site Control for 100% of the proposed Generating Facility.

Transmission Provider shall conduct the Transitional Cluster Study and issue both an associated interim Transitional Cluster Study Report and an associated final Transitional Cluster Study Report. The interim Transitional Cluster Study Report shall provide the following information:

- identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;

- identification of any thermal overload or voltage limit violations resulting from the interconnection;

- identification of any instability or inadequately damped response to system disturbances resulting from the interconnection; and

- Transmission Provider's Interconnection Facilities and Network Upgrades that are expected to be required as a result of the Interconnection Request(s) and a non-binding, good faith estimate of cost responsibility and a non-binding, good faith estimated time to construct.

In addition to the information provided in the interim Transitional Cluster Study Report, the final Transitional Cluster Study Report shall provide a description of, estimated cost of, and schedule for construction of Transmission Provider's Interconnection Facilities and Network Upgrades required to interconnect the Generating Facility to the Transmission System that resolve issues identified in the interim Transitional Cluster Study Report.

The interim and final Transitional Cluster Study Reports shall be issued within three hundred (300) and three hundred sixty (360) Calendar Days of the Commission-approved effective date of this LGIP, respectively, and shall be posted on Transmission Provider's OASIS consistent with the posting of other study results pursuant to Section 3.5.1 of this LGIP. Interconnection Customer shall have thirty (30) Calendar Days to comment on the interim Transitional Cluster Study Report, once it has been received.

After Transmission Provider issues the final Transitional Cluster Study Report, Interconnection Customer shall proceed pursuant to Section 11 of this LGIP. If Interconnection Customer withdraws its Interconnection Request or if Interconnection Customer's Generating Facility otherwise does not reach Commercial Operation, a Transitional Withdrawal Penalty will be imposed on Interconnection Customer equal to nine (9) times Interconnection Customer's total study cost incurred since entering Transmission Provider's interconnection queue (including the cost of studies conducted under Section 5 of this LGIP).

5.1.2 Transmission Providers with Existing Cluster Study Processes or Currently in Transition

If Transmission Provider is not conducting a transition process under Section 5.1.1, it will continue processing Interconnection Requests under its current Cluster Study Process. Within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP, Interconnection Customers that have not executed an LGIA or requested an LGIA to be filed unexecuted must meet the requirements of Sections 3.4.2, 7.5, or 8.1 of this LGIP, based on Interconnection Customer's Queue Position.

Any Interconnection Customer that fails to meet these requirements within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP shall have its Interconnection Request deemed withdrawn by Transmission Provider pursuant to Section 3.7 of this LGIP. In such case, Transmission Provider shall not assess Interconnection Customer any Withdrawal Penalty.

5.2 New Transmission Provider.

If Transmission Provider transfers control of its Transmission System to a successor Transmission Provider during the period when an Interconnection Request is pending, the original Transmission Provider shall transfer to the successor Transmission Provider any amount of the deposit or payment with interest thereon that exceeds the cost that it incurred to evaluate the request for interconnection. Any difference between such net amount and

the deposit or payment required by this LGIP shall be paid by or refunded to Interconnection Customer, as appropriate. The original Transmission Provider shall coordinate with the successor Transmission Provider to complete any Interconnection Study, as appropriate, that the original Transmission Provider has begun but has not completed. If Transmission Provider has tendered a draft LGIA to Interconnection Customer but Interconnection Customer has not either executed the LGIA or requested the filing of an unexecuted LGIA with FERC, unless otherwise provided, Interconnection Customer must complete negotiations with the successor Transmission Provider.

Section 6. Interconnection Information Access

6.1 Publicly Posted Interconnection Information.

Transmission Provider shall maintain and make publicly available: (1) an interactive visual representation of the estimated incremental injection capacity (in megawatts) available at each point of interconnection in Transmission Provider's footprint under N-1 conditions, and (2) a table of metrics concerning the estimated impact of a potential Generating Facility on Transmission Provider's Transmission System based on a user-specified addition of a particular number of megawatts at a particular voltage level at a particular point of interconnection. At a minimum, for each transmission facility impacted by the user-specified megawatt addition, the following information will be provided in the table: (1) the distribution factor; (2) the megawatt impact (based on the megawatt values of the proposed Generating Facility and the distribution factor); (3) the percentage impact on each impacted transmission facility (based on the megawatt values of the proposed Generating Facility and the facility rating); (4) the percentage of power flow on each impacted transmission facility before the injection of the proposed project; (5) the percentage power flow on each impacted transmission facility after the injection of the proposed Generating Facility. These metrics must be calculated based on the power flow model of the Transmission System with the transfer simulated from each point of interconnection to the whole Transmission Provider's footprint (to approximate Network Resource Interconnection Service), and with the incremental capacity at each point of interconnection decremented by the existing and queued Generating Facilities (based on the existing or

requested interconnection service limit of the generation). These metrics must be updated within thirty (30) Calendar Days after the completion of each Cluster Study and Cluster Restudy. This information must be publicly posted, without a password or a fee. The website will define all underlying assumptions, including the name of the most recent Cluster Study or Restudy used in the Base Case.

Section 7. Cluster Study

7.1 Cluster Study Agreement.

No later than five (5) Business Days after the close of a Cluster Request Window, Transmission Provider shall tender to each Interconnection Customer that submitted a valid Interconnection Request a Cluster Study Agreement in the form of Appendix 2 to this LGIP. The Cluster Study Agreement shall require Interconnection Customer to compensate Transmission Provider for the actual cost of the Cluster Study pursuant to Section 13.3 of this LGIP. The specifications, assumptions, or other provisions in the appendices of the Cluster Study Agreement provided pursuant to Section 7.1 of this LGIP shall be subject to change by Transmission Provider following the conclusion of the Scoping Meeting.

7.2 Execution of Cluster Study Agreement.

Interconnection Customer shall execute the Cluster Study Agreement and deliver the executed Cluster Study Agreement to Transmission Provider no later than the close of the Customer Engagement Window.

If Interconnection Customer does not provide all required technical data when it delivers the Cluster Study Agreement, Transmission Provider shall notify Interconnection Customer of the deficiency within five (5) Business Days of the receipt of the executed Cluster Study Agreement and Interconnection Customer shall cure the deficiency within ten (10) Business Days of receipt of the notice, provided, however, such deficiency does not include failure to deliver the executed Cluster Study Agreement or study deposit.

7.3 Scope of Cluster Study.

The Cluster Study shall evaluate the impact of the proposed interconnection on the reliability of the Transmission System. The Cluster Study will consider the Base Case as well as all Generating Facilities (and with respect

to (iii) below, any identified Network Upgrades associated with such higher queued interconnection) that, on the date the Cluster Study is commenced: (i) are directly interconnected to the Transmission System; (ii) are interconnected to Affected Systems and may have an impact on the Interconnection Request; (iii) have a pending higher queued Interconnection Request to interconnect to the Transmission System; and (iv) have no Queue Position but have executed an LGIA or requested that an unexecuted LGIA be filed with FERC.

For purposes of determining necessary Interconnection Facilities and Network Upgrades, the Cluster Study shall use the level of Interconnection Service requested by Interconnection Customers in the Cluster, except where Transmission Provider otherwise determines that it must study the full Generating Facility Capacity due to safety or reliability concerns.

The Cluster Study will consist of power flow, stability, and short circuit analyses, the results of which are documented in a single Cluster Study Report, as applicable. At the conclusion of the Cluster Study, Transmission Provider shall issue a Cluster Study Report. The Cluster Study Report will state the assumptions upon which it is based; state the results of the analyses; and provide the requirements or potential impediments to providing the requested Interconnection Service, including a preliminary indication of the cost and length of time that would be necessary to correct any problems identified in those analyses and implement the interconnection. The Cluster Study Report shall identify the Interconnection Facilities and Network Upgrades expected to be required to reliably interconnect the Generating Facilities in that Cluster Study at the requested Interconnection Service level and shall provide non-binding cost estimates for required Network Upgrades. The Cluster Study Report shall identify each Interconnection Customer's estimated allocated costs for Interconnection Facilities and Network Upgrades pursuant to the method in Section 4.2.1 of this LGIP. Transmission Provider shall hold an open stakeholder meeting pursuant to Section 7.4 of this LGIP.

For purposes of determining necessary Interconnection Facilities and Network Upgrades, the Cluster Study shall use operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at

peak load) that reflect the proposed charging behavior of a Generating Facility that includes at least one electric storage resource as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions. Transmission Provider may require the inclusion of control technologies sufficient to limit the operation of the Generating Facility per the operating assumptions as set forth in the Interconnection Request and to respond to dispatch instructions by Transmission Provider. As determined by Transmission Provider, Interconnection Customer may be subject to testing and validation of those control technologies consistent with Article 6 of the LGIA.

The Cluster Study shall evaluate the use of static synchronous compensators, static VAR compensators, advanced power flow control devices, transmission switching, synchronous condensers, voltage source converters, advanced conductors, and tower lifting. Transmission Provider shall evaluate each identified alternative transmission technology and determine whether the above technologies should be used, consistent with Good Utility Practice, Applicable Reliability Standards, and Applicable Laws and Regulations. Transmission Provider shall include an explanation of the results of Transmission Provider's evaluation for each technology in the Cluster Study Report.

The Cluster Study Report will provide a list of facilities that are required as a result of the Interconnection Requests within the Cluster and a non-binding good faith estimate of cost responsibility and a non-binding good faith estimated time to construct.

7.4 Cluster Study Procedures.

Transmission Provider shall coordinate the Cluster Study with any Affected System Operator that is affected by the Interconnection Request pursuant to Section 3.6 of this LGIP. Transmission Provider shall utilize existing studies to the extent practicable when it performs the Cluster Study. Interconnection Requests for a Cluster Study may be submitted only within the Cluster Request Window and Transmission Provider shall initiate the Cluster Study Process pursuant to Section 7 of this LGIP.

Transmission Provider shall complete the Cluster Study within one hundred fifty (150) Calendar Days of the close of the Customer Engagement Window.

Within ten (10) Business Days of simultaneously furnishing a Cluster Study Report to each Interconnection Customer within the Cluster and posting such report on OASIS, Transmission Provider shall convene a Cluster Study Report Meeting.

At the request of Interconnection Customer or at any time Transmission Provider determines that it will not meet the required time frame for completing the Cluster Study, Transmission Provider shall notify Interconnection Customers as to the schedule status of the Cluster Study. If Transmission Provider is unable to complete the Cluster Study within the time period, it shall notify Interconnection Customers and provide an estimated completion date with an explanation of the reasons why additional time is required. Upon request, Transmission Provider shall provide Interconnection Customers all supporting documentation, workpapers and relevant pre-Interconnection Request and post-Interconnection Request power flow, short circuit and stability databases for the Cluster Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

7.5 Cluster Study Restudies.

(1) Within twenty (20) Calendar Days after the Cluster Study Report Meeting, Interconnection Customer must provide the following:

(a) Demonstration of continued Site Control pursuant to Section 3.4.2(iii) of this LGIP; and

(b) An additional deposit that brings the total Commercial Readiness Deposit submitted to Transmission Provider to five percent (5%) of Interconnection Customer's Network Upgrade cost assignment identified in the Cluster Study in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is

reasonably acceptable to Transmission Provider. Transmission Provider shall refund the deposit to Interconnection Customer upon withdrawal in accordance with Section 3.7 of this LGIP.

Interconnection Customer shall promptly inform Transmission Provider of any material change to Interconnection Customer's demonstration of Site Control under Section 3.4.2(iii) of this LGIP. Upon Transmission Provider determining that Interconnection Customer no longer satisfies the Site Control requirement, Transmission Provider shall notify Interconnection Customer. Within ten (10) Business Days of such notification, Interconnection Customer must demonstrate compliance with the applicable requirement subject to Transmission Provider's approval, not to be unreasonably withheld. Absent such demonstration, Transmission Provider shall deem the subject Interconnection Request withdrawn pursuant to Section 3.7 of this LGIP.

(2) If no Interconnection Customer withdraws from the Cluster after completion of the Cluster Study or Cluster Restudy or is deemed withdrawn pursuant to Section 3.7 of this LGIP after completion of the Cluster Study or Cluster Restudy, Transmission Provider shall notify Interconnection Customers in the Cluster that a Cluster Restudy is not required.

(3) If one or more Interconnection Customers withdraw from the Cluster or are deemed withdrawn pursuant to Section 3.7 of this LGIP, Transmission Provider shall determine if a Cluster Restudy is necessary within thirty (30) Calendar Days after the Cluster Study Report Meeting. If Transmission Provider determines a Cluster Restudy is not necessary, Transmission Provider shall notify Interconnection Customers in the Cluster that a Cluster Restudy is not required and Transmission Provider shall provide an updated Cluster Study Report within thirty (30) Calendar Days of such determination.

(4) If one or more Interconnection Customers withdraws from the Cluster or is deemed withdrawn pursuant to Section 3.7 of this LGIP, and Transmission Provider determines a Cluster Restudy is necessary as a result, Transmission Provider shall notify Interconnection Customers in the Cluster and post on OASIS that a Cluster Restudy is required within thirty

(30) Calendar Days after the Cluster Study Report Meeting. Transmission Provider shall continue with such restudies until Transmission Provider determines that no further restudies are required. If an Interconnection Customer withdraws or is deemed withdrawn pursuant to Section 3.7 of this LGIP during the Interconnection Facilities Study, or after other Interconnection Customers in the same Cluster have executed LGIAs, or requested that unexecuted LGIAs be filed, and Transmission Provider determines a Cluster Restudy is necessary, the Cluster shall be restudied. If a Cluster Restudy is required due to a higher queued project withdrawing from the queue, or a modification of a higher or equally queued project subject to Section 4.4 of this LGIP, Transmission Provider shall so notify affected Interconnection Customers in writing. Except as provided in Section 3.7 of this LGIP in the case of withdrawing Interconnection Customers, any cost of Restudy shall be borne by Interconnection Customers being restudied.

(5) The scope of any Cluster Restudy shall be consistent with the scope of an initial Cluster Study pursuant to Section 7.3 of this LGIP. Transmission Provider shall complete the Cluster Restudy within one hundred fifty (150) Calendar Days of Transmission Provider informing Interconnection Customers in the Cluster that restudy is needed. The results of the Cluster Restudy shall be combined into a single report (Cluster Restudy Report). Transmission Provider shall hold a meeting with Interconnection Customers in the Cluster (Cluster Restudy Report Meeting) within ten (10) Business Days of simultaneously furnishing the Cluster Restudy Report to each Interconnection Customer in the Cluster Restudy and publishing the Cluster Restudy Report on OASIS.

If additional restudies are required, Interconnection Customer and Transmission Provider shall follow the procedures of this Section 7.5 of this LGIP until such time that Transmission Provider determines that no further restudies are required. Transmission Provider shall notify each Interconnection Customer within the Cluster when no further restudies are required.

Section 8. Interconnection Facilities Study

8.1 Interconnection Facilities Study Agreement.

Within five (5) Business Days following Transmission Provider notifying each Interconnection Customer within the Cluster that no further Cluster Restudy is required (per Section 7.5 of this LGIP), Transmission Provider shall provide to Interconnection Customer an Interconnection Facilities Study Agreement in the form of Appendix 3 to this LGIP. Interconnection Customer shall compensate Transmission Provider for the actual cost of the Interconnection Facilities Study. Within five (5) Business Days following the Cluster Report Meeting or Cluster Restudy Report Meeting if applicable, Transmission Provider shall provide to Interconnection Customer a non-binding good faith estimate of the cost and timeframe for completing the Interconnection Facilities Study. Interconnection Customer shall execute the Interconnection Facilities Study Agreement and deliver the executed Interconnection Facilities Study Agreement to Transmission Provider within thirty (30) Calendar Days after its receipt, together with:

- (1) any required technical data;
- (2) Demonstration of one-hundred percent (100%) Site Control or demonstration of a regulatory limitation and applicable deposit in lieu of Site Control provided to Transmission Provider in accordance with Section 3.4.2 of this LGIP; and
- (3) An additional deposit that brings the total Commercial Readiness Deposit submitted to Transmission Provider to ten percent (10%) of Interconnection Customer's Network Upgrade cost assignment identified in the Cluster Study or Cluster Restudy, if applicable, in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider. Transmission Provider shall refund the deposit to Interconnection Customer upon withdrawal in accordance with Section 3.7 of this LGIP.

Interconnection Customer shall promptly inform Transmission Provider of any material change to Interconnection Customer's demonstration of Site Control under Section 3.4.2(iii) of this LGIP. Upon Transmission Provider

determining separately that Interconnection Customer no longer satisfies the Site Control requirement, Transmission Provider shall notify Interconnection Customer. Within ten (10) Business Days of such notification, Interconnection Customer must demonstrate compliance with the applicable requirement subject to Transmission Provider's approval, not to be unreasonably withheld. Absent such demonstration, Transmission Provider shall deem the subject Interconnection Request withdrawn pursuant to Section 3.7 of this LGIP.

8.2 Scope of Interconnection Facilities Study.

The Interconnection Facilities Study shall be specific to each Interconnection Request and performed on an individual, i.e., non-clustered, basis. The Interconnection Facilities Study shall specify and provide a non-binding estimate of the cost of the equipment, engineering, procurement and construction work needed to implement the conclusions of the Cluster Study Report (and any associated restudies) in accordance with Good Utility Practice to physically and electrically connect the Interconnection Facilities to the Transmission System. The Interconnection Facilities Study shall also identify the electrical switching configuration of the connection equipment, including, without limitation: the transformer, switchgear, meters, and other station equipment; the nature and estimated cost of any Transmission Provider's Interconnection Facilities and Network Upgrades necessary to accomplish the interconnection; and an estimate of the time required to complete the construction and installation of such facilities. The Interconnection Facilities Study will also identify any potential control equipment for (1) requests for Interconnection Service that are lower than the Generating Facility Capacity, and/or (2) requests to study a Generating Facility that includes at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect its proposed charging behavior, as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise require the use of different operating assumptions.

8.3 Interconnection Facilities Study Procedures.

Transmission Provider shall coordinate the Interconnection Facilities Study with any Affected System Operator pursuant to Section 3.6 of this LGIP.

Transmission Provider shall utilize existing studies to the extent practicable in performing the Interconnection Facilities Study. Transmission Provider shall complete the study and issue a draft Interconnection Facilities Study Report to Interconnection Customer within the following number of days after receipt of an executed Interconnection Facilities Study Agreement: ninety (90) Calendar Days after receipt of an executed Interconnection Facilities Study Agreement, with no more than a +/- twenty percent (20%) cost estimate contained in the report; or one hundred eighty (180) Calendar Days, if Interconnection Customer requests a +/- ten percent (10%) cost estimate.

At the request of Interconnection Customer or at any time Transmission Provider determines that it will not meet the required time frame for completing the Interconnection Facilities Study, Transmission Provider shall notify Interconnection Customer as to the schedule status of the Interconnection Facilities Study. If Transmission Provider is unable to complete the Interconnection Facilities Study and issue a draft Interconnection Facilities Study Report within the time required, it shall notify Interconnection Customer and provide an estimated completion date and an explanation of the reasons why additional time is required.

Interconnection Customer may, within thirty (30) Calendar Days after receipt of the draft Interconnection Facilities Study Report, provide written comments to Transmission Provider, which Transmission Provider shall include in completing the final Interconnection Facilities Study Report. Transmission Provider shall issue the final Interconnection Facilities Study Report within fifteen (15) Business Days of receiving Interconnection Customer's comments or promptly upon receiving Interconnection Customer's statement that it will not provide comments. Transmission Provider may reasonably extend such fifteen (15) Business Day period upon notice to Interconnection Customer if Interconnection Customer's comments require Transmission Provider to perform additional analyses or make other significant modifications prior to the issuance of the final Interconnection Facilities Study Report. Upon request, Transmission Provider shall provide Interconnection Customer supporting documentation, workpapers, and databases or data developed in the preparation of the Interconnection Facilities Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

8.4 Meeting with Transmission Provider.

Within ten (10) Business Days of providing a draft Interconnection Facilities Study Report to Interconnection Customer, Transmission Provider and Interconnection Customer shall meet to discuss the results of the Interconnection Facilities Study.

8.5 Restudy.

If restudy of the Interconnection Facilities Study is required due to a higher or equally queued project withdrawing from the queue or a modification of a higher or equally queued project pursuant to Section 4.4 of this LGIP, Transmission Provider shall so notify Interconnection Customer in writing. Transmission Provider shall ensure that such restudy takes no longer than sixty (60) Calendar Days from the date of notice. Except as provided in Section 3.7 of this LGIP in the case of withdrawing Interconnection Customers, any cost of restudy shall be borne by Interconnection Customer being restudied.

Section 9. Affected System Study.**9.1 Applicability.**

This Section 9 outlines the duties of Transmission Provider when it receives notification that an Affected System Interconnection Customer's proposed interconnection to its host transmission provider may impact Transmission Provider's Transmission System.

9.2 Response to Notifications.**9.2.1 Response to Initial Notification.**

When Transmission Provider receives initial notification either following the Cluster Study or a Cluster Restudy that an Affected System Interconnection Customer's proposed interconnection to its host transmission provider may impact Transmission Provider's Transmission System, Transmission Provider must respond in

writing within twenty (20) Business Days whether it intends to conduct an Affected System Study.

By fifteen (15) Business Days after Transmission Provider responds with its affirmative intent to conduct an Affected System Study, Transmission Provider shall share with Affected System Interconnection Customer(s) and the Affected System Interconnection Customer's host transmission provider a non-binding good faith estimate of the cost and the schedule to complete the Affected System Study.

9.2.2 Response to Notification of Cluster Restudy.

Within five (5) Business Days of receipt of notification of Cluster Restudy, Transmission Provider will send written notification to Affected System Interconnection Customer(s) involved in the Cluster Restudy and the host transmission provider that Transmission Provider intends to delay a planned or in-progress Affected System Study until after completion of the Cluster Restudy. If Transmission Provider decides to delay the Affected System Study, it is not required to meet its obligations under Section 9 of this LGIP until the time that it receives notification from the host transmission provider that the Cluster Restudy is complete. If Transmission Provider decides to move forward with its Affected System Study despite the Cluster Restudy, then it must meet all requirements under Section 9 of this LGIP.

9.3 Affected System Queue Position.

Transmission Provider must assign an Affected System Queue Position to Affected System Interconnection Customer(s) that require(s) an Affected System Study. Such Affected System Queue Position shall be assigned based upon the date of execution of the Affected System Study Agreement. Relative to Transmission Provider's Interconnection Customers, this Affected System Queue Position shall be higher-queued than any Cluster that has not yet received its Cluster Study Report and shall be lower-queued than any Cluster that has already received its Cluster Study Report. Consistent with Section 9.7 of this LGIP, Transmission Provider shall study the Affected System Interconnection Customer(s) via Clustering, and all Affected System Interconnection Customers studied in the same Cluster under Section 9.7 of this LGIP shall be equally queued. For Affected

System Interconnection Customers that are equally queued, the Affected System Queue Position shall have no bearing on the assignment of Affected System Network Upgrades identified in the applicable Affected System Study. The costs of the Affected System Network Upgrades shall be allocated among the Affected System Interconnection Customers in accordance with Section 9.9 of this LGIP.

9.4 Affected System Study Agreement/Multiparty Affected System Study Agreement.

Unless otherwise agreed, Transmission Provider shall provide to Affected System Interconnection Customer(s) an Affected System Study Agreement/Multiparty Affected System Study Agreement, in the form of Appendix 9 or Appendix 10 to this LGIP, as applicable, within ten (10) Business Days of Transmission Provider sharing the schedule for the Affected System Study per Section 9.2.1 of this LGIP.

Upon Affected System Interconnection Customer(s)' receipt of the Affected System Study Report, Affected System Interconnection Customer(s) shall compensate Transmission Provider for the actual cost of the Affected System Study. Any difference between the study deposit and the actual cost of the Affected System Study shall be paid by or refunded to the Affected System Interconnection Customer(s). Any invoices for the Affected System Study shall include a detailed and itemized accounting of the cost of the study. Affected System Interconnection Customer(s) shall pay any excess costs beyond the already-paid Affected System Study deposit or be reimbursed for any costs collected over the actual cost of the Affected System Study within thirty (30) Calendar Days of receipt of an invoice thereof. If Affected System Interconnection Customer(s) fail to pay such undisputed costs within the time allotted, it shall lose its Affected System Queue Position. Transmission Provider shall notify Affected System Interconnection Customer's host transmission provider of such failure to pay.

9.5 Execution of Affected System Study Agreement/Multiparty Affected System Study Agreement.

Affected System Interconnection Customer(s) shall execute the Affected System Study Agreement/Multiparty Affected System Study Agreement,

deliver the executed Affected System Study Agreement/Multiparty Affected System Study Agreement to Transmission Provider, and provide the Affected System Study deposit within ten (10) Business Days of receipt. If Transmission Provider notifies Affected System Interconnection Customer(s) that it will delay the Affected System Study pursuant to Section 9.2.2 of this LGIP, Affected System Interconnection Customer(s) are neither required to execute and return the previously tendered Affected System Study/Multiparty Affected System Study Agreement nor provide the Affected System Study deposit for the previously tendered Affected System Study/Multiparty Affected System Study Agreement.

If Affected System Interconnection Customer does not provide all required technical data when it delivers the Affected System Study Agreement/Multiparty Affected System Study Agreement, Transmission Provider shall notify the deficient Affected System Interconnection Customer, as well as the host transmission provider with which Affected System Interconnection Customer seeks to interconnect, of the technical data deficiency within five (5) Business Days of the receipt of the executed Affected System Study Agreement/Multiparty Affected System Study Agreement and the deficient Affected System Interconnection Customer shall cure the technical deficiency within ten (10) Business Days of receipt of the notice: provided, however, that such deficiency does not include failure to deliver the executed Affected System Study Agreement/Multiparty Affected System Study Agreement or deposit for the Affected System Study Agreement/Multiparty Affected System Study Agreement. If Affected System Interconnection Customer does not cure the technical data deficiency within the cure period or fails to execute the Affected System Study Agreement/Multiparty Affected System Study Agreement or provide the deposit, the Affected System Interconnection Customer shall lose its Affected System Queue Position.

9.6 Scope of Affected System Study.

The Affected System Study shall evaluate the impact that any Affected System Interconnection Customer's proposed interconnection to another transmission provider's transmission system will have on the reliability of Transmission Provider's Transmission System. The Affected System Study shall consider the Base Case as well as all Generating Facilities (and with respect to (iii) below, any identified Affected System Network

Upgrades associated with such higher-queued Interconnection Request) that, on the date the Affected System Study is commenced: (i) are directly interconnected to Transmission Provider's Transmission System; (ii) are directly interconnected to another transmission provider's transmission system and may have an impact on Affected System Interconnection Customer's interconnection request; (iii) have a pending higher-queued Interconnection Request to interconnect to Transmission Provider's Transmission System; and (iv) have no queue position but have executed an LGIA or requested that an unexecuted LGIA be filed with FERC. Transmission Provider has no obligation to study impacts of Affected System Interconnection Customers of which it is not notified.

The Affected System Study shall consist of a power flow, stability, and short circuit analysis. The Affected System Study Report will: state the assumptions upon which it is based; state the results of the analyses; and provide the potential impediments to Affected System Interconnection Customer's receipt of interconnection service on its host transmission provider's transmission system, including a preliminary indication of the cost and length of time that would be necessary to correct any problems identified in those analyses and implement the interconnection. For purposes of determining necessary Affected System Network Upgrades, the Affected System Study shall consider the level of interconnection service requested in megawatts by Affected System Interconnection Customer, unless otherwise required to study the full generating facility capacity due to safety or reliability concerns. The Affected System Study Report shall provide a list of facilities that are required as a result of Affected System Interconnection Customer's proposed interconnection to another transmission provider's system, a non-binding good faith estimate of cost responsibility, and a non-binding good faith estimated time to construct. The Affected System Study may consist of a system impact study, a facilities study, or some combination thereof.

9.7 Affected System Study Procedures.

Transmission Provider shall use Clustering in conducting the Affected System Study and shall use existing studies to the extent practicable, when multiple Affected System Interconnection Customers that are part of a single Cluster may cause the need for Affected System Network Upgrades. Transmission Provider shall complete the Affected System Study and

provide the Affected System Study Report to Affected System Interconnection Customer(s) and the host transmission provider with whom interconnection has been requested within one hundred fifty (150) Calendar Days after the receipt of the Affected System Study Agreement and deposit.

At the request of Affected System Interconnection Customer, Transmission Provider shall notify Affected System Interconnection Customer as to the status of the Affected System Study. If Transmission Provider is unable to complete the Affected System Study within the requisite time period, it shall notify Affected System Interconnection Customer(s), as well as transmission provider with which Affected System Interconnection Customer seeks to interconnect, and shall provide an estimated completion date with an explanation of the reasons why additional time is required. If Transmission Provider does not meet the deadlines in this Section, Transmission Provider shall be subject to the financial penalties as described in Section 3.9 of this LGIP. Upon request, Transmission Provider shall provide Affected System Interconnection Customer(s) with all supporting documentation, workpapers and relevant power flow, short circuit and stability databases for the Affected System Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

Transmission Provider must study an Affected System Interconnection Customer using the Energy Resource Interconnection Service modeling standard used for Interconnection Requests on its own Transmission System, regardless of the level of interconnection service that Affected System Interconnection Customer is seeking from the host transmission provider with whom it seeks to interconnect.

9.8 Meeting with Transmission Provider.

Within ten (10) Business Days of providing the Affected System Study Report to Affected System Interconnection Customer(s), Transmission Provider and Affected System Interconnection Customer(s) shall meet to discuss the results of the Affected System Study.

9.9 Affected System Cost Allocation.

Transmission Provider shall allocate Affected System Network Upgrade costs identified during the Affected System Study to Affected System Interconnection Customer(s) using a proportional impact method, consistent with Section 4.2.1(1)(b) of this LGIP.

9.10 Tender of Affected Systems Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement.

Transmission Provider shall tender to Affected System Interconnection Customer(s) an Affected System Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement, as applicable, in the form of Appendix 11 or 12 to this LGIP, within thirty (30) Calendar Days of providing the Affected System Study Report. Within ten (10) Business Days of the receipt of the Affected System Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement, the Affected System Interconnection Customer(s) must execute the agreement or request the agreement to be filed unexecuted with FERC. Transmission Provider shall execute the agreement or file the agreement unexecuted within five (5) Business Days after receiving direction from Affected System Interconnection Customer(s). Affected System Interconnection Customer's failure to execute the Affected System Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement, or failure to request the agreement to be filed unexecuted with FERC, shall result in the loss of its Affected System Queue Position.

9.11 Restudy.

If restudy of the Affected System Study is required, Transmission Provider shall notify Affected System Interconnection Customer(s) in writing within thirty (30) Calendar Days of discovery of the need for restudy. Such restudy shall take no longer than sixty (60) Calendar Days from the date of notice. Any cost of restudy shall be borne by the Affected System Interconnection Customer(s) being restudied.

Section 10. Optional Interconnection Study

10.1 Optional Interconnection Study Agreement.

On or after the date when Interconnection Customer receives Cluster Study results, Interconnection Customer may request, and Transmission Provider shall perform a reasonable number of Optional Interconnection Studies. The request shall describe the assumptions that Interconnection Customer wishes Transmission Provider to study within the scope described in Section 10.2 of this LGIP. Within five (5) Business Days after receipt of a request for an Optional Interconnection Study, Transmission Provider shall provide to Interconnection Customer an Optional Interconnection Study Agreement in the form of Appendix 4.

The Optional Interconnection Study Agreement shall: (i) specify the technical data that Interconnection Customer must provide for each phase of the Optional Interconnection Study, (ii) specify Interconnection Customer's assumptions as to which Interconnection Requests with earlier queue priority dates will be excluded from the Optional Interconnection Study case and assumptions as to the type of Interconnection Service for Interconnection Requests remaining in the Optional Interconnection Study case, and (iii) Transmission Provider's estimate of the cost of the Optional Interconnection Study. To the extent known by Transmission Provider, such estimate shall include any costs expected to be incurred by any Affected System Operator whose participation is necessary to complete the Optional Interconnection Study. Notwithstanding the above, Transmission Provider shall not be required as a result of an Optional Interconnection Study request to conduct any additional Interconnection Studies with respect to any other Interconnection Request.

Interconnection Customer shall execute the Optional Interconnection Study Agreement within ten (10) Business Days of receipt and deliver the Optional Interconnection Study Agreement, the technical data and a \$10,000 deposit to Transmission Provider.

10.2 Scope of Optional Interconnection Study.

The Optional Interconnection Study will consist of a sensitivity analysis based on the assumptions specified by Interconnection Customer in the Optional Interconnection Study Agreement. The Optional Interconnection Study will also identify Transmission Provider's Interconnection Facilities and the Network Upgrades, and the estimated cost thereof, that may be

required to provide transmission service or Interconnection Service based upon the results of the Optional Interconnection Study. The Optional Interconnection Study shall be performed solely for informational purposes. Transmission Provider shall use Reasonable Efforts to coordinate the study with any Affected Systems that may be affected by the types of Interconnection Services that are being studied. Transmission Provider shall utilize existing studies to the extent practicable in conducting the Optional Interconnection Study.

10.3 Optional Interconnection Study Procedures.

The executed Optional Interconnection Study Agreement, the prepayment, and technical and other data called for therein must be provided to Transmission Provider within ten (10) Business Days of Interconnection Customer receipt of the Optional Interconnection Study Agreement. Transmission Provider shall use Reasonable Efforts to complete the Optional Interconnection Study within a mutually agreed upon time period specified within the Optional Interconnection Study Agreement. If Transmission Provider is unable to complete the Optional Interconnection Study within such time period, it shall notify Interconnection Customer and provide an estimated completion date and an explanation of the reasons why additional time is required. Any difference between the study payment and the actual cost of the study shall be paid to Transmission Provider or refunded to Interconnection Customer, as appropriate. Upon request, Transmission Provider shall provide Interconnection Customer supporting documentation and workpapers and databases or data developed in the preparation of the Optional Interconnection Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

Section 11. Standard Large Generator Interconnection Agreement (LGIA)

11.1 Tender.

Interconnection Customer shall tender comments on the draft Interconnection Facilities Study Report within thirty (30) Calendar Days of receipt of the report. Within thirty (30) Calendar Days after the comments are submitted or after Interconnection Customer notifies Transmission Provider that it will not provide comments, Transmission Provider shall tender a draft LGIA, together with draft appendices. The draft LGIA shall

be in the form of Transmission Provider's FERC-approved standard form LGIA, which is in Appendix 5. Interconnection Customer shall execute and return the LGIA and completed draft appendices within thirty (30) Calendar Days, unless (1) the sixty (60) Calendar Day negotiation period under Section 11.2 of this LGIP has commenced, or (2) LGIA execution, or filing unexecuted, has been delayed to await the Affected System Study Report pursuant to Section 11.2.1 of this LGIP.

11.2 Negotiation.

Notwithstanding Section 11.1 of this LGIP, at the request of Interconnection Customer, Transmission Provider shall begin negotiations with Interconnection Customer concerning the appendices to the LGIA at any time after Interconnection Customer executes the Interconnection Facilities Study Agreement. Transmission Provider and Interconnection Customer shall negotiate concerning any disputed provisions of the appendices to the draft LGIA for not more than sixty (60) Calendar Days after tender of the final Interconnection Facilities Study Report. If Interconnection Customer determines that negotiations are at an impasse, it may request termination of the negotiations at any time after tender of the draft LGIA pursuant to Section 11.1 of this LGIP and request submission of the unexecuted LGIA with FERC or initiate Dispute Resolution procedures pursuant to Section 13.5 of this LGIP. If Interconnection Customer requests termination of the negotiations, but within sixty (60) Calendar Days thereafter fails to request either the filing of the unexecuted LGIA or initiate Dispute Resolution, it shall be deemed to have withdrawn its Interconnection Request. Unless otherwise agreed by the Parties, if Interconnection Customer has not executed the LGIA, requested filing of an unexecuted LGIA, or initiated Dispute Resolution procedures pursuant to Section 13.5 of this LGIP within sixty (60) Calendar Days of tender of draft LGIA, it shall be deemed to have withdrawn its Interconnection Request. Transmission Provider shall provide to Interconnection Customer a final LGIA within fifteen (15) Business Days after the completion of the negotiation process.

11.2.1 Delay in LGIA Execution, or Filing Unexecuted, to Await Affected System Study Report.

If Interconnection Customer has not received its Affected System Study Report from the Affected System Operator prior to the date

that it would be required to execute its LGIA (or request that its LGIA be filed unexecuted) pursuant to Section 11.1 of this LGIP, Transmission Provider shall, upon request of Interconnection Customer, extend this deadline to thirty (30) Calendar Days after Interconnection Customer's receipt of the Affected System Study Report. If Interconnection Customer, after delaying LGIA execution, or requesting unexecuted filing, to await Affected System Study Report, decides to proceed to LGIA execution, or request unexecuted filing, without those results, it may notify Transmission Provider of its intent to proceed with LGIA execution (or request that its LGIA be filed unexecuted) pursuant to Section 11.1 of this LGIP. If Transmission Provider determines that further delay to the LGIA execution date would cause a material impact on the cost or timing of an equal- or lower-queued Interconnection Customer, Transmission Provider must notify Interconnection Customer of such impacts and set the deadline to execute the LGIA (or request that the LGIA be filed unexecuted) to thirty (30) Calendar Days after such notice is provided.

11.3 Execution and Filing.

Simultaneously with submitting the executed LGIA to Transmission Provider, or within ten (10) Business Days after Interconnection Customer requests that Transmission Provider file the LGIA unexecuted at the Commission, Interconnection Customer shall provide Transmission Provider with the following: (1) demonstration of continued Site Control pursuant to Section 8.1(2) of this LGIP; and (2) the LGIA Deposit equal to twenty percent (20%) of Interconnection Customer's estimated Network Upgrade costs identified in the draft LGIA minus the total amount of Commercial Readiness Deposits that Interconnection Customer has provided to Transmission Provider for its Interconnection Request. Transmission Provider shall use LGIA Deposit as (or as a portion of) Interconnection Customer's security required under LGIA Article 11.5. Interconnection Customer may not request to suspend its LGIA under LGIA Article 5.16 until Interconnection Customer has provided (1) and (2) to Transmission Provider. If Interconnection Customer fails to provide (1) and (2) to Transmission Provider within the thirty (30) Calendar Days allowed for returning the executed LGIA and appendices under LGIP Section 11.1, or within ten (10) Business Days after Interconnection Customer requests that Transmission Provider file the LGIA unexecuted at

the Commission as allowed in this Section 11.3 of this LGIP, the Interconnection Request will be deemed withdrawn pursuant to Section 3.7 of this LGIP.

At the same time, Interconnection Customer also shall provide reasonable evidence that one or more of the following milestones in the development of the Large Generating Facility, at Interconnection Customer election, has been achieved (unless such milestone is inapplicable due to the characteristics of the Generating Facility): (i) the execution of a contract for the supply or transportation of fuel to the Large Generating Facility; (ii) the execution of a contract for the supply of cooling water to the Large Generating Facility; (iii) execution of a contract for the engineering for, procurement of major equipment for, or construction of, the Large Generating Facility; (iv) execution of a contract (or comparable evidence) for the sale of electric energy or capacity from the Large Generating Facility; or (v) application for an air, water, or land use permit.

Interconnection Customer shall either: (i) execute two originals of the tendered LGIA and return them to Transmission Provider; or (ii) request in writing that Transmission Provider file with FERC an LGIA in unexecuted form. As soon as practicable, but not later than ten (10) Business Days after receiving either the two executed originals of the tendered LGIA (if it does not conform with a FERC-approved Standard Large Generator Interconnection Agreement) or the request to file an unexecuted LGIA, Transmission Provider shall file the LGIA with FERC, together with its explanation of any matters as to which Interconnection Customer and Transmission Provider disagree and support for the costs that Transmission Provider proposes to charge to Interconnection Customer under the LGIA. An unexecuted LGIA should contain terms and conditions deemed appropriate by Transmission Provider for the Interconnection Request. If the Parties agree to proceed with design, procurement, and construction of facilities and upgrades under the agreed-upon terms of the unexecuted LGIA, they may proceed pending FERC action.

11.4 Commencement of Interconnection Activities.

If Interconnection Customer executes the final LGIA, Transmission Provider and Interconnection Customer shall perform their respective

obligations in accordance with the terms of the LGIA, subject to modification by FERC. Upon submission of an unexecuted LGIA, Interconnection Customer and Transmission Provider shall promptly comply with the unexecuted LGIA, subject to modification by FERC.

Section 12. Construction of Transmission Provider's Interconnection Facilities and Network Upgrades

12.1 Schedule.

Transmission Provider and Interconnection Customer shall negotiate in good faith concerning a schedule for the construction of Transmission Provider's Interconnection Facilities and the Network Upgrades.

12.2 Construction Sequencing.

12.2.1 General.

In general, the In-Service Date of an Interconnection Customer seeking interconnection to the Transmission System will determine the sequence of construction of Network Upgrades.

12.2.2 Advance Construction of Network Upgrades that are an Obligation of an Entity other than Interconnection Customer.

An Interconnection Customer with an LGIA, in order to maintain its In-Service Date, may request that Transmission Provider advance to the extent necessary the completion of Network Upgrades that: (i) were assumed in the Interconnection Studies for such Interconnection Customer, (ii) are necessary to support such In-Service Date, and (iii) would otherwise not be completed, pursuant to a contractual obligation of an entity other than Interconnection Customer that is seeking interconnection to the Transmission System, in time to support such In-Service Date. Upon such request, Transmission Provider will use Reasonable Efforts to advance the construction of such Network Upgrades to accommodate

such request; provided that Interconnection Customer commits to pay Transmission Provider: (i) any associated expediting costs and (ii) the cost of such Network Upgrades.

Transmission Provider will refund to Interconnection Customer both the expediting costs and the cost of Network Upgrades, in accordance with Article 11.4 of the LGIA. Consequently, the entity with a contractual obligation to construct such Network Upgrades shall be obligated to pay only that portion of the costs of the Network Upgrades that Transmission Provider has not refunded to Interconnection Customer. Payment by that entity shall be due on the date that it would have been due had there been no request for advance construction. Transmission Provider shall forward to Interconnection Customer the amount paid by the entity with a contractual obligation to construct the Network Upgrades as payment in full for the outstanding balance owed to Interconnection Customer. Transmission Provider then shall refund to that entity the amount that it paid for the Network Upgrades, in accordance with Article 11.4 of the LGIA.

12.2.3

Advancing Construction of Network Upgrades that are Part of an Expansion Plan of Transmission Provider.

An Interconnection Customer with an LGIA, in order to maintain its In-Service Date, may request that Transmission Provider advance to the extent necessary the completion of Network Upgrades that: (i) are necessary to support such In-Service Date and (ii) would otherwise not be completed, pursuant to an expansion plan of Transmission Provider, in time to support such In-Service Date. Upon such request, Transmission Provider will use Reasonable Efforts to advance the construction of such Network Upgrades to accommodate such request; provided that Interconnection Customer commits to pay Transmission Provider any associated expediting costs. Interconnection Customer shall be entitled to transmission credits, if any, for any expediting costs paid.

12.2.4 Amended Interconnection Cluster Study Report.

An Interconnection Cluster Study Report will be amended to determine the facilities necessary to support the requested In-Service Date. This amended study report will include those transmission and Large Generating Facilities that are expected to be in service on or before the requested In-Service Date.

Section 13. Miscellaneous**13.1 Confidentiality.**

Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied by either of the Parties to the other prior to the execution of an LGIA.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential.

If requested by either Party, the other Party shall provide in writing, the basis for asserting that the information referred to in this Article warrants confidential treatment, and the requesting Party may disclose such writing to the appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

13.1.1 Scope.

Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the

receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a third party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of the LGIA; or (6) is required, in accordance with Section 13.1.6 of this LGIP, Order of Disclosure, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under the

LGIA. Information designated as Confidential Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the other Party that it no longer is confidential.

13.1.2

Release of Confidential Information.

Neither Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), employees, consultants, or to parties who may be or considering providing financing to or equity participation with Interconnection Customer, or to potential purchasers or assignees of Interconnection Customer, on a need-to-know basis in connection with these procedures, unless such person has first been advised of the confidentiality provisions of this Section 13.1 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Section 13.1.

13.1.3 Rights.

Each Party retains all rights, title, and interest in the Confidential Information that each Party discloses to the other Party. The disclosure by each Party to the other Party of Confidential Information shall not be deemed a waiver by either Party or any other person or entity of the right to protect the Confidential Information from public disclosure.

13.1.4 No Warranties.

By providing Confidential Information, neither Party makes any warranties or representations as to its accuracy or completeness. In addition, by supplying Confidential Information, neither Party obligates itself to provide any particular information or Confidential Information to the other Party nor to enter into any further agreements or proceed with any other relationship or joint venture.

13.1.5 Standard of Care.

Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under these procedures or its regulatory requirements.

13.1.6 Order of Disclosure.

If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires either Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the other Party with prompt notice of such request(s) or requirement(s) so that the other Party may seek an appropriate protective order or waive compliance with the terms of the LGIA. Notwithstanding the absence of a protective order or waiver, the Party may disclose such

Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance that confidential treatment will be accorded any Confidential Information so furnished.

13.1.7

Remedies.

The Parties agree that monetary damages would be inadequate to compensate a Party for the other Party's Breach of its obligations under this Section 13.1. Each Party accordingly agrees that the other Party shall be entitled to equitable relief, by way of injunction or otherwise, if the first Party Breaches or threatens to Breach its obligations under this Section 13.1, which equitable relief shall be granted without bond or proof of damages, and the receiving Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Section 13.1, but shall be in addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. No Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Section 13.1.

13.1.8

Disclosure to FERC, its Staff, or a State.

Notwithstanding anything in this Section 13.1 to the contrary, and pursuant to 18 CFR section 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to the LGIP, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information. In providing the information to FERC or its staff, the Party must, consistent with 18 CFR section 388.112, request that the information be treated as confidential and non-public by FERC and its staff and that the information be

withheld from public disclosure. Parties are prohibited from notifying the other Party prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Party to the LGIA when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR section 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner, consistent with applicable state rules and regulations.

- 13.1.9 Subject to the exception in Section 13.1.8 of this LGIP, any information that a Party claims is competitively sensitive, commercial or financial information (“Confidential Information”) shall not be disclosed by the other Party to any person not employed or retained by the other Party, except to the extent disclosure is (i) required by law; (ii) reasonably deemed by the disclosing Party to be required to be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (iii) otherwise permitted by consent of the other Party, such consent not to be unreasonably withheld; or (iv) necessary to fulfill its obligations under this LGIP or as a transmission service provider or a Balancing Authority Area operator including disclosing the Confidential Information to an RTO or ISO or to a subregional, regional or national reliability organization or planning group. The Party asserting confidentiality shall notify the other Party in writing of the information it claims is confidential. Prior to any disclosures of the other Party’s Confidential Information under this subparagraph, or if any third party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the disclosing Party agrees to promptly notify the other Party in writing and agrees to assert confidentiality and cooperate with the other Party in seeking to protect the Confidential Information from public disclosure by confidentiality agreement, protective order or other reasonable measures.

13.1.10 This provision shall not apply to any information that was or is hereafter in the public domain (except as a result of a Breach of this provision).

13.1.11 Transmission Provider shall, at Interconnection Customer's election, destroy, in a confidential manner, or return the Confidential Information provided at the time of Confidential Information is no longer needed.

13.2 Delegation of Responsibility.

Transmission Provider may use the services of subcontractors as it deems appropriate to perform its obligations under this LGIP. Transmission Provider shall remain primarily liable to Interconnection Customer for the performance of such subcontractors and compliance with its obligations of this LGIP. The subcontractor shall keep all information provided confidential and shall use such information solely for the performance of such obligation for which it was provided and no other purpose.

13.3 Obligation for Study Costs.

In the event an Interconnection Customer withdraws its Interconnection Request prior to the commencement of the Cluster Study, Interconnection Customer must pay Transmission Provider the actual costs of processing its Interconnection Request. In the event an Interconnection Customer withdraws after the commencement of the Cluster Study, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Interconnection Studies. The costs of any interconnection study conducted on a clustered basis shall be allocated among each Interconnection Customer within the cluster as follows:

Transmission Provider shall determine each Interconnection Customer's share of the costs of the Cluster Study by allocating: (1) fifty percent (50%) of the applicable study costs to Interconnection Customers on a per capita basis based on number of Interconnection Requests included in the applicable Cluster; and (2) fifty percent (50%) of the applicable study costs

to Interconnection Customers on a pro-rata basis based on requested megawatts included in the applicable Cluster. The Interconnection Facilities Study portion of the Definitive Interconnection Study Process is an individual study and costs for each Interconnection Facilities Study are directly assigned to the Interconnection Customer associated with such study.

Any difference between the study deposit and the actual cost of the Interconnection Studies shall be paid by or refunded to, except as otherwise provided herein, to Interconnection Customers. Any invoices for Interconnection Studies shall include a detailed and itemized accounting of the cost of each Interconnection Study. Interconnection Customers shall pay any such undisputed costs within thirty (30) Calendar Days of receipt of an invoice therefor. If Interconnection Customer fails to pay such undisputed costs within the time allotted, its Interconnection Request shall be deemed withdrawn from the Cluster Study Process and will be subject to Withdrawal Penalties pursuant to Section 3.7 of this LGIP.

13.4 Third Parties Conducting Studies.

If (i) at the time of the signing of an Interconnection Study Agreement there is disagreement as to the estimated time to complete an Interconnection Study, (ii) Interconnection Customer receives notice pursuant to Sections 6.3, 7.4 or 8.3 of this LGIP that Transmission Provider will not complete an Interconnection Study within the applicable timeframe for such Interconnection Study, or (iii) Interconnection Customer receives neither the Interconnection Study nor a notice under Sections 6.3, 7.4 or 8.3 of this LGIP within the applicable timeframe for such Interconnection Study, then Interconnection Customer may require Transmission Provider to utilize a third party consultant reasonably acceptable to Interconnection Customer and Transmission Provider to perform such Interconnection Study under the direction of Transmission Provider. At other times, Transmission Provider may also utilize a third party consultant to perform such Interconnection Study, either in response to a general request of Interconnection Customer, or on its own volition.

In all cases, use of a third party consultant shall be in accord with Article 26 of the LGIA (Subcontractors) and limited to situations where Transmission

Provider determines that doing so will help maintain or accelerate the study process for Interconnection Customer's pending Interconnection Request and not interfere with Transmission Provider's progress on Interconnection Studies for other pending Interconnection Requests. In cases where Interconnection Customer requests use of a third party consultant to perform such Interconnection Study, Interconnection Customer and Transmission Provider shall negotiate all of the pertinent terms and conditions, including reimbursement arrangements and the estimated study completion date and study review deadline. Transmission Provider shall convey all workpapers, data bases, study results and all other supporting documentation prepared to date with respect to the Interconnection Request as soon as soon as practicable upon Interconnection Customer's request subject to the confidentiality provision in Section 13.1 of this LGIP. In any case, such third party contract may be entered into with either Interconnection Customer or Transmission Provider at Transmission Provider's discretion. In the case of (iii) Interconnection Customer maintains its right to submit a claim to Dispute Resolution to recover the costs of such third party study. Such third party consultant shall be required to comply with this LGIP, Article 26 of the LGIA (Subcontractors), and the relevant Tariff procedures and protocols as would apply if Transmission Provider were to conduct the Interconnection Study and shall use the information provided to

it solely for purposes of performing such services and for no other purposes. Transmission Provider shall cooperate with such third party consultant and Interconnection Customer to complete and issue the Interconnection Study in the shortest reasonable time.

13.5 Disputes.

13.5.1 Submission.

In the event either Party has a dispute, or asserts a claim, that arises out of or in connection with the LGIA, the LGIP, or their performance, such Party (the "disputing Party") shall provide the other Party with written notice of the dispute or claim ("Notice of Dispute"). Such dispute or claim shall be referred to a designated senior representative of each Party for resolution on an informal basis as promptly as practicable after receipt of the Notice of Dispute by the other Party. In

the event the designated representatives are unable to resolve the claim or dispute through unassisted or assisted negotiations within thirty (30) Calendar Days of the other Party's receipt of the Notice of Dispute, such claim or dispute may, upon mutual agreement of the Parties, be submitted to arbitration and resolved in accordance with the arbitration procedures set forth below. In the event the Parties do not agree to submit such claim or dispute to arbitration, each Party may exercise whatever rights and remedies it may have in equity or at law consistent with the terms of this LGIA.

13.5.2 External Arbitration Procedures.

Any arbitration initiated under these procedures shall be conducted before a single neutral arbitrator appointed by the Parties. If the Parties fail to agree upon a single arbitrator within ten (10) Calendar Days of the submission of the dispute to arbitration, each Party shall choose one arbitrator who shall sit on a three-member arbitration panel. The two arbitrators so chosen shall within twenty (20) Calendar Days select a third arbitrator to chair the arbitration panel. In either case, the arbitrators shall be knowledgeable in electric utility matters, including electric transmission and bulk power issues, and shall not have any current or past substantial business or financial relationships with any party to the arbitration (except prior arbitration). The arbitrator(s) shall provide each of the Parties an opportunity to be heard and, except as otherwise provided herein, shall conduct the arbitration in accordance with the Commercial Arbitration Rules of the American Arbitration Association ("Arbitration Rules") and any applicable FERC regulations or RTO rules; provided, however, in the event of a conflict between the Arbitration Rules and the terms of this Section 13, the terms of this Section 13 shall prevail.

13.5.3 Arbitration Decisions.

Unless otherwise agreed by the Parties, the arbitrator(s) shall render a decision within ninety (90) Calendar Days of appointment and shall notify the Parties in writing of such

decision and the reasons therefor. The arbitrator(s) shall be authorized only to interpret and apply the provisions of the LGIA and LGIP and shall have no power to modify or change any provision of the LGIA and LGIP in any manner. The decision of the arbitrator(s) shall be final and binding upon the Parties, and judgment on the award may be entered in any court having jurisdiction. The decision of the arbitrator(s) may be appealed solely on the grounds that the conduct of the arbitrator(s), or the decision itself, violated the standards set forth in the Federal Arbitration Act or the Administrative Dispute Resolution Act. The final decision of the arbitrator must also be filed with FERC if it affects jurisdictional rates, terms and conditions of service, Interconnection Facilities, or Network Upgrades.

13.5.4

Costs.

Each Party shall be responsible for its own costs incurred during the arbitration process and for the following costs, if applicable: (1) the cost of the arbitrator chosen by the Party to sit on the three member panel and one half of the cost of the third arbitrator chosen; or (2) one half the cost of the single arbitrator jointly chosen by the Parties.

13.5.5

Non-binding dispute resolution procedures.

If a Party has submitted a Notice of Dispute pursuant to Section 13.5.1 of this LGIP, and the Parties are unable to resolve the claim or dispute through unassisted or assisted negotiations within the thirty (30) Calendar Days provided in that section, and the Parties cannot reach mutual agreement to pursue the Section 13.5 arbitration process, a Party may request that Transmission Provider engage in Non-binding Dispute Resolution pursuant to this Section by providing written notice to Transmission Provider (“Request for Non-binding Dispute Resolution”). Conversely, either Party may file a Request for Non-binding Dispute Resolution pursuant to this Section without first seeking mutual agreement to pursue the Section 13.5 arbitration process. The process in this Section 13.5.5 shall serve as an alternative to, and not a

replacement of, the Section 13.5 arbitration process. Pursuant to this process, a Transmission Provider must within thirty (30) Calendar Days of receipt of the Request for Non-binding Dispute Resolution appoint a neutral decision-maker that is an independent subcontractor that shall not have any current or past substantial business or financial relationships with either Party. Unless otherwise agreed by the Parties, the decision-maker shall render a decision within sixty (60) Calendar Days of appointment and shall notify the Parties in writing of such decision and reasons therefore. This decision-maker shall be authorized only to interpret and apply the provisions of the LGIP and LGIA and shall have no power to modify or change any provision of the LGIP and LGIA in any manner. The result reached in this process is not binding, but, unless otherwise agreed, the Parties may cite the record and decision in the non-binding dispute resolution process in future dispute resolution processes, including in a Section 13.5 arbitration, or in a Federal Power Act section 206 complaint. Each Party shall be responsible for its own costs incurred during the process and the cost of the decision-maker shall be divided equally among each Party to the dispute.

13.6 Local Furnishing Bonds.

13.6.1 Transmission Providers That Own Facilities Financed by Local Furnishing Bonds.

This provision is applicable only to a Transmission Provider that has financed facilities for the local furnishing of electric energy with tax-exempt bonds, as described in Section 142(f) of the Internal Revenue Code (“local furnishing bonds”). Notwithstanding any other provision of this LGIA and LGIP, Transmission Provider shall not be required to provide Interconnection Service to Interconnection Customer pursuant to this LGIA and LGIP if the provision of such Transmission Service would jeopardize the tax-exempt status of any local furnishing bond(s) used to finance Transmission Provider’s facilities that would be used in providing such Interconnection Service.

13.6.2 Alternative Procedures for Requesting Interconnection Service.

If Transmission Provider determines that the provision of Interconnection Service requested by Interconnection Customer would jeopardize the tax-exempt status of any local furnishing bond(s) used to finance its facilities that would be used in providing such Interconnection Service, it shall advise Interconnection Customer within thirty (30) Calendar Days of receipt of the Interconnection Request.

Interconnection Customer thereafter may renew its request for interconnection using the process specified in Section 5.2(ii) of Transmission Provider's Tariff.

13.7 Engineering & Procurement ('E&P') Agreement.

Prior to executing an LGIA, an Interconnection Customer may, in order to advance the implementation of its interconnection, request and Transmission Provider shall offer Interconnection Customer, an E&P Agreement that authorizes Transmission Provider to begin engineering and procurement of long lead-time items necessary for the establishment of the interconnection. However, Transmission Provider shall not be obligated to offer an E&P Agreement if Interconnection Customer is in Dispute Resolution as a result of an allegation that Interconnection Customer has failed to meet any milestones or comply with any prerequisites specified in other parts of the LGIP. The E&P Agreement is an optional procedure and it will not alter Interconnection Customer's Queue Position or In-Service Date. The E&P Agreement shall provide for Interconnection Customer to pay the cost of all activities authorized by Interconnection Customer and to make advance payments or provide other satisfactory security for such costs.

Interconnection Customer shall pay the cost of such authorized activities and any cancellation costs for equipment that is already ordered for its interconnection, which cannot be mitigated as hereafter described, whether or not such items or equipment later become unnecessary. If

Interconnection Customer withdraws its Interconnection Request or either Party terminates the E&P Agreement, to the extent the equipment ordered can be canceled under reasonable terms, Interconnection Customer shall be obligated to pay the associated cancellation costs. To the extent that the equipment cannot be reasonably canceled, Transmission Provider may elect: (i) to take title to the equipment, in which event Transmission Provider shall refund Interconnection Customer any amounts paid by Interconnection Customer for such equipment and shall pay the cost of delivery of such equipment, or (ii) to transfer title to and deliver such equipment to Interconnection Customer, in which event Interconnection Customer shall pay any unpaid balance and cost of delivery of such equipment.

APPENDIX 1 to LGIP
INTERCONNECTION REQUEST FOR A
LARGE GENERATING FACILITY

1. The undersigned Interconnection Customer submits this request to interconnect its Large Generating Facility with Transmission Provider's Transmission System pursuant to a Tariff.

2. This Interconnection Request is for (check one):
 A proposed new Large Generating Facility.
 An increase in the generating capacity or a Material Modification of an existing Generating Facility.

3. The type of interconnection service requested (check one):
 Energy Resource Interconnection Service
 Network Resource Interconnection Service

4. Check here only if Interconnection Customer requesting Network Resource Interconnection Service also seeks to have its Generating Facility studied for Energy Resource Interconnection Service

5. Interconnection Customer provides the following information:
 - a. Address or location of the proposed new Large Generating Facility site (to the extent known) or, in the case of an existing Generating Facility, the name and specific location of the existing Generating Facility;

- b. Maximum summer at _____ degrees C and winter at _____ degrees C megawatt electrical output of the proposed new Large Generating Facility or the amount of megawatt increase in the generating capacity of an existing Generating Facility;
 - c. General description of the equipment configuration;
 - d. Commercial Operation Date (Day, Month, and Year);
 - e. Name, address, telephone number, and e-mail address of Interconnection Customer's contact person;
 - f. Approximate location of the proposed Point of Interconnection (optional);
 - g. Interconnection Customer Data (set forth in Attachment A);
 - h. Primary frequency response operating range for electric storage resources;
 - i. Requested capacity (in MW) of Interconnection Service (if lower than the Generating Facility Capacity);
 - j. If applicable, (1) the requested operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) to be used by Transmission Provider that reflect the proposed charging behavior of a Generating Facility that includes at least one electric storage resource, and (2) a description of any control technologies (software and/or hardware) that will limit the operation of the Generating Facility to its intended operation.
6. Applicable deposit amount as specified in the LGIP.

7. Evidence of Site Control as specified in the LGIP (check one)

_____ Is attached to this Interconnection Request

_____ Will be provided at a later date in accordance with this LGIP

8. This Interconnection Request shall be submitted to the representative indicated below:

{To be completed by Transmission Provider}

9. Representative of Interconnection Customer to contact:

{To be completed by Interconnection Customer}

10. This Interconnection Request is submitted by:

Name of Interconnection Customer: _____

By (signature): _____

Name (type or print): _____

Title: _____

Date: _____

Attachment A to Appendix 1
Interconnection Request

LARGE GENERATING FACILITY DATA

UNIT RATINGS

kVA _____ °F _____ Voltage _____
 Power Factor _____
 Speed (RPM) _____ Connection (e.g. Wye) _____
 Short Circuit Ratio _____ Frequency, Hertz _____
 Stator Amperes at Rated kVA _____ Field Volts _____
 Max Turbine MW _____ °F _____

Primary frequency response operating range for electric storage
resources:

Minimum State of Charge: _____

Maximum State of Charge: _____

COMBINED TURBINE-GENERATOR-EXCITER INERTIA DATA

Inertia Constant, H = _____ kW sec/kVA

Moment-of-Inertia, WR^2 = _____ lb. ft.²

REACTANCE DATA (PER UNIT-RATED KVA)

	DIRECT AXIS	QUADRATURE AXIS
Synchronous – saturated	X_{dv} _____	X_{qv} _____
Synchronous – unsaturated	X_{di} _____	X_{qi} _____
Transient – saturated	X'_{dv} _____	X'_{qv} _____
Transient – unsaturated	X'_{di} _____	X'_{qi} _____
Subtransient – saturated	X''_{dv} _____	X''_{qv} _____
Subtransient – unsaturated	X''_{di} _____	X''_{qi} _____
Negative Sequence – saturated	X_{2v} _____	
Negative Sequence – unsaturated	X_{2i} _____	
Zero Sequence – saturated	X_{0v} _____	
Zero Sequence – unsaturated	X_{0i} _____	
Leakage Reactance	X_{lm} _____	

FIELD TIME CONSTANT DATA (SEC)

Open Circuit	T'_{do}	_____	T'_{qo}	_____
Three-Phase Short Circuit Transient	T'_{d3}	_____	T'_q	_____
Line to Line Short Circuit Transient	T'_{d2}	_____		
Line to Neutral Short Circuit Transient	T'_{d1}	_____		
Short Circuit Subtransient	T''_d	_____	T''_q	_____
Open Circuit Subtransient	T''_{do}	_____	T''_{qo}	_____

ARMATURE TIME CONSTANT DATA (SEC)

Three Phase Short Circuit	T_{a3}	_____
Line to Line Short Circuit	T_{a2}	_____
Line to Neutral Short Circuit	T_{a1}	_____

NOTE: If requested information is not applicable, indicate by marking "N/A."

**MW CAPABILITY AND PLANT CONFIGURATION
LARGE GENERATING FACILITY DATA**

ARMATURE WINDING RESISTANCE DATA (PER UNIT)

Positive R_1 _____

Negative R_2 _____

Zero R_0 _____

Rotor Short Time Thermal Capacity $I_2^2t =$ _____

Field Current at Rated kVA, Armature Voltage and PF = _____ amps

Field Current at Rated kVA and Armature Voltage, 0 PF = _____ amps

Three Phase Armature Winding Capacitance = _____ microfarad

Field Winding Resistance = _____ ohms _____ °C

Armature Winding Resistance (Per Phase) = _____ ohms _____ °C

CURVES

Provide Saturation, Vee, Reactive Capability, Capacity Temperature Correction curves.
Designate normal and emergency Hydrogen Pressure operating range for multiple curves.

GENERATOR STEP-UP TRANSFORMER DATA RATINGS

Capacity Self-cooled/
 Maximum Nameplate
_____ / _____ kVA

Voltage Ratio(Generator Side/System side/Tertiary)
_____ / _____ / _____ kV

Winding Connections (Low V/High V/Tertiary V (Delta or Wye))
_____ / _____ / _____

Fixed Taps Available _____

Present Tap Setting _____

IMPEDANCE

Positive Z_1 (on self-cooled kVA rating) _____ % _____ X/R

Zero Z_0 (on self-cooled kVA rating) _____ % _____ X/R

EXCITATION SYSTEM DATA

Identify appropriate IEEE model block diagram of excitation system and power system stabilizer (PSS) for computer representation in power system stability simulations and the corresponding excitation system and PSS constants for use in the model.

GOVERNOR SYSTEM DATA

Identify appropriate IEEE model block diagram of governor system for computer representation in power system stability simulations and the corresponding governor system constants for use in the model.

WIND GENERATORS

Number of generators to be interconnected pursuant to this Interconnection Request:

Elevation: _____ _____ Single Phase _____ Three Phase

Inverter manufacturer, model name, number, and version:

List of adjustable setpoints for the protective equipment or software:

Note: A completed General Electric Company Power Systems Load Flow (PSLF) data sheet or other compatible formats, such as IEEE and PTI power flow models, must be supplied with the Interconnection Request. If other data sheets are more appropriate to the proposed device, then they shall be provided and discussed at Scoping Meeting.

INDUCTION GENERATORS

- (*) Field Volts: _____
- (*) Field Amperes: _____
- (*) Motoring Power (kW): _____
- (*) Neutral Grounding Resistor (If Applicable): _____
- (*) I_2^2t or K (Heating Time Constant): _____
- (*) Rotor Resistance: _____
- (*) Stator Resistance: _____
- (*) Stator Reactance: _____
- (*) Rotor Reactance: _____
- (*) Magnetizing Reactance: _____
- (*) Short Circuit Reactance: _____
- (*) Exciting Current: _____
- (*) Temperature Rise: _____
- (*) Frame Size: _____
- (*) Design Letter: _____
- (*) Reactive Power Required In Vars (No Load): _____
- (*) Reactive Power Required In Vars (Full Load): _____
- (*) Total Rotating Inertia, H: _____ Per Unit on KVA Base

Note: Please consult Transmission Provider prior to submitting the Interconnection Request to determine if the information designated by (*) is required.

MODELS FOR NON-SYNCHRONOUS GENERATORS

For a non-synchronous Large Generating Facility, Interconnection Customer shall provide (1) a validated user-defined root mean squared (RMS) positive sequence dynamics model; (2) an appropriately parameterized generic library RMS positive sequence dynamics model, including model block diagram of the inverter control and plant control systems, as defined by the selection in Table 1 or a model otherwise approved by the Western Electricity Coordinating Council, that corresponds to Interconnection Customer's Large Generating Facility; and (3) if applicable, a validated electromagnetic transient model if Transmission Provider performs an electromagnetic transient study as part of the interconnection study process. A user-defined model is a set of programming code created by equipment manufacturers or developers that captures the latest features of controllers that are mainly software based and represents the entities' control strategies but does not necessarily correspond to any generic library model. Interconnection Customer must also demonstrate that the model is validated by providing evidence that the equipment behavior is consistent with the model behavior (e.g., an attestation from Interconnection Customer that the model accurately represents the entire Large Generating Facility; attestations from each equipment manufacturer that the user defined model accurately represents the component of the Large Generating Facility; or test data).

Table 1: Acceptable Generic Library RMS Positive Sequence Dynamics Models

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
pvd1		PVD1	Distributed PV system model
der_a	DERAU1	DER_A	Distributed energy resource model
regc_a	REGCAU1, REGCA1	REGC_A	Generator/converter model
regc_b	REGCBU1	REGC_B	Generator/converter model

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
wt1g	WT1G1	WT1G and WT1G1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)
wt2g	WT2G1	WT2G and WT2G1	Generator model for generic Type-2 wind turbines
wt2e	WT2E1	WT2E and WT2E1	Rotor resistance control model for wound-rotor induction wind-turbine generator wt2g
reec_a	REECAU1, REECA1	REEC_A	Renewable energy electrical control model
reec_c	REECCU1	REEC_C	Electrical control model for battery energy storage system
reec_d	REECDU1	REEC_D	Renewable energy electrical control model
wt1t	WT12T1	WT1T and WT12T1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)
wt1p_b	wt1p_b	WT12A1U_B	Generic wind turbine pitch controller for WTGs of Types 1 and 2
wt2t	WT12T1	WT2T	Wind turbine model for Type-2 wind turbines (directly connected induction generator wind turbines with an external rotor resistance)
wtgt_a	WTDTAU1, WTDTA1	WTGT_A	Wind turbine drive train model
wtga_a	WTARAU1, WTARA1	WTGA_A	Simple aerodynamic model
wtgp_a	WTPTAU1, WTPTA1	WTGPT_A	Wind Turbine Generator Pitch controller
wtgq_a	WTTQAU1, WTTQA1	WTGTRQ_A	Wind Turbine Generator Torque controller

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
wtgwo_a	WTGWGOAU	WTGWGO_A	Supplementary control model for Weak Grids
wtgibffr_a	WTGIBFFRA	WTGIBFFR_A	Inertial-base fast frequency response control
wtgp_b	WTPTBU1	WTGPT_B	Wind Turbine Generator Pitch controller
wtgt_b	WTDTBU1	WTGT_B	Drive train model
repc_a	Type 4: REPCAU1 (v33), REPCA1 (v34) Type 3: REPCTAU1 (v33), REPCTA1 (v34)	REPC_A	Power Plant Controller

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
repc_b	PLNTBU1	REPC_B	<p>Power Plant Level Controller for controlling several plants/devices</p> <p>In regard to Siemens PSS/E*: Names of other models for interface with other devices: REA3XBU1, REAX4BU1- for interface with Type 3 and 4 renewable machines SWSAXBU1- for interface with SVC (modeled as switched shunt in powerflow) SYNAXBU1- for interface with synchronous condenser FCTAXBUI- for interface with FACTS device</p>
repc_c	REPCCU	REPC_C	Power plant controller

APPENDIX 2 to LGIP
CLUSTER STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ___ day of _____, 20___ by and between _____, a _____ organized and existing under the laws of the State of _____, (“Interconnection Customer,”) and _____ a _____ organized and existing under the laws of the State of _____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party, ” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a Cluster Study to assess the impact of interconnecting the Large Generating Facility to the Transmission System, and of any Affected Systems; and

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be performed a Cluster Study consistent with Section 7.0 of this LGIP in accordance with the Tariff.
- 3.0 The scope of the Cluster Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Cluster Study will be based upon the technical information provided by Interconnection Customer in the Interconnection Request, subject to any modifications in accordance with Section 4.4 of this LGIP. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the Cluster Study.
- 5.0 The Cluster Study Report shall provide the following information:
 - identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection and

- description and non-binding, good faith estimated cost of facilities required to interconnect the Large Generating Facility to the Transmission System and to address the identified short circuit, instability, and power flow issues.

6.0 Transmission Provider's good faith estimate for the time of completion of the Cluster Study is {insert date}.

Upon receipt of the Cluster Study Report, Transmission Provider shall charge and Interconnection Customer shall pay its share of the actual costs of the Cluster Study, consistent with Section 13.3 of this LGIP.

Any difference between the deposit and the actual cost of the study shall be paid by or refunded to Interconnection Customer, as appropriate.

7.0 Miscellaneous. The Cluster Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP and the LGIA.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

Attachment A To Appendix 2
Cluster Study Agreement

ASSUMPTIONS USED IN CONDUCTING THE
CLUSTER STUDY

The Cluster Study will be based upon the technical information provided by Interconnection Customer in the Interconnection Request, subject to any modifications in accordance with Section 4.4 of this LGIP, and the following assumptions:

Designation of Point of Interconnection and configuration to be studied.

Designation of alternative Point(s) of Interconnection and configuration.

{Above assumptions to be completed by Interconnection Customer and other assumptions to be provided by Interconnection Customer and Transmission Provider}

APPENDIX 3 to LGIP
INTERCONNECTION FACILITIES STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ___ day of _____, 20___ by and between _____, a _____ organized and existing under the laws of the State of _____, (“Interconnection Customer,”) and _____ a _____ organized and existing under the laws of the State of _____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party,,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Transmission Provider has completed a Cluster Study (the “Cluster Study”) and provided the results of said study to Interconnection Customer; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform an Interconnection Facilities Study to specify and estimate the cost of the equipment, engineering, procurement and construction work needed to implement the

conclusions of the Cluster Study in accordance with Good Utility Practice to physically and electrically connect the Large Generating Facility to the Transmission System.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in Transmission Provider's FERC-approved LGIP.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause an Interconnection Facilities Study consistent with Section 8.0 of this LGIP to be performed in accordance with the Tariff.
- 3.0 The scope of the Interconnection Facilities Study shall be subject to the assumptions set forth in Attachment A and the data provided in Attachment B to this Agreement.
- 4.0 The Interconnection Facilities Study Report (i) shall provide a description, estimated cost of (consistent with Attachment A), schedule for required facilities to interconnect the Large Generating Facility to the Transmission System and (ii) shall address the short circuit, instability, and power flow issues identified in the Cluster Study.
- 5.0 Interconnection Customer shall provide a Commercial Readiness Deposit per Section 8.1 of this LGIP to enter the Interconnection Facilities Study. The time for completion of the Interconnection Facilities Study is specified in Attachment A.

6.0 Miscellaneous. The Interconnection Facilities Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP and the LGIA.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

Attachment A To Appendix 3
Interconnection Facilities
Study Agreement

**INTERCONNECTION CUSTOMER SCHEDULE ELECTION FOR
CONDUCTING THE INTERCONNECTION FACILITIES STUDY**

Transmission Provider shall complete the study and issue a draft Interconnection Facilities Study Report to Interconnection Customer within the following number of days after receipt of an executed copy of this Interconnection Facilities Study Agreement:

- ninety (90) Calendar Days with no more than a +/- 20 percent cost estimate contained in the report, or

- one hundred eighty (180) Calendar Days with no more than a +/- 10 percent cost estimate contained in the report.

Attachment B to Appendix 3
Interconnection Facilities
Study Agreement

DATA FORM TO BE PROVIDED BY INTERCONNECTION CUSTOMER
WITH THE
INTERCONNECTION FACILITIES STUDY AGREEMENT

Provide location plan and simplified one-line diagram of the plant and station facilities. For staged projects, please indicate future generation, transmission circuits, etc.

One set of metering is required for each generation connection to the new ring bus or existing Transmission Provider station. Number of generation connections:

On the one-line diagram indicate the generation capacity attached at each metering location. (Maximum load on CT/PT)

On the one-line diagram indicate the location of auxiliary power. (Minimum load on CT/PT) Amps

Will an alternate source of auxiliary power be available during CT/PT maintenance?

Yes No

Will a transfer bus on the generation side of the metering require that each meter set be designed for the total plant generation? ____Yes ____No (Please indicate on one line diagram).

What type of control system or PLC will be located at Interconnection Customer's Large Generating Facility?

What protocol does the control system or PLC use?

Please provide a 7.5-minute quadrangle of the site. Sketch the plant, station, transmission line, and property line.

Physical dimensions of the proposed interconnection station:

Bus length from generation to interconnection station:

Line length from interconnection station to Transmission Provider's transmission line.

Tower number observed in the field. (Painted on tower leg)* _____

Number of third party easements required for transmission lines*:

* To be completed in coordination with Transmission Provider.

Is the Large Generating Facility in Transmission Provider's service area?

Yes No Local provider: _____

Please provide proposed schedule dates:

Begin Construction Date: _____

Generator step-up transformer
receives back feed power Date: _____

Generation Testing Date: _____

Commercial Operation Date: _____

APPENDIX 4 to LGIP
OPTIONAL INTERCONNECTION STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ___ day of _____, 20___ by and between _____, a _____ organized and existing under the laws of the State of _____, (“Interconnection Customer,”) and _____ a _____ organized and existing under the laws of the State of _____ - _____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party, ” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer is proposing to establish an interconnection with the Transmission System; and

WHEREAS, Interconnection Customer has submitted to Transmission Provider an Interconnection Request; and

WHEREAS, on or after the date when Interconnection Customer receives the Cluster Study results, Interconnection Customer has further requested that Transmission Provider prepare an Optional Interconnection Study;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in Transmission Provider's FERC-approved LGIP.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause an Optional Interconnection Study consistent with Section 10.0 of this LGIP to be performed in accordance with the Tariff.
- 3.0 The scope of the Optional Interconnection Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Optional Interconnection Study shall be performed solely for informational purposes.
- 5.0 The Optional Interconnection Study report shall provide a sensitivity analysis based on the assumptions specified by Interconnection Customer in Attachment A to this Agreement. The Optional Interconnection Study will identify Transmission Provider's Interconnection Facilities and the Network Upgrades, and the estimated cost thereof, that may be required to provide transmission service or interconnection service based upon the assumptions specified by Interconnection Customer in Attachment A.
- 6.0 Interconnection Customer shall provide a deposit of \$10,000 for the performance of the Optional Interconnection Study. Transmission Provider's good faith estimate for the time of completion of the Optional Interconnection Study is {insert date}.

Upon receipt of the Optional Interconnection Study, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Optional Study.

Any difference between the initial payment and the actual cost of the study shall be paid by or refunded to Interconnection Customer, as appropriate.

7.0 Miscellaneous. The Optional Interconnection Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP and the LGIA.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____

Title: _____

Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

APPENDIX 5 to LGIP
LARGE GENERATOR INTERCONNECTION AGREEMENT
(SEE LGIA)

APPENDIX 6 to LGIP
INTERCONNECTION PROCEDURES FOR A WIND GENERATING PLANT

Appendix 6 sets forth procedures specific to a wind generating plant. All other requirements of this LGIP continue to apply to wind generating plant interconnections.

A. Special Procedures Applicable to Wind Generators

The wind plant Interconnection Customer, in completing the Interconnection Request required by Section 3.3 of this LGIP, may provide to Transmission Provider a set of preliminary electrical design specifications depicting the wind plant as a single equivalent generator. Upon satisfying these and other applicable Interconnection Request conditions, the wind plant may enter the queue and receive the base case data as provided for in this LGIP.

No later than six months after submitting an Interconnection Request completed in this manner, the wind plant Interconnection Customer must submit completed detailed electrical design specifications and other data (including collector system layout data) needed to allow Transmission Provider to complete the Cluster Study.

**APPENDIX 7 to LGIP
TRANSITIONAL CLUSTER STUDY AGREEMENT**

THIS AGREEMENT is made and entered into this ____ day of _____, 20__ by and between _____, a _____ organized and existing under the laws of the State of _____ (“Interconnection Customer”), and _____, a _____ organized and existing under the laws of the State of _____ (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____;

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a “Transitional Cluster Study,” which combines the Cluster Study and Interconnection Facilities Study, in a single cluster study, followed by any needed restudies, to specify and estimate the cost of the equipment, engineering, procurement, and construction work needed to physically and electrically connect the Large Generating Facility to Transmission Provider’s Transmission System; and

WHEREAS, Interconnection Customer has a valid Queue Position as of the {Transmission Provider to insert Commission-approved effective date of compliance filing}.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Interconnection Customer elects, and Transmission Provider shall cause to be performed, a Transitional Cluster Study.
- 3.0 The Transitional Cluster Study shall be based upon the technical information provided by Interconnection Customer in the Interconnection Request. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the Transitional Cluster Study and Interconnection Customer shall provide such data as quickly as reasonable.
- 4.0 Pursuant to Section 5.1.1.2 of this LGIP, the interim Transitional Cluster Study Report shall provide the information below:
 - identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection; and

- Transmission Provider's Interconnection Facilities and Network Upgrades that are expected to be required as a result of the Interconnection Request(s) and a non-binding, good faith estimate of cost responsibility and a non-binding, good faith estimated time to construct.
- 5.0 Pursuant to Section 5.1.1.2 of this LGIP, the final Transitional Cluster Study Report shall: (1) provide all the information included in the interim Transitional Cluster Study Report; (2) provide a description of, estimated cost of, and schedule for required facilities to interconnect the Generating Facility to the Transmission System; and (3) address the short circuit, instability, and power flow issues identified in the interim Transitional Cluster Study Report.
- 6.0 Interconnection Customer has met the requirements described in Section 5.1.1.2 of this LGIP.
- 7.0 Interconnection Customer previously provided a deposit for the performance of Interconnection Studies. Upon receipt of the final Transitional Cluster Study Report, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Transitional Cluster Study. Any difference between the study deposit and the actual cost of the study shall be paid by or refunded to Interconnection Customer, in accordance with the provisions of Section 13.3 of this LGIP.
- 8.0 Miscellaneous. The Transitional Cluster Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP and the LGIA.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____

Title: _____

Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

APPENDIX 8 to LGIP**TRANSITIONAL SERIAL INTERCONNECTION FACILITIES STUDY
AGREEMENT**

THIS AGREEMENT is made and entered into this ___ day of ___, 20___, by and between _____, a _____ organized and existing under the laws of the State of _____ (“Interconnection Customer”) and _____, a _____ organized and existing under the laws of the State of _____ (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Large Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to continue processing its Interconnection Facilities Study to specify and estimate the cost of the equipment, engineering, procurement, and construction work needed to implement the conclusions of the final interconnection system impact study (from the previously effective serial study process) in accordance with Good Utility Practice to physically and electrically connect the Large Generating Facility to the Transmission System; and

WHEREAS, Transmission Provider has provided an Interconnection Facilities Study Agreement to Interconnection Customer on or before {Transmission Provider to insert Commission-approved effective date of compliance filing}.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be performed an Interconnection Facilities Study consistent with Section 8 of this LGIP.
- 3.0 The scope of the Interconnection Facilities Study shall be subject to the assumptions set forth in Attachment A to this Agreement, which shall be the same assumptions as the previous Interconnection Facilities Study Agreement executed by Interconnection Customer.
- 4.0 The Interconnection Facilities Study Report shall: (1) provide a description, estimated cost of (consistent with Attachment A), and schedule for required facilities to interconnect the Large Generating Facility to the Transmission System; and (2) address the short circuit, instability, and power flow issues identified in the most recently published Cluster Study Report.
- 5.0 Interconnection Customer has met the requirements described in Section 5.1.1.1 of this LGIP. The time for completion of the Interconnection Facilities Study is specified in Attachment A, and shall be no later than one hundred fifty (150) Calendar Days after {Transmission Provider to insert Commission-approved effective date of compliance filing}.
- 6.0 Interconnection Customer previously provided a deposit of _____ dollars (\$____) for the performance of the Interconnection Facilities Study.

- 7.0 Upon receipt of the Interconnection Facilities Study results, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Interconnection Facilities Study.

- 8.0 Any difference between the study deposit and the actual cost of the study shall be paid by or refunded to Interconnection Customer, as appropriate.

- 9.0 Miscellaneous. The Interconnection Facilities Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP and this LGIA.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____

Title:

Date: _____

{Insert name of Interconnection Customer}

By:

Title:

Date:

**Attachment A to Appendix 8
Transitional Serial Interconnection Facilities Study Agreement**

**ASSUMPTIONS USED IN CONDUCTING THE TRANSITIONAL SERIAL
INTERCONNECTION FACILITIES STUDY**

{Assumptions to be completed by Interconnection Customer and Transmission Provider}

APPENDIX 9 to LGIP
TWO-PARTY AFFECTED SYSTEM STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ____ day of _____, 20____, by and between _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer) and _____, a _____ organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Affected System Interconnection Customer is proposing to develop a {description of generating facility or generating capacity addition to an existing generating facility} consistent with the interconnection request submitted by Affected System Interconnection Customer to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customer desires to interconnect the {generating facility} with {name of host transmission provider}’s transmission system;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.

- 2.0 Transmission Provider shall coordinate with Affected System Interconnection Customer to perform an Affected System Study consistent with Section 9 of this LGIP.
- 3.0 The scope of the Affected System Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Affected System Study will be based upon the technical information provided by Affected System Interconnection Customer and {name of host transmission provider}. Transmission Provider reserves the right to request additional technical information from Affected System Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the Affected System Study.
- 5.0 The Affected System Study shall provide the following information:
 - identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection;
 - non-binding, good faith estimated cost and time required to construct facilities required on Transmission Provider's Transmission System

to accommodate the interconnection of the {generating facility} to the transmission system of the host transmission provider; and

- description of how such facilities will address the identified short circuit, instability, and power flow issues.

6.0 Affected System Interconnection Customer shall provide a deposit of _____ for performance of the Affected System Study. Upon receipt of the results of the Affected System Study by the Affected System Interconnection Customer, Transmission Provider shall charge, and Affected System Interconnection Customer shall pay, the actual cost of the Affected System Study. Any difference between the deposit and the actual cost of the Affected System Study shall be paid by or refunded to Affected System Interconnection Customer, as appropriate, including interest calculated in accordance with section 35.19a(a)(2) of FERC’s regulations.

7.0 This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability, and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Affected System Interconnection Customer}

By: _____

Title: _____

Date: _____

Project No. _____

**Attachment A to Appendix 9
Two-Party Affected System Study Agreement**

**ASSUMPTIONS USED IN CONDUCTING THE
AFFECTED SYSTEM STUDY**

The Affected System Study will be based upon the following assumptions:

{Assumptions to be completed by Affected System Interconnection Customer and
Transmission Provider}

APPENDIX 10 to LGIP

MULTIPARTY AFFECTED SYSTEM STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ___ day of _____, 20___, by and among _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); and _____, a _____ organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customers and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.” When it is not important to differentiate among them, Affected System Interconnection Customers each may be referred to as “Affected System Interconnection Customer” or collectively as the “Affected System Interconnection Customers.”

RECITALS

WHEREAS, Affected System Interconnection Customers are proposing to develop {description of generating facilities or generating capacity additions to an existing generating facility}, consistent with the interconnection requests submitted by Affected System Interconnection Customers to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customers desire to interconnect the {generating facilities} with {name of host transmission provider}’s transmission system;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Transmission Provider shall coordinate with Affected System Interconnection Customers to perform an Affected System Study consistent with Section 9 of this LGIP.
- 3.0 The scope of the Affected System Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Affected System Study will be based upon the technical information provided by Affected System Interconnection Customers and {name of host transmission provider}. Transmission Provider reserves the right to request additional technical information from Affected System Interconnection Customers as may reasonably become necessary consistent with Good Utility Practice during the course of the Affected System Study.
- 5.0 The Affected System Study shall provide the following information:
 - identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection;

- non-binding, good faith estimated cost and time required to construct facilities required on Transmission Provider’s Transmission System to accommodate the interconnection of the {generating facilities} to the transmission system of the host transmission provider; and
- description of how such facilities will address the identified short circuit, instability, and power flow issues.

6.0 Affected System Interconnection Customers shall each provide a deposit of _____ for performance of the Affected System Study. Upon receipt of the results of the Affected System Study by the Affected System Interconnection Customers, Transmission Provider shall charge, and Affected System Interconnection Customers shall pay, the actual cost of the Affected System Study. Any difference between the deposit and the actual cost of the Affected System Study shall be paid by or refunded to Affected System Interconnection Customers, as appropriate, including interest calculated in accordance with section 35.19a(a)(2) of FERC’s regulations.

7.0 This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability, and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Affected System Interconnection Customer}

By: _____

Title: _____

Date: _____

Project No. _____

{Insert name of Affected System Interconnection Customer}

By: _____

Title: _____

Date: _____

Project No. _____

Attachment A to Appendix 10
Multiparty Affected System Study Agreement

ASSUMPTIONS USED IN CONDUCTING THE
MULTIPARTY AFFECTED SYSTEM STUDY

The Affected System Study will be based upon the following assumptions:

{Assumptions to be completed by Affected System Interconnection Customers and
Transmission Provider}

APPENDIX 11 TO LGIP
TWO-PARTY AFFECTED SYSTEM FACILITIES CONSTRUCTION
AGREEMENT

THIS AGREEMENT is made and entered into this ____ day of _____, 20__, by and between _____, organized and existing under the laws of the State of _____ (Affected System Interconnection Customer) and _____, an entity organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customer and Transmission Provider each may be referred to as a “Party” or collectively as the “Parties.”

RECITALS

WHEREAS, Affected System Interconnection Customer is proposing to develop a {description of generating facility or generating capacity addition to an existing generating facility} consistent with the interconnection request submitted by Affected System Interconnection Customer to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customer desires to interconnect the {generating facility} to {name of host transmission provider}’s transmission system; and

WHEREAS, additions, modifications, and upgrade(s) must be made to certain existing facilities of Transmission Provider’s Transmission System to accommodate such interconnection; and

WHEREAS, Affected System Interconnection Customer has requested, and Transmission Provider has agreed, to enter into this Agreement for the purpose of facilitating the construction of necessary Affected System Network Upgrade(s);

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

ARTICLE 1
DEFINITIONS

When used in this Agreement, with initial capitalization, the terms specified and not otherwise defined in this Agreement shall have the meanings indicated in this LGIP.

ARTICLE 2
TERM OF AGREEMENT

2.1 Effective Date. This Agreement shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by FERC.

2.2 Term.

2.2.1 General. This Agreement shall become effective as provided in Article 2.1 and shall continue in full force and effect until the earlier of (1) the final repayment, where applicable, by Transmission Provider of the amount funded by Affected System Interconnection Customer for Transmission Provider's design, procurement, construction and installation of the Affected System Network Upgrade(s) provided in Appendix A; (2) the Parties agree to mutually terminate this Agreement; (3) earlier termination is permitted or provided for under Appendix A of this Agreement; or (4) Affected System Interconnection Customer terminates this Agreement after providing Transmission Provider with written notice at least sixty (60) Calendar Days prior to the proposed termination date, provided that Affected System Interconnection Customer has no outstanding contractual obligations to Transmission Provider under this Agreement. No

termination of this Agreement shall be effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination. The term of this Agreement may be adjusted upon mutual agreement of the Parties if (1) the commercial operation date for the {generating facility} is adjusted in accordance with the rules and procedures established by {name of host transmission provider} or (2) the in-service date for the Affected System Network Upgrade(s) is adjusted in accordance with the rules and procedures established by Transmission Provider.

2.2.2 Termination Upon Default. Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 5 of this Agreement where Breach and Breaching Party are defined in Article 5. Defaulting Party shall mean the Party that is in Default. In the event of a Default by a Party, the non-Defaulting Party shall have the termination rights described in Articles 5 and 6; provided, however, Transmission Provider may not terminate this Agreement if Affected System Interconnection Customer is the Defaulting Party and compensates Transmission Provider within thirty (30) Calendar Days for the amount of damages billed to Affected System Interconnection Customer by Transmission Provider for any such damages, including costs and expenses, incurred by Transmission Provider as a result of such Default.

2.2.3 Consequences of Termination. In the event of a termination by either Party, other than a termination by Affected System Interconnection Customer due to a Default by Transmission Provider, Affected System Interconnection Customer shall be responsible for the payment to Transmission Provider of all amounts then due and payable for construction and installation of the Affected System Network Upgrade(s) (including, without limitation, any equipment ordered related to such construction), plus all out-of-pocket expenses incurred by Transmission Provider in connection with the construction and installation of the Affected System Network Upgrade(s), through the date of termination, and, in the event of the termination of the entire Agreement, any actual costs which Transmission Provider reasonably incurs in (1) winding up work and construction demobilization and (2) ensuring the safety of persons and

property and the integrity and safe and reliable operation of Transmission Provider's Transmission System. Transmission Provider shall use Reasonable Efforts to minimize such costs.

- 2.2.4 Reservation of Rights.** Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Affected System Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement pursuant to section 206 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations thereunder, except to the extent that the Parties otherwise mutually agree as provided herein.
- 2.3 Filing.** Transmission Provider shall file this Agreement (and any amendment hereto) with the appropriate Governmental Authority, if required. Affected System Interconnection Customer may request that any information so provided be subject to the confidentiality provisions of Article 8. If Affected System Interconnection Customer has executed this Agreement, or any amendment thereto, Affected System Interconnection Customer shall reasonably cooperate with Transmission Provider with respect to such filing and to provide any information reasonably requested by Transmission Provider needed to comply with applicable regulatory requirements.
- 2.4 Survival.** This Agreement shall continue in effect after termination, to the extent necessary, to provide for final billings and payments and for costs incurred hereunder, including billings and payments pursuant to this Agreement; to permit the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and

to permit each Party to have access to the lands of the other Party pursuant to this Agreement or other applicable agreements, to disconnect, remove, or salvage its own facilities and equipment.

- 2.5 Termination Obligations.** Upon any termination pursuant to this Agreement, Affected System Interconnection Customer shall be responsible for the payment of all costs or other contractual obligations incurred prior to the termination date, including previously incurred capital costs, penalties for early termination, and costs of removal and site restoration.

ARTICLE 3

CONSTRUCTION OF AFFECTED SYSTEM NETWORK UPGRADE(S)

3.1 Construction.

3.1.1 Transmission Provider Obligations. Transmission Provider shall (or shall cause such action to) design, procure, construct, and install, and Affected System Interconnection Customer shall pay, consistent with Article 3.2, the costs of all Affected System Network Upgrade(s) identified in Appendix A. All Affected System Network Upgrade(s) designed, procured, constructed, and installed by Transmission Provider pursuant to this Agreement shall satisfy all requirements of applicable safety and/or engineering codes and comply with Good Utility Practice, and further, shall satisfy all Applicable Laws and Regulations. Transmission Provider shall not be required to undertake any action which is inconsistent with its standard safety practices, its material and equipment specifications, its design criteria and construction procedures, its labor agreements, or any Applicable Laws and Regulations.

3.1.2 Suspension of Work.

3.1.2.1 Right to Suspend. Affected System Interconnection Customer must provide to Transmission Provider written notice of its request for suspension. Only the milestones described in the Appendices of this Agreement are subject to suspension under this Article 3.1.2. Affected System Network Upgrade(s) will be constructed on the schedule described in the Appendices of this Agreement unless: (1) construction is prevented by the order of a Governmental Authority; (2) the Affected System Network Upgrade(s) are not needed by any other Interconnection Customer; or (3) Transmission Provider determines that a Force Majeure event prevents construction. In the event of (1), (2), or (3), any security paid to Transmission Provider under Article 4.1 of this Agreement shall be released by Transmission Provider upon the determination by Transmission Provider that the Affected System Network Upgrade(s) will no longer be constructed. If suspension occurs, Affected System Interconnection Customer shall be responsible for the costs which Transmission Provider incurs (i) in accordance with this Agreement prior to the suspension; (ii) in suspending such work, including any costs incurred to perform such work as may be necessary to ensure the safety of persons and property and the integrity of Transmission Provider's Transmission System and, if applicable, any costs incurred in connection with the cancellation of contracts and orders for material which Transmission Provider cannot reasonably avoid; and (iii) reasonably incurs in winding up work and construction demobilization; provided, however, that, prior to canceling any such contracts or orders, Transmission Provider shall obtain Affected System Interconnection Customer's authorization. Affected System Interconnection Customer shall be responsible for all costs incurred in connection with Affected System Interconnection Customer's failure to authorize cancellation of such contracts or orders.

Interest on amounts paid by Affected System Interconnection Customer to Transmission Provider for the design,

procurement, construction, and installation of the Affected System Network Upgrade(s) shall not accrue during periods in which Affected System Interconnection Customer has suspended construction under this Article 3.1.2.

Transmission Provider shall invoice Affected System Interconnection Customer pursuant to Article 4 and will use Reasonable Efforts to minimize its costs. In the event Affected System Interconnection Customer suspends work by Affected System Transmission Provider required under this Agreement pursuant to this Article 3.1.2.1, and has not requested Affected System Transmission Provider to recommence the work required under this Agreement on or before the expiration of three (3) years following commencement of such suspension, this Agreement shall be deemed terminated. The three-year period shall begin on the date the suspension is requested, or the date of the written notice to Affected System Transmission Provider, whichever is earlier, if no effective date of suspension is specified.

3.1.3 Construction Status. Transmission Provider shall keep Affected System Interconnection Customer advised periodically as to the progress of its design, procurement and construction efforts, as described in Appendix A. Affected System Interconnection Customer may, at any time and reasonably, request a progress report from Transmission Provider. If, at any time, Affected System Interconnection Customer determines that the completion of the Affected System Network Upgrade(s) will not be required until after the specified in-service date, Affected System Interconnection Customer will provide written notice to Transmission Provider of such later date upon which the completion of the Affected System Network Upgrade(s) would be required. Transmission Provider may delay the in-service date of the Affected System Network Upgrade(s) accordingly.

3.1.4 Timely Completion. Transmission Provider shall use Reasonable Efforts to design, procure, construct, install, and test the Affected System Network Upgrade(s) in accordance with the schedule set forth in Appendix A, which schedule may be revised from time to time by mutual agreement of the Parties. If any event occurs that will affect the time or ability to complete the Affected System Network Upgrade(s), Transmission Provider shall promptly notify Affected System Interconnection Customer. In such circumstances, Transmission Provider shall, within fifteen (15) Calendar Days of such notice, convene a meeting with Affected System Interconnection Customer to evaluate the alternatives available to Affected System Interconnection Customer. Transmission Provider shall also make available to Affected System Interconnection Customer all studies and work papers related to the event and corresponding delay, including all information that is in the possession of Transmission Provider that is reasonably needed by Affected System Interconnection Customer to evaluate alternatives, subject to confidentiality arrangements consistent with Article 8. Transmission Provider shall, at Affected System Interconnection Customer's request and expense, use Reasonable Efforts to accelerate its work under this Agreement to meet the schedule set forth in Appendix A, provided that (1) Affected System Interconnection Customer authorizes such actions, such authorization to be withheld, conditioned, or delayed by Affected System Interconnection Customer only if it can demonstrate that the acceleration would have a material adverse effect on it; and (2) the Affected System Interconnection Customer funds costs associated therewith in advance.

3.2 Interconnection Costs.

3.2.1 Costs. Affected System Interconnection Customer shall pay to Transmission Provider costs (including taxes and financing costs) associated with seeking and obtaining all necessary approvals and of designing, engineering, constructing, and testing the Affected System Network Upgrade(s), as identified in Appendix A, in accordance with the cost recovery method provided herein. Unless Transmission Provider elects to fund the Affected System Network Upgrade(s), they shall be initially funded by Affected System Interconnection Customer.

3.2.1.1 Lands of Other Property Owners. If any part of the Affected System Network Upgrade(s) is to be installed on property owned by persons other than Affected System Interconnection Customer or Transmission Provider, Transmission Provider shall, at Affected System Interconnection Customer's expense, use efforts similar in nature and extent to those that it typically undertakes on its own behalf or on behalf of its Affiliates, including use of its eminent domain authority to the extent permitted and consistent with Applicable Laws and Regulations and, to the extent consistent with such Applicable Laws and Regulations, to procure from such persons any rights of use, licenses, rights-of-way, and easements that are necessary to construct, operate, maintain, test, inspect, replace, or remove the Affected System Network Upgrade(s) upon such property.

3.2.2 Repayment.

3.2.2.1 Repayment. Consistent with Articles 11.4.1 and 11.4.2 of Transmission Provider's pro forma LGIA, Affected System Interconnection Customer shall be entitled to a cash repayment by Transmission Provider of the amount paid to Transmission Provider, if any, for the Affected System Network Upgrade(s), including any tax gross-up or other tax-related payments associated with the Affected System Network Upgrade(s), and not refunded to Affected System Interconnection Customer pursuant to Article 3.3.1 or otherwise. The Parties may mutually agree to a repayment schedule, to be outlined in Appendix A, not to exceed twenty (20) years from the commercial operation date, for the complete repayment for all applicable costs associated with the Affected System Network Upgrade(s). Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 CFR 35.19 a(a)(2)(iii) from the date of any payment for Affected System

Network Upgrade(s) through the date on which Affected System Interconnection Customer receives a repayment of such payment pursuant to this subparagraph. Interest shall not accrue during periods in which Affected System Interconnection Customer has suspended construction pursuant to Article 3.1.2. Affected System Interconnection Customer may assign such repayment rights to any person.

3.2.2.2 Impact of Failure to Achieve Commercial Operation. If the Affected System Interconnection Customer's generating facility fails to achieve commercial operation, but it or another generating facility is later constructed and makes use of the Affected System Network Upgrade(s), Transmission Provider shall at that time reimburse Affected System Interconnection Customer for the amounts advanced for the Affected System Network Upgrade(s). Before any such reimbursement can occur, Affected System Interconnection Customer (or the entity that ultimately constructs the generating facility, if different), is responsible for identifying the entity to which the reimbursement must be made.

3.3 Taxes.

3.3.1 Indemnification for Contributions in Aid of Construction. With regard only to payments made by Affected System Interconnection Customer to Transmission Provider for the installation of the Affected System Network Upgrade(s), Transmission Provider shall not include a gross-up for income taxes in the amounts it charges Affected System Interconnection Customer for the installation of the Affected System Network Upgrade(s) unless (1) Transmission Provider has determined, in good faith, that the payments or property transfers made by Affected System Interconnection Customer to Transmission Provider should be reported as income subject to taxation, or (2) any Governmental Authority directs Transmission Provider to report payments or property as income subject to taxation. Affected System

Interconnection Customer shall reimburse Transmission Provider for such costs on a fully grossed-up basis, in accordance with this Article, within thirty (30) Calendar Days of receiving written notification from Transmission Provider of the amount due, including detail about how the amount was calculated.

The indemnification obligation shall terminate at the earlier of (1) the expiration Of the ten (10)-year testing period and the applicable statute of limitation, as it may be extended by Transmission Provider upon request of the Internal Revenue Service, to keep these years open for audit or adjustment, or (2) the occurrence of a subsequent taxable event and the payment of any related indemnification obligations as contemplated by this Article. Notwithstanding the foregoing provisions of this Article 3.3.1, and to the extent permitted by law, to the extent that the receipt of such payments by Transmission Provider is determined by any Governmental Authority to constitute income by Transmission Provider subject to taxation, Affected System Interconnection Customer shall protect, indemnify, and hold harmless Transmission Provider and its Affiliates, from all claims by any such Governmental Authority for any tax, interest, and/or penalties associated with such determination. Upon receiving written notification of such determination from the Governmental Authority, Transmission Provider shall provide Affected System Interconnection Customer with written notification within thirty (30) Calendar Days of such determination and notification. Transmission Provider, upon the timely written request by Affected System Interconnection Customer and at Affected System Interconnection Customer's expense, shall appeal, protest, seek abatement of, or otherwise oppose such determination. Transmission Provider reserves the right to make all decisions with regard to the prosecution of such appeal, protest, abatement, or other contest, including the compromise or settlement of the claim; provided that Transmission Provider shall cooperate and consult in good faith with Affected System Interconnection Customer regarding the conduct of such contest. Affected System Interconnection Customer shall not be required to pay Transmission Provider for the tax, interest, and/or penalties prior to the seventh (7th) Calendar Day before the date on which Transmission Provider (1) is required to pay the tax, interest, and/or penalties or other amount in lieu thereof pursuant to a compromise or

settlement of the appeal, protest, abatement, or other contest; (2) is required to pay the tax, interest, and/or penalties as the result of a final, non-appealable order by a Governmental Authority; or (3) is required to pay the tax, interest, and/or penalties as a prerequisite to an appeal, protest, abatement, or other contest. In the event such appeal, protest, abatement, or other contest results in a determination that Transmission Provider is not liable for any portion of any tax, interest, and/or penalties for which Affected System Interconnection Customer has already made payment to Transmission Provider, Transmission Provider shall promptly refund to Affected System Interconnection Customer any payment attributable to the amount determined to be non-taxable, plus any interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)) or other payments Transmission Provider receives or which Transmission Provider may be entitled with respect to such payment. Affected System Interconnection Customer shall provide Transmission Provider with credit assurances sufficient to meet Affected System Interconnection Customer's estimated liability for reimbursement of Transmission Provider for taxes, interest, and/or penalties under this Article 3.3.1. Such estimated liability shall be stated in Appendix A.

To the extent that Transmission Provider is a limited liability company and not a corporation, and has elected to be taxed as a partnership, then the following shall apply: Transmission Provider represents, and the Parties acknowledge, that Transmission Provider is a limited liability company and is treated as a partnership for federal income tax purposes. Any payment made by Affected System Interconnection Customer to Transmission Provider for Affected System Network Upgrade(s) is to be treated as an upfront payment. It is anticipated by the Parties that any amounts paid by Affected System Interconnection Customer to Transmission Provider for Affected System Network Upgrade(s) will be reimbursed to Affected System Interconnection Customer in accordance with the terms of this Agreement, provided Affected System Interconnection Customer fulfills its obligations under this Agreement.

3.3.2 Private Letter Ruling. At Affected System Interconnection Customer's request and expense, Transmission Provider shall file with the Internal

Revenue Service a request for a private letter ruling as to whether any property transferred or sums paid, or to be paid, by Affected System Interconnection Customer to Transmission Provider under this Agreement are subject to federal income taxation. Affected System Interconnection Customer will prepare the initial draft of the request for a private letter ruling and will certify under penalties of perjury that all facts represented in such request are true and accurate to the best of Affected System Interconnection Customer's knowledge. Transmission Provider and Affected System Interconnection Customer shall cooperate in good faith with respect to the submission of such request.

3.3.3 Other Taxes. Upon the timely request by Affected System Interconnection Customer, and at Affected System Interconnection Customer's sole expense, Transmission Provider shall appeal, protest, seek abatement of, or otherwise contest any tax (other than federal or state income tax) asserted or assessed against Transmission Provider for which Affected System Interconnection Customer may be required to reimburse Transmission Provider under the terms of this Agreement. Affected System Interconnection Customer shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission Provider's documented reasonable costs of prosecuting such appeal, protest, abatement, or other contest. Affected System Interconnection Customer and Transmission Provider shall cooperate in good faith with respect to any such contest. Unless the payment of such taxes is a prerequisite to an appeal or abatement or cannot be deferred, no amount shall be payable by Affected System Interconnection Customer to Transmission Provider for such taxes until they are assessed by a final, non-appealable order by any court or agency of competent jurisdiction. In the event that a tax payment is withheld and ultimately due and payable after appeal, Affected System Interconnection Customer will be responsible for all taxes, interest and penalties, other than penalties attributable to any delay caused by Transmission Provider. Each Party shall cooperate with the other Party to maintain each Party's tax status. Nothing in this Agreement is intended to adversely affect any Party's tax-exempt status with respect to the issuance of bonds including, but not limited to, local furnishing bonds, as described in section 142(f) of the Internal Revenue Code.

ARTICLE 4

SECURITY, BILLING, AND PAYMENTS

- 4.1 Provision of Security.** By the earlier of (1) thirty (30) Calendar Days prior to the due date for Affected System Interconnection Customer's first payment under the payment schedule specified in Appendix A, or (2) the first date specified in Appendix A for the ordering of equipment by Transmission Provider for installing the Affected System Network Upgrade(s), Affected System Interconnection Customer shall provide Transmission Provider, at Affected System Interconnection Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to Transmission Provider. Such security for payment shall be in an amount sufficient to cover the costs for constructing, procuring, and installing the applicable portion of Affected System Network Upgrade(s) and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider for these purposes.

The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider and contain terms and conditions that guarantee payment of any amount that may be due from Affected System Interconnection Customer, up to an agreed-to maximum amount. The letter of credit must be issued by a financial institution reasonably acceptable to Transmission Provider and must specify a reasonable expiration date. The surety bond must be issued by an insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.

- 4.2 Invoice.** Each Party shall submit to the other Party, on a monthly basis, invoices of amounts due, if any, for the preceding month. Each invoice shall state the month to which the invoice applies and fully describe the services and equipment provided. The Parties may discharge mutual debts and payment obligations due and owing to each other on the same date through netting, in which case all amounts a Party owes to the other Party under this Agreement, including interest payments, shall be netted so that only the net amount remaining due shall be paid by the owing Party.

- 4.3 Payment.** Invoices shall be rendered to the paying Party at the address specified by the Parties. The Party receiving the invoice shall pay the invoice within thirty (30) Calendar Days of receipt. All payments shall be made in immediately available funds payable to the other Party, or by wire transfer to a bank named and account designated by the invoicing Party. Payment of invoices by a Party will not constitute a waiver of any rights or claims that Party may have under this Agreement.
- 4.4 Final Invoice.** Within six (6) months after completion of the construction of the Affected System Network Upgrade(s), Transmission Provider shall provide an invoice of the final cost of the construction of the Affected System Network Upgrade(s) and shall set forth such costs in sufficient detail to enable Affected System Interconnection Customer to compare the actual costs with the estimates and to ascertain deviations, if any, from the cost estimates. Transmission Provider shall refund, with interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)), to Affected System Interconnection Customer any amount by which the actual payment by Affected System Interconnection Customer for estimated costs exceeds the actual costs of construction within thirty (30) Calendar Days of the issuance of such final construction invoice.
- 4.5 Interest.** Interest on any unpaid amounts shall be calculated in accordance with 18 CFR 35.19a(a)(2)(iii).
- 4.6 Payment During Dispute.** In the event of a billing dispute among the Parties, Transmission Provider shall continue to construct the Affected System Network Upgrade(s) under this Agreement as long as Affected System Interconnection Customer: (1) continues to make all payments not in dispute; and (2) pays to Transmission Provider or into an independent escrow account the portion of the invoice in dispute, pending resolution of such dispute. If Affected System Interconnection Customer fails to meet these two requirements, then Transmission Provider may provide notice to Affected System Interconnection Customer of a Default pursuant to Article 5. Within thirty (30) Calendar Days after the resolution of the dispute, the Party that owes money to another Party shall pay the amount due with interest calculated in accordance with the methodology set forth in 18 CFR 35.19a(a)(2)(iii).

ARTICLE 5
BREACH, CURE AND DEFAULT

5.1 Events of Breach. A Breach of this Agreement shall include the:

(a) Failure to pay any amount when due;

(b) Failure to comply with any material term or condition of this Agreement, including but not limited to any material Breach of a representation, warranty, or covenant made in this Agreement;

(c) Failure of a Party to provide such access rights, or a Party's attempt to revoke access or terminate such access rights, as provided under this Agreement; or

(d) Failure of a Party to provide information or data to another Party as required under this Agreement, provided the Party entitled to the information or data under this Agreement requires such information or data to satisfy its obligations under this Agreement.

5.2 Definition. Breaching Party shall mean the Party that is in Breach.

5.3 Notice of Breach, Cure, and Default. Upon the occurrence of an event of Breach, the Party not in Breach, when it becomes aware of the Breach, shall give written notice of the Breach to the Breaching Party and to any other person representing a Party to this Agreement identified in writing to the other Party in advance. Such notice shall set forth, in reasonable detail, the nature of the Breach, and where known and applicable, the steps necessary to cure such Breach.

5.3.1 Upon receiving written notice of the Breach hereunder, the Breaching Party shall have a period to cure such Breach (hereinafter referred to as the “Cure Period”) which shall be sixty (60) Calendar Days.

5.3.2 In the event the Breaching Party fails to cure within the Cure Period, the Breaching Party will be in Default of this Agreement, and the non-Defaulting Party may terminate this Agreement in accordance with Article 6.2 of this Agreement or take whatever action at law or in equity as may appear necessary or desirable to enforce the performance or observance of any rights, remedies, obligations, agreement, or covenants under this Agreement.

5.4 Rights in the Event of Default. Notwithstanding the foregoing, upon the occurrence of a Default, the non-Defaulting Party shall be entitled to exercise all rights and remedies it may have in equity or at law.

ARTICLE 6

TERMINATION OF AGREEMENT

6.1 Expiration of Term. Except as otherwise specified in this Article 6, the Parties’ obligations under this Agreement shall terminate at the conclusion of the term of this Agreement.

6.2 Termination. In addition to the termination provisions set forth in Article 2.2, a Party may terminate this Agreement upon the Default of the other Party in accordance with Article 5.2.2 of this Agreement. Subject to the limitations set forth in Article 6.3, in the event of a Default, the termination of this Agreement by the non-Defaulting Party shall require a filing at FERC of a notice of termination, which filing must be accepted for filing by FERC.

6.3 Disposition of Facilities Upon Termination of Agreement.

6.3.1 Transmission Provider Obligations. Upon termination of this Agreement, unless otherwise agreed to by the Parties in writing, Transmission Provider:

- (a) shall, prior to the construction and installation of any portion of the Affected System Network Upgrade(s) and to the extent possible, cancel any pending orders of, or return, such equipment or material for such Affected System Network Upgrade(s);
- (b) may keep in place any portion of the Affected System Network Upgrade(s) already constructed and installed; and,
- (c) shall perform such work as may be necessary to ensure the safety of persons and property and to preserve the integrity of Transmission Provider's Transmission System (e.g., construction demobilization to return the system to its original state, wind-up work).

6.3.2 Affected System Interconnection Customer Obligations. Upon billing by Transmission Provider, Affected System Interconnection Customer shall reimburse Transmission Provider for any costs incurred by Transmission Provider in performance of the actions required or permitted by Article 6.3.1 and for the cost of any Affected System Network Upgrade(s) described in Appendix A. Transmission Provider shall use Reasonable Efforts to minimize costs and shall offset the amounts owed by any salvage value of facilities, if applicable. Affected System Interconnection Customer shall pay these costs pursuant to Article 4.3 of this Agreement.

6.3.3 Pre-construction or Installation. Upon termination of this Agreement and prior to the construction and installation of any portion of the Affected System Network Upgrade(s), Transmission Provider may, at its option, retain any portion of such Affected System Network Upgrade(s) not cancelled or returned in accordance with Article 6.3.1(a), in which case

Transmission Provider shall be responsible for all costs associated with procuring such Affected System Network Upgrade(s). To the extent that Affected System Interconnection Customer has already paid Transmission Provider for any or all of such costs, Transmission Provider shall refund Affected System Interconnection Customer for those payments. If Transmission Provider elects to not retain any portion of such facilities, Transmission Provider shall convey and make available to Affected System Interconnection Customer such facilities as soon as practicable after Affected System Interconnection Customer's payment for such facilities.

- 6.4 Survival of Rights.** Termination or expiration of this Agreement shall not relieve either Party of any of its liabilities and obligations arising hereunder prior to the date termination becomes effective, and each Party may take whatever judicial or administrative actions as appear necessary or desirable to enforce its rights hereunder. The applicable provisions of this Agreement will continue in effect after expiration, or early termination hereof to the extent necessary to provide for (1) final billings, billing adjustments, and other billing procedures set forth in this Agreement; (2) the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and (3) the confidentiality provisions set forth in Article 8.

ARTICLE 7

SUBCONTRACTORS

- 7.1 Subcontractors.** Nothing in this Agreement shall prevent a Party from utilizing the services of subcontractors, as it deems appropriate, to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services, and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

- 7.1.1 Responsibility of Principal.** The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. In accordance with the provisions of this Agreement, each Party shall be fully responsible to the other Party for the acts or omissions

of any subcontractor it hires as if no subcontract had been made. Any applicable obligation imposed by this Agreement upon a Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

7.1.2 No Third-Party Beneficiary. Except as may be specifically set forth to the contrary herein, no subcontractor or any other party is intended to be, nor will it be deemed to be, a third-party beneficiary of this Agreement.

7.1.3 No Limitation by Insurance. The obligations under this Article 7 will not be limited in any way by any limitation of any insurance policies or coverages, including any subcontractor's insurance.

ARTICLE 8

CONFIDENTIALITY

8.1 Confidentiality. Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied to the other Party prior to the execution of this Agreement.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential. The Parties shall maintain as confidential any information that is provided and identified by a Party as Critical Energy Infrastructure Information (CEII), as that term is defined in 18 CFR 388.113(c).

Such confidentiality will be maintained in accordance with this Article 8. If requested by the receiving Party, the disclosing Party shall provide in writing, the basis for asserting that the information referred to in this Article warrants confidential treatment, and the requesting Party may disclose such writing to the

appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

8.1.1 Term. During the term of this Agreement, and for a period of three (3) years after the expiration or termination of this Agreement, except as otherwise provided in this Article 8 or with regard to CEII, each Party shall hold in confidence and shall not disclose to any person Confidential Information. CEII shall be treated in accordance with FERC policies and regulations.

8.1.2 Scope. Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a non-Party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of this Agreement; or (6) is required, in accordance with Article 8.1.6 of this Agreement, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under this Agreement. Information designated as Confidential Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the receiving Party that it no longer is confidential.

8.1.3 Release of Confidential Information. No Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), subcontractors, employees, agents, consultants, or to non-Parties that may be or are considering providing financing to or equity participation with Affected System Interconnection Customer, or to potential purchasers or assignees of

Affected System Interconnection Customer, on a need-to-know basis in connection with this Agreement, unless such person has first been advised of the confidentiality provisions of this Article 8 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Article 8.

- 8.1.4 Rights.** Each Party shall retain all rights, title, and interest in the Confidential Information that it discloses to the receiving Party. The disclosure by a Party to the receiving Party of Confidential Information shall not be deemed a waiver by the disclosing Party or any other person or entity of the right to protect the Confidential Information from public disclosure.
- 8.1.5 Standard of Care.** Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication, or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under this Agreement or its regulatory requirements.
- 8.1.6 Order of Disclosure.** If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires either Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the disclosing Party with prompt notice of such request(s) or requirement(s) so that the disclosing Party may seek an appropriate protective order or waive compliance with the terms of this Agreement. Notwithstanding the absence of a protective order or waiver, the Party may disclose such Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance that confidential treatment will be accorded any Confidential Information so furnished.

8.1.7 Termination of Agreement. Upon termination of this Agreement for any reason, each Party shall, within ten (10) Business Days of receipt of a written request from the other Party, use Reasonable Efforts to destroy, erase, or delete (with such destruction, erasure, and deletion certified in writing to the requesting Party) or return to the requesting Party any and all written or electronic Confidential Information received from the requesting Party, except that each Party may keep one copy for archival purposes, provided that the obligation to treat it as Confidential Information in accordance with this Article 8 shall survive such termination.

8.1.8 Remedies. The Parties agree that monetary damages would be inadequate to compensate a Party for the other Party's Breach of its obligations under this Article 8. Each Party accordingly agrees that the disclosing Party shall be entitled to equitable relief, by way of injunction or otherwise, if the receiving Party Breaches or threatens to Breach its obligations under this Article 8, which equitable relief shall be granted without bond or proof of damages, and the breaching Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Article 8, but it shall be in addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. Neither Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Article 8.

8.1.9 Disclosure to FERC, its Staff, or a State Regulatory Body.

Notwithstanding anything in this Article 8 to the contrary, and pursuant to 18 CFR 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from a Party that is otherwise required to be maintained in confidence pursuant to this Agreement, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information. In providing the information to FERC or its staff, the Party must, consistent with 18 CFR 388.112, request that the information be treated as confidential and non-public by FERC and

its staff and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party to this Agreement prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Party to the Agreement when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

8.1.10 Subject to the exception in Article 8.1.9, any information that a disclosing Party claims is competitively sensitive, commercial, or financial information under this Agreement shall not be disclosed by the receiving Party to any person not employed or retained by the receiving Party, except to the extent disclosure is (1) required by law; (2) reasonably deemed by the disclosing Party to be required to be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (3) otherwise permitted by consent of the disclosing Party, such consent not to be unreasonably withheld; or (4) necessary to fulfill its obligations under this Agreement or as Transmission Provider or a balancing authority, including disclosing the Confidential Information to a regional or national reliability organization. The Party asserting confidentiality shall notify the receiving Party in writing of the information that Party claims is confidential. Prior to any disclosures of that Party's Confidential Information under this subparagraph, or if any non-Party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the Party that received the Confidential Information from the disclosing Party agrees to promptly notify the disclosing Party in writing and agrees to assert confidentiality and cooperate with the disclosing Party in seeking to protect the Confidential Information from public disclosure by confidentiality agreement, protective order, or other reasonable measures.

ARTICLE 9

INFORMATION ACCESS AND AUDIT RIGHTS

- 9.1 Information Access.** Each Party shall make available to the other Party information necessary to verify the costs incurred by the other Party for which the requesting Party is responsible under this Agreement and carry out obligations and responsibilities under this Agreement, provided that the Parties shall not use such information for purposes other than those set forth in this Article 9.1 and to enforce their rights under this Agreement.
- 9.2 Audit Rights.** Subject to the requirements of confidentiality under Article 8 of this Agreement, the accounts and records related to the design, engineering, procurement, and construction of the Affected System Network Upgrade(s) shall be subject to audit during the period of this Agreement and for a period of twenty-four (24) months following Transmission Provider's issuance of a final invoice in accordance with Article 4.4. Affected System Interconnection Customer at its expense shall have the right, during normal business hours, and upon prior reasonable notice to Transmission Provider, to audit such accounts and records. Any audit authorized by this Article 9.2 shall be performed at the offices where such accounts and records are maintained and shall be limited to those portions of such accounts and records that relate to obligations under this Agreement.

ARTICLE 10

NOTICES

- 10.1 General.** Any notice, demand, or request required or permitted to be given by a Party to the other Party, and any instrument required or permitted to be tendered or delivered by a Party in writing to another Party, may be so given, tendered, or delivered, as the case may be, by depositing the same with the United States Postal Service with postage prepaid, for transmission by certified or registered mail, addressed to the Parties, or personally delivered to the Parties, at the address set out below:

To Transmission Provider:

To Affected System Interconnection Customer:

10.2 Billings and Payments. Billings and payments shall be sent to the addresses shown in Article 10.1 unless otherwise agreed to by the Parties.

10.3 Alternative Forms of Notice. Any notice or request required or permitted to be given by a Party to the other Party and not required by this Agreement to be given in writing may be so given by telephone, facsimile or email to the telephone numbers and email addresses set out below:

To Transmission Provider:

To Affected System Interconnection Customer:

10.4 Execution and Filing. Affected System Interconnection Customer shall either: (i) execute two originals of this tendered Agreement and return them to Transmission Provider; or (ii) request in writing that Transmission Provider file with FERC this Agreement in unexecuted form. As soon as practicable, but not later than ten (10) Business Days after receiving either the two executed originals of this tendered Agreement (if it does not conform with a FERC-approved standard form of this Agreement) or the request to file this Agreement unexecuted, Transmission Provider shall file this Agreement with FERC, together with its explanation of any matters as to which Affected System Interconnection Customer and Transmission Provider disagree and support for the costs that Transmission Provider proposes to charge to Affected System Interconnection Customer under this Agreement. An unexecuted version of this Agreement should contain terms and conditions deemed appropriate by Transmission Provider for the Affected

System Interconnection Customer's generating facility. If the Parties agree to proceed with design, procurement, and construction of facilities and upgrades under the agreed-upon terms of the unexecuted version of this Agreement, they may proceed pending FERC action.

ARTICLE 11

MISCELLANEOUS

- 11.1** This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP.

{Signature Page to Follow}

IN WITNESS WHEREOF, the Parties have executed this Agreement in multiple originals, each of which shall constitute and be an original Agreement among the Parties.

Transmission Provider

{Transmission Provider}

By: _____

Name: _____

Title: _____

Affected System Interconnection Customer

{Affected System Interconnection Customer}

By: _____

Name: _____

Title: _____

Project No. _____

**Attachment A to Appendix 11
Two-Party Affected System Facilities Construction Agreement**

**AFFECTED SYSTEM NETWORK UPGRADE(S), COST ESTIMATES AND
RESPONSIBILITY, CONSTRUCTION SCHEDULE AND MONTHLY
PAYMENT SCHEDULE**

This Appendix A is a part of the Affected System Facilities Construction Agreement between Affected System Interconnection Customer and Transmission Provider.

1.1 Affected System Network Upgrade(s) to be installed by Transmission Provider.

{description}

1.2 First Equipment Order (including permitting).

{description}

1.2.1. Permitting and Land Rights – Transmission Provider Affected System Network Upgrade(s)

{description}

1.3 Construction Schedule. Where applicable, construction of the Affected System Network Upgrade(s) is scheduled as follows and will be periodically updated as necessary:

Table 1: Transmission Provider Construction Activities

MILESTONE NUMBER	DESCRIPTION	START DATE	END DATE

Note: Construction schedule assumes that Transmission Provider has obtained final authorizations and security from Affected System Interconnection Customer and all necessary permits from Governmental Authorities as necessary prerequisites to commence construction of any of the Affected System Network Upgrade(s).

1.4 Payment Schedule.

1.4.1 Timing of and Adjustments to Affected System Interconnection Customer’s Payments and Security.

{description}

1.4.2 Monthly Payment Schedule. Affected System Interconnection Customer’s payment schedule is as follows.

{description}

Table 2: Affected System Interconnection Customer’s Payment/Security Obligations for Affected System Network Upgrade(s).

MILESTONE NUMBER	DESCRIPTION	DATE

Note: Affected System Interconnection Customer’s payment or provision of security as provided in this Agreement operates as a condition precedent to Transmission Provider’s obligations to construct any Affected System Network Upgrade(s), and failure to meet this schedule will constitute a Breach pursuant to Article 5.1 of this Agreement.

1.5 Permits, Licenses, and Authorizations.

{description}

Attachment B to Appendix 11
Two-Party Affected System Facilities Construction Agreement

NOTIFICATION OF COMPLETED CONSTRUCTION

This Appendix B is a part of the Affected Systems Facilities Construction Agreement between Affected System Interconnection Customer and Transmission Provider. Where applicable, when Transmission Provider has completed construction of the Affected System Network Upgrade(s), Transmission Provider shall send notice to Affected System Interconnection Customer in substantially the form following:

{Date}

{Affected System Interconnection Customer Address}

Re: Completion of Affected System Network Upgrade(s)

Dear {Name or Title}:

This letter is sent pursuant to the Affected System Facilities Construction Agreement between {Transmission Provider} and {Affected System Interconnection Customer}, dated _____, 20__.

On {Date}, Transmission Provider completed to its satisfaction all work on the Affected System Network Upgrade(s) required to facilitate the safe and reliable interconnection and operation of Affected System Interconnection Customer's {description of generating facility}. Transmission Provider confirms that the Affected System Network Upgrade(s) are in place.

Thank you.

{Signature}

{Transmission Provider Representative}

**Attachment C to Appendix 11
Two-Party Affected System Facilities Construction Agreement**

EXHIBITS

This Appendix C is a part of the Affected System Facilities Construction Agreement between Affected System Interconnection Customer and Transmission Provider.

Exhibit A1

Transmission Provider Site Map

Exhibit A2

Site Plan

Exhibit A3

Affected System Network Upgrade(s) Plan & Profile

Exhibit A4

Estimated Cost of Affected System Network Upgrade(s)

	Location	Facilities to Be Constructed by Transmission Provider	Estimate in Dollars

		Total:	
--	--	---------------	--

APPENDIX 12 TO LGIP

MULTIPARTY AFFECTED SYSTEM FACILITIES CONSTRUCTION AGREEMENT

THIS AGREEMENT is made and entered into this ____ day of _____, 20__, by and among _____, organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); and _____, an entity organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customers and Transmission Provider each may be referred to as a “Party” or collectively as the “Parties.” When it is not important to differentiate among them, Affected System Interconnection Customers each may be referred to as “Affected System Interconnection Customer” or collectively as “Affected System Interconnection Customers.”

RECITALS

WHEREAS, Affected System Interconnection Customers are proposing to develop {description of generating facilities or generating capacity additions to an existing generating facility}, consistent with the interconnection requests submitted by Affected System Interconnection Customers to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customers desire to interconnect the {generating facilities} to {name of host transmission provider}’s transmission system; and

WHEREAS, additions, modifications, and upgrade(s) must be made to certain existing facilities of Transmission Provider's Transmission System to accommodate such interconnection; and

WHEREAS, Affected System Interconnection Customers have requested, and Transmission Provider has agreed, to enter into this Agreement for the purpose of facilitating the construction of necessary Affected System Network Upgrade(s);

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

ARTICLE 1

DEFINITIONS

When used in this Agreement, with initial capitalization, the terms specified and not otherwise defined in this Agreement shall have the meanings indicated in this LGIP.

ARTICLE 2

TERM OF AGREEMENT

2.1 Effective Date. This Agreement shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by FERC.

2.2 Term.

2.2.1 General. This Agreement shall become effective as provided in Article 2.1 and shall continue in full force and effect until the earlier of (1) the final repayment, where applicable, by Transmission Provider of the amount funded by Affected System Interconnection Customers for Transmission Provider's design, procurement, construction, and installation of the

Affected System Network Upgrade(s) provided in Appendix A; (2) the Parties agree to mutually terminate this Agreement; (3) earlier termination is permitted or provided for under Appendix A of this Agreement; or (4) Affected System Interconnection Customers terminate this Agreement after providing Transmission Provider with written notice at least sixty (60) Calendar Days prior to the proposed termination date, provided that Affected System Interconnection Customers have no outstanding contractual obligations to Transmission Provider under this Agreement. No termination of this Agreement shall be effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination. The term of this Agreement may be adjusted upon mutual agreement of the Parties if the commercial operation date(s) for the {generating facilities} is adjusted in accordance with the rules and procedures established by {name of host transmission provider} or the in-service date for the Affected System Network Upgrade(s) is adjusted in accordance with the rules and procedures established by Transmission Provider.

2.2.2 Termination Upon Default. Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 5 of this Agreement where Breach and Breaching Party are defined in Article 5. Defaulting Party shall mean the Party that is in Default. In the event of a Default by a Party, each non-Defaulting Party shall have the termination rights described in Articles 5 and 6; provided, however, Transmission Provider may not terminate this Agreement if an Affected System Interconnection Customer is the Defaulting Party and compensates Transmission Provider within thirty (30) Calendar Days for the amount of damages billed to Affected System Interconnection Customer(s) by Transmission Provider for any such damages, including costs and expenses incurred by Transmission Provider as a result of such Default. Notwithstanding the foregoing, Default by one or more Affected System Interconnection Customers shall not provide the other Affected System Interconnection Customer(s), either individually or in concert, with the right to terminate the entire Agreement. The non-Defaulting Party/Parties may, individually or in concert, initiate the removal of an Affected System Interconnection Customer that is a Defaulting Party from this Agreement. Transmission Provider shall not terminate this Agreement or the participation of any Affected System

Interconnection Customer without provision being made for Transmission Provider to be fully reimbursed for all of its costs incurred under this Agreement.

2.2.3 Consequences of Termination. In the event of a termination by a Party, other than a termination by Affected System Interconnection Customer(s) due to a Default by Transmission Provider, each Affected System Interconnection Customer whose participation in this Agreement is terminated shall be responsible for the payment to Transmission Provider of all amounts then due and payable for construction and installation of the Affected System Network Upgrade(s) (including, without limitation, any equipment ordered related to such construction), plus all out-of-pocket expenses incurred by Transmission Provider in connection with the construction and installation of the Affected System Network Upgrade(s), through the date of termination, and, in the event of the termination of the entire Agreement, any actual costs which Transmission Provider reasonably incurs in (1) winding up work and construction demobilization and (2) ensuring the safety of persons and property and the integrity and safe and reliable operation of Transmission Provider's Transmission System. Transmission Provider shall use Reasonable Efforts to minimize such costs. The cost responsibility of other Affected System Interconnection Customers shall be adjusted, as necessary, based on the payments by an Affected System Interconnection Customer that is terminated from the Agreement.

2.2.4 Reservation of Rights. Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Affected System Interconnection Customers shall have the right to make a unilateral filing with FERC to modify this Agreement pursuant to section 206 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be

considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations thereunder, except to the extent that the Parties otherwise mutually agree as provided herein.

- 2.3 Filing.** Transmission Provider shall file this Agreement (and any amendment hereto) with the appropriate Governmental Authority, if required. Affected System Interconnection Customers may request that any information so provided be subject to the confidentiality provisions of Article 8. Each Affected System Interconnection Customer that has executed this Agreement, or any amendment thereto, shall reasonably cooperate with Transmission Provider with respect to such filing and to provide any information reasonably requested by Transmission Provider needed to comply with applicable regulatory requirements.
- 2.4 Survival.** This Agreement shall continue in effect after termination, to the extent necessary, to provide for final billings and payments and for costs incurred hereunder, including billings and payments pursuant to this Agreement; to permit the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and to permit each Party to have access to the lands of the other Party pursuant to this Agreement or other applicable agreements, to disconnect, remove, or salvage its own facilities and equipment.
- 2.5 Termination Obligations.** Upon any termination pursuant to this Agreement or termination of the participation in this Agreement of an Affected System Interconnection Customer, each Affected System Interconnection Customer shall be responsible for the payment of its proportionate share of all costs or other contractual obligations incurred prior to the termination date, including previously incurred capital costs, penalties for early termination, and costs of removal and site restoration. The cost responsibility of the other Affected System Interconnection Customers shall be adjusted as necessary.

ARTICLE 3

CONSTRUCTION OF AFFECTED SYSTEM NETWORK UPGRADE(S)

3.1 Construction.

3.1.1 Transmission Provider Obligations. Transmission Provider shall (or shall cause such action to) design, procure, construct, and install, and Affected System Interconnection Customers shall pay, consistent with Article 3.2, the costs of all Affected System Network Upgrade(s) identified in Appendix A. All Affected System Network Upgrade(s) designed, procured, constructed, and installed by Transmission Provider pursuant to this Agreement shall satisfy all requirements of applicable safety and/or engineering codes and comply with Good Utility Practice, and further, shall satisfy all Applicable Laws and Regulations. Transmission Provider shall not be required to undertake any action which is inconsistent with its standard safety practices, its material and equipment specifications, its design criteria and construction procedures, its labor agreements, or any Applicable Laws and Regulations.

3.1.2 Suspension of Work.

3.1.2.1 Right to Suspend. Affected System Interconnection Customers must jointly provide to Transmission Provider written notice of their request for suspension. Only the milestones described in the Appendices of this Agreement are subject to suspension under this Article 3.1.2. Affected System Network Upgrade(s) will be constructed on the schedule described in the Appendices of this Agreement unless: (1) construction is prevented by the order of a Governmental Authority; (2) the Affected System Network Upgrade(s) are not needed by any other Interconnection Customer; or (3) Transmission Provider determines that a Force Majeure event prevents construction. In the event of (1), (2), or (3), any security paid to Transmission Provider under Article 4.1 of this Agreement shall be released by Transmission Provider upon the determination by Transmission Provider that the Affected System Network

Upgrade(s) will no longer be constructed. If suspension occurs, Affected System Interconnection Customers shall be responsible for the costs which Transmission Provider incurs (i) in accordance with this Agreement prior to the suspension; (ii) in suspending such work, including any costs incurred to perform such work as may be necessary to ensure the safety of persons and property and the integrity of Transmission Provider's Transmission System and, if applicable, any costs incurred in connection with the cancellation of contracts and orders for material which Transmission Provider cannot reasonably avoid; and (iii) reasonably incurs in winding up work and construction demobilization; provided, however, that, prior to canceling any such contracts or orders, Transmission Provider shall obtain Affected System Interconnection Customers' authorization. Affected System Interconnection Customers shall be responsible for all costs incurred in connection with Affected System Interconnection Customers' failure to authorize cancellation of such contracts or orders.

Interest on amounts paid by Affected System Interconnection Customers to Transmission Provider for the design, procurement, construction, and installation of the Affected System Network Upgrade(s) shall not accrue during periods in which Affected System Interconnection Customers have suspended construction under this Article 3.1.2.

Transmission Provider shall invoice Affected System Interconnection Customers pursuant to Article 4 and will use Reasonable Efforts to minimize its costs. In the event Affected System Interconnection Customers suspend work by Affected System Transmission Provider required under this Agreement pursuant to this Article 3.1.2.1, and have not requested Affected System Transmission Provider to recommence the work required under this Agreement on or before the expiration of three (3) years following

commencement of such suspension, this Agreement shall be deemed terminated. The three-year period shall begin on the date the suspension is requested, or the date of the written notice to Affected System Transmission Provider, whichever is earlier, if no effective date of suspension is specified.

- 3.1.3 Construction Status.** Transmission Provider shall keep Affected System Interconnection Customers advised periodically as to the progress of its design, procurement, and construction efforts, as described in Appendix A. An Affected System Interconnection Customer may, at any time and reasonably, request a progress report from Transmission Provider. If, at any time, an Affected System Interconnection Customer determines that the completion of the Affected System Network Upgrade(s) will not be required until after the specified in-service date, such Affected System Interconnection Customer will provide written notice to all other Parties of such later date for which the completion of the Affected System Network Upgrade(s) would be required. Transmission Provider may delay the in-service date of the Affected System Network Upgrade(s) accordingly, but only if agreed to by all other Affected System Interconnection Customers.
- 3.1.4 Timely Completion.** Transmission Provider shall use Reasonable Efforts to design, procure, construct, install, and test the Affected System Network Upgrade(s) in accordance with the schedule set forth in Appendix A, which schedule may be revised from time to time by mutual agreement of the Parties. If any event occurs that will affect the time or ability to complete the Affected System Network Upgrade(s), Transmission Provider shall promptly notify all other Parties. In such circumstances, Transmission Provider shall, within fifteen (15) Calendar Days of such notice, convene a meeting with Affected System Interconnection Customers to evaluate the alternatives available to Affected System Interconnection Customers. Transmission Provider shall also make available to Affected System Interconnection Customers all studies and work papers related to the event and corresponding delay, including all information that is in the possession of transmission Provider that is reasonably needed by Affected System Interconnection Customers to evaluate alternatives, subject to confidentiality arrangements consistent with Article 8. Transmission

Provider shall, at any Affected System Interconnection Customer's request and expense, use Reasonable Efforts to accelerate its work under this Agreement to meet the schedule set forth in Appendix A, provided that (1) Affected System Interconnection Customers jointly authorize such actions, such authorizations to be withheld, conditioned, or delayed by a given Affected System Interconnection Customer only if it can demonstrate that the acceleration would have a material adverse effect on it; and (2) the requesting Affected System Interconnection Customer(s) funds the costs associated therewith in advance, or all Affected System Interconnection Customers agree in advance to fund such costs based on such other allocation method as they may adopt.

3.2 Interconnection Costs.

3.2.1 Costs. Affected System Interconnection Customers shall pay to Transmission Provider costs (including taxes and financing costs) associated with seeking and obtaining all necessary approvals and of designing, engineering, constructing, and testing the Affected System Network Upgrade(s), as identified in Appendix A, in accordance with the cost recovery method provided herein. Except as expressly otherwise agreed, Affected System Interconnection Customers shall be collectively responsible for these costs, based on their proportionate share of cost responsibility, as provided in Appendix A. Unless Transmission Provider elects to fund the Affected System Network Upgrade(s), they shall be initially funded by the applicable Affected System Interconnection Customer.

3.2.1.1 Lands of Other Property Owners. If any part of the Affected System Network Upgrade(s) is to be installed on property owned by persons other than Affected System Interconnection Customers or Transmission Provider, Transmission Provider shall, at Affected System Interconnection Customers' expense, use efforts similar in nature and extent to those that it typically undertakes on its

own behalf or on behalf of its Affiliates, including use of its eminent domain authority to the extent permitted and consistent with Applicable Laws and Regulations and, to the extent consistent with such Applicable Laws and Regulations, to procure from such persons any rights of use, licenses, rights-of-way, and easements that are necessary to construct, operate, maintain, test, inspect, replace, or remove the Affected System Network Upgrade(s) upon such property.

3.2.2 Repayment.

3.2.2.1 Repayment. Consistent with articles 11.4.1 and 11.4.2 of Transmission Provider's pro forma LGIA, each Affected System Interconnection Customer shall be entitled to a cash repayment by Transmission Provider of the amount each Affected System Interconnection Customer paid to Transmission Provider, if any, for the Affected System Network Upgrade(s), including any tax gross-up or other tax-related payments associated with the Affected System Network Upgrade(s), and not refunded to Affected System Interconnection Customer pursuant to Article 3.3.1 or otherwise. The Parties may mutually agree to a repayment schedule, to be outlined in Appendix A, not to exceed twenty (20) years from the commercial operation date, for the complete repayment for all applicable costs associated with the Affected System Network Upgrade(s). Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 CFR 35.19 a(a)(2)(iii) from the date of any payment for Affected System Network Upgrade(s) through the date on which Affected System Interconnection Customers receive a repayment of such payment pursuant to this subparagraph. Interest shall not accrue during periods in which Affected System Interconnection Customers have suspended construction pursuant to Article 3.1.2.1. Affected System Interconnection Customers may assign such repayment rights to any person.

3.2.2.2 Impact of Failure to Achieve Commercial Operation. If an Affected System Interconnection Customer's generating facility fails to achieve commercial operation, but it or another generating facility is later constructed and makes use of the Affected System Network Upgrade(s), Transmission Provider shall at that time reimburse such Affected System Interconnection Customers for the portion of the Affected System Network Upgrade(s) it funded. Before any such reimbursement can occur, Affected System Interconnection Customer (or the entity that ultimately constructs the generating facility, if different), is responsible for identifying the entity to which the reimbursement must be made.

3.3 Taxes.

3.3.1 Indemnification for Contributions in Aid of Construction. With regard only to payments made by Affected System Interconnection Customers to Transmission Provider for the installation of the Affected System Network Upgrade(s), Transmission Provider shall not include a gross-up for income taxes in the amounts it charges Affected System Interconnection Customers for the installation of the Affected System Network Upgrade(s) unless (1) Transmission Provider has determined, in good faith, that the payments or property transfers made by Affected System Interconnection Customers to Transmission Provider should be reported as income subject to taxation, or (2) any Governmental Authority directs Transmission Provider to report payments or property as income subject to taxation. Affected System Interconnection Customers shall reimburse Transmission Provider for such costs on a fully grossed-up basis, in accordance with this Article, within thirty (30) Calendar Days of receiving written notification from Transmission Provider of the amount due, including detail about how the amount was calculated.

The indemnification obligation shall terminate at the earlier of (1) the expiration of the ten (10)-year testing period and the applicable statute of limitation, as it may be extended by Transmission Provider upon request of the Internal Revenue Service, to keep these years open for audit or adjustment, or (2) the occurrence of a subsequent taxable event and the payment of any related indemnification obligations as contemplated by this Article. Notwithstanding the foregoing provisions of this Article 3.3.1, and to the extent permitted by law, to the extent that the receipt of such payments by Transmission Provider is determined by any Governmental Authority to constitute income by Transmission Provider subject to taxation, Affected System Interconnection Customers shall protect, indemnify, and hold harmless Transmission Provider and its Affiliates, from all claims by any such Governmental Authority for any tax, interest, and/or penalties associated with such determination. Upon receiving written notification of such determination from the Governmental Authority, Transmission Provider shall provide Affected System Interconnection Customers with written notification within thirty (30) Calendar Days of such determination and notification. Transmission Provider, upon the timely written request by any one or more Affected System Interconnection Customer(s) and at the expense of such Affected System Interconnection Customer(s), shall appeal, protest, seek abatement of, or otherwise oppose such determination. Transmission Provider reserves the right to make all decisions with regard to the prosecution of such appeal, protest, abatement or other contest, including the compromise or settlement of the claim; provided that Transmission Provider shall cooperate and consult in good faith with the requesting Affected System Interconnection Customer(s) regarding the conduct of such contest. Affected System Interconnection Customer(s) shall not be required to pay Transmission Provider for the tax, interest, and/or penalties prior to the seventh (7th) Calendar Day before the date on which Transmission Provider (1) is required to pay the tax, interest, and/or penalties or other amount in lieu thereof pursuant to a compromise or settlement of the appeal, protest, abatement, or other contest; (2) is required to pay the tax, interest, and/or penalties as the result of a final, non-appealable order by a Governmental Authority; or (3) is required to pay the tax, interest, and/or penalties as a prerequisite to an appeal, protest, abatement, or other contest. In the event such appeal, protest, abatement, or other contest results in a determination that Transmission Provider is not liable for any portion of any tax, interest,

and/or penalties for which any Affected System Interconnection Customer(s) has already made payment to Transmission Provider, Transmission Provider shall promptly refund to such Affected System Interconnection Customer(s) any payment attributable to the amount determined to be non-taxable, plus any interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)) or other payments Transmission Provider receives or to which Transmission Provider may be entitled with respect to such payment. Each Affected System Interconnection Customer shall provide Transmission Provider with credit assurances sufficient to meet each Affected System Interconnection Customer's estimated liability for reimbursement of Transmission Provider for taxes, interest, and/or penalties under this Article 3.3.1. Such estimated liability shall be stated in Appendix A.

To the extent that Transmission Provider is a limited liability company and not a corporation, and has elected to be taxed as a partnership, then the following shall apply: Transmission Provider represents, and the Parties acknowledge, that Transmission Provider is a limited liability company and is treated as a partnership for federal income tax purposes. Any payment made by Affected System Interconnection Customers to Transmission Provider for Affected System Network Upgrade(s) is to be treated as an upfront payment. It is anticipated by the Parties that any amounts paid by each Affected System Interconnection Customer to Transmission Provider for Affected System Network Upgrade(s) will be reimbursed to such Affected System Interconnection Customer in accordance with the terms of this Agreement, provided such Affected System Interconnection Customer fulfills its obligations under this Agreement.

3.3.2 Private Letter Ruling. At the request and expense of any Affected System Interconnection Customer(s), Transmission Provider shall file with the Internal Revenue Service a request for a private letter ruling as to whether any property transferred or sums paid, or to be paid, by such Affected System Interconnection Customer(s) to Transmission Provider under this Agreement are subject to federal income taxation. Each Affected System Interconnection Customer desiring such a request will prepare the initial draft of the request for a private letter ruling and will certify under penalties

of perjury that all facts represented in such request are true and accurate to the best of such Affected System Interconnection Customer's knowledge. Transmission Provider and such Affected System Interconnection Customer(s) shall cooperate in good faith with respect to the submission of such request.

3.3.3 Other Taxes. Upon the timely request by any one or more Affected System Interconnection Customer(s), and at such Affected System Interconnection Customer(s)' sole expense, Transmission Provider shall appeal, protest, seek abatement of, or otherwise contest any tax (other than federal or state income tax) asserted or assessed against Transmission Provider for which such Affected System Interconnection Customer(s) may be required to reimburse Transmission Provider under the terms of this Agreement. Affected System Interconnection Customer(s) who requested the action shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission Provider's documented reasonable costs of prosecuting such appeal, protest, abatement, or other contest. The requesting Affected System Interconnection Customer(s) and Transmission Provider shall cooperate in good faith with respect to any such contest. Unless the payment of such taxes is a prerequisite to an appeal or abatement or cannot be deferred, no amount shall be payable by Affected System Interconnection Customer(s) to Transmission Provider for such taxes until they are assessed by a final, non-appealable order by any court or agency of competent jurisdiction. In the event that a tax payment is withheld and ultimately due and payable after appeal, Affected System Interconnection Customer(s) will be responsible for all taxes, interest, and penalties, other than penalties attributable to any delay caused by Transmission Provider. Each Party shall cooperate with the other Party to maintain each Party's tax status. Nothing in this Agreement is intended to adversely affect any Party's tax-exempt status with respect to the issuance of bonds including, but not limited to, local furnishing bonds, as described in section 142(f) of the Internal Revenue Code.

ARTICLE 4

SECURITY, BILLING, AND PAYMENTS

- 4.1 Provision of Security.** By the earlier of (1) thirty (30) Calendar Days prior to the due date for each Affected System Interconnection Customer's first payment under the payment schedule specified in Appendix A, or (2) the first date specified in Appendix A for the ordering of equipment by Transmission Provider for installing the Affected System Network Upgrade(s), each Affected System Interconnection Customer shall provide Transmission Provider, at each Affected System Interconnection Customer's option, a guarantee, a surety bond, letter of credit, or other form of security that is reasonably acceptable to Transmission Provider. Such security for payment shall be in an amount sufficient to cover the costs for constructing, procuring, and installing the applicable portion of Affected System Network Upgrade(s) and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider for these purposes.

The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider and contain terms and conditions that guarantee payment of any amount that may be due from such Affected System Interconnection Customer, up to an agreed-to maximum amount. The letter of credit must be issued by a financial institution reasonably acceptable to Transmission Provider and must specify a reasonable expiration date. The surety bond must be issued by an insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.

- 4.2 Invoice.** Each Party shall submit to the other Parties, on a monthly basis, invoices of amounts due, if any, for the preceding month. Each invoice shall state the month to which the invoice applies and fully describe the services and equipment provided. The Parties may discharge mutual debts and payment obligations due and owing to each other on the same date through netting, in which case all amounts a Party owes to another Party under this Agreement, including interest payments, shall be netted so that only the net amount remaining due shall be paid by the owing Party.
- 4.3 Payment.** Invoices shall be rendered to the paying Party at the address specified by the Parties. The Party receiving the invoice shall pay the invoice within thirty (30) Calendar Days of receipt. All payments shall be made in immediately

available funds payable to the other Party, or by wire transfer to a bank named and account designated by the invoicing Party. Payment of invoices by a Party will not constitute a waiver of any rights or claims that Party may have under this Agreement.

- 4.4 Final Invoice.** Within six (6) months after completion of the construction of the Affected System Network Upgrade(s) Transmission Provider shall provide an invoice of the final cost of the construction of the Affected System Network Upgrade(s) and shall set forth such costs in sufficient detail to enable each Affected System Interconnection Customer to compare the actual costs with the estimates and to ascertain deviations, if any, from the cost estimates. Transmission Provider shall refund, with interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)), to each Affected System Interconnection Customer any amount by which the actual payment by Affected System Interconnection Customer for estimated costs exceeds the actual costs of construction within thirty (30) Calendar Days of the issuance of such final construction invoice.
- 4.5 Interest.** Interest on any unpaid amounts shall be calculated in accordance with 18 CFR 35.19a(a)(2)(iii).
- 4.6 Payment During Dispute.** In the event of a billing dispute among the Parties, Transmission Provider shall continue to construct the Affected System Network Upgrade(s) under this Agreement as long as each Affected System Interconnection Customer: (1) continues to make all payments not in dispute; and (2) pays to Transmission Provider or into an independent escrow account the portion of the invoice in dispute, pending resolution of such dispute. If any Affected System Interconnection Customer fails to meet these two requirements, then Transmission Provider may provide notice to such Affected System Interconnection Customer of a Default pursuant to Article 5. Within thirty (30) Calendar Days after the resolution of the dispute, the Party that owes money to another Party shall pay the amount due with interest calculated in accordance with the methodology set forth in 18 CFR 35.19a(a)(2)(iii).

ARTICLE 5

BREACH, CURE, AND DEFAULT

5.1 Events of Breach. A Breach of this Agreement shall include the:

- (a) Failure to pay any amount when due;
- (b) Failure to comply with any material term or condition of this Agreement, including but not limited to any material Breach of a representation, warranty, or covenant made in this Agreement;
- (c) Failure of a Party to provide such access rights, or a Party's attempt to revoke access or terminate such access rights, as provided under this Agreement; or
- (d) Failure of a Party to provide information or data to another Party as required under this Agreement, provided the Party entitled to the information or data under this Agreement requires such information or data to satisfy its obligations under this Agreement.

5.2 Definition. Breaching Party shall mean the Party that is in Breach.

5.3 Notice of Breach, Cure, and Default. Upon the occurrence of an event of Breach, any Party aggrieved by the Breach, when it becomes aware of the Breach, shall give written notice of the Breach to the Breaching Party and to any other person representing a Party to this Agreement identified in writing to the other Party in advance. Such notice shall set forth, in reasonable detail, the nature of the Breach, and where known and applicable, the steps necessary to cure such Breach.

5.2.1 Upon receiving written notice of the Breach hereunder, the Breaching Party shall have a period to cure such Breach (hereinafter referred to as the "Cure

Period”) which shall be sixty (60) Calendar Days. If an Affected System Interconnection Customer is the Breaching Party and the Breach results from a failure to provide payments or security under Article 4.1 of this Agreement, the other Affected System Interconnection Customers, either individually or in concert, may cure the Breach by paying the amounts owed or by providing adequate security, without waiver of contribution rights against the breaching Affected System Interconnection Customer. Such cure for the Breach of an Affected System Interconnection Customer is subject to the reasonable consent of Transmission Provider. Transmission Provider may also cure such Breach by funding the proportionate share of the Affected System Network Upgrade costs related to the Breach of Affected System Interconnection Customer. Transmission Provider must notify all Parties that it will exercise this option within thirty (30) Calendar Days of notification that an Affected System Interconnection Customer has failed to provide payments or security under Article 4.1.

5.2.2 In the event the Breach is not cured within the Cure Period, the Breaching Party will be in Default of this Agreement, and the non-Defaulting Parties may (1) act in concert to amend the Agreement to remove an Affected System Interconnection Customer that is in Default from this Agreement for cause and to make other changes as necessary, or (2) either in concert or individually take whatever action at law or in equity as may appear necessary or desirable to enforce the performance or observance of any rights, remedies, obligations, agreement, or covenants under this Agreement.

5.3 Rights in the Event of Default. Notwithstanding the foregoing, upon the occurrence of Default, the non-Defaulting Parties shall be entitled to exercise all rights and remedies it may have in equity or at law.

ARTICLE 6

TERMINATION OF AGREEMENT

6.1 Expiration of Term. Except as otherwise specified in this Article 6, the Parties' obligations under this Agreement shall terminate at the conclusion of the term of this Agreement.

6.2 Termination and Removal. Subject to the limitations set forth in Article 6.3, in the event of a Default, termination of this Agreement, as to a given Affected System Interconnection Customer or in its entirety, shall require a filing at FERC of a notice of termination, which filing must be accepted for filing by FERC.

6.3 Disposition of Facilities Upon Termination of Agreement.

6.3.1 Transmission Provider Obligations. Upon termination of this Agreement, unless otherwise agreed to by the Parties in writing, Transmission Provider:

(a) shall, prior to the construction and installation of any portion of the Affected System Network Upgrade(s) and to the extent possible, cancel any pending orders of, or return, such equipment or material for such Affected System Network Upgrade(s);

(b) may keep in place any portion of the Affected System Network Upgrade(s) already constructed and installed; and,

(c) shall perform such work as may be necessary to ensure the safety of persons and property and to preserve the integrity of Transmission Provider's Transmission System (e.g., construction demobilization to return the system to its original state, wind-up work).

6.3.2 Affected System Interconnection Customer Obligations. Upon billing by Transmission Provider, each Affected System Interconnection Customer shall reimburse Transmission Provider for its share of any costs incurred by Transmission Provider in performance of the actions required or permitted by Article 6.3.1 and for its share of the cost of any Affected System Network Upgrade(s) described in Appendix A. Transmission Provider shall use Reasonable Efforts to minimize costs and shall offset the amounts owed by any salvage value of facilities, if applicable. Each Affected

System Interconnection Customer shall pay these costs pursuant to Article 4.3 of this Agreement.

6.3.3 Pre-construction or Installation. Upon termination of this Agreement and prior to the construction and installation of any portion of the Affected System Network Upgrade(s), Transmission Provider may, at its option, retain any portion of such Affected System Network Upgrade(s) not cancelled or returned in accordance with Article 6.3.1(a), in which case Transmission Provider shall be responsible for all costs associated with procuring such Affected System Network Upgrade(s). To the extent that an Affected System Interconnection Customer has already paid Transmission Provider for any or all of such costs, Transmission Provider shall refund Affected System Interconnection Customer for those payments. If Transmission Provider elects to not retain any portion of such facilities, and one or more of Affected System Interconnection Customers wish to purchase such facilities, Transmission Provider shall convey and make available to the applicable Affected System Interconnection Customer(s) such facilities as soon as practicable after Affected System Interconnection Customer(s)' payment for such facilities.

6.4 Survival of Rights. Termination or expiration of this Agreement shall not relieve any Party of any of its liabilities and obligations arising hereunder prior to the date termination becomes effective, and each Party may take whatever judicial or administrative actions as appear necessary or desirable to enforce its rights hereunder. The applicable provisions of this Agreement will continue in effect after expiration, or early termination hereof, to the extent necessary to provide for (1) final billings, billing adjustments, and other billing procedures set forth in this Agreement; (2) the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and (3) the confidentiality provisions set forth in Article 8.

ARTICLE 7

SUBCONTRACTORS

7.1 Subcontractors. Nothing in this Agreement shall prevent a Party from utilizing the services of subcontractors, as it deems appropriate, to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this

Agreement in providing such services, and each Party shall remain primarily liable to the other Parties for the performance of such subcontractor.

7.1.1 Responsibility of Principal. The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. In accordance with the provisions of this Agreement, each Party shall be fully responsible to the other Parties for the acts or omissions of any subcontractor it hires as if no subcontract had been made. Any applicable obligation imposed by this Agreement upon a Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

7.1.2 No Third-Party Beneficiary. Except as may be specifically set forth to the contrary herein, no subcontractor or any other party is intended to be, nor will it be deemed to be, a third-party beneficiary of this Agreement.

7.1.3 No Limitation by Insurance. The obligations under this Article 7 will not be limited in any way by any limitation of any insurance policies or coverages, including any subcontractor's insurance.

ARTICLE 8

CONFIDENTIALITY

8.1 Confidentiality. Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied to the other Parties prior to the execution of this Agreement.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential.

The Parties shall maintain as confidential any information that is provided and identified by a Party as Critical Energy Infrastructure Information (CEII), as that term is defined in 18 CFR 388.113(c).

Such confidentiality will be maintained in accordance with this Article 8. If requested by the receiving Party, the disclosing Party shall provide in writing, the basis for asserting that the information referred to in this Article warrants confidential treatment, and the requesting Party may disclose such writing to the appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

8.1.1 Term. During the term of this Agreement, and for a period of three (3) years after the expiration or termination of this Agreement, except as otherwise provided in this Article 8 or with regard to CEII, each Party shall hold in confidence and shall not disclose to any person Confidential Information. CEII shall be treated in accordance with FERC policies and regulations.

8.1.2 Scope. Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a non-Party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of this Agreement; or (6) is required, in accordance with Article 8.1.6 of this Agreement, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under this Agreement. Information designated as Confidential

Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the receiving Party that it no longer is confidential.

- 8.1.3 Release of Confidential Information.** No Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), subcontractors, employees, agents, consultants, or to non-Parties that may be or are considering providing financing to or equity participation with Affected System Interconnection Customer(s), or to potential purchasers or assignees of Affected System Interconnection Customer(s), on a need-to-know basis in connection with this Agreement, unless such person has first been advised of the confidentiality provisions of this Article 8 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Article 8.
- 8.1.4 Rights.** Each Party shall retain all rights, title, and interest in the Confidential Information that it discloses to the receiving Party. The disclosure by a Party to the receiving Party of Confidential Information shall not be deemed a waiver by the disclosing Party or any other person or entity of the right to protect the Confidential Information from public disclosure.
- 8.1.5 Standard of Care.** Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication, or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under this Agreement or its regulatory requirements.

8.1.6 Order of Disclosure. If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires any Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the disclosing Party with prompt notice of such request(s) or requirement(s) so that the disclosing Party may seek an appropriate protective order or waive compliance with the terms of this Agreement. Notwithstanding the absence of a protective order or waiver, the Party may disclose such Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance that confidential treatment will be accorded any Confidential Information so furnished.

8.1.7 Termination of Agreement. Upon termination of this Agreement for any reason, each Party shall, within ten (10) Business Days of receipt of a written request from the other Party, use Reasonable Efforts to destroy, erase, or delete (with such destruction, erasure, and deletion certified in writing to the requesting Party) or return to the requesting Party any and all written or electronic Confidential Information received from the requesting Party, except that each Party may keep one copy for archival purposes, provided that the obligation to treat it as Confidential Information in accordance with this Article 8 shall survive such termination.

8.1.8 Remedies. The Parties agree that monetary damages would be inadequate to compensate a Party for another Party's Breach of its obligations under this Article 8. Each Party accordingly agrees that the disclosing Party shall be entitled to equitable relief, by way of injunction or otherwise, if the receiving Party Breaches or threatens to Breach its obligations under this Article 8, which equitable relief shall be granted without bond or proof of damages, and the Breaching Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Article 8, but it shall be in

addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. No Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Article 8.

8.1.9 Disclosure to FERC, its Staff, or a State Regulatory Body.

Notwithstanding anything in this Article 8 to the contrary, and pursuant to 18 CFR 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from a Party that is otherwise required to be maintained in confidence pursuant to this Agreement, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information. In providing the information to FERC or its staff, the Party must, consistent with 18 CFR 388.112, request that the information be treated as confidential and non-public by FERC and its staff and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Parties to this Agreement prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Parties to the Agreement when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

8.1.10 Subject to the exception in Article 8.1.9, any information that a disclosing Party claims is competitively sensitive, commercial, or financial information under this Agreement shall not be disclosed by the receiving Party to any person not employed or retained by the receiving Party, except to the extent disclosure is (1) required by law; (2) reasonably deemed by the disclosing Party to be required to

be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (3) otherwise permitted by consent of the disclosing Party, such consent not to be unreasonably withheld; or (4) necessary to fulfill its obligations under this Agreement or as Transmission Provider or a balancing authority, including disclosing the Confidential Information to a regional or national reliability organization. The Party asserting confidentiality shall notify the receiving Party in writing of the information that Party claims is confidential. Prior to any disclosures of that Party's Confidential Information under this subparagraph, or if any non-Party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the Party that received the Confidential Information from the disclosing Party agrees to promptly notify the disclosing Party in writing and agrees to assert confidentiality and cooperate with the disclosing Party in seeking to protect the Confidential Information from public disclosure by confidentiality agreement, protective order, or other reasonable measures.

ARTICLE 9

INFORMATION ACCESS AND AUDIT RIGHTS

- 9.1 Information Access.** Each Party shall make available to the other Parties information necessary to verify the costs incurred by the other Parties for which the requesting Party is responsible under this Agreement and carry out obligations and responsibilities under this Agreement, provided that the Parties shall not use such information for purposes other than those set forth in this Article 9.1 and to enforce their rights under this Agreement.
- 9.2 Audit Rights.** Subject to the requirements of confidentiality under Article 8 of this Agreement, the accounts and records related to the design, engineering, procurement, and construction of the Affected System Network Upgrade(s) shall be subject to audit during the period of this Agreement and for a period of twenty-four (24) months following Transmission Provider's issuance of a final invoice in accordance with Article 4.4. Affected System Interconnection Customers may,

jointly or individually, at the expense of the requesting Party(ies), during normal business hours, and upon prior reasonable notice to Transmission Provider, audit such accounts and records. Any audit authorized by this Article 9.2 shall be performed at the offices where such accounts and records are maintained and shall be limited to those portions of such accounts and records that relate to obligations under this Agreement.

ARTICLE 10

NOTICES

10.1 General. Any notice, demand, or request required or permitted to be given by a Party to the other Parties, and any instrument required or permitted to be tendered or delivered by a Party in writing to another Party, may be so given, tendered, or delivered, as the case may be, by depositing the same with the United States Postal Service with postage prepaid, for transmission by certified or registered mail, addressed to the Parties, or personally delivered to the Parties, at the address set out below:

To Transmission Provider:

To Affected System Interconnection Customers:

10.2 Billings and Payments. Billings and payments shall be sent to the addresses shown in Article 10.1 unless otherwise agreed to by the Parties.

10.3 Alternative Forms of Notice. Any notice or request required or permitted to be given by a Party to the other Parties and not required by this Agreement to be given in writing may be so given by telephone, facsimile, or email to the telephone numbers and email addresses set out below:

To Transmission Provider:

To Affected System Interconnection Customers:

10.4 Execution and Filing. Affected System Interconnection Customers shall either: (i) execute two originals of this tendered Agreement and return them to Transmission Provider; or (ii) request in writing that Transmission Provider file with FERC this Agreement in unexecuted form. As soon as practicable, but not later than ten (10) Business Days after receiving either the two executed originals of this tendered Agreement (if it does not conform with a FERC-approved standard form of this Agreement) or the request to file this Agreement unexecuted, Transmission Provider shall file this Agreement with FERC, together with its explanation of any matters as to which Affected System Interconnection Customers and Transmission Provider disagree and support for the costs that Transmission Provider proposes to charge to Affected System Interconnection Customers under this Agreement. An unexecuted version of this Agreement should contain terms and conditions deemed appropriate by Transmission Provider for the Affected System Interconnection Customers' generating facilities. If the Parties agree to proceed with design, procurement, and construction of facilities and upgrades under the agreed-upon terms of the unexecuted version of this Agreement, they may proceed pending FERC action.

ARTICLE 11
MISCELLANEOUS

11.1 This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability, and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP.

{Signature Page to Follow}

IN WITNESS WHEREOF, the Parties have executed this Agreement in multiple originals, each of which shall constitute and be an original Agreement among the Parties.

Transmission Provider

{Transmission Provider}

By: _____

Name: _____

Title: _____

Affected System Interconnection Customer

{Affected System Interconnection Customer}

By: _____

Name: _____

Title: _____

Project No. _____

Affected System Interconnection Customer

{Affected System Interconnection Customer}

By: _____

Name: _____

Title: _____

Project No. _____

Attachment A to Appendix 12

Multiparty Affected System Facilities Construction Agreement

**AFFECTED SYSTEM NETWORK UPGRADE(S), COST ESTIMATES AND
RESPONSIBILITY, CONSTRUCTION SCHEDULE, AND MONTHLY
PAYMENT SCHEDULE**

This Appendix A is a part of the Multiparty Affected System Facilities Construction Agreement among Affected System Interconnection Customers and Transmission Provider.

1.1 Affected System Network Upgrade(s) to be installed by Transmission Provider.

{description}

1.2 First Equipment Order (including permitting).

{description}

1.2.1. Permitting and Land Rights – Transmission Provider Affected System Network Upgrade(s)

{description}

1.3 Construction Schedule. Where applicable, construction of the Affected System Network Upgrade(s) is scheduled as follows and will be periodically updated as necessary:

Table 3: Transmission Provider Construction Activities

MILESTONE NUMBER	DESCRIPTION	START DATE	END DATE

Note: Construction schedule assumes that Transmission Provider has obtained final authorizations and security from Affected System Interconnection Customers and all necessary permits from Governmental Authorities as necessary prerequisites to commence construction of any of the Affected System Network Upgrade(s).

1.4 Payment Schedule.

1.4.1 Timing of and Adjustments to Affected System Interconnection Customers' Payments and Security.

{description}

1.4.2 Monthly Payment Schedule. Affected System Interconnection Customers' payment schedule is as follows.

* Affected System Interconnection Customers' proportionate responsibility for each payment is as follows:

Affected System Interconnection Customer 1 ____._%

Affected System Interconnection Customer 2 ____._%

Affected System Interconnection Customer N ____._%

Note: Affected System Interconnection Customers' payment or provision of security as provided in this Agreement operates as a condition precedent to Transmission Provider's obligations to construct any Affected System Network Upgrade(s), and failure to meet this schedule will constitute a Breach pursuant to Article 5.1 of this Agreement.

1.5 Permits, Licenses, and Authorizations.

{description}

Attachment B to Appendix 12
Multiparty Affected System Facilities Construction Agreement

NOTIFICATION OF COMPLETED CONSTRUCTION

This Appendix B is a part of the Multiparty Affected System Facilities Construction Agreement among Affected System Interconnection Customers and Transmission Provider. Where applicable, when Transmission Provider has completed construction of the Affected System Network Upgrade(s), Transmission Provider shall send notice to Affected System Interconnection Customers in substantially the form following:

{Date}

{Affected System Interconnection Customers Addresses}

Re: Completion of Affected System Network Upgrade(s)

Dear {Name or Title}:

This letter is sent pursuant to the Multiparty Affected System Facilities Construction Agreement among {Transmission Provider} and {Affected System Interconnection Customers}, dated _____, 20__.

On {Date}, Transmission Provider completed to its satisfaction all work on the Affected System Network Upgrade(s) required to facilitate the safe and reliable interconnection and operation of Affected System Interconnection Customer's generating facilities. Transmission Provider confirms that the Affected System Network Upgrade(s) are in place.

Thank you.

{Signature}

{Transmission Provider Representative}

Attachment C to Appendix 12
Multiparty Affected System Facilities Construction Agreement

EXHIBITS

This Appendix C is a part of the Multiparty Affected System Facilities Construction Agreement among Affected System Interconnection Customers and Transmission Provider.

Exhibit A1

Transmission Provider Site Map

Exhibit A2

Site Plan

Exhibit A3

Affected System Network Upgrade(s) Plan & Profile

Exhibit A4

Estimated Cost of Affected System Network Upgrade(s)

	Location	Facilities to Be Constructed by Transmission Provider	Estimate in Dollars

		Total:	
--	--	---------------	--

ATTACHMENT N

STANDARD LARGE GENERATOR

INTERCONNECTION AGREEMENT (LGIA)

TABLE OF CONTENTS

	Page
Recitals	- 1 -
Article 1. Definitions	- 2 -
Article 2. Effective Date, Term, and Termination	- 13 -
2.1 Effective Date.	- 13 -
2.2 Term of Agreement.	- 13 -
2.3 Termination Procedures.	- 13 -
2.3.1 Written Notice.	- 13 -
2.3.2 Default.	- 13 -
2.4 Termination Costs.	- 14 -
2.5 Disconnection.	- 15 -
2.6 Survival.....	- 15 -
Article 3. Regulatory Filings	- 16 -
3.1 Filing.	- 16 -
Article 4. Scope of Service	- 16 -
4.1 Interconnection Product Options.	- 16 -
4.1.1 Energy Resource Interconnection Service.....	- 16 -
4.1.2 Network Resource Interconnection Service.	- 18 -
4.2 Provision of Service.	- 20 -
4.3 Performance Standards.....	- 20 -
4.4 No Transmission Delivery Service.	- 21 -
4.5 Interconnection Customer Provided Services.	- 21 -
Article 5. Interconnection Facilities Engineering, Procurement, and Construction	- 21 -
5.1 Options.	- 21 -
5.1.1 Standard Option.....	- 21 -
5.1.2 Alternate Option.	- 22 -
5.1.3 Option to Build.....	- 22 -
5.1.4 Negotiated Option.	- 23 -
5.2 General Conditions Applicable to Option to Build.	- 23 -
5.3 Liquidated Damages.....	- 26 -
5.4 Power System Stabilizers.	- 27 -
5.5 Equipment Procurement.	- 27 -
5.6 Construction Commencement.	- 28 -

5.7 Work Progress.....- 28 -

5.8 Information Exchange.....- 29 -

5.9 Other Interconnection Options.- 29 -

 5.9.1 Limited Operation.- 29 -

 5.9.2 Provisional Interconnection Service.....- 29 -

5.10 Interconnection Customer's Interconnection Facilities ('ICIF').....- 30 -

 5.10.1 Interconnection Customer's Interconnection Facility Specifications.- 31 -

 5.10.2 Transmission Provider’s Review.- 31 -

 5.10.3 ICIF Construction.....- 31 -

5.11 Transmission Provider’s Interconnection Facilities Construction.- 32 -

5.12 Access Rights.....- 32 -

5.13 Lands of Other Property Owners.- 33 -

5.14 Permits.- 33 -

5.15 Early Construction of Base Case Facilities.- 33 -

5.16 Suspension.- 34 -

5.17 Taxes.- 34 -

 5.17.1 Interconnection Customer Payments Not Taxable.....- 34 -

 5.17.2 Representations and Covenants.- 35 -

 5.17.3 Indemnification for the Cost Consequences of Current Tax Liability
 Imposed Upon Transmission Provider.- 35 -

 5.17.4 Tax Gross-Up Amount.- 37 -

 5.17.5 Private Letter Ruling or Change or Clarification of Law.....- 38 -

 5.17.6 Subsequent Taxable Events.- 38 -

 5.17.7 Contests.....- 39 -

 5.17.8 Refund.....- 40 -

 5.17.9 Taxes Other Than Income Taxes.- 41 -

 5.17.10Transmission Owners Who Are Not Transmission Providers.
 - 42 -

5.18 Tax Status.- 42 -

5.19 Modification.....- 42 -

 5.19.1 General.....- 42 -

 5.19.2 Standards.....- 43 -

 5.19.3 Modification Costs.- 43 -

Article 6. Testing and Inspection- 44 -

 6.1 Pre-Commercial Operation Date Testing and Modifications.....- 44 -

 6.2 Post-Commercial Operation Date Testing and Modifications.- 44 -

 6.3 Right to Observe Testing.....- 44 -

 6.4 Right to Inspect.....- 44 -

Article 7. Metering.....- 45 -

7.1 General. - 45 -

7.2 Check Meters. - 45 -

7.3 Standards. - 46 -

7.4 Testing of Metering Equipment. - 46 -

7.5 Metering Data. - 46 -

Article 8. Communications..... - 47 -

8.1 Interconnection Customer Obligations. - 47 -

8.2 Remote Terminal Unit. - 47 -

8.3 No Annexation. - 48 -

8.4 Provision of Data from a Variable Energy Resource. - 48 -

Article 9. Operations - 49 -

9.1 General. - 49 -

9.2 Balancing Authority Area Notification. - 49 -

9.3 Transmission Provider Obligations. - 49 -

9.4 Interconnection Customer Obligations. - 49 -

9.5 Start-Up and Synchronization. - 50 -

9.6 Reactive Power and Primary Frequency Response. - 50 -

9.6.1 Power Factor Design Criteria. - 50 -

9.6.2 Voltage Schedules. - 51 -

9.6.3 Payment for Reactive Power. - 52 -

9.6.4 Primary Frequency Response. - 52 -

9.7 Outages and Interruptions. - 56 -

9.7.1 Outages. - 57 -

9.7.2 Interruption of Service. - 58 -

9.7.3 Ride Through Capability and Performance. - 59 -

9.7.4 System Protection and Other Control Requirements. - 60 -

9.7.5 Requirements for Protection. - 62 -

9.7.6 Power Quality. - 62 -

9.8 Switching and Tagging Rules. - 62 -

9.9 Use of Interconnection Facilities by Third Parties. - 63 -

9.9.1 Purpose of Interconnection Facilities. - 63 -

9.9.2 Third Party Users. - 63 -

9.10 Disturbance Analysis Data Exchange. - 63 -

Article 10. Maintenance..... - 64 -

10.1 Transmission Provider Obligations. - 64 -

10.2 Interconnection Customer Obligations. - 64 -

10.3 Coordination. - 64 -

10.4 Secondary Systems. - 64 -

10.5 Operating and Maintenance Expenses. - 65 -

Article 11. Performance Obligation- 65 -

 11.1 Interconnection Customer Interconnection Facilities.- 65 -

 11.2 Transmission Provider’s Interconnection Facilities.- 65 -

 11.3 Network Upgrades and Distribution Upgrades.- 65 -

 11.4 Transmission Credits.....- 65 -

 11.4.1 Repayment of Amounts Advanced for Network Upgrades.....- 66 -

 11.4.2 Special Provisions for Affected Systems.- 67 -

 11.5 Provision of Security.....- 67 -

 11.6 Interconnection Customer Compensation.- 69 -

 11.6.1 Interconnection Customer Compensation for Actions During
 Emergency Condition.- 69 -

Article 12. Invoice- 69 -

 12.1 General.- 69 -

 12.2 Final Invoice.- 70 -

 12.3 Payment.- 70 -

 12.4 Disputes.- 70 -

Article 13. Emergencies- 71 -

 13.1 Definition.....- 71 -

 13.2 Obligations.....- 71 -

 13.3 Notice.- 71 -

 13.4 Immediate Action.....- 72 -

 13.5 Transmission Provider Authority.....- 72 -

 13.5.1 General.....- 72 -

 13.5.2 Reduction and Disconnection.- 73 -

 13.6 Interconnection Customer Authority.- 73 -

 13.7 Limited Liability.- 74 -

Article 14. Regulatory Requirements and Governing Law.....- 74 -

 14.1 Regulatory Requirements.- 74 -

 14.2 Governing Law.- 74 -

Article 15. Notices.- 75 -

 15.1 General.- 75 -

 15.2 Billings and Payments.- 75 -

 15.3 Alternative Forms of Notice.- 75 -

 15.4 Operations and Maintenance Notice.- 75 -

Article 16. Force Majeure.....- 75 -

 16.1 Force Majeure.- 76 -

Article 17. Default - 76 -

 17.1 Default - 76 -

 17.1.1 General..... - 76 -

 17.1.2 Right to Terminate..... - 77 -

 17.2 Violation of Operating Assumptions for Generating Facilities..... - 77 -

Article 18. Indemnity, Consequential Damages and Insurance..... - 77 -

 18.1 Indemnity..... - 78 -

 18.1.1 Indemnified Person..... - 78 -

 18.1.2 Indemnifying Party..... - 78 -

 18.1.3 Indemnity Procedures. - 78 -

 18.2 Consequential Damages. - 79 -

 18.3 Insurance..... - 80 -

Article 19. Assignment..... - 83 -

 19.1 Assignment. - 83 -

Article 20. Severability - 83 -

 20.1 Severability. - 83 -

Article 21. Comparability - 84 -

 21.1 Comparability. - 84 -

Article 22. Confidentiality - 84 -

 22.1 Confidentiality. - 84 -

 22.1.1 Term..... - 84 -

 22.1.2 Scope..... - 85 -

 22.1.3 Release of Confidential Information. - 85 -

 22.1.4 Rights..... - 86 -

 22.1.5 No Warranties. - 86 -

 22.1.6 Standard of Care..... - 86 -

 22.1.7 Order of Disclosure. - 86 -

 22.1.8 Termination of Agreement..... - 87 -

 22.1.9 Remedies..... - 87 -

 22.1.10 Disclosure to FERC, its Staff, or a State. - 87 -

Article 23. Environmental Releases - 89 -

Article 24. Information Requirements - 89 -

 24.1 Information Acquisition. - 89 -

 24.2 Information Submission by Transmission Provider. - 89 -

 24.3 Updated Information Submission by Interconnection Customer. - 90 -

 24.4 Information Supplementation. - 90 -

Article 25. Information Access and Audit Rights.....- 91 -

25.1 Information Access.- 91 -

25.2 Reporting of Non-Force Majeure Events.- 92 -

25.3 Audit Rights.- 92 -

25.4 Audit Rights Periods.- 92 -

 25.4.1 Audit Rights Period for Construction-Related Accounts and
 Records.- 92 -

 25.4.2 Audit Rights Period for All Other Accounts and Records.- 93 -

25.5 Audit Results.....- 93 -

Article 26. Subcontractors- 93 -

26.1 General.- 93 -

26.2 Responsibility of Principal.- 93 -

26.3 No Limitation by Insurance.....- 94 -

Article 27. Disputes- 94 -

27.1 Submission.....- 94 -

27.2 External Arbitration Procedures.- 94 -

27.3 Arbitration Decisions.- 95 -

27.4 Costs.- 95 -

Article 28. Representations, Warranties, and Covenants- 95 -

28.1 General.- 96 -

 28.1.1 Good Standing.....- 96 -

 28.1.2 Authority.....- 96 -

 28.1.3 No Conflict.....- 96 -

 28.1.4 Consent and Approval.- 96 -

Article 29. Joint Operating Committee.....- 97 -

29.1 Joint Operating Committee.....- 97 -

Article 30. Miscellaneous- 98 -

30.1 Binding Effect.....- 98 -

30.2 Conflicts.....- 98 -

30.3 Rules of Interpretation.....- 98 -

30.4 Entire Agreement.- 99 -

30.5 No Third Party Beneficiaries.- 99 -

30.6 Waiver.- 100 -

30.7 Headings.- 100 -

30.8 Multiple Counterparts.- 100 -

30.9 Amendment.....- 100 -

30.10 Modification by the Parties. - 100 -
30.11 Reservation of Rights. - 100 -
30.12 No Partnership. - 101 -

Appendix A – Interconnection Facilities, Network Upgrades, and Distribution Upgrades

Appendix B – Milestones

Appendix C – Interconnection Details

Appendix D – Security Arrangements Details

Appendix E – Commercial Operation Date

Appendix F – Addresses for Delivery of Notices and Billings

Appendix G – Interconnection Requirements for a Wind Generating Plant

Appendix H – Operating Assumptions for Generating Facility

STANDARD LARGE GENERATOR INTERCONNECTION AGREEMENT

THIS STANDARD LARGE GENERATOR INTERCONNECTION AGREEMENT (“Agreement”) is made and entered into this ____ day of _____ 20 __, by and between _____, a _____ organized and existing under the laws of the State/Commonwealth of _____ (“Interconnection Customer” with a Large Generating Facility), and _____, a _____ organized and existing under the laws of the State/Commonwealth of _____ (“Transmission Provider and/or Transmission Owner”). Interconnection Customer and Transmission Provider each may be referred to as a “Party” or collectively as the “Parties.”

Recitals

WHEREAS, Transmission Provider operates the Transmission System; and

WHEREAS, Interconnection Customer intends to own, lease and/or control and operate the Generating Facility identified as a Large Generating Facility in Appendix C to this Agreement; and,

WHEREAS, Interconnection Customer and Transmission Provider have agreed to enter into this Agreement for the purpose of interconnecting the Large Generating Facility with the Transmission System;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, it is agreed:

When used in this Standard Large Generator Interconnection Agreement, terms with initial capitalization that are not defined in Article 1 shall have the meanings specified in the Article in which they are used or the Open Access Transmission Tariff (Tariff).

Article 1. Definitions

Adverse System Impact shall mean the negative effects due to technical or operational limits on conductors or equipment being exceeded that may compromise the safety and reliability of the electric system.

Affected System shall mean an electric system other than Transmission Provider's Transmission System that may be affected by the proposed interconnection.

Affected System Operator shall mean the entity that operates an Affected System.

Affiliate shall mean, with respect to a corporation, partnership or other entity, each such other corporation, partnership or other entity that directly or indirectly, through one or more intermediaries, controls, is controlled by, or is under common control with, such corporation, partnership or other entity.

Ancillary Services shall mean those services that are necessary to support the transmission of capacity and energy from resources to loads while maintaining reliable operation of Transmission Provider's Transmission System in accordance with Good Utility Practice.

Applicable Laws and Regulations shall mean all duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Applicable Reliability Standards shall mean the requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Balancing Authority shall mean an entity that integrates resource plans ahead of time, maintains demand and resource balance within a Balancing Authority Area, and supports interconnection frequency in real time.

Balancing Authority Area shall mean the collection of generation, transmission, and loads within the metered boundaries of the Balancing Authority. The Balancing Authority maintains load-resource balance within this area.

Base Case shall mean the base case power flow, short circuit, and stability data bases used for the Interconnection Studies by Transmission Provider or Interconnection Customer.

Breach shall mean the failure of a Party to perform or observe any material term or condition of the Standard Large Generator Interconnection Agreement.

Breaching Party shall mean a Party that is in Breach of the Standard Large Generator Interconnection Agreement.

Business Day shall mean Monday through Friday, excluding Federal Holidays.

Calendar Day shall mean any day including Saturday, Sunday or a Federal Holiday.

Cluster shall mean a group of one or more Interconnection Requests that are studied together for the purpose of conducting a Cluster Study.

Cluster Restudy shall mean a restudy of a Cluster Study conducted pursuant to Section 7.5 of the LGIP.

Cluster Study shall mean the evaluation of one or more Interconnection Requests within a Cluster as described in Section 7 of the LGIP.

Clustering shall mean the process whereby one or more Interconnection Requests are studied together, instead of serially, as described in Section 7 of the LGIP.

Commercial Operation shall mean the status of a Generating Facility that has commenced generating electricity for sale, excluding electricity generated during Trial Operation.

Commercial Operation Date of a unit shall mean the date on which the Generating Facility commences Commercial Operation as agreed to by the Parties pursuant to Appendix E to the Standard Large Generator Interconnection Agreement.

Confidential Information shall mean any confidential, proprietary or trade secret information of a plan, specification, pattern, procedure, design, device, list, concept, policy or compilation relating to the present or planned business of a Party, which is designated as confidential by the Party supplying the information, whether conveyed orally, electronically, in writing, through inspection, or otherwise.

Contingent Facilities shall mean those unbuilt Interconnection Facilities and Network Upgrades upon which the Interconnection Request's costs, timing, and study findings are dependent, and if delayed or not built, could cause a need for restudies of the Interconnection Request or a reassessment of the Interconnection Facilities and/or Network Upgrades and/or costs and timing.

Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 17 of the Standard Large Generator Interconnection Agreement.

Dispute Resolution shall mean the procedure for resolution of a dispute between the Parties in which they will first attempt to resolve the dispute on an informal basis.

Distribution System shall mean Transmission Provider's facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which distribution systems operate differ among areas.

Distribution Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Generating Facility and render the transmission service necessary to effect Interconnection Customer's wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Effective Date shall mean the date on which the Standard Large Generator Interconnection Agreement becomes effective upon execution by the Parties subject to acceptance by FERC, or if filed unexecuted, upon the date specified by FERC.

Electric Reliability Organization shall mean the North American Electric Reliability Corporation (NERC) or its successor organization.

Emergency Condition shall mean a condition or situation: (1) that in the judgment of the Party making the claim is imminently likely to endanger life or property;

or (2) that, in the case of a Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to Transmission Provider's Transmission System, Transmission Provider's Interconnection Facilities or the electric systems of others to which Transmission Provider's Transmission System is directly connected; or (3) that, in the case of Interconnection Customer, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Generating Facility or Interconnection Customer's Interconnection Facilities. System restoration and black start shall be considered Emergency Conditions; provided, that Interconnection Customer is not obligated by the Standard Large Generator Interconnection Agreement to possess black start capability.

Energy Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to connect its Generating Facility to Transmission Provider's Transmission System to be eligible to deliver the Generating Facility's electric output using the existing firm or nonfirm capacity of Transmission Provider's Transmission System on an as available basis. Energy Resource Interconnection Service in and of itself does not convey transmission service.

Engineering & Procurement (E&P) Agreement shall mean an agreement that authorizes Transmission Provider to begin engineering and procurement of long lead-time items necessary for the establishment of the interconnection in order to advance the implementation of the Interconnection Request.

Environmental Law shall mean Applicable Laws or Regulations relating to pollution or protection of the environment or natural resources.

Federal Power Act shall mean the Federal Power Act, as amended, 16 U.S.C. §§ 791a et seq.

FERC shall mean the Federal Energy Regulatory Commission (Commission) or its successor.

Force Majeure shall mean any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, breakage or accident to machinery or equipment, any order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, or any other cause beyond a Party's control. A Force Majeure event does not include acts of negligence or intentional wrongdoing by the Party claiming Force Majeure.

Generating Facility shall mean Interconnection Customer's devices for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer's Interconnection Facilities.

Generating Facility Capacity shall mean the net capacity of the Generating Facility or the aggregate net capacity of the Generating Facility where it includes more than one device for the production and/or storage for later injection of electricity.

Good Utility Practice shall mean any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Governmental Authority shall mean any federal, state, local or other governmental regulatory or administrative agency, court, commission, department, board, or other governmental subdivision, legislature, rulemaking board, tribunal, or other governmental authority having jurisdiction over the Parties, their respective facilities, or the respective services they provide, and exercising or entitled to exercise any administrative, executive, police, or taxing authority or power; provided, however, that such term does not include Interconnection Customer, Transmission Provider, or any Affiliate thereof.

Hazardous Substances shall mean any chemicals, materials or substances defined as or included in the definition of "hazardous substances," "hazardous wastes," "hazardous materials," "hazardous constituents," "restricted hazardous materials," "extremely hazardous substances," "toxic substances," "radioactive substances," "contaminants," "pollutants," "toxic pollutants" or words of similar meaning and regulatory effect under any applicable Environmental Law, or any other chemical, material or substance, exposure to which is prohibited, limited or regulated by any applicable Environmental Law.

Initial Synchronization Date shall mean the date upon which the Generating Facility is initially synchronized and upon which Trial Operation begins.

In-Service Date shall mean the date upon which Interconnection Customer reasonably expects it will be ready to begin use of Transmission Provider's Interconnection Facilities to obtain back feed power.

Interconnection Customer shall mean any entity, including Transmission Provider, Transmission Owner or any of the Affiliates or subsidiaries of either, that proposes to interconnect its Generating Facility with Transmission Provider's Transmission System.

Interconnection Customer's Interconnection Facilities shall mean all facilities and equipment, as identified in Appendix A of the Standard Large Generator Interconnection Agreement, that are located between the Generating Facility and the Point of Change of Ownership, including any modification, addition, or upgrades to such facilities and equipment necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Customer's Interconnection Facilities are sole use facilities.

Interconnection Facilities shall mean Transmission Provider's Interconnection Facilities and Interconnection Customer's Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Interconnection Facilities Study shall mean a study conducted by Transmission Provider or a third party consultant for Interconnection Customer to determine a list of facilities (including Transmission Provider's Interconnection Facilities and Network Upgrades as identified in the Cluster Study), the cost of those facilities, and the time required to interconnect the Generating Facility with Transmission Provider's Transmission System. The scope of the study is defined in Section 8 of the LGIP.

Interconnection Facilities Study Agreement shall mean the form of agreement contained in Appendix 3 of the Standard Large Generator Interconnection Procedures for conducting the Interconnection Facilities Study.

Interconnection Request shall mean an Interconnection Customer's request, in the form of Appendix 1 to the LGIP, in accordance with the Tariff, to interconnect a new Generating Facility, or to increase the capacity of, or make a Material Modification to the

operating characteristics of, an existing Generating Facility that is interconnected with Transmission Provider's Transmission System.

Interconnection Service shall mean the service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling it to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Standard Large Generator Interconnection Agreement and, if applicable, Transmission Provider's Tariff.

Interconnection Study shall mean any of the following studies: the Cluster Study, the Cluster Restudy, the Surplus Interconnection Service Study, the Interconnection Facilities Study, the Affected System Study, Optional Interconnection Study, and Material Modification assessment, described in the LGIP.

IRS shall mean the Internal Revenue Service.

Joint Operating Committee shall be a group made up of representatives from Interconnection Customers and Transmission Provider to coordinate operating and technical considerations of Interconnection Service.

Large Generating Facility shall mean a Generating Facility having a Generating Facility Capacity of more than 20 MW.

LGIA Deposit shall mean the deposit Interconnection Customer submits when returning the executed LGIA, or within ten (10) Business Days of requesting that the LGIA be filed unexecuted at the Commission, in accordance with Section 11.3 of the LGIP.

Loss shall mean any and all losses relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's performance, or non-performance of its obligations under the Standard Large Generator Interconnection Agreement on behalf of the Indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the Indemnifying Party.

Material Modification shall mean those modifications that have a material impact on the cost or timing of any Interconnection Request with an equal or later Queue Position.

Metering Equipment shall mean all metering equipment installed or to be installed at the Generating Facility pursuant to the Standard Large Generator Interconnection Agreement at the metering points, including but not limited to instrument

transformers, MWh-meters, data acquisition equipment, transducers, remote terminal unit, communications equipment, phone lines, and fiber optics.

Network Resource shall mean any designated generating resource owned, purchased, or leased by a Network Customer under the Network Integration Transmission Service Tariff. Network Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Network Customer's Network Load on a non-interruptible basis.

Network Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to integrate its Large Generating Facility with Transmission Provider's Transmission System (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an RTO or ISO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service in and of itself does not convey transmission service.

Network Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Transmission System required at or beyond the point at which the Interconnection Facilities connect to Transmission Provider's Transmission System to accommodate the interconnection of the Large Generating Facility to Transmission Provider's Transmission System.

Notice of Dispute shall mean a written notice of a dispute or claim that arises out of or in connection with the Standard Large Generator Interconnection Agreement or its performance.

Optional Interconnection Study shall mean a sensitivity analysis based on assumptions specified by Interconnection Customer in the Optional Interconnection Study Agreement.

Optional Interconnection Study Agreement shall mean the form of agreement contained in Appendix 4 of the LGIP for conducting the Optional Interconnection Study.

Party or Parties shall mean Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Point of Change of Ownership shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where Interconnection Customer's Interconnection Facilities connect to Transmission Provider's Interconnection Facilities.

Point of Interconnection shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where the Interconnection Facilities connect to Transmission Provider's Transmission System.

Proportional Impact Method shall mean a technical analysis conducted by Transmission Provider to determine the degree to which each Generating Facility in the Cluster Study contributes to the need for a specific System Network Upgrade.

Provisional Interconnection Service shall mean Interconnection Service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling that Transmission System to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Provisional Large Generator Interconnection Agreement and, if applicable, the Tariff.

Provisional Large Generator Interconnection Agreement shall mean the interconnection agreement for Provisional Interconnection Service established between Transmission Provider and/or the Transmission Owner and Interconnection Customer. This agreement shall take the form of the Standard Large Generator Interconnection Agreement, modified for provisional purposes.

Queue Position shall mean the order of a valid Interconnection Request, relative to all other pending valid Interconnection Requests, established pursuant to Section 4.1 of this LGIP.

Reasonable Efforts shall mean, with respect to an action required to be attempted or taken by a Party under the Standard Large Generator Interconnection Agreement, efforts that are timely and consistent with Good Utility Practice and are otherwise substantially equivalent to those a Party would use to protect its own interests.

Scoping Meeting shall mean the meeting between representatives of Interconnection Customer(s) and Transmission Provider conducted for the purpose of discussing the proposed Interconnection Request and any alternative interconnection options, exchanging information including any transmission data and earlier study evaluations that would be reasonably expected to impact such interconnection options, refining information and models provided by Interconnection Customer(s), discussing the Cluster Study materials posted to OASIS pursuant to Section 3.5 of the LGIP, and analyzing such information.

Site Control shall mean the exclusive land right to develop, construct, operate, and maintain the Generating Facility over the term of expected operation of the Generating Facility. Site Control may be demonstrated by documentation establishing:

(1) ownership of, a leasehold interest in, or a right to develop a site of sufficient size to construct and operate the Generating Facility; (2) an option to purchase or acquire a leasehold site of sufficient size to construct and operate the Generating Facility for such purpose; or (3) any other documentation that clearly demonstrates the right of Interconnection Customer to exclusively occupy a site of sufficient size to construct and operate the Generating Facility. Transmission Provider will maintain acreage requirements for each Generating Facility type on its OASIS or public website.

Small Generating Facility shall mean a Generating Facility that has a Generating Facility Capacity of no more than 20 MW.

Stand Alone Network Upgrades shall mean Network Upgrades that are not part of an Affected System that an Interconnection Customer may construct without affecting day-to-day operations of the Transmission System during their construction. Both Transmission Provider and Interconnection Customer must agree as to what constitutes Stand Alone Network Upgrades and identify them in Appendix A to the Standard Large Generator Interconnection Agreement. If Transmission Provider and Interconnection Customer disagree about whether a particular Network Upgrade is a Stand Alone Network Upgrade, Transmission Provider must provide Interconnection Customer a written technical explanation outlining why Transmission Provider does not consider the Network Upgrade to be a Stand Alone Network Upgrade within fifteen (15) Business Days of its determination.

Standard Large Generator Interconnection Agreement (LGIA) shall mean the form of interconnection agreement applicable to an Interconnection Request pertaining to a Large Generating Facility that is included in Transmission Provider's Tariff.

Standard Large Generator Interconnection Procedures (LGIP) shall mean the interconnection procedures applicable to an Interconnection Request pertaining to a Large Generating Facility that are included in Transmission Provider's Tariff.

Substation Network Upgrades shall mean Network Upgrades that are required at the substation located at the Point of Interconnection.

Surplus Interconnection Service shall mean any unneeded portion of Interconnection Service established in a Standard Large Generator Interconnection Agreement, such that if Surplus Interconnection Service is utilized the total amount of Interconnection Service at the Point of Interconnection would remain the same.

System Network Upgrades shall mean Network Upgrades that are required beyond the substation located at the Point of Interconnection.

System Protection Facilities shall mean the equipment, including necessary protection signal communications equipment, required to protect (1) Transmission Provider's Transmission System from faults or other electrical disturbances occurring at the Generating Facility and (2) the Generating Facility from faults or other electrical system disturbances occurring on Transmission Provider's Transmission System or on other delivery systems or other generating systems to which Transmission Provider's Transmission System is directly connected.

Tariff shall mean Transmission Provider's Tariff through which open access transmission service and Interconnection Service are offered, as filed with FERC, and as amended or supplemented from time to time, or any successor tariff.

Transmission Owner shall mean an entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Standard Large Generator Interconnection Agreement to the extent necessary.

Transmission Provider shall mean the public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission Provider's Interconnection Facilities shall mean all facilities and equipment owned, controlled, or operated by Transmission Provider from the Point of Change of Ownership to the Point of Interconnection as identified in Appendix A to the Standard Large Generator Interconnection Agreement, including any modifications, additions or upgrades to such facilities and equipment. Transmission Provider's Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Transmission System shall mean the facilities owned, controlled or operated by Transmission Provider or Transmission Owner that are used to provide transmission service under the Tariff.

Trial Operation shall mean the period during which Interconnection Customer is engaged in on-site test operations and commissioning of the Generating Facility prior to Commercial Operation.

Variable Energy Resource shall mean a device for the production of electricity that is characterized by an energy source that: (1) is renewable; (2) cannot be stored by

the facility owner or operator; and (3) has variability that is beyond the control of the facility owner or operator.

Withdrawal Penalty shall mean the penalty assessed by Transmission Provider to an Interconnection Customer that chooses to withdraw or is deemed withdrawn from Transmission Provider's interconnection queue or whose Generating Facility does not otherwise reach Commercial Operation. The calculation of the Withdrawal Penalty is set forth in Section 3.7.1 of the LGIP.

Article 2. Effective Date, Term, and Termination

2.1 **Effective Date.** This LGIA shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by FERC. Transmission Provider shall promptly file this LGIA with FERC upon execution in accordance with Article 3.1, if required.

2.2 **Term of Agreement.** Subject to the provisions of Article 2.3, this LGIA shall remain in effect for a period of ten (10) years from the Effective Date or such other longer period as Interconnection Customer may request (Term to be specified in individual agreements) and shall be automatically renewed for each successive one-year period thereafter.

2.3 Termination Procedures.

2.3.1 **Written Notice.** This LGIA may be terminated by Interconnection Customer after giving Transmission Provider ninety (90) Calendar Days advance written notice, or by Transmission Provider notifying FERC after the Generating Facility permanently ceases Commercial Operation.

2.3.2 **Default.** Either Party may terminate this LGIA in accordance with Article 17.

- 2.3.3** Notwithstanding Articles 2.3.1 and 2.3.2, no termination shall become effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination, including the filing with FERC of a notice of termination of this LGIA, which notice has been accepted for filing by FERC.
- 2.4** Termination Costs. If a Party elects to terminate this Agreement pursuant to Article 2.3 above, each Party shall pay all costs incurred (including any cancellation costs relating to orders or contracts for Interconnection Facilities and equipment) or charges assessed by the other Party, as of the date of the other Party's receipt of such notice of termination, that are the responsibility of the Terminating Party under this LGIA. In the event of termination by a Party, the Parties shall use commercially Reasonable Efforts to mitigate the costs, damages and charges arising as a consequence of termination. Upon termination of this LGIA, unless otherwise ordered or approved by FERC:
- 2.4.1** With respect to any portion of Transmission Provider's Interconnection Facilities that have not yet been constructed or installed, Transmission Provider shall to the extent possible and with Interconnection Customer's authorization cancel any pending orders of, or return, any materials or equipment for, or contracts for construction of, such facilities; provided that in the event Interconnection Customer elects not to authorize such cancellation, Interconnection Customer shall assume all payment obligations with respect to such materials, equipment, and contracts, and Transmission Provider shall deliver such material and equipment, and, if necessary, assign such contracts, to Interconnection Customer as soon as practicable, at Interconnection Customer's expense. To the extent that Interconnection Customer has already paid Transmission Provider for any or all such costs of materials or equipment not taken by Interconnection Customer, Transmission Provider shall promptly refund such amounts to Interconnection Customer, less any costs, including penalties incurred by Transmission Provider to cancel any pending orders of or return such materials, equipment, or contracts.

If an Interconnection Customer terminates this LGIA, it shall be responsible for all costs incurred in association with that Interconnection Customer's interconnection, including any cancellation costs relating to orders or contracts for Interconnection Facilities and equipment, and other expenses including any Network Upgrades for which Transmission Provider has incurred expenses and has not been reimbursed by Interconnection Customer.

- 2.4.2** Transmission Provider may, at its option, retain any portion of such materials, equipment, or facilities that Interconnection Customer chooses not to accept delivery of, in which case Transmission Provider shall be responsible for all costs associated with procuring such materials, equipment, or facilities.
- 2.4.3** With respect to any portion of the Interconnection Facilities, and any other facilities already installed or constructed pursuant to the terms of this LGIA, Interconnection Customer shall be responsible for all costs associated with the removal, relocation or other disposition or retirement of such materials, equipment, or facilities.
- 2.5** Disconnection. Upon termination of this LGIA, the Parties will take all appropriate steps to disconnect the Large Generating Facility from the Transmission System. All costs required to effectuate such disconnection shall be borne by the terminating Party, unless such termination resulted from the non-terminating Party's Default of this LGIA or such non-terminating Party otherwise is responsible for these costs under this LGIA.
- 2.6** Survival. This LGIA shall continue in effect after termination to the extent necessary to provide for final billings and payments and for costs incurred hereunder, including billings and payments pursuant to this LGIA; to permit the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this LGIA was in effect; and to permit each Party to have access to the lands of the other Party pursuant to this LGIA or

other applicable agreements, to disconnect, remove or salvage its own facilities and equipment.

Article 3. Regulatory Filings

- 3.1 **Filing.** Transmission Provider shall file this LGIA (and any amendment hereto) with the appropriate Governmental Authority, if required. Interconnection Customer may request that any information so provided be subject to the confidentiality provisions of Article 22. If Interconnection Customer has executed this LGIA, or any amendment thereto, Interconnection Customer shall reasonably cooperate with Transmission Provider with respect to such filing and to provide any information reasonably requested by Transmission Provider needed to comply with applicable regulatory requirements.

Article 4. Scope of Service

- 4.1 **Interconnection Product Options.** Interconnection Customer has selected the following (checked) type of Interconnection Service:

4.1.1 Energy Resource Interconnection Service.

- 4.1.1.1 **The Product.** Energy Resource Interconnection Service allows Interconnection Customer to connect the Large Generating Facility to the Transmission System and be eligible to deliver the Large Generating Facility's output using the existing firm or non-firm capacity of the Transmission System on an "as available" basis. To the extent Interconnection Customer wants to receive Energy Resource Interconnection Service, Transmission Provider shall construct facilities identified in Attachment A.

4.1.1.2 Transmission Delivery Service Implications.

Under Energy Resource Interconnection Service, Interconnection Customer will be eligible to inject power from the Large Generating Facility into and deliver power across the interconnecting Transmission Provider's Transmission System on an "as available" basis up to the amount of MWs identified in the applicable stability and steady state studies to the extent the upgrades initially required to qualify for Energy Resource Interconnection Service have been constructed. Where eligible to do so (e.g., PJM, ISO-NE, NYISO), Interconnection Customer may place a bid to sell into the market up to the maximum identified Large Generating Facility output, subject to any conditions specified in the interconnection service approval, and the Large Generating Facility will be dispatched to the extent Interconnection Customer's bid clears. In all other instances, no transmission delivery service from the Large Generating Facility is assured, but Interconnection Customer may obtain Point-to-Point Transmission Service, Network Integration Transmission Service, or be used for secondary network transmission service, pursuant to Transmission Provider's Tariff, up to the maximum output identified in the stability and steady state studies. In those instances, in order for Interconnection Customer to obtain the right to deliver or inject energy beyond the Large Generating Facility Point of Interconnection or to improve its ability to do so, transmission delivery service must be obtained pursuant to the provisions of Transmission Provider's Tariff. Interconnection Customer's ability to inject its Large Generating Facility output beyond the Point of Interconnection, therefore, will depend on the existing capacity of Transmission Provider's Transmission System at such time as a transmission service request is made that would accommodate such delivery. The provision of firm Point-to-Point Transmission Service or Network Integration Transmission Service may require the construction of additional Network Upgrades.

4.1.2 Network Resource Interconnection Service.

4.1.2.1 The Product. Transmission Provider must conduct the necessary studies and construct the Network Upgrades needed to integrate the Large Generating Facility (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an ISO or RTO with market based congestion management, in the same manner as all Network Resources. To the extent Interconnection Customer wants to receive Network Resource Interconnection Service, Transmission Provider shall construct the facilities identified in Attachment A to this LGIA.

4.1.2.2 Transmission Delivery Service Implications. Network Resource Interconnection Service allows Interconnection Customer's Large Generating Facility to be designated by any Network Customer under the Tariff on Transmission Provider's Transmission System as a Network Resource, up to the Large Generating Facility's full output, on the same basis as existing Network Resources interconnected to Transmission Provider's Transmission System, and to be studied as a Network Resource on the assumption that such a designation will occur. Although Network Resource Interconnection Service does not convey a reservation of transmission service, any Network Customer under the Tariff can utilize its network service under the Tariff to obtain delivery of energy from the interconnected Interconnection Customer's Large Generating Facility in the same manner as it accesses Network Resources. A Large Generating Facility receiving Network Resource Interconnection Service may also be used to provide Ancillary Services after technical studies and/or periodic analyses are performed with respect to the Large Generating Facility's ability to provide any applicable Ancillary Services, provided that such studies and

analyses have been or would be required in connection with the provision of such Ancillary Services by any existing Network Resource. However, if an Interconnection Customer's Large Generating Facility has not been designated as a Network Resource by any load, it cannot be required to provide Ancillary Services except to the extent such requirements extend to all generating facilities that are similarly situated. The provision of Network Integration Transmission Service or firm Point-to-Point Transmission Service may require additional studies and the construction of additional upgrades. Because such studies and upgrades would be associated with a request for delivery service under the Tariff, cost responsibility for the studies and upgrades would be in accordance with FERC's policy for pricing transmission delivery services.

Network Resource Interconnection Service does not necessarily provide Interconnection Customer with the capability to physically deliver the output of its Large Generating Facility to any particular load on Transmission Provider's Transmission System without incurring congestion costs. In the event of transmission constraints on Transmission Provider's Transmission System, Interconnection Customer's Large Generating Facility shall be subject to the applicable congestion management procedures in Transmission Provider's Transmission System in the same manner as Network Resources.

There is no requirement either at the time of study or interconnection, or at any point in the future, that Interconnection Customer's Large Generating Facility be designated as a Network Resource by a Network Service Customer under the Tariff or that Interconnection Customer identify a specific buyer (or sink). To the extent a Network Customer does designate the Large Generating Facility as a

Network Resource, it must do so pursuant to Transmission Provider's Tariff.

Once an Interconnection Customer satisfies the requirements for obtaining Network Resource Interconnection Service, any future transmission service request for delivery from the Large Generating Facility within Transmission Provider's Transmission System of any amount of capacity and/or energy, up to the amount initially studied, will not require that any additional studies be performed or that any further upgrades associated with such Large Generating Facility be undertaken, regardless of whether or not such Large Generating Facility is ever designated by a Network Customer as a Network Resource and regardless of changes in ownership of the Large Generating Facility. However, the reduction or elimination of congestion or redispatch costs may require additional studies and the construction of additional upgrades.

To the extent Interconnection Customer enters into an arrangement for long term transmission service for deliveries from the Large Generating Facility outside Transmission Provider's Transmission System, such request may require additional studies and upgrades in order for Transmission Provider to grant such request.

- 4.2 Provision of Service. Transmission Provider shall provide Interconnection Service for the Large Generating Facility at the Point of Interconnection.
- 4.3 Performance Standards. Each Party shall perform all of its obligations under this LGIA in accordance with Applicable Laws and Regulations, Applicable Reliability Standards, and Good Utility Practice, and to the extent a Party is required or prevented or limited in taking any action by such regulations and standards, such Party shall not be deemed to be in Breach of this LGIA for its

compliance therewith. If such Party is a Transmission Provider or Transmission Owner, then that Party shall amend the LGIA and submit the amendment to FERC for approval.

- 4.4 No Transmission Delivery Service. The execution of this LGIA does not constitute a request for, nor the provision of, any transmission delivery service under Transmission Provider's Tariff, and does not convey any right to deliver electricity to any specific customer or Point of Delivery.
- 4.5 Interconnection Customer Provided Services. The services provided by Interconnection Customer under this LGIA are set forth in Article 9.6 and Article 13.5.1. Interconnection Customer shall be paid for such services in accordance with Article 11.6.

Article 5. Interconnection Facilities Engineering, Procurement, and Construction

- 5.1 Options. Unless otherwise mutually agreed to between the Parties, Interconnection Customer shall select the In-Service Date, Initial Synchronization Date, and Commercial Operation Date; and either the Standard Option or Alternate Option set forth below, and such dates and selected option shall be set forth in Appendix B, Milestones. At the same time, Interconnection Customer shall indicate whether it elects to exercise the Option to Build set forth in Article 5.1.3 below. If the dates designated by Interconnection Customer are not acceptable to Transmission Provider, Transmission Provider shall so notify Interconnection Customer within thirty (30) Calendar Days. Upon receipt of the notification that Interconnection Customer's designated dates are not acceptable to Transmission Provider, Interconnection Customer shall notify Transmission Provider within thirty (30) Calendar Days whether it elects to exercise the Option to Build if it has not already elected to exercise the Option to Build.

- 5.1.1 Standard Option. Transmission Provider shall design, procure, and construct Transmission Provider's Interconnection Facilities and Network

Upgrades, using Reasonable Efforts to complete Transmission Provider's Interconnection Facilities and Network Upgrades by the dates set forth in Appendix B, Milestones. Transmission Provider shall not be required to undertake any action which is inconsistent with its standard safety practices, its material and equipment specifications, its design criteria and construction procedures, its labor agreements, and Applicable Laws and Regulations. In the event Transmission Provider reasonably expects that it will not be able to complete Transmission Provider's Interconnection Facilities and Network Upgrades by the specified dates, Transmission Provider shall promptly provide written notice to Interconnection Customer and shall undertake Reasonable Efforts to meet the earliest dates thereafter.

- 5.1.2 **Alternate Option.** If the dates designated by Interconnection Customer are acceptable to Transmission Provider, Transmission Provider shall so notify Interconnection Customer within thirty (30) Calendar Days, and shall assume responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities by the designated dates.

If Transmission Provider subsequently fails to complete Transmission Provider's Interconnection Facilities by the In-Service Date, to the extent necessary to provide back feed power; or fails to complete Network Upgrades by the Initial Synchronization Date to the extent necessary to allow for Trial Operation at full power output, unless other arrangements are made by the Parties for such Trial Operation; or fails to complete the Network Upgrades by the Commercial Operation Date, as such dates are reflected in Appendix B, Milestones; Transmission Provider shall pay Interconnection Customer liquidated damages in accordance with Article 5.3, Liquidated Damages, provided, however, the dates designated by Interconnection Customer shall be extended day for day for each day that the applicable RTO or ISO refuses to grant clearances to install equipment.

- 5.1.3 **Option to Build.** Individual or Multiple Interconnection Customer shall have the option to assume responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades on the dates specified in Article 5.1.2, if

the requirements of this Article 5.1.3 are met. When multiple Interconnection Customers exercise this option, multiple Interconnection Customers may agree to exercise this option provided (1) all Transmission Provider's Interconnection Facilities and Stand Alone Network upgrades constructed under this option are only required for Interconnection Customers in a single Cluster and (2) all impacted Interconnection Customers execute and provide to Transmission Provider an agreement regarding responsibilities and payment for the construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades planned to be built under this option. Transmission Provider and the individual Interconnection Customer or each of the multiple Interconnection Customers must agree as to what constitutes Stand Alone Network Upgrades and identify such Stand Alone Network Upgrades in Appendix A. Except for Stand Alone Network Upgrades, Interconnection Customer shall have no right to construct Network Upgrades under this option.

5.1.4 Negotiated Option. If the dates designated by Interconnection Customer are not acceptable to Transmission Provider, the Parties shall in good faith attempt to negotiate terms and conditions (including revision of the specified dates and liquidated damages, the provision of incentives, or the procurement and construction of all facilities other than Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades if Interconnection Customer elects to exercise the Option to Build under Article 5.1.3). If the Parties are unable to reach agreement on such terms and conditions, then pursuant to Article 5.1.1 (Standard Option), Transmission Provider shall assume responsibility for the design, procurement and construction of all facilities other than Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades if Interconnection Customer elects to exercise the Option to Build.

5.2 General Conditions Applicable to Option to Build. If Interconnection Customer assumes responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades,

(1) Interconnection Customer shall engineer, procure equipment, and construct Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades (or portions thereof) using Good Utility Practice and using standards and specifications provided in advance by Transmission Provider;

(2) Interconnection Customer's engineering, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades shall comply with all requirements of law to which Transmission Provider would be subject in the engineering, procurement or construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades;

(3) Transmission Provider shall review and approve the engineering design, equipment acceptance tests, and the construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades;

(4) prior to commencement of construction, Interconnection Customer shall provide to Transmission Provider a schedule for construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades, and shall promptly respond to requests for information from Transmission Provider;

(5) at any time during construction, Transmission Provider shall have the right to gain unrestricted access to Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades and to conduct inspections of the same;

(6) at any time during construction, should any phase of the engineering, equipment procurement, or construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades not meet the standards and specifications provided by Transmission Provider, Interconnection Customer shall be obligated to remedy deficiencies in that

portion of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades;

(7) Interconnection Customer shall indemnify Transmission Provider for claims arising from Interconnection Customer's construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades under the terms and procedures applicable to Article 18.1 Indemnity;

(8) Interconnection Customer shall transfer control of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades to Transmission Provider;

(9) Unless Parties otherwise agree, Interconnection Customer shall transfer ownership of Transmission Provider's Interconnection Facilities and Stand-Alone Network Upgrades to Transmission Provider;

(10) Transmission Provider shall approve and accept for operation and maintenance Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades to the extent engineered, procured, and constructed in accordance with this Article 5.2; and

(11) Interconnection Customer shall deliver to Transmission Provider "as-built" drawings, information, and any other documents that are reasonably required by Transmission Provider to assure that the Interconnection Facilities and Stand-Alone Network Upgrades are built to the standards and specifications required by Transmission Provider.

(12) If Interconnection Customer exercises the Option to Build pursuant to Article 5.1.3, Interconnection Customer shall pay Transmission Provider the agreed upon amount of {\$ PLACEHOLDER} for Transmission Provider to execute the responsibilities enumerated to Transmission

Provider under Article 5.2. Transmission Provider shall invoice Interconnection Customer for this total amount to be divided on a monthly basis pursuant to Article 12.

- 5.3 Liquidated Damages. The actual damages to Interconnection Customer, in the event Transmission Provider's Interconnection Facilities or Network Upgrades are not completed by the dates designated by Interconnection Customer and accepted by Transmission Provider pursuant to subparagraphs 5.1.2 or 5.1.4, above, may include Interconnection Customer's fixed operation and maintenance costs and lost opportunity costs. Such actual damages are uncertain and impossible to determine at this time. Because of such uncertainty, any liquidated damages paid by Transmission Provider to Interconnection Customer in the event that Transmission Provider does not complete any portion of Transmission Provider's Interconnection Facilities or Network Upgrades by the applicable dates, shall be an amount equal to $\frac{1}{2}$ of 1 percent per day of the actual cost of Transmission Provider's Interconnection Facilities and Network Upgrades, in the aggregate, for which Transmission Provider has assumed responsibility to design, procure and construct.

However, in no event shall the total liquidated damages exceed 20 percent of the actual cost of Transmission Provider's Interconnection Facilities and Network Upgrades for which Transmission Provider has assumed responsibility to design, procure, and construct. The foregoing payments will be made by Transmission Provider to Interconnection Customer as just compensation for the damages caused to Interconnection Customer, which actual damages are uncertain and impossible to determine at this time, and as reasonable liquidated damages, but not as a penalty or a method to secure performance of this LGIA. Liquidated damages, when the Parties agree to them, are the exclusive remedy for Transmission Provider's failure to meet its schedule.

No liquidated damages shall be paid to Interconnection Customer if: (1) Interconnection Customer is not ready to commence use of Transmission Provider's Interconnection Facilities or Network Upgrades to take the delivery of power for the Large Generating Facility's Trial Operation or to export power from the Large Generating Facility on the specified dates, unless Interconnection

Customer would have been able to commence use of Transmission Provider's Interconnection Facilities or Network Upgrades to take the delivery of power for Large Generating Facility's Trial Operation or to export power from the Large Generating Facility, but for Transmission Provider's delay; (2) Transmission Provider's failure to meet the specified dates is the result of the action or inaction of Interconnection Customer or any other Interconnection Customer who has entered into an LGIA with Transmission Provider or any cause beyond Transmission Provider's reasonable control or reasonable ability to cure; (3) Interconnection Customer has assumed responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades; or (4) the Parties have otherwise agreed.

5.4 Power System Stabilizers. Interconnection Customer shall procure, install, maintain and operate Power System Stabilizers in accordance with the guidelines and procedures established by the Electric Reliability Organization. Transmission Provider reserves the right to reasonably establish minimum acceptable settings for any installed Power System Stabilizers, subject to the design and operating limitations of the Large Generating Facility. If the Large Generating Facility's Power System Stabilizers are removed from service or not capable of automatic operation, Interconnection Customer shall immediately notify Transmission Provider's system operator, or its designated representative. The requirements of this paragraph shall not apply to wind generators.

5.5 Equipment Procurement. If responsibility for construction of Transmission Provider's Interconnection Facilities or Network Upgrades is to be borne by Transmission Provider, then Transmission Provider shall commence design of Transmission Provider's Interconnection Facilities or Network Upgrades and procure necessary equipment as soon as practicable after all of the following conditions are satisfied, unless the Parties otherwise agree in writing:

5.5.1 Transmission Provider has completed the Interconnection Facilities Study pursuant to the Interconnection Facilities Study Agreement;

- 5.5.2** Transmission Provider has received written authorization to proceed with design and procurement from Interconnection Customer by the date specified in Appendix B, Milestones; and
- 5.5.3** Interconnection Customer has provided security to Transmission Provider in accordance with Article 11.5 by the dates specified in Appendix B, Milestones.
- 5.6** Construction Commencement. Transmission Provider shall commence construction of Transmission Provider's Interconnection Facilities and Network Upgrades for which it is responsible as soon as practicable after the following additional conditions are satisfied:
- 5.6.1** Approval of the appropriate Governmental Authority has been obtained for any facilities requiring regulatory approval;
- 5.6.2** Necessary real property rights and rights-of-way have been obtained, to the extent required for the construction of a discrete aspect of Transmission Provider's Interconnection Facilities and Network Upgrades;
- 5.6.3** Transmission Provider has received written authorization to proceed with construction from Interconnection Customer by the date specified in Appendix B, Milestones; and
- 5.6.4** Interconnection Customer has provided security to Transmission Provider in accordance with Article 11.5 by the dates specified in Appendix B, Milestones.
- 5.7** Work Progress. The Parties will keep each other advised periodically as to the progress of their respective design, procurement and construction efforts. Either Party may, at any time, request a progress report from the other Party. If, at any

time, Interconnection Customer determines that the completion of Transmission Provider's Interconnection Facilities will not be required until after the specified In-Service Date, Interconnection Customer will provide written notice to Transmission Provider of such later date upon which the completion of Transmission Provider's Interconnection Facilities will be required.

- 5.8 Information Exchange. As soon as reasonably practicable after the Effective Date, the Parties shall exchange information regarding the design and compatibility of the Parties' Interconnection Facilities and compatibility of the Interconnection Facilities with Transmission Provider's Transmission System, and shall work diligently and in good faith to make any necessary design changes.

5.9 Other Interconnection Options.

5.9.1 Limited Operation. If any of Transmission Provider's Interconnection Facilities or Network Upgrades are not reasonably expected to be completed prior to the Commercial Operation Date of the Large Generating Facility, Transmission Provider shall, upon the request and at the expense of Interconnection Customer, perform operating studies on a timely basis to determine the extent to which the Large Generating Facility and Interconnection Customer's Interconnection Facilities may operate prior to the completion of Transmission Provider's Interconnection Facilities or Network Upgrades consistent with Applicable Laws and Regulations, Applicable Reliability Standards, Good Utility Practice, and this LGIA. Transmission Provider shall permit Interconnection Customer to operate the Large Generating Facility and Interconnection Customer's Interconnection Facilities in accordance with the results of such studies.

5.9.2 **Provisional Interconnection Service.** Upon the request of Interconnection Customer, and prior to completion of requisite Interconnection Facilities, Network Upgrades, Distribution Upgrades, or System Protection Facilities Transmission Provider may execute a Provisional Large Generator Interconnection Agreement or Interconnection Customer may request the filing of an unexecuted Provisional Large Generator Interconnection

Agreement with Interconnection Customer for limited Interconnection Service at the discretion of Transmission Provider based upon an evaluation that will consider the results of available studies. Transmission Provider shall determine, through available studies or additional studies as necessary, whether stability, short circuit, thermal, and/or voltage issues would arise if Interconnection Customer interconnects without modifications to the Generating Facility or Transmission System. Transmission Provider shall determine whether any Interconnection Facilities, Network Upgrades, Distribution Upgrades, or System Protection Facilities that are necessary to meet the requirements of the Electric Reliability Organization, or any applicable Regional Entity for the interconnection of a new, modified and/or expanded Generating Facility are in place prior to the commencement of Interconnection Service from the Generating Facility. Where available studies indicate that such, Interconnection Facilities, Network Upgrades, Distribution Upgrades, and/or System Protection Facilities that are required for the interconnection of a new, modified and/or expanded Generating Facility are not currently in place, Transmission Provider will perform a study, at Interconnection Customer's expense, to confirm the facilities that are required for Provisional Interconnection Service. The maximum permissible output of the Generating Facility in the Provisional Large Generator Interconnection Agreement shall be studied and updated {on a frequency determined by Transmission Provider and at Interconnection Customer's expense}. Interconnection Customer assumes all risk and liabilities with respect to changes between the Provisional Large Generator Interconnection Agreement and the Large Generator Interconnection Agreement, including changes in output limits and Interconnection Facilities, Network Upgrades, Distribution Upgrades, and/or System Protection Facilities cost responsibilities.

- 5.10 Interconnection Customer's Interconnection Facilities ('ICIF'). Interconnection Customer shall, at its expense, design, procure, construct, own and install the ICIF, as set forth in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades.

- 5.10.1 Interconnection Customer's Interconnection Facility Specifications. Interconnection Customer shall submit initial specifications for the ICIF, including System Protection Facilities, to Transmission Provider at least one hundred eighty (180) Calendar Days prior to the Initial Synchronization Date; and final specifications for review and comment at least ninety (90) Calendar Days prior to the Initial Synchronization Date. Transmission Provider shall review such specifications to ensure that the ICIF are compatible with the technical specifications, operational control, and safety requirements of Transmission Provider and comment on such specifications within thirty (30) Calendar Days of Interconnection Customer's submission. All specifications provided hereunder shall be deemed confidential.
- 5.10.2 **Transmission Provider's Review.** Transmission Provider's review of Interconnection Customer's final specifications shall not be construed as confirming, endorsing, or providing a warranty as to the design, fitness, safety, durability or reliability of the Large Generating Facility, or the ICIF. Interconnection Customer shall make such changes to the ICIF as may reasonably be required by Transmission Provider, in accordance with Good Utility Practice, to ensure that the ICIF are compatible with the technical specifications, operational control, and safety requirements of Transmission Provider.
- 5.10.3 **ICIF Construction.** The ICIF shall be designed and constructed in accordance with Good Utility Practice. Within one hundred twenty (120) Calendar Days after the Commercial Operation Date, unless the Parties agree on another mutually acceptable deadline, Interconnection Customer shall deliver to Transmission Provider "as-built" drawings, information and documents for the ICIF, such as: a one-line diagram, a site plan showing the Large Generating Facility and the ICIF, plan and elevation drawings showing the layout of the ICIF, a relay functional diagram, relaying AC and DC schematic wiring diagrams and relay settings for all facilities associated with Interconnection Customer's step-up transformers, the

facilities connecting the Large Generating Facility to the step-up transformers and the ICIF, and the impedances (determined by factory tests) for the associated step-up transformers and the Large Generating Facility. Interconnection Customer shall provide Transmission Provider specifications for the excitation system, automatic voltage regulator, Large Generating Facility control and protection settings, transformer tap settings, and communications, if applicable.

- 5.11 **Transmission Provider's Interconnection Facilities Construction.** Transmission Provider's Interconnection Facilities shall be designed and constructed in accordance with Good Utility Practice. Upon request, within one hundred twenty (120) Calendar Days after the Commercial Operation Date, unless the Parties agree on another mutually acceptable deadline, Transmission Provider shall deliver to Interconnection Customer the following "as-built" drawings, information and documents for Transmission Provider's Interconnection Facilities {include appropriate drawings and relay diagrams}.

Transmission Provider will obtain control of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades upon completion of such facilities.

- 5.12 **Access Rights.** Upon reasonable notice and supervision by a Party, and subject to any required or necessary regulatory approvals, a Party ("Granting Party") shall furnish at no cost to the other Party ("Access Party") any rights of use, licenses, rights of way and easements with respect to lands owned or controlled by the Granting Party, its agents (if allowed under the applicable agency agreement), or any Affiliate, that are necessary to enable the Access Party to obtain ingress and egress to construct, operate, maintain, repair, test (or witness testing), inspect, replace or remove facilities and equipment to: (i) interconnect the Large Generating Facility with the Transmission System; (ii) operate and maintain the Large Generating Facility, the Interconnection Facilities and the Transmission System; and (iii) disconnect or remove the Access Party's facilities and equipment upon termination of this LGIA. In exercising such licenses, rights of way and easements, the Access Party shall not unreasonably disrupt or interfere with

normal operation of the Granting Party's business and shall adhere to the safety rules and procedures established in advance, as may be changed from time to time, by the Granting Party and provided to the Access Party.

- 5.13 Lands of Other Property Owners. If any part of Transmission Provider or Transmission Owner's Interconnection Facilities and/or Network Upgrades is to be installed on property owned by persons other than Interconnection Customer or Transmission Provider or Transmission Owner, Transmission Provider or Transmission Owner shall at Interconnection Customer's expense use efforts, similar in nature and extent to those that it typically undertakes on its own behalf or on behalf of its Affiliates, including use of its eminent domain authority, and to the extent consistent with state law, to procure from such persons any rights of use, licenses, rights of way and easements that are necessary to construct, operate, maintain, test, inspect, replace or remove Transmission Provider or Transmission Owner's Interconnection Facilities and/or Network Upgrades upon such property.
- 5.14 Permits. Transmission Provider or Transmission Owner and Interconnection Customer shall cooperate with each other in good faith in obtaining all permits, licenses, and authorizations that are necessary to accomplish the interconnection in compliance with Applicable Laws and Regulations. With respect to this paragraph, Transmission Provider or Transmission Owner shall provide permitting assistance to Interconnection Customer comparable to that provided to Transmission Provider's own, or an Affiliate's generation.
- 5.15 Early Construction of Base Case Facilities. Interconnection Customer may request Transmission Provider to construct, and Transmission Provider shall construct, using Reasonable Efforts to accommodate Interconnection Customer's In-Service Date, all or any portion of any Network Upgrades required for Interconnection Customer to be interconnected to the Transmission System which are included in the Base Case of the Interconnection Facilities Study for Interconnection Customer, and which also are required to be constructed for another Interconnection Customer, but where such construction is not scheduled to be completed in time to achieve Interconnection Customer's In-Service Date.

5.16 Suspension. Interconnection Customer reserves the right, upon written notice to Transmission Provider, to suspend at any time all work by Transmission Provider associated with the construction and installation of Transmission Provider's Interconnection Facilities and/or Network Upgrades required under this LGIA with the condition that Transmission System shall be left in a safe and reliable condition in accordance with Good Utility Practice and Transmission Provider's safety and reliability criteria. In such event, Interconnection Customer shall be responsible for all reasonable and necessary costs which Transmission Provider (i) has incurred pursuant to this LGIA prior to the suspension and (ii) incurs in suspending such work, including any costs incurred to perform such work as may be necessary to ensure the safety of persons and property and the integrity of the Transmission System during such suspension and, if applicable, any costs incurred in connection with the cancellation or suspension of material, equipment and labor contracts which Transmission Provider cannot reasonably avoid; provided, however, that prior to canceling or suspending any such material, equipment or labor contract, Transmission Provider shall obtain Interconnection Customer's authorization to do so.

Transmission Provider shall invoice Interconnection Customer for such costs pursuant to Article 12 and shall use due diligence to minimize its costs. In the event Interconnection Customer suspends work by Transmission Provider required under this LGIA pursuant to this Article 5.16, and has not requested Transmission Provider to recommence the work required under this LGIA on or before the expiration of three (3) years following commencement of such suspension, this LGIA shall be deemed terminated. The three-year period shall begin on the date the suspension is requested, or the date of the written notice to Transmission Provider, if no effective date is specified.

5.17 Taxes.

5.17.1 Interconnection Customer Payments Not Taxable. The Parties intend that all payments or property transfers made by Interconnection Customer to Transmission Provider for the installation of Transmission Provider's Interconnection Facilities and the Network Upgrades shall be non-taxable, either as

contributions to capital, or as an advance, in accordance with the Internal Revenue Code and any applicable state income tax laws and shall not be taxable as contributions in aid of construction or otherwise under the Internal Revenue Code and any applicable state income tax laws.

- 5.17.2 Representations and Covenants. In accordance with IRS Notice 2001-82 and IRS Notice 88-129, Interconnection Customer represents and covenants that (i) ownership of the electricity generated at the Large Generating Facility will pass to another party prior to the transmission of the electricity on the Transmission System, (ii) for income tax purposes, the amount of any payments and the cost of any property transferred to Transmission Provider for Transmission Provider's Interconnection Facilities will be capitalized by Interconnection Customer as an intangible asset and recovered using the straight-line method over a useful life of twenty (20) years, and (iii) any portion of Transmission Provider's Interconnection Facilities that is a "dual-use intertie," within the meaning of IRS Notice 88-129, is reasonably expected to carry only a de minimis amount of electricity in the direction of the Large Generating Facility. For this purpose, "de minimis amount" means no more than 5 percent of the total power flows in both directions, calculated in accordance with the "5 percent test" set forth in IRS Notice 88-129. This is not intended to be an exclusive list of the relevant conditions that must be met to conform to IRS requirements for non-taxable treatment.

At Transmission Provider's request, Interconnection Customer shall provide Transmission Provider with a report from an independent engineer confirming its representation in clause (iii), above. Transmission Provider represents and covenants that the cost of Transmission Provider's Interconnection Facilities paid for by Interconnection Customer will have no net effect on the base upon which rates are determined.

- 5.17.3 Indemnification for the Cost Consequences of Current Tax Liability Imposed Upon Transmission Provider. Notwithstanding Article

5.17.1, Interconnection Customer shall protect, indemnify and hold harmless Transmission Provider from the cost consequences of any current tax liability imposed against Transmission Provider as the result of payments or property transfers made by Interconnection Customer to Transmission Provider under this LGIA for Interconnection Facilities, as well as any interest and penalties, other than interest and penalties attributable to any delay caused by Transmission Provider.

Transmission Provider shall not include a gross-up for the cost consequences of any current tax liability in the amounts it charges Interconnection Customer under this LGIA unless (i) Transmission Provider has determined, in good faith, that the payments or property transfers made by Interconnection Customer to Transmission Provider should be reported as income subject to taxation or (ii) any Governmental Authority directs Transmission Provider to report payments or property as income subject to taxation; provided, however, that Transmission Provider may require Interconnection Customer to provide security for Interconnection Facilities, in a form reasonably acceptable to Transmission Provider (such as a parental guarantee or a letter of credit), in an amount equal to the cost consequences of any current tax liability under this Article 5.17. Interconnection Customer shall reimburse Transmission Provider for such costs on a fully grossed-up basis, in accordance with Article 5.17.4, within thirty (30) Calendar Days of receiving written notification from Transmission Provider of the amount due, including detail about how the amount was calculated.

The indemnification obligation shall terminate at the earlier of (1) the expiration of the ten year testing period and the applicable statute of limitation, as it may be extended by Transmission Provider upon request of the IRS, to keep these years open for audit or adjustment, or (2) the occurrence of a subsequent taxable event and the payment of any related indemnification obligations as contemplated by this Article 5.17.

5.17.4 Tax Gross-Up Amount. Interconnection Customer's liability for the cost consequences of any current tax liability under this Article 5.17 shall be calculated on a fully grossed-up basis. Except as may otherwise be agreed to by the parties, this means that Interconnection Customer will pay Transmission Provider, in addition to the amount paid for the Interconnection Facilities and Network Upgrades, an amount equal to (1) the current taxes imposed on Transmission Provider ("Current Taxes") on the excess of (a) the gross income realized by Transmission Provider as a result of payments or property transfers made by Interconnection Customer to Transmission Provider under this LGIA (without regard to any payments under this Article 5.17) (the "Gross Income Amount") over (b) the present value of future tax deductions for depreciation that will be available as a result of such payments or property transfers (the "Present Value Depreciation Amount"), plus (2) an additional amount sufficient to permit Transmission Provider to receive and retain, after the payment of all Current Taxes, an amount equal to the net amount described in clause (1).

For this purpose, (i) Current Taxes shall be computed based on Transmission Provider's composite federal and state tax rates at the time the payments or property transfers are received and Transmission Provider will be treated as being subject to tax at the highest marginal rates in effect at that time (the "Current Tax Rate"), and (ii) the Present Value Depreciation Amount shall be computed by discounting Transmission Provider's anticipated tax depreciation deductions as a result of such payments or property transfers by Transmission Provider's current weighted average cost of capital. Thus, the formula for calculating Interconnection Customer's liability to Transmission Owner pursuant to this Article 5.17.4 can be expressed as follows: $(\text{Current Tax Rate} \times (\text{Gross Income Amount} - \text{Present Value of Tax Depreciation})) / (1 - \text{Current Tax Rate})$. Interconnection Customer's estimated tax liability in the event taxes are imposed shall be stated in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades.

5.17.5 Private Letter Ruling or Change or Clarification of Law. At Interconnection Customer's request and expense, Transmission Provider shall file with the IRS a request for a private letter ruling as to whether any property transferred or sums paid, or to be paid, by Interconnection Customer to Transmission Provider under this LGIA are subject to federal income taxation. Interconnection Customer will prepare the initial draft of the request for a private letter ruling, and will certify under penalties of perjury that all facts represented in such request are true and accurate to the best of Interconnection Customer's knowledge. Transmission Provider and Interconnection Customer shall cooperate in good faith with respect to the submission of such request.

Transmission Provider shall keep Interconnection Customer fully informed of the status of such request for a private letter ruling and shall execute either a privacy act waiver or a limited power of attorney, in a form acceptable to the IRS, that authorizes Interconnection Customer to participate in all discussions with the IRS regarding such request for a private letter ruling. Transmission Provider shall allow Interconnection Customer to attend all meetings with IRS officials about the request and shall permit Interconnection Customer to prepare the initial drafts of any follow-up letters in connection with the request.

5.17.6 Subsequent Taxable Events. If, within 10 years from the date on which the relevant Transmission Provider's Interconnection Facilities are placed in service, (i) Interconnection Customer Breaches the covenants contained in Article 5.17.2, (ii) a "disqualification event" occurs within the meaning of IRS Notice 88-129, or (iii) this LGIA terminates and Transmission Provider retains ownership of the Interconnection Facilities and Network Upgrades, Interconnection Customer shall pay a tax gross-up for the cost consequences of any current tax liability imposed on Transmission Provider, calculated using the methodology described in Article 5.17.4 and in accordance with IRS Notice 90-60.

5.17.7 Contests. In the event any Governmental Authority determines that Transmission Provider's receipt of payments or property constitutes income that is subject to taxation, Transmission Provider shall notify Interconnection Customer, in writing, within thirty (30) Calendar Days of receiving notification of such determination by a Governmental Authority. Upon the timely written request by Interconnection Customer and at Interconnection Customer's sole expense, Transmission Provider may appeal, protest, seek abatement of, or otherwise oppose such determination. Upon Interconnection Customer's written request and sole expense, Transmission Provider may file a claim for refund with respect to any taxes paid under this Article 5.17, whether or not it has received such a determination. Transmission Provider reserves the right to make all decisions with regard to the prosecution of such appeal, protest, abatement or other contest, including the selection of counsel and compromise or settlement of the claim, but Transmission Provider shall keep Interconnection Customer informed, shall consider in good faith suggestions from Interconnection Customer about the conduct of the contest, and shall reasonably permit Interconnection Customer or an Interconnection Customer representative to attend contest proceedings.

Interconnection Customer shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission Provider's documented reasonable costs of prosecuting such appeal, protest, abatement or other contest. At any time during the contest, Transmission Provider may agree to a settlement either with Interconnection Customer's consent or after obtaining written advice from nationally-recognized tax counsel, selected by Transmission Provider, but reasonably acceptable to Interconnection Customer, that the proposed settlement represents a reasonable settlement given the hazards of litigation. Interconnection Customer's obligation shall be based on the amount of the settlement agreed to by Interconnection Customer, or if a higher amount, so much of the settlement that is supported by the written advice from nationally-recognized tax counsel selected under the terms of the preceding

sentence. The settlement amount shall be calculated on a fully grossed-up basis to cover any related cost consequences of the current tax liability. Any settlement without Interconnection Customer's consent or such written advice will relieve Interconnection Customer from any obligation to indemnify Transmission Provider for the tax at issue in the contest.

5.17.8 Refund. In the event that (a) a private letter ruling is issued to Transmission Provider which holds that any amount paid or the value of any property transferred by Interconnection Customer to Transmission Provider under the terms of this LGIA is not subject to federal income taxation, (b) any legislative change or administrative announcement, notice, ruling or other determination makes it reasonably clear to Transmission Provider in good faith that any amount paid or the value of any property transferred by Interconnection Customer to Transmission Provider under the terms of this LGIA is not taxable to Transmission Provider, (c) any abatement, appeal, protest, or other contest results in a determination that any payments or transfers made by Interconnection Customer to Transmission Provider are not subject to federal income tax, or (d) if Transmission Provider receives a refund from any taxing authority for any overpayment of tax attributable to any payment or property transfer made by Interconnection Customer to Transmission Provider pursuant to this LGIA, Transmission Provider shall promptly refund to Interconnection Customer the following:

(i) any payment made by Interconnection Customer under this Article 5.17 for taxes that is attributable to the amount determined to be non-taxable, together with interest thereon,

(ii) interest on any amounts paid by Interconnection Customer to Transmission Provider for such taxes which Transmission Provider did not submit to the taxing authority, calculated in accordance with the methodology set forth in FERC's regulations at 18 CFR §35.19a(a)(2)(iii) from the date

payment was made by Interconnection Customer to the date Transmission Provider refunds such payment to Interconnection Customer, and

(iii) with respect to any such taxes paid by Transmission Provider, any refund or credit Transmission Provider receives or to which it may be entitled from any Governmental Authority, interest (or that portion thereof attributable to the payment described in clause (i), above) owed to Transmission Provider for such overpayment of taxes (including any reduction in interest otherwise payable by Transmission Provider to any Governmental Authority resulting from an offset or credit); provided, however, that Transmission Provider will remit such amount promptly to Interconnection Customer only after and to the extent that Transmission Provider has received a tax refund, credit or offset from any Governmental Authority for any applicable overpayment of income tax related to Transmission Provider's Interconnection Facilities.

The intent of this provision is to leave the Parties, to the extent practicable, in the event that no taxes are due with respect to any payment for Interconnection Facilities and Network Upgrades hereunder, in the same position they would have been in had no such tax payments been made.

5.17.9 Taxes Other Than Income Taxes. Upon the timely request by Interconnection Customer, and at Interconnection Customer's sole expense, Transmission Provider may appeal, protest, seek abatement of, or otherwise contest any tax (other than federal or state income tax) asserted or assessed against Transmission Provider for which Interconnection Customer may be required to reimburse Transmission Provider under the terms of this LGIA. Interconnection Customer shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission

Provider's documented reasonable costs of prosecuting such appeal, protest, abatement, or other contest. Interconnection Customer and Transmission Provider shall cooperate in good faith with respect to any such contest. Unless the payment of such taxes is a prerequisite to an appeal or abatement or cannot be deferred, no amount shall be payable by Interconnection Customer to Transmission Provider for such taxes until they are assessed by a final, non-appealable order by any court or agency of competent jurisdiction. In the event that a tax payment is withheld and ultimately due and payable after appeal, Interconnection Customer will be responsible for all taxes, interest and penalties, other than penalties attributable to any delay caused by Transmission Provider.

5.17.10 Transmission Owners Who Are Not Transmission Providers. If Transmission Provider is not the same entity as the Transmission Owner, then (i) all references in this Article 5.17 to Transmission Provider shall be deemed also to refer to and to include the Transmission Owner, as appropriate, and (ii) this LGIA shall not become effective until such Transmission Owner shall have agreed in writing to assume all of the duties and obligations of Transmission Provider under this Article 5.17 of this LGIA.

5.18 Tax Status. Each Party shall cooperate with the other to maintain the other Party's tax status. Nothing in this LGIA is intended to adversely affect any Transmission Provider's tax exempt status with respect to the issuance of bonds including, but not limited to, Local Furnishing Bonds.

5.19 Modification.

5.19.1 General. Either Party may undertake modifications to its facilities. If a Party plans to undertake a modification that reasonably may be expected to affect the other Party's facilities, that Party shall provide to the other Party sufficient information regarding such modification so that the other Party may evaluate the potential impact of such

modification prior to commencement of the work. Such information shall be deemed to be confidential hereunder and shall include information concerning the timing of such modifications and whether such modifications are expected to interrupt the flow of electricity from the Large Generating Facility. The Party desiring to perform such work shall provide the relevant drawings, plans, and specifications to the other Party at least ninety (90) Calendar Days in advance of the commencement of the work or such shorter period upon which the Parties may agree, which agreement shall not unreasonably be withheld, conditioned or delayed.

In the case of Large Generating Facility modifications that do not require Interconnection Customer to submit an Interconnection Request, Transmission Provider shall provide, within thirty (30) Calendar Days (or such other time as the Parties may agree), an estimate of any additional modifications to the Transmission System, Transmission Provider's Interconnection Facilities or Network Upgrades necessitated by such Interconnection Customer modification and a good faith estimate of the costs thereof.

- 5.19.2 Standards.** Any additions, modifications, or replacements made to a Party's facilities shall be designed, constructed and operated in accordance with this LGIA and Good Utility Practice.
- 5.19.3 Modification Costs.** Interconnection Customer shall not be directly assigned for the costs of any additions, modifications, or replacements that Transmission Provider makes to Transmission Provider's Interconnection Facilities or the Transmission System to facilitate the interconnection of a third party to Transmission Provider's Interconnection Facilities or the Transmission System, or to provide transmission service to a third party under Transmission Provider's Tariff. Interconnection Customer shall be responsible for the costs of any additions, modifications, or replacements to Interconnection Customer's Interconnection Facilities that may be necessary to maintain or upgrade such Interconnection Customer's

Interconnection Facilities consistent with Applicable Laws and Regulations, Applicable Reliability Standards or Good Utility Practice.

Article 6. Testing and Inspection

- 6.1 Pre-Commercial Operation Date Testing and Modifications.** Prior to the Commercial Operation Date, Transmission Provider shall test Transmission Provider's Interconnection Facilities and Network Upgrades and Interconnection Customer shall test the Large Generating Facility and Interconnection Customer's Interconnection Facilities to ensure their safe and reliable operation. Similar testing may be required after initial operation. Each Party shall make any modifications to its facilities that are found to be necessary as a result of such testing. Interconnection Customer shall bear the cost of all such testing and modifications. Interconnection Customer shall generate test energy at the Large Generating Facility only if it has arranged for the delivery of such test energy.
- 6.2 Post-Commercial Operation Date Testing and Modifications.** Each Party shall at its own expense perform routine inspection and testing of its facilities and equipment in accordance with Good Utility Practice as may be necessary to ensure the continued interconnection of the Large Generating Facility with the Transmission System in a safe and reliable manner. Each Party shall have the right, upon advance written notice, to require reasonable additional testing of the other Party's facilities, at the requesting Party's expense, as may be in accordance with Good Utility Practice.
- 6.3 Right to Observe Testing.** Each Party shall notify the other Party in advance of its performance of tests of its Interconnection Facilities. The other Party has the right, at its own expense, to observe such testing.
- 6.4 Right to Inspect.** Each Party shall have the right, but shall have no obligation to:
- (i) observe the other Party's tests and/or inspection of any of its System Protection Facilities and other protective equipment, including Power System Stabilizers;
 - (ii) review the settings of the other Party's System Protection Facilities and other

protective equipment; and (iii) review the other Party's maintenance records relative to the Interconnection Facilities, the System Protection Facilities and other protective equipment. A Party may exercise these rights from time to time as it deems necessary upon reasonable notice to the other Party. The exercise or non-exercise by a Party of any such rights shall not be construed as an endorsement or confirmation of any element or condition of the Interconnection Facilities or the System Protection Facilities or other protective equipment or the operation thereof, or as a warranty as to the fitness, safety, desirability, or reliability of same. Any information that a Party obtains through the exercise of any of its rights under this Article 6.4 shall be deemed to be Confidential Information and treated pursuant to Article 22 of this LGIA.

Article 7. Metering

- 7.1 General. Each Party shall comply with the Electric Reliability Organization requirements. Unless otherwise agreed by the Parties, Transmission Provider shall install Metering Equipment at the Point of Interconnection prior to any operation of the Large Generating Facility and shall own, operate, test and maintain such Metering Equipment. Power flows to and from the Large Generating Facility shall be measured at or, at Transmission Provider's option, compensated to, the Point of Interconnection. Transmission Provider shall provide metering quantities, in analog and/or digital form, to Interconnection Customer upon request. Interconnection Customer shall bear all reasonable documented costs associated with the purchase, installation, operation, testing and maintenance of the Metering Equipment.
- 7.2 Check Meters. Interconnection Customer, at its option and expense, may install and operate, on its premises and on its side of the Point of Interconnection, one or more check meters to check Transmission Provider's meters. Such check meters shall be for check purposes only and shall not be used for the measurement of power flows for purposes of this LGIA, except as provided in Article 7.4 below. The check meters shall be subject at all reasonable times to inspection and examination by Transmission Provider or its designee. The installation, operation

and maintenance thereof shall be performed entirely by Interconnection Customer in accordance with Good Utility Practice.

- 7.3 Standards. Transmission Provider shall install, calibrate, and test revenue quality Metering Equipment in accordance with applicable ANSI standards.
- 7.4 Testing of Metering Equipment. Transmission Provider shall inspect and test all Transmission Provider-owned Metering Equipment upon installation and at least once every two (2) years thereafter. If requested to do so by Interconnection Customer, Transmission Provider shall, at Interconnection Customer's expense, inspect or test Metering Equipment more frequently than every two (2) years. Transmission Provider shall give reasonable notice of the time when any inspection or test shall take place, and Interconnection Customer may have representatives present at the test or inspection. If at any time Metering Equipment is found to be inaccurate or defective, it shall be adjusted, repaired or replaced at Interconnection Customer's expense, in order to provide accurate metering, unless the inaccuracy or defect is due to Transmission Provider's failure to maintain, then Transmission Provider shall pay. If Metering Equipment fails to register, or if the measurement made by Metering Equipment during a test varies by more than two percent from the measurement made by the standard meter used in the test, Transmission Provider shall adjust the measurements by correcting all measurements for the period during which Metering Equipment was in error by using Interconnection Customer's check meters, if installed. If no such check meters are installed or if the period cannot be reasonably ascertained, the adjustment shall be for the period immediately preceding the test of the Metering Equipment equal to one-half the time from the date of the last previous test of the Metering Equipment.
- 7.5 Metering Data. At Interconnection Customer's expense, the metered data shall be telemetered to one or more locations designated by Transmission Provider and one or more locations designated by Interconnection Customer. Such telemetered data shall be used, under normal operating conditions, as the official measurement of the amount of energy delivered from the Large Generating Facility to the Point of Interconnection.

Article 8. Communications

8.1 Interconnection Customer Obligations. Interconnection Customer shall maintain satisfactory operating communications with Transmission Provider's Transmission System dispatcher or representative designated by Transmission Provider. Interconnection Customer shall provide standard voice line, dedicated voice line and facsimile communications at its Large Generating Facility control room or central dispatch facility through use of either the public telephone system, or a voice communications system that does not rely on the public telephone system. Interconnection Customer shall also provide the dedicated data circuit(s) necessary to provide Interconnection Customer data to Transmission Provider as set forth in Appendix D, Security Arrangements Details. The data circuit(s) shall extend from the Large Generating Facility to the location(s) specified by Transmission Provider. Any required maintenance of such communications equipment shall be performed by Interconnection Customer. Operational communications shall be activated and maintained under, but not be limited to, the following events: system paralleling or separation, scheduled and unscheduled shutdowns, equipment clearances, and hourly and daily load data.

8.2 Remote Terminal Unit. Prior to the Initial Synchronization Date of the Large Generating Facility, a Remote Terminal Unit, or equivalent data collection and transfer equipment acceptable to the Parties, shall be installed by Interconnection Customer, or by Transmission Provider at Interconnection Customer's expense, to gather accumulated and instantaneous data to be telemetered to the location(s) designated by Transmission Provider through use of a dedicated point-to-point data circuit(s) as indicated in Article 8.1. The communication protocol for the data circuit(s) shall be specified by Transmission Provider. Instantaneous bi-directional analog real power and reactive power flow information must be telemetered directly to the location(s) specified by Transmission Provider.

Each Party will promptly advise the other Party if it detects or otherwise learns of any metering, telemetry or communications equipment errors or malfunctions that require the attention and/or correction by the other Party. The Party owning such equipment shall correct such error or malfunction as soon as reasonably feasible.

- 8.3 No Annexation. Any and all equipment placed on the premises of a Party shall be and remain the property of the Party providing such equipment regardless of the mode and manner of annexation or attachment to real property, unless otherwise mutually agreed by the Parties.
- 8.4 Provision of Data from a Variable Energy Resource. Interconnection Customer whose Generating Facility contains at least one Variable Energy Resource shall provide meteorological and forced outage data to Transmission Provider to the extent necessary for Transmission Provider's development and deployment of power production forecasts for that class of Variable Energy Resources. Interconnection Customer with a Variable Energy Resource having wind as the energy source, at a minimum, will be required to provide Transmission Provider with site-specific meteorological data including: temperature, wind speed, wind direction, and atmospheric pressure. Interconnection Customer with a Variable Energy Resource having solar as the energy source, at a minimum, will be required to provide Transmission Provider with site-specific meteorological data including: temperature, atmospheric pressure, and irradiance. Transmission Provider and Interconnection Customer whose Generating Facility contains a Variable Energy Resource shall mutually agree to any additional meteorological data that are required for the development and deployment of a power production forecast. Interconnection Customer whose Generating Facility contains a Variable Energy Resource also shall submit data to Transmission Provider regarding all forced outages to the extent necessary for Transmission Provider's development and deployment of power production forecasts for that class of Variable Energy Resources. The exact specifications of the meteorological and forced outage data to be provided by Interconnection Customer to Transmission Provider, including the frequency and timing of data submittals, shall be made taking into account the size and configuration of the Variable Energy Resource, its characteristics, location, and its importance in maintaining generation resource adequacy and transmission system reliability in its area. All requirements for meteorological and forced outage data must be commensurate with the power production forecasting employed by Transmission Provider. Such requirements for meteorological and forced outage data are set forth in Appendix C, Interconnection Details, of this LGIA, as they may change from time to time.

Article 9. Operations

- 9.1 General. Each Party shall comply with the Electric Reliability Organization requirements. Each Party shall provide to the other Party all information that may reasonably be required by the other Party to comply with Applicable Laws and Regulations and Applicable Reliability Standards.
- 9.2 **Balancing Authority** Area Notification. At least three months before Initial Synchronization Date, Interconnection Customer shall notify Transmission Provider in writing of the Balancing Authority Area in which the Large Generating Facility will be located. If Interconnection Customer elects to locate the Large Generating Facility in a Balancing Authority Area other than the Balancing Authority Area in which the Large Generating Facility is physically located, and if permitted to do so by the relevant transmission tariffs, all necessary arrangements, including but not limited to those set forth in Article 7 and Article 8 of this LGIA, and remote Balancing Authority Area generator interchange agreements, if applicable, and the appropriate measures under such agreements, shall be executed and implemented prior to the placement of the Large Generating Facility in the other Balancing Authority Area.
- 9.3 Transmission Provider Obligations. Transmission Provider shall cause the Transmission System and Transmission Provider's Interconnection Facilities to be operated, maintained and controlled in a safe and reliable manner and in accordance with this LGIA. Transmission Provider may provide operating instructions to Interconnection Customer consistent with this LGIA and Transmission Provider's operating protocols and procedures as they may change from time to time. Transmission Provider will consider changes to its operating protocols and procedures proposed by Interconnection Customer.
- 9.4 Interconnection Customer Obligations. Interconnection Customer shall at its own expense operate, maintain and control the Large Generating Facility and Interconnection Customer's Interconnection Facilities in a safe and reliable manner and in accordance with this LGIA. Interconnection Customer shall operate the Large Generating Facility and Interconnection Customer's Interconnection Facilities in accordance with all applicable requirements of the

Balancing Authority Area of which it is part, as such requirements are set forth in Appendix C, Interconnection Details, of this LGIA. Appendix C, Interconnection Details, will be modified to reflect changes to the requirements as they may change from time to time. Either Party may request that the other Party provide copies of the requirements set forth in Appendix C, Interconnection Details, of this LGIA.

9.5 Start-Up and Synchronization. Consistent with the Parties' mutually acceptable procedures, Interconnection Customer is responsible for the proper synchronization of the Large Generating Facility to Transmission Provider's Transmission System.

9.6 Reactive Power and Primary Frequency Response.

9.6.1 Power Factor Design Criteria.

9.6.1.1 Synchronous Generation. Interconnection Customer shall design the Large Generating Facility to maintain a composite power delivery at continuous rated power output at the Point of Interconnection at a power factor within the range of 0.95 leading to 0.95 lagging, unless Transmission Provider has established different requirements that apply to all synchronous generators in the Balancing Authority Area on a comparable basis.

9.6.1.2 Non-Synchronous Generation. Interconnection Customer shall design the Large Generating Facility to maintain a composite power delivery at continuous rated power output at the high-side of the generator substation at a power factor within the range of 0.95 leading to 0.95 lagging, unless Transmission Provider has established a different power factor range that applies to all non-synchronous generators in the Balancing Authority Area on a comparable basis. This

power factor range standard shall be dynamic and can be met using, for example, power electronics designed to supply this level of reactive capability (taking into account any limitations due to voltage level, real power output, etc.) or fixed and switched capacitors, or a combination of the two. This requirement shall only apply to newly interconnecting non-synchronous generators that have not yet executed a Facilities Study Agreement as of the effective date of the Final Rule establishing this requirement (Order No. 827).

9.6.2 Voltage Schedules. Once Interconnection Customer has synchronized the Large Generating Facility with the Transmission System, Transmission Provider shall require Interconnection Customer to operate the Large Generating Facility to produce or absorb reactive power within the design limitations of the Large Generating Facility set forth in Article 9.6.1 (Power Factor Design Criteria). Transmission Provider's voltage schedules shall treat all sources of reactive power in the Balancing Authority Area in an equitable and not unduly discriminatory manner. Transmission Provider shall exercise Reasonable Efforts to provide Interconnection Customer with such schedules at least one (1) day in advance, and may make changes to such schedules as necessary to maintain the reliability of the Transmission System. Interconnection Customer shall operate the Large Generating Facility to maintain the specified output voltage or power factor at the Point of Interconnection within the design limitations of the Large Generating Facility set forth in Article 9.6.1 (Power Factor Design Criteria). If Interconnection Customer is unable to maintain the specified voltage or power factor, it shall promptly notify the System Operator.

9.6.2.1 Voltage Regulators. Whenever the Large Generating Facility is operated in parallel with the Transmission System and voltage regulators are capable of operation, Interconnection Customer shall operate the Large Generating Facility with its voltage regulators in automatic operation. If the Large Generating Facility's voltage regulators are not capable of such automatic operation, Interconnection Customer shall immediately notify Transmission Provider's system operator,

or its designated representative, and ensure that such Large Generating Facility's reactive power production or absorption (measured in MVARs) are within the design capability of the Large Generating Facility's generating unit(s) and steady state stability limits. Interconnection Customer shall not cause its Large Generating Facility to disconnect automatically or instantaneously from the Transmission System or trip any generating unit comprising the Large Generating Facility for an under or over frequency condition unless the abnormal frequency condition persists for a time period beyond the limits set forth in ANSI/IEEE Standard C37.106, or such other standard as applied to other generators in the Balancing Authority Area on a comparable basis.

9.6.3 Payment for Reactive Power. Transmission Provider is required to pay Interconnection Customer for reactive power that Interconnection Customer provides or absorbs from the Large Generating Facility when Transmission Provider requests Interconnection Customer to operate its Large Generating Facility outside the range specified in Article 9.6.1, provided that if Transmission Provider pays its own or affiliated generators for reactive power service within the specified range, it must also pay Interconnection Customer. Payments shall be pursuant to Article 11.6 or such other agreement to which the Parties have otherwise agreed.

9.6.4 Primary Frequency Response. Interconnection Customer shall ensure the primary frequency response capability of its Large Generating Facility by installing, maintaining, and operating a functioning governor or equivalent controls. The term "functioning governor or equivalent controls" as used herein shall mean the required hardware and/or software that provides frequency responsive real power control with the ability to sense changes in system frequency and autonomously adjust the Large Generating Facility's real power output in accordance with the droop and deadband parameters and in the direction needed to correct frequency deviations. Interconnection Customer is required to install a governor or equivalent controls with the capability of operating: (1) with a maximum 5 percent droop and ± 0.036 Hz deadband; or (2) in accordance with the relevant

droop, deadband, and timely and sustained response settings from an approved Electric Reliability Organization reliability standard providing for equivalent or more stringent parameters. The droop characteristic shall be: (1) based on the nameplate capacity of the Large Generating Facility, and shall be linear in the range of frequencies between 59 to 61 Hz that are outside of the deadband parameter; or (2) based on an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter. The deadband parameter shall be: the range of frequencies above and below nominal (60 Hz) in which the governor or equivalent controls is not expected to adjust the Large Generating Facility's real power output in response to frequency deviations. The deadband shall be implemented: (1) without a step to the droop curve, that is, once the frequency deviation exceeds the deadband parameter, the expected change in the Large Generating Facility's real power output in response to frequency deviations shall start from zero and then increase (for under-frequency deviations) or decrease (for over-frequency deviations) linearly in proportion to the magnitude of the frequency deviation; or (2) in accordance with an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter. Interconnection Customer shall notify Transmission Provider that the primary frequency response capability of the Large Generating Facility has been tested and confirmed during commissioning. Once Interconnection Customer has synchronized the Large Generating Facility with the Transmission system, Interconnection Customer shall operate the Large Generating Facility consistent with the provisions specified in articles 9.6.4.1 and 9.6.4.2 of this Agreement. The primary frequency response requirements contained herein shall apply to both synchronous and non-synchronous Large Generating Facilities.

9.6.4.1 Governor or Equivalent Controls. Whenever the Large Generating Facility is operated in parallel with the Transmission System, Interconnection Customer shall operate the Large Generating Facility with its governor or equivalent controls in service and responsive to frequency. Interconnection Customer shall: (1) in coordination with Transmission Provider and/or the relevant balancing authority, set the deadband parameter to: (1) a maximum of

± 0.036 Hz and set the droop parameter to a maximum of 5 percent; or (2) implement the relevant droop and deadband settings from an approved Electric Reliability Organization reliability standard that provides for equivalent or more stringent parameters. Interconnection Customer shall be required to provide the status and settings of the governor or equivalent controls to Transmission Provider and/or the relevant balancing authority upon request. If Interconnection Customer needs to operate the Large Generating Facility with its governor or equivalent controls not in service, Interconnection Customer shall immediately notify Transmission Provider and the relevant balancing authority, and provide both with the following information: (1) the operating status of the governor or equivalent controls (i.e., whether it is currently out of service or when it will be taken out of service); (2) the reasons for removing the governor or equivalent controls from service; and (3) a reasonable estimate of when the governor or equivalent controls will be returned to service. Interconnection Customer shall make Reasonable Efforts to return its governor or equivalent controls into service as soon as practicable. Interconnection Customer shall make Reasonable Efforts to keep outages of the Large Generating Facility's governor or equivalent controls to a minimum whenever the Large Generating Facility is operated in parallel with the Transmission System.

9.6.4.2 Timely and Sustained Response. Interconnection Customer shall ensure that the Large Generating Facility's real power response to sustained frequency deviations outside of the deadband setting is automatically provided and shall begin immediately after frequency deviates outside of the deadband, and to the extent the Large Generating Facility has operating capability in the direction needed to correct the frequency deviation. Interconnection Customer shall not block or otherwise inhibit the ability of the governor or equivalent controls to respond and shall ensure that the response is not inhibited, except under certain operational constraints

including, but not limited to, ambient temperature limitations, physical energy limitations, outages of mechanical equipment, or regulatory requirements. The Large Generating Facility shall sustain the real power response at least until system frequency returns to a value within the deadband setting of the governor or equivalent controls. A Commission-approved reliability standard with equivalent or more stringent requirements shall supersede the above requirements.

- 9.6.4.3 Exemptions. Large Generating Facilities that are regulated by the United States Nuclear Regulatory Commission shall be exempt from articles 9.6.4, 9.6.4.1, and 9.6.4.2 of this Agreement. Large Generating Facilities that are behind the meter generation that is sized-to-load (i.e., the thermal load and the generation are near-balanced in real-time operation and the generation is primarily controlled to maintain the unique thermal, chemical, or mechanical output necessary for the operating requirements of its host facility) shall be required to install primary frequency response capability in accordance with the droop and deadband capability requirements specified in article 9.6.4, but shall be otherwise exempt from the operating requirements in articles 9.6.4, 9.6.4.1, 9.6.4.2, and 9.6.4.4 of this Agreement.
- 9.6.4.4 Electric Storage Resources. Interconnection Customer interconnecting a Generating Facility that contains an electric storage resource shall establish an operating range in Appendix C of its LGIA that specifies a minimum state of charge and a maximum state of charge between which the electric storage resource will be required to provide primary frequency response consistent with the conditions set forth in articles 9.6.4, 9.6.4.1, 9.6.4.2 and 9.6.4.3 of this Agreement. Appendix C shall specify whether the operating range is static or dynamic, and shall consider (1) the expected magnitude of frequency deviations in the interconnection; (2) the expected

duration that system frequency will remain outside of the deadband parameter in the interconnection; (3) the expected incidence of frequency deviations outside of the deadband parameter in the interconnection; (4) the physical capabilities of the electric storage resource; (5) operational limitations of the electric storage resource due to manufacturer specifications; and (6) any other relevant factors agreed to by Transmission Provider and Interconnection Customer, and in consultation with the relevant transmission owner or balancing authority as appropriate. If the operating range is dynamic, then Appendix C must establish how frequently the operating range will be reevaluated and the factors that may be considered during its reevaluation.

Interconnection Customer's electric storage resource is required to provide timely and sustained primary frequency response consistent with article 9.6.4.2 of this Agreement when it is online and dispatched to inject electricity to the Transmission System and/or receive electricity from the Transmission System. This excludes circumstances when the electric storage resource is not dispatched to inject electricity to the Transmission System and/or dispatched to receive electricity from the Transmission System. If Interconnection

Customer's electric storage resource is charging at the time of a frequency deviation outside of its deadband parameter, it is to increase (for over-frequency deviations) or decrease (for under-frequency deviations) the rate at which it is charging in accordance with its droop parameter. Interconnection Customer's electric storage resource is not required to change from charging to discharging, or vice versa, unless the response necessitated by the droop and deadband settings requires it to do so and it is technically capable of making such a transition.

9.7 Outages and Interruptions.

9.7.1 Outages.

9.7.1.1 Outage Authority and Coordination. Each Party may in accordance with Good Utility Practice in coordination with the other Party remove from service any of its respective Interconnection Facilities or Network Upgrades that may impact the other Party's facilities as necessary to perform maintenance or testing or to install or replace equipment. Absent an Emergency Condition, the Party scheduling a removal of such facility(ies) from service will use Reasonable Efforts to schedule such removal on a date and time mutually acceptable to the Parties. In all circumstances, any Party planning to remove such facility(ies) from service shall use Reasonable Efforts to minimize the effect on the other Party of such removal.

9.7.1.2 Outage Schedules. Transmission Provider shall post scheduled outages of its transmission facilities on the OASIS. Interconnection Customer shall submit its planned maintenance schedules for the Large Generating Facility to Transmission Provider for a minimum of a rolling twenty-four month period. Interconnection Customer shall update its planned maintenance schedules as necessary. Transmission Provider may request Interconnection Customer to reschedule its maintenance as necessary to maintain the reliability of the Transmission System; provided, however, adequacy of generation supply shall not be a criterion in determining Transmission System reliability. Transmission Provider shall compensate Interconnection Customer for any additional direct costs that Interconnection Customer incurs as a result of having to reschedule maintenance, including any additional overtime, breaking of maintenance contracts or other costs above and beyond the cost Interconnection Customer would have incurred absent Transmission Provider's request to reschedule maintenance. Interconnection Customer will not

be eligible to receive compensation, if during the twelve (12) months prior to the date of the scheduled maintenance, Interconnection Customer had modified its schedule of maintenance activities.

9.7.1.3 **Outage Restoration.** If an outage on a Party's Interconnection Facilities or Network Upgrades adversely affects the other Party's operations or facilities, the Party that owns or controls the facility that is out of service shall use Reasonable Efforts to promptly restore such facility(ies) to a normal operating condition consistent with the nature of the outage. The Party that owns or controls the facility that is out of service shall provide the other Party, to the extent such information is known, information on the nature of the Emergency Condition, an estimated time of restoration, and any corrective actions required. Initial verbal notice shall be followed up as soon as practicable with written notice explaining the nature of the outage.

9.7.2 Interruption of Service. If required by Good Utility Practice to do so, Transmission Provider may require Interconnection Customer to interrupt or reduce deliveries of electricity if such delivery of electricity could adversely affect Transmission Provider's ability to perform such activities as are necessary to safely and reliably operate and maintain the Transmission System. The following provisions shall apply to any interruption or reduction permitted under this Article 9.7.2:

9.7.2.1 The interruption or reduction shall continue only for so long as reasonably necessary under Good Utility Practice;

9.7.2.2 Any such interruption or reduction shall be made on an equitable, non-discriminatory basis with respect to all generating facilities directly connected to the Transmission System;

9.7.2.3 When the interruption or reduction must be made under circumstances which do not allow for advance notice, Transmission Provider shall notify Interconnection Customer by telephone as soon as practicable of the reasons for the curtailment, interruption, or reduction, and, if known, its expected duration. Telephone notification shall be followed by written notification as soon as practicable;

9.7.2.4 Except during the existence of an Emergency Condition, when the interruption or reduction can be scheduled without advance notice, Transmission Provider shall notify Interconnection Customer in advance regarding the timing of such scheduling and further notify Interconnection Customer of the expected duration. Transmission Provider shall coordinate with Interconnection Customer using Good Utility Practice to schedule the interruption or reduction during periods of least impact to Interconnection Customer and Transmission Provider;

9.7.2.5 The Parties shall cooperate and coordinate with each other to the extent necessary in order to restore the Large Generating Facility, Interconnection Facilities, and the Transmission System to their normal operating state, consistent with system conditions and Good Utility Practice.

9.7.3 Ride Through Capability and Performance. The Transmission System is designed to automatically activate a load-shed program as required by the Electric Reliability Organization in the event of an under-frequency system disturbance. Interconnection Customer shall implement under-frequency and over-frequency relay set points for the Large Generating Facility as required by the Electric Reliability Organization to ensure frequency “ride through” capability of the Transmission System. Large Generating Facility response to frequency deviations of pre-determined magnitudes, both under-frequency and over-frequency deviations, shall be studied and

coordinated with Transmission Provider in accordance with Good Utility Practice. Interconnection Customer shall also implement under-voltage and over-voltage relay set points, or equivalent electronic controls, as required by the Electric Reliability Organization to ensure voltage “ride through” capability of the Transmission System. The term “ride through” as used herein shall mean the ability of a Generating Facility to stay connected to and synchronized with the Transmission System during system disturbances within a range of under-frequency, over-frequency, under-voltage, and over-voltage conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other Generating Facilities in the Balancing Authority Area on a comparable basis. For abnormal frequency conditions and voltage conditions within the “no trip zone” defined by Reliability Standard PRC-024-3 or successor mandatory ride through reliability standards, the non-synchronous Large Generating Facility must ensure that, within any physical limitations of the Large Generating Facility, its control and protection settings are configured or set to (1) continue active power production during disturbance and post disturbance periods at pre-disturbance levels, unless reactive power priority mode is enabled or unless providing primary frequency response or fast frequency response; (2) minimize reductions in active power and remain within dynamic voltage and current limits, if reactive power priority mode is enabled, unless providing primary frequency response or fast frequency response; (3) not artificially limit dynamic reactive power capability during disturbances; and (4) return to pre-disturbance active power levels without artificial ramp rate limits if active power is reduced, unless providing primary frequency response or fast frequency response.

9.7.4 System Protection and Other Control Requirements.

9.7.4.1 System Protection Facilities. Interconnection Customer shall, at its expense, install, operate and maintain System Protection Facilities as a part of the Large Generating Facility or Interconnection Customer’s Interconnection Facilities. Transmission Provider shall install at Interconnection Customer’s expense any System Protection Facilities that

may be required on Transmission Provider's Interconnection Facilities or the Transmission System as a result of the interconnection of the Large Generating Facility and Interconnection Customer's Interconnection Facilities.

- 9.7.4.2** Each Party's protection facilities shall be designed and coordinated with other systems in accordance with Good Utility Practice.
- 9.7.4.3** Each Party shall be responsible for protection of its facilities consistent with Good Utility Practice.
- 9.7.4.4** Each Party's protective relay design shall incorporate the necessary test switches to perform the tests required in Article 6. The required test switches will be placed such that they allow operation of lockout relays while preventing breaker failure schemes from operating and causing unnecessary breaker operations and/or the tripping of Interconnection Customer's units.
- 9.7.4.5** Each Party will test, operate and maintain System Protection Facilities in accordance with Good Utility Practice.
- 9.7.4.6** Prior to the In-Service Date, and again prior to the Commercial Operation Date, each Party or its agent shall perform a complete calibration test and functional trip test of the System Protection Facilities. At intervals suggested by Good Utility Practice and following any apparent malfunction of the System Protection Facilities, each Party shall perform both calibration and functional trip tests of its System Protection Facilities. These tests do not require the tripping of any in-service generation unit. These tests do, however,

require that all protective relays and lockout contacts be activated.

- 9.7.5 Requirements for Protection. In compliance with Good Utility Practice, Interconnection Customer shall provide, install, own, and maintain relays, circuit breakers and all other devices necessary to remove any fault contribution of the Large Generating Facility to any short circuit occurring on the Transmission System not otherwise isolated by Transmission Provider's equipment, such that the removal of the fault contribution shall be coordinated with the protective requirements of the Transmission System. Such protective equipment shall include, without limitation, a disconnecting device or switch with load-interrupting capability located between the Large Generating Facility and the Transmission System at a site selected upon mutual agreement (not to be unreasonably withheld, conditioned or delayed) of the Parties. Interconnection Customer shall be responsible for protection of the Large Generating Facility and Interconnection Customer's other equipment from such conditions as negative sequence currents, over- or under-frequency, sudden load rejection, over- or under-voltage, and generator loss-of-field. Interconnection Customer shall be solely responsible to disconnect the Large Generating Facility and Interconnection Customer's other equipment if conditions on the Transmission System could adversely affect the Large Generating Facility.
- 9.7.6 Power Quality. Neither Party's facilities shall cause excessive voltage flicker nor introduce excessive distortion to the sinusoidal voltage or current waves as defined by ANSI Standard C84.1-1989, in accordance with IEEE Standard 519, or any applicable superseding electric industry standard. In the event of a conflict between ANSI Standard C84.1-1989, or any applicable superseding electric industry standard, ANSI Standard C84.1-1989, or the applicable superseding electric industry standard, shall control.
- 9.8 Switching and Tagging Rules. Each Party shall provide the other Party a copy of its switching and tagging rules that are applicable to the other Party's activities.

Such switching and tagging rules shall be developed on a non-discriminatory basis. The Parties shall comply with applicable switching and tagging rules, as amended from time to time, in obtaining clearances for work or for switching operations on equipment.

9.9 Use of Interconnection Facilities by Third Parties.

9.9.1 Purpose of Interconnection Facilities. Except as may be required by Applicable Laws and Regulations, or as otherwise agreed to among the Parties, the Interconnection Facilities shall be constructed for the sole purpose of interconnecting the Large Generating Facility to the Transmission System and shall be used for no other purpose.

9.9.2 Third Party Users. If required by Applicable Laws and Regulations or if the Parties mutually agree, such agreement not to be unreasonably withheld, to allow one or more third parties to use Transmission Provider's Interconnection Facilities, or any part thereof, Interconnection Customer will be entitled to compensation for the capital expenses it incurred in connection with the Interconnection Facilities based upon the pro rata use of the Interconnection Facilities by Transmission Provider, all third party users, and Interconnection Customer, in accordance with Applicable Laws and Regulations or upon some other mutually-agreed upon methodology. In addition, cost responsibility for ongoing costs, including operation and maintenance costs associated with the Interconnection Facilities, will be allocated between Interconnection Customer and any third party users based upon the pro rata use of the Interconnection Facilities by Transmission Provider, all third party users, and Interconnection Customer, in accordance with Applicable Laws and Regulations or upon some other mutually agreed upon methodology. If the issue of such compensation or allocation cannot be resolved through such negotiations, it shall be submitted to FERC for resolution.

9.10 Disturbance Analysis Data Exchange. The Parties will cooperate with one another in the analysis of disturbances to either the Large Generating Facility or

Transmission Provider's Transmission System by gathering and providing access to any information relating to any disturbance, including information from oscillography, protective relay targets, breaker operations and sequence of events records, and any disturbance information required by Good Utility Practice.

Article 10. Maintenance

10.1 Transmission Provider Obligations. Transmission Provider shall maintain the Transmission System and Transmission Provider's Interconnection Facilities in a safe and reliable manner and in accordance with this LGIA.

10.2 Interconnection Customer Obligations. Interconnection Customer shall maintain the Large Generating Facility and Interconnection Customer's Interconnection Facilities in a safe and reliable manner and in accordance with this LGIA.

10.3 Coordination. The Parties shall confer regularly to coordinate the planning, scheduling and performance of preventive and corrective maintenance on the Large Generating Facility and the Interconnection Facilities.

10.4 Secondary Systems. Each Party shall cooperate with the other in the inspection, maintenance, and testing of control or power circuits that operate below 600 volts, AC or DC, including, but not limited to, any hardware, control or protective devices, cables, conductors, electric raceways, secondary equipment panels, transducers, batteries, chargers, and voltage and current transformers that directly affect the operation of a Party's facilities and equipment which may reasonably be expected to impact the other Party. Each Party shall provide advance notice to the other Party before undertaking any work on such circuits, especially on electrical circuits involving circuit breaker trip and close contacts, current transformers, or potential transformers.

- 10.5 **Operating and Maintenance Expenses.** Subject to the provisions herein addressing the use of facilities by others, and except for operations and maintenance expenses associated with modifications made for providing interconnection or transmission service to a third party and such third party pays for such expenses, Interconnection Customer shall be responsible for all reasonable expenses including overheads, associated with: (1) owning, operating, maintaining, repairing, and replacing Interconnection Customer's Interconnection Facilities; and (2) operation, maintenance, repair and replacement of Transmission Provider's Interconnection Facilities.

Article 11. Performance Obligation

- 11.1 **Interconnection Customer Interconnection Facilities.** Interconnection Customer shall design, procure, construct, install, own and/or control Interconnection Customer Interconnection Facilities described in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades, at its sole expense.
- 11.2 **Transmission Provider's Interconnection Facilities.** Transmission Provider or Transmission Owner shall design, procure, construct, install, own and/or control Transmission Provider's Interconnection Facilities described in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades, at the sole expense of Interconnection Customer.
- 11.3 **Network Upgrades and Distribution Upgrades.** Transmission Provider or Transmission Owner shall design, procure, construct, install, and own the Network Upgrades and Distribution Upgrades described in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades. Interconnection Customer shall be responsible for all costs related to Distribution Upgrades. Unless Transmission Provider or Transmission Owner elects to fund the capital for the Network Upgrades, they shall be solely funded by Interconnection Customer.
- 11.4 **Transmission Credits.**

11.4.1 Repayment of Amounts Advanced for Network Upgrades. Interconnection Customer shall be entitled to a cash repayment, equal to the total amount paid to Transmission Provider and Affected System Operator, if any, for the Network Upgrades, including any tax gross-up or other tax-related payments associated with Network Upgrades, and not refunded to Interconnection Customer pursuant to Article 5.17.8 or otherwise, to be paid to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, as payments are made under Transmission Provider's Tariff and Affected System's Tariff for transmission services with respect to the Large Generating Facility. Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 C.F.R. § 35.19a(a)(2)(iii) from the date of any payment for Network Upgrades through the date on which Interconnection Customer receives a repayment of such payment pursuant to this subparagraph. Interconnection Customer may assign such repayment rights to any person.

Notwithstanding the foregoing, Interconnection Customer, Transmission Provider, and Affected System Operator may adopt any alternative payment schedule that is mutually agreeable so long as Transmission Provider and Affected System Operator take one of the following actions no later than five years from the Commercial Operation Date: (1) return to Interconnection Customer any amounts advanced for Network Upgrades not previously repaid, or (2) declare in writing that Transmission Provider or Affected System Operator will continue to provide payments to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, or develop an alternative schedule that is mutually agreeable and provides for the return of all amounts advanced for Network Upgrades not previously repaid; however, full reimbursement shall not extend beyond twenty (20) years from the Commercial Operation Date.

If the Large Generating Facility fails to achieve commercial operation, but it or another Generating Facility is later constructed and makes use of the Network Upgrades, Transmission Provider and Affected System Operator shall at that time reimburse Interconnection Customer for the amounts advanced for the Network Upgrades. Before any such reimbursement can occur, Interconnection Customer, or the entity that ultimately constructs the Generating Facility, if different, is responsible for identifying the entity to which reimbursement must be made.

11.4.2 Special Provisions for Affected Systems. Unless Transmission Provider provides, under the LGIA, for the repayment of amounts advanced to Affected System Operator for Network Upgrades, Interconnection Customer and Affected System Operator shall enter into an agreement that provides for such repayment. The agreement shall specify the terms governing payments to be made by Interconnection Customer to the Affected System Operator as well as the repayment by the Affected System Operator.

11.4.3 Notwithstanding any other provision of this LGIA, nothing herein shall be construed as relinquishing or foreclosing any rights, including but not limited to firm transmission rights, capacity rights, transmission congestion rights, or transmission credits, that Interconnection Customer, shall be entitled to, now or in the future under any other agreement or tariff as a result of, or otherwise associated with, the transmission capacity, if any, created by the Network Upgrades, including the right to obtain cash reimbursements or transmission credits for transmission service that is not associated with the Large Generating Facility.

11.5 Provision of Security. At least thirty (30) Calendar Days prior to the commencement of the procurement, installation, or construction of a discrete portion of a Transmission Provider's Interconnection Facilities, Network Upgrades, or Distribution Upgrades, Interconnection Customer shall provide

Transmission Provider, at Interconnection Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to Transmission Provider and is consistent with the Uniform Commercial Code of the jurisdiction identified in Article 14.2.1. Such security for payment, as specified in Appendix B of this LGIA, shall be in an amount sufficient to cover the costs for constructing, procuring and installing the applicable portion of Transmission Provider's Interconnection Facilities, Network Upgrades, or Distribution Upgrades and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider for these purposes. Transmission Provider must use the LGIA Deposit required in Section 11.3 of the LGIP before requiring Interconnection Customer to submit security in addition to that LGIA Deposit. Transmission Provider must specify, in Appendix B of this LGIA, the dates for which Interconnection Customer must provide additional security for construction of each discrete portion of Transmission Provider's Interconnection Facilities, Network Upgrades, or Distribution Upgrades and Interconnection Customer must provide such additional security.

In addition:

- 11.5.1** The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider, and contain terms and conditions that guarantee payment of any amount that may be due from Interconnection Customer, up to an agreed-to maximum amount.
- 11.5.2** The letter of credit must be issued by a financial institution reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.
- 11.5.3** The surety bond must be issued by an insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.

11.6 Interconnection Customer Compensation. If Transmission Provider requests or directs Interconnection Customer to provide a service pursuant to Articles 9.6.3 (Payment for Reactive Power), or 13.5.1 of this LGIA, Transmission Provider shall compensate Interconnection Customer in accordance with Interconnection Customer's applicable rate schedule then in effect unless the provision of such service(s) is subject to an RTO or ISO FERC-approved rate schedule. Interconnection Customer shall serve Transmission Provider or RTO or ISO with any filing of a proposed rate schedule at the time of such filing with FERC. To the extent that no rate schedule is in effect at the time Interconnection Customer is required to provide or absorb any Reactive Power under this LGIA, Transmission Provider agrees to compensate Interconnection Customer in such amount as would have been due Interconnection Customer had the rate schedule been in effect at the time service commenced; provided, however, that such rate schedule must be filed at FERC or other appropriate Governmental Authority within sixty (60) Calendar Days of the commencement of service.

11.6.1 Interconnection Customer Compensation for Actions During Emergency Condition. Transmission Provider or RTO or ISO shall compensate Interconnection Customer for its provision of real and reactive power and other Emergency Condition services that Interconnection Customer provides to support the Transmission System during an Emergency Condition in accordance with Article 11.6.

Article 12. Invoice

12.1 General. Each Party shall submit to the other Party, on a monthly basis, invoices of amounts due for the preceding month. Each invoice shall state the month to which the invoice applies and fully describe the services and equipment provided. The Parties may discharge mutual debts and payment obligations due and owing to each other on the same date through netting, in which case all amounts a Party owes to the other Party under this LGIA, including interest payments or credits, shall be netted so that only the net amount remaining due shall be paid by the owing Party.

- 12.2 Final Invoice. Within six months after completion of the construction of Transmission Provider's Interconnection Facilities and the Network Upgrades, Transmission Provider shall provide an invoice of the final cost of the construction of Transmission Provider's Interconnection Facilities and the Network Upgrades and shall set forth such costs in sufficient detail to enable Interconnection Customer to compare the actual costs with the estimates and to ascertain deviations, if any, from the cost estimates. Transmission Provider shall refund to Interconnection Customer any amount by which the actual payment by Interconnection Customer for estimated costs exceeds the actual costs of construction within thirty (30) Calendar Days of the issuance of such final construction invoice.
- 12.3 Payment. Invoices shall be rendered to the paying Party at the address specified in Appendix F. The Party receiving the invoice shall pay the invoice within thirty (30) Calendar Days of receipt. All payments shall be made in immediately available funds payable to the other Party, or by wire transfer to a bank named and account designated by the invoicing Party. Payment of invoices by either Party will not constitute a waiver of any rights or claims either Party may have under this LGIA.
- 12.4 Disputes. In the event of a billing dispute between Transmission Provider and Interconnection Customer, Transmission Provider shall continue to provide Interconnection Service under this LGIA as long as Interconnection Customer: (i) continues to make all payments not in dispute; and (ii) pays to Transmission Provider or into an independent escrow account the portion of the invoice in dispute, pending resolution of such dispute. If Interconnection Customer fails to meet these two requirements for continuation of service, then Transmission Provider may provide notice to Interconnection Customer of a Default pursuant to Article 17. Within thirty (30) Calendar Days after the resolution of the dispute, the Party that owes money to the other Party shall pay the amount due with interest calculated in accord with the methodology set forth in FERC's regulations at 18 CFR § 35.19a(a)(2)(iii).

Article 13. Emergencies

13.1 Definition. “Emergency Condition” shall mean a condition or situation: (i) that in

the judgment of the Party making the claim is imminently likely to endanger life or property; or (ii) that, in the case of Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to the Transmission System, Transmission Provider’s Interconnection Facilities or the Transmission Systems of others to which the Transmission System is directly connected; or (iii) that, in the case of Interconnection Customer, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Large Generating Facility or Interconnection Customer’s Interconnection Facilities’ System restoration and black start shall be considered Emergency Conditions; provided, that Interconnection Customer is not obligated by this LGIA to possess black start capability.

13.2 Obligations. Each Party shall comply with the Emergency Condition procedures of the applicable ISO/RTO, the Electric Reliability Organization, Applicable Laws and Regulations, and any emergency procedures agreed to by the Joint Operating Committee.

13.3 Notice. Transmission Provider shall notify Interconnection Customer promptly when it becomes aware of an Emergency Condition that affects Transmission Provider’s Interconnection Facilities or the Transmission System that may reasonably be expected to affect Interconnection Customer’s operation of the Large Generating Facility or Interconnection Customer’s Interconnection Facilities. Interconnection Customer shall notify Transmission Provider promptly when it becomes aware of an Emergency Condition that affects the Large Generating Facility or Interconnection Customer’s Interconnection Facilities that may reasonably be expected to affect the Transmission System or Transmission Provider’s Interconnection Facilities. To the extent information is known, the notification shall describe the Emergency Condition, the extent of the damage or deficiency, the expected effect on the operation of Interconnection Customer’s or Transmission Provider’s facilities and operations, its anticipated duration and the corrective action taken and/or to be taken. The initial notice shall be followed as soon as practicable with written notice.

13.4 Immediate Action. Unless, in Interconnection Customer's reasonable judgment, immediate action is required, Interconnection Customer shall obtain the consent of Transmission Provider, such consent to not be unreasonably withheld, prior to performing any manual switching operations at the Large Generating Facility or Interconnection Customer's Interconnection Facilities in response to an Emergency Condition either declared by Transmission Provider or otherwise regarding the Transmission System.

13.5 Transmission Provider Authority.

13.5.1 General. Transmission Provider may take whatever actions or inactions with regard to the Transmission System or Transmission Provider's Interconnection Facilities it deems necessary during an Emergency Condition in order to (i) preserve public health and safety, (ii) preserve the reliability of the Transmission System or Transmission Provider's Interconnection Facilities, (iii) limit or prevent damage, and (iv) expedite restoration of service.

Transmission Provider shall use Reasonable Efforts to minimize the effect of such actions or inactions on the Large Generating Facility or Interconnection Customer's Interconnection Facilities.

Transmission Provider may, on the basis of technical considerations, require the Large Generating Facility to mitigate an Emergency Condition by taking actions necessary and limited in scope to remedy the Emergency Condition, including, but not limited to, directing Interconnection Customer to shut-down, start-up, increase or decrease the real or reactive power output of the Large Generating Facility; implementing a reduction or disconnection pursuant to Article 13.5.2; directing Interconnection Customer to assist with blackstart (if available) or restoration efforts; or altering the outage schedules of the Large Generating Facility and Interconnection Customer's Interconnection Facilities. Interconnection Customer shall comply with all of Transmission Provider's operating instructions concerning Large Generating Facility real power and

reactive power output within the manufacturer's design limitations of the Large Generating Facility's equipment that is in service and physically available for operation at the time, in compliance with Applicable Laws and Regulations.

13.5.2 Reduction and Disconnection. Transmission Provider may reduce Interconnection Service or disconnect the Large Generating Facility or Interconnection Customer's Interconnection Facilities, when such, reduction or disconnection is necessary under Good Utility Practice due to Emergency Conditions. These rights are separate and distinct from any right of curtailment of Transmission Provider pursuant to Transmission Provider's Tariff. When Transmission Provider can schedule the reduction or disconnection in advance, Transmission Provider shall notify Interconnection Customer of the reasons, timing and expected duration of the reduction or disconnection. Transmission Provider shall coordinate with Interconnection Customer using Good Utility Practice to schedule the reduction or disconnection during periods of least impact to Interconnection Customer and Transmission Provider. Any reduction or disconnection shall continue only for so long as reasonably necessary under Good Utility Practice. The Parties shall cooperate with each other to restore the Large Generating Facility, the Interconnection Facilities, and the Transmission System to their normal operating state as soon as practicable consistent with Good Utility Practice.

13.6 Interconnection Customer Authority. Consistent with Good Utility Practice and the LGIA and the LGIP, Interconnection Customer may take actions or inactions with regard to the Large Generating Facility or Interconnection Customer's Interconnection Facilities during an Emergency Condition in order to (i) preserve public health and safety, (ii) preserve the reliability of the Large Generating Facility or Interconnection Customer's Interconnection Facilities, (iii) limit or prevent damage, and (iv) expedite restoration of service. Interconnection Customer shall use Reasonable Efforts to minimize the effect of such actions or inactions on the Transmission System and Transmission Provider's

Interconnection Facilities. Transmission Provider shall use Reasonable Efforts to assist Interconnection Customer in such actions.

- 13.7 Limited Liability. Except as otherwise provided in Article 11.6.1 of this LGIA, neither Party shall be liable to the other for any action it takes in responding to an Emergency Condition so long as such action is made in good faith and is consistent with Good Utility Practice.

Article 14. Regulatory Requirements and Governing Law

- 14.1 Regulatory Requirements. Each Party's obligations under this LGIA shall be subject to its receipt of any required approval or certificate from one or more Governmental Authorities in the form and substance satisfactory to the applying Party, or the Party making any required filings with, or providing notice to, such Governmental Authorities, and the expiration of any time period associated therewith. Each Party shall in good faith seek and use its Reasonable Efforts to obtain such other approvals. Nothing in this LGIA shall require Interconnection Customer to take any action that could result in its inability to obtain, or its loss of, status or exemption under the Federal Power Act, the Public Utility Holding Company Act of 1935, as amended, or the Public Utility Regulatory Policies Act of 1978.

14.2 Governing Law.

- 14.2.1** The validity, interpretation and performance of this LGIA and each of its provisions shall be governed by the laws of the state where the Point of Interconnection is located, without regard to its conflicts of law principles.

- 14.2.2** This LGIA is subject to all Applicable Laws and Regulations.

14.2.3 Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, rules, or regulations of a Governmental Authority.

Article 15. Notices.

15.1 General. Unless otherwise provided in this LGIA, any notice, demand or request required or permitted to be given by either Party to the other and any instrument required or permitted to be tendered or delivered by either Party in writing to the other shall be effective when delivered and may be so given, tendered or delivered, by recognized national courier, or by depositing the same with the United States Postal Service with postage prepaid, for delivery by certified or registered mail, addressed to the Party, or personally delivered to the Party, at the address set out in Appendix F, Addresses for Delivery of Notices and Billings.

Either Party may change the notice information in this LGIA by giving five (5) Business Days written notice prior to the effective date of the change.

15.2 Billings and Payments. Billings and payments shall be sent to the addresses set out in Appendix F.

15.3 Alternative Forms of Notice. Any notice or request required or permitted to be given by a Party to the other and not required by this Agreement to be given in writing may be so given by telephone, facsimile or email to the telephone numbers and email addresses set out in Appendix F.

15.4 Operations and Maintenance Notice. Each Party shall notify the other Party in writing of the identity of the person(s) that it designates as the point(s) of contact with respect to the implementation of Articles 9 and 10.

Article 16. Force Majeure

16.1 Force Majeure.

16.1.1 Economic hardship is not considered a Force Majeure event.

16.1.2 Neither Party shall be considered to be in Default with respect to any obligation hereunder, (including obligations under Article 4), other than the obligation to pay money when due, if prevented from fulfilling such obligation by Force Majeure. A Party unable to fulfill any obligation hereunder (other than an obligation to pay money when due) by reason of Force Majeure shall give notice and the full particulars of such Force Majeure to the other Party in writing or by telephone as soon as reasonably possible after the occurrence of the cause relied upon. Telephone notices given pursuant to this article shall be confirmed in writing as soon as reasonably possible and shall specifically state full particulars of the Force Majeure, the time and date when the Force Majeure occurred and when the Force Majeure is reasonably expected to cease. The Party affected shall exercise due diligence to remove such disability with reasonable dispatch, but shall not be required to accede or agree to any provision not satisfactory to it in order to settle and terminate a strike or other labor disturbance.

Article 17. Default

17.1 Default

17.1.1 General. No Default shall exist where such failure to discharge an obligation (other than the payment of money) is the result of Force Majeure as defined in this LGIA or the result of an act of omission of the other Party. Upon a Breach, the non-breaching Party shall give written notice of such Breach to the breaching Party. Except as provided in Article 17.1.2, the breaching Party shall have thirty (30)

Calendar Days from receipt of the Default notice within which to cure such Breach; provided however, if such Breach is not capable of cure within thirty (30) Calendar Days, the breaching Party shall commence such cure within thirty (30) Calendar Days after notice and continuously and diligently complete such cure within ninety (90) Calendar Days from receipt of the Default notice; and, if cured within such time, the Breach specified in such notice shall cease to exist.

- 17.1.2 Right to Terminate. If a Breach is not cured as provided in this article, or if a Breach is not capable of being cured within the period provided for herein, the non-breaching Party shall have the right to declare a Default and terminate this LGIA by written notice at any time until cure occurs, and be relieved of any further obligation hereunder and, whether or not that Party terminates this LGIA, to recover from the breaching Party all amounts due hereunder, plus all other damages and remedies to which it is entitled at law or in equity. The provisions of this article will survive termination of this LGIA.

- 17.2 Violation of Operating Assumptions for Generating Facilities.** If Transmission Provider requires Interconnection Customer to memorialize the operating assumptions for the charging behavior of a Generating Facility that includes at least one electric storage resource in Appendix H of this LGIA, Transmission Provider may consider Interconnection Customer to be in Breach of the LGIA if Interconnection Customer fails to operate the Generating Facility in accordance with those operating assumptions for charging behavior. However, if Interconnection Customer operates contrary to the operating assumptions for charging behavior specified in Appendix H of this LGIA at the direction of Transmission Provider, Transmission Provider shall not consider Interconnection Customer in Breach of this LGIA.

Article 18. Indemnity, Consequential Damages and Insurance

18.1 Indemnity. The Parties shall at all times indemnify, defend, and hold the other Party harmless from, any and all damages, losses, claims, including claims and actions relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's action or inactions of its obligations under this LGIA on behalf of the Indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the indemnified Party.

18.1.1 Indemnified Person. If an Indemnified Person is entitled to indemnification under this Article 18 as a result of a claim by a third party, and the Indemnifying Party fails, after notice and reasonable opportunity to proceed under Article 18.1, to assume the defense of such claim, such Indemnified Person may at the expense of the Indemnifying Party contest, settle or consent to the entry of any judgment with respect to, or pay in full, such claim.

18.1.2 Indemnifying Party. If an Indemnifying Party is obligated to indemnify and hold any Indemnified Person harmless under this Article 18, the amount owing to the Indemnified Person shall be the amount of such Indemnified Person's actual Loss, net of any insurance or other recovery.

18.1.3 Indemnity Procedures. Promptly after receipt by an Indemnified Person of any claim or notice of the commencement of any action or administrative or legal proceeding or investigation as to which the indemnity provided for in Article 18.1 may apply, the Indemnified Person shall notify the Indemnifying Party of such fact. Any failure of or delay in such notification shall not affect a Party's indemnification obligation unless such failure or delay is materially prejudicial to the Indemnifying Party.

The Indemnifying Party shall have the right to assume the defense thereof with counsel designated by such Indemnifying Party and

reasonably satisfactory to the Indemnified Person. If the defendants in any such action include one or more Indemnified Persons and the Indemnifying Party and if the Indemnified Person reasonably concludes that there may be legal defenses available to it and/or other Indemnified Persons which are different from or additional to those available to the Indemnifying Party, the Indemnified Person shall have the right to select separate counsel to assert such legal defenses and to otherwise participate in the defense of such action on its own behalf. In such instances, the Indemnifying Party shall only be required to pay the fees and expenses of one additional attorney to represent an Indemnified Person or Indemnified Persons having such differing or additional legal defenses.

The Indemnified Person shall be entitled, at its expense, to participate in any such action, suit or proceeding, the defense of which has been assumed by the Indemnifying Party.

Notwithstanding the foregoing, the Indemnifying Party (i) shall not be entitled to assume and control the defense of any such action, suit or proceedings if and to the extent that, in the opinion of the Indemnified Person and its counsel, such action, suit or proceeding involves the potential imposition of criminal liability on the Indemnified Person, or there exists a conflict or adversity of interest between the Indemnified Person and the Indemnifying Party, in such event the Indemnifying Party shall pay the reasonable expenses of the Indemnified Person, and (ii) shall not settle or consent to the entry of any judgment in any action, suit or proceeding without the consent of the Indemnified Person, which shall not be reasonably withheld, conditioned or delayed.

- 18.2 Consequential Damages. Other than the Liquidated Damages heretofore described, in no event shall either Party be liable under any provision of this LGIA for any losses, damages, costs or expenses for any special, indirect, incidental, consequential, or punitive damages, including but not limited to loss of profit or revenue, loss of the use of equipment, cost of capital, cost of temporary equipment or services, whether based in whole or in part in contract, in tort, including negligence, strict liability, or any other theory of liability; provided, however, that

damages for which a Party may be liable to the other Party under another agreement will not be considered to be special, indirect, incidental, or consequential damages hereunder.

18.3 Insurance. Each party shall, at its own expense, maintain in force throughout the period of this LGIA, and until released by the other Party, the following minimum insurance coverages, with insurers authorized to do business in the state where the Point of Interconnection is located:

18.3.1 Employers' Liability and Workers' Compensation Insurance providing statutory benefits in accordance with the laws and regulations of the state in which the Point of Interconnection is located.

18.3.2 Commercial General Liability Insurance including premises and operations, personal injury, broad form property damage, broad form blanket contractual liability coverage (including coverage for the contractual indemnification) products and completed operations coverage, coverage for explosion, collapse and underground hazards, independent contractors coverage, coverage for pollution to the extent normally available and punitive damages to the extent normally available and a cross liability endorsement, with minimum limits of One Million Dollars (\$1,000,000) per occurrence/One Million Dollars (\$1,000,000) aggregate combined single limit for personal injury, bodily injury, including death and property damage.

18.3.3 Comprehensive Automobile Liability Insurance for coverage of owned and non-owned and hired vehicles, trailers or semi-trailers designed for travel on public roads, with a minimum, combined single limit of One Million Dollars (\$1,000,000) per occurrence for bodily injury, including death, and property damage.

- 18.3.4** Excess Public Liability Insurance over and above the Employers' Liability Commercial General Liability and Comprehensive Automobile Liability Insurance coverage, with a minimum combined single limit of Twenty Million Dollars (\$20,000,000) per occurrence/Twenty Million Dollars (\$20,000,000) aggregate.
- 18.3.5** The Commercial General Liability Insurance, Comprehensive Automobile Insurance and Excess Public Liability Insurance policies shall name the other Party, its parent, associated and Affiliate companies and their respective directors, officers, agents, servants and employees ("Other Party Group") as additional insured. All policies shall contain provisions whereby the insurers waive all rights of subrogation in accordance with the provisions of this LGIA against the Other Party Group and provide thirty (30) Calendar Days advance written notice to the Other Party Group prior to anniversary date of cancellation or any material change in coverage or condition.
- 18.3.6** The Commercial General Liability Insurance, Comprehensive Automobile Liability Insurance and Excess Public Liability Insurance policies shall contain provisions that specify that the policies are primary and shall apply to such extent without consideration for other policies separately carried and shall state that each insured is provided coverage as though a separate policy had been issued to each, except the insurer's liability shall not be increased beyond the amount for which the insurer would have been liable had only one insured been covered. Each Party shall be responsible for its respective deductibles or retentions.
- 18.3.7** The Commercial General Liability Insurance, Comprehensive Automobile Liability Insurance and Excess Public Liability Insurance policies, if written on a Claims First Made Basis, shall be maintained in full force and effect for two (2) years after termination of this LGIA, which coverage may be in the form of tail coverage or extended reporting period coverage if agreed by the Parties.

- 18.3.8** The requirements contained herein as to the types and limits of all insurance to be maintained by the Parties are not intended to and shall not in any manner, limit or qualify the liabilities and obligations assumed by the Parties under this LGIA.
- 18.3.9** Within ten (10) Business Days following execution of this LGIA, and as soon as practicable after the end of each fiscal year or at the renewal of the insurance policy and in any event within ninety (90) Calendar Days thereafter, each Party shall provide certification of all insurance required in this LGIA, executed by each insurer or by an authorized representative of each insurer.
- 18.3.10** Notwithstanding the foregoing, each Party may self-insure to meet the minimum insurance requirements of Articles 18.3.2 through 18.3.8 to the extent it maintains a self-insurance program; provided that, such Party's senior secured debt is rated at investment grade or better by Standard & Poor's and that its self-insurance program meets the minimum insurance requirements of Articles 18.3.2 through 18.3.8. For any period of time that a Party's senior secured debt is unrated by Standard & Poor's or is rated at less than investment grade by Standard & Poor's, such Party shall comply with the insurance requirements applicable to it under Articles 18.3.2 through 18.3.9. In the event that a Party is permitted to self-insure pursuant to this article, it shall notify the other Party that it meets the requirements to self-insure and that its self-insurance program meets the minimum insurance requirements in a manner consistent with that specified in Article 18.3.9.
- 18.3.11** The Parties agree to report to each other in writing as soon as practical all accidents or occurrences resulting in injuries to any person, including death, and any property damage arising out of this LGIA.

Article 19. Assignment

19.1 Assignment. This LGIA may be assigned by either Party only with the written consent of the other; provided that either Party may assign this LGIA without the consent of the other Party to any Affiliate of the assigning Party with an equal or greater credit rating and with the legal authority and operational ability to satisfy the obligations of the assigning Party under this LGIA; and provided further that Interconnection Customer shall have the right to assign this LGIA, without the consent of Transmission Provider, for collateral security purposes to aid in providing financing for the Large Generating Facility, provided that Interconnection Customer will promptly notify Transmission Provider of any such assignment. Any financing arrangement entered into by Interconnection Customer pursuant to this article will provide that prior to or upon the exercise of the secured party's, trustee's or mortgagee's assignment rights pursuant to said arrangement, the secured creditor, the trustee or mortgagee will notify Transmission Provider of the date and particulars of any such exercise of assignment right(s), including providing Transmission Provider with proof that it meets the requirements of Articles 11.5 and 18.3. Any attempted assignment that violates this article is void and ineffective. Any assignment under this LGIA shall not relieve a Party of its obligations, nor shall a Party's obligations be enlarged, in whole or in part, by reason thereof. Where required, consent to assignment will not be unreasonably withheld, conditioned or delayed.

Article 20. Severability

20.1 Severability. If any provision in this LGIA is finally determined to be invalid, void or unenforceable by any court or other Governmental Authority having jurisdiction, such determination shall not invalidate, void or make unenforceable any other provision, agreement or covenant of this LGIA; provided that if Interconnection Customer (or any third party, but only if such third party is not acting at the direction of Transmission Provider) seeks and obtains such a final determination with respect to any provision of the Alternate Option (Article 5.1.2), or the Negotiated Option (Article 5.1.4), then none of these provisions shall thereafter have any force or effect and the Parties' rights and obligations shall be governed solely by the Standard Option (Article 5.1.1).

Article 21. Comparability

21.1 Comparability. The Parties will comply with all applicable comparability and code of conduct laws, rules and regulations, as amended from time to time.

Article 22. Confidentiality

22.1 Confidentiality. Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied by either of the Parties to the other prior to the execution of this LGIA.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential.

If requested by either Party, the other Party shall provide in writing, the basis for asserting that the information referred to in this Article 22 warrants confidential treatment, and the requesting Party may disclose such writing to the appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

22.1.1 Term. During the term of this LGIA, and for a period of three (3) years after the expiration or termination of this LGIA, except as otherwise provided in this Article 22, each Party shall hold in confidence and shall not disclose to any person Confidential Information.

- 22.1.2 Scope. Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a third party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of this LGIA; or (6) is required, in accordance with Article 22.1.7 of the LGIA, Order of Disclosure, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under this LGIA. Information designated as Confidential Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the other Party that it no longer is confidential.
- 22.1.3 Release of Confidential Information. Neither Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), subcontractors, employees, consultants, or to parties who may be or considering providing financing to or equity participation with Interconnection Customer, or to potential purchasers or assignees of Interconnection Customer, on a need-to-know basis in connection with this LGIA, unless such person has first been advised of the confidentiality provisions of this Article 22 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Article 22.

- 22.1.4 Rights. Each Party retains all rights, title, and interest in the Confidential Information that each Party discloses to the other Party. The disclosure by each Party to the other Party of Confidential Information shall not be deemed a waiver by either Party or any other person or entity of the right to protect the Confidential Information from public disclosure.
- 22.1.5 No Warranties. By providing Confidential Information, neither Party makes any warranties or representations as to its accuracy or completeness. In addition, by supplying Confidential Information, neither Party obligates itself to provide any particular information or Confidential Information to the other Party nor to enter into any further agreements or proceed with any other relationship or joint venture.
- 22.1.6 Standard of Care. Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under this LGIA or its regulatory requirements.
- 22.1.7 Order of Disclosure. If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires either Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the other Party with prompt notice of such request(s) or requirement(s) so that the other Party may seek an appropriate protective order or waive compliance with the terms of this LGIA. Notwithstanding the absence of a protective order or waiver, the Party may disclose such Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance

that confidential treatment will be accorded any Confidential Information so furnished.

- 22.1.8 Termination of Agreement. Upon termination of this LGIA for any reason, each Party shall, within ten (10) Calendar Days of receipt of a written request from the other Party, use Reasonable Efforts to destroy, erase, or delete (with such destruction, erasure, and deletion certified in writing to the other Party) or return to the other Party, without retaining copies thereof, any and all written or electronic Confidential Information received from the other Party.
- 22.1.9 Remedies. The Parties agree that monetary damages would be inadequate to compensate a Party for the other Party's Breach of its obligations under this Article 22. Each Party accordingly agrees that the other Party shall be entitled to equitable relief, by way of injunction or otherwise, if the first Party Breaches or threatens to Breach its obligations under this Article 22, which equitable relief shall be granted without bond or proof of damages, and the receiving Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Article 22, but shall be in addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. No Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Article 22.
- 22.1.10 Disclosure to FERC, its Staff, or a State. Notwithstanding anything in this Article 22 to the contrary, and pursuant to 18 CFR section 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to this LGIA, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information.

In providing the information to FERC or its staff, the Party must, consistent with 18 CFR section 388.112, request that the information be treated as confidential and non-public by FERC and its staff and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party to this LGIA prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Party to the LGIA when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR section 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

22.1.11 Subject to the exception in Article 22.1.10, any information that a Party claims is competitively sensitive, commercial or financial information under this LGIA (“Confidential Information”) shall not be disclosed by the other Party to any person not employed or retained by the other Party, except to the extent disclosure is (i) required by law; (ii) reasonably deemed by the disclosing Party to be required to be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (iii) otherwise permitted by consent of the other Party, such consent not to be unreasonably withheld; or (iv) necessary to fulfill its obligations under this LGIA or as a transmission service provider or a Balancing Authority Area operator including disclosing the Confidential Information to an RTO or ISO or to a regional or national reliability organization. The Party asserting confidentiality shall notify the other Party in writing of the information it claims is confidential. Prior to any disclosures of the other Party’s Confidential Information under this subparagraph, or if any third party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the disclosing Party agrees to promptly notify the other Party in writing and agrees to assert confidentiality and cooperate with the other Party in seeking to protect the Confidential Information from public

disclosure by confidentiality agreement, protective order or other reasonable measures.

Article 23. Environmental Releases

23.1 Each Party shall notify the other Party, first orally and then in writing, of the release of any Hazardous Substances, any asbestos or lead abatement activities, or any type of remediation activities related to the Large Generating Facility or the Interconnection Facilities, each of which may reasonably be expected to affect the other Party. The notifying Party shall: (i) provide the notice as soon as practicable, provided such Party makes a good faith effort to provide the notice no later than twenty-four hours after such Party becomes aware of the occurrence; and (ii) promptly furnish to the other Party copies of any publicly available reports filed with any Governmental Authorities addressing such events.

Article 24. Information Requirements

24.1 Information Acquisition. Transmission Provider and Interconnection Customer shall submit specific information regarding the electrical characteristics of their respective facilities to each other as described below and in accordance with Applicable Reliability Standards.

24.2 Information Submission by Transmission Provider. The initial information submission by Transmission Provider shall occur no later than one hundred eighty (180) Calendar Days prior to Trial Operation and shall include Transmission System information necessary to allow Interconnection Customer to select equipment and meet any system protection and stability requirements, unless otherwise agreed to by the Parties. On a monthly basis Transmission Provider shall provide Interconnection Customer a status report on the construction and installation of Transmission Provider's Interconnection Facilities and Network Upgrades, including, but not limited to, the following information: (1) progress to

date; (2) a description of the activities since the last report (3) a description of the action items for the next period; and (4) the delivery status of equipment ordered.

- 24.3 Updated Information Submission by Interconnection Customer. The updated information submission by Interconnection Customer, including manufacturer information, shall occur no later than one hundred eighty (180) Calendar Days prior to the Trial Operation. Interconnection Customer shall submit a completed copy of the Large Generating Facility data requirements contained in Appendix 1 to the LGIP. It shall also include any additional information provided to Transmission Provider for the Cluster Study and Facilities Study. Information in this submission shall be the most current Large Generating Facility design or expected performance data. Information submitted for stability models shall be compatible with Transmission Provider standard models. If there is no compatible model, Interconnection Customer will work with a consultant mutually agreed to by the Parties to develop and supply a standard model and associated information.

If Interconnection Customer's data is materially different from what was originally provided to Transmission Provider pursuant to the Interconnection Study Agreement between Transmission Provider and Interconnection Customer, then Transmission Provider will conduct appropriate studies to determine the impact on Transmission Provider Transmission System based on the actual data submitted pursuant to this Article 24.3. Interconnection Customer shall not begin Trial Operation until such studies are completed.

- 24.4 Information Supplementation. Prior to the Operation Date, the Parties shall supplement their information submissions described above in this Article 24 with any and all "as-built" Large Generating Facility information or "as-tested" performance information that differs from the initial submissions or, alternatively, written confirmation that no such differences exist. Interconnection Customer shall conduct tests on the Large Generating Facility as required by Good Utility Practice such as an open circuit "step voltage" test on the Large Generating Facility to verify proper operation of the Large Generating Facility's automatic voltage regulator.

Unless otherwise agreed, the test conditions shall include: (1) Large Generating Facility at synchronous speed; (2) automatic voltage regulator on and in voltage control mode; and (3) a five percent change in Large Generating Facility terminal voltage initiated by a change in the voltage regulators reference voltage. Interconnection Customer shall provide validated test recordings showing the responses of Large Generating Facility terminal and field voltages. In the event that direct recordings of these voltages is impractical, recordings of other voltages or currents that mirror the response of the Large Generating Facility's terminal or field voltage are acceptable if information necessary to translate these alternate quantities to actual Large Generating Facility terminal or field voltages is provided. Large Generating Facility testing shall be conducted and results provided to Transmission Provider for each individual generating unit in a station.

Subsequent to the Operation Date, Interconnection Customer shall provide Transmission Provider any information changes due to equipment replacement, repair, or adjustment. Transmission Provider shall provide Interconnection Customer any information changes due to equipment replacement, repair or adjustment in the directly connected substation or any adjacent Transmission Provider-owned substation that may affect Interconnection Customer's Interconnection Facilities equipment ratings, protection or operating requirements. The Parties shall provide such information no later than thirty (30) Calendar Days after the date of the equipment replacement, repair or adjustment.

Article 25. Information Access and Audit Rights

- 25.1 Information Access. Each Party (the "disclosing Party") shall make available to the other Party information that is in the possession of the disclosing Party and is necessary in order for the other Party to: (i) verify the costs incurred by the disclosing Party for which the other Party is responsible under this LGIA; and (ii) carry out its obligations and responsibilities under this LGIA. The Parties shall not use such information for purposes other than those set forth in this Article 25.1 and to enforce their rights under this LGIA.

- 25.2 Reporting of Non-Force Majeure Events. Each Party (the “notifying Party”) shall notify the other Party when the notifying Party becomes aware of its inability to comply with the provisions of this LGIA for a reason other than a Force Majeure event. The Parties agree to cooperate with each other and provide necessary information regarding such inability to comply, including the date, duration, reason for the inability to comply, and corrective actions taken or planned to be taken with respect to such inability to comply. Notwithstanding the foregoing, notification, cooperation or information provided under this article shall not entitle the Party receiving such notification to allege a cause for anticipatory breach of this LGIA.
- 25.3 Audit Rights. Subject to the requirements of confidentiality under Article 22 of this LGIA, each Party shall have the right, during normal business hours, and upon prior reasonable notice to the other Party, to audit at its own expense the other Party’s accounts and records pertaining to either Party’s performance or either Party’s satisfaction of obligations under this LGIA. Such audit rights shall include audits of the other Party’s costs, calculation of invoiced amounts, Transmission Provider’s efforts to allocate responsibility for the provision of reactive support to the Transmission System, Transmission Provider’s efforts to allocate responsibility for interruption or reduction of generation on the Transmission System, and each Party’s actions in an Emergency Condition. Any audit authorized by this article shall be performed at the offices where such accounts and records are maintained and shall be limited to those portions of such accounts and records that relate to each Party’s performance and satisfaction of obligations under this LGIA. Each Party shall keep such accounts and records for a period equivalent to the audit rights periods described in Article 25.4.

25.4 Audit Rights Periods.

- 25.4.1 Audit Rights Period for Construction-Related Accounts and Records. Accounts and records related to the design, engineering, procurement, and construction of Transmission Provider’s Interconnection Facilities and Network Upgrades shall be subject to audit for a period of twenty-four months following Transmission

Provider's issuance of a final invoice in accordance with Article 12.2.

25.4.2 Audit Rights Period for All Other Accounts and Records. Accounts and records related to either Party's performance or satisfaction of all obligations under this LGIA other than those described in Article 25.4.1 shall be subject to audit as follows: (i) for an audit relating to cost obligations, the applicable audit rights period shall be twenty-four months after the auditing Party's receipt of an invoice giving rise to such cost obligations; and (ii) for an audit relating to all other obligations, the applicable audit rights period shall be twenty-four months after the event for which the audit is sought.

25.5 Audit Results. If an audit by a Party determines that an overpayment or an underpayment has occurred, a notice of such overpayment or underpayment shall be given to the other Party together with those records from the audit which support such determination.

Article 26. Subcontractors

26.1 General. Nothing in this LGIA shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this LGIA; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this LGIA in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

26.2 Responsibility of Principal. The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this LGIA. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or

inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under Article 5 of this LGIA. Any applicable obligation imposed by this LGIA upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

- 26.3 **No Limitation by Insurance.** The obligations under this Article 26 will not be limited in any way by any limitation of subcontractor's insurance.

Article 27. Disputes

- 27.1 Submission.** In the event either Party has a dispute, or asserts a claim, that arises out of or in connection with this LGIA or its performance, such Party (the "disputing Party") shall provide the other Party with written notice of the dispute or claim ("Notice of Dispute"). Such dispute or claim shall be referred to a designated senior representative of each Party for resolution on an informal basis as promptly as practicable after receipt of the Notice of Dispute by the other Party. In the event the designated representatives are unable to resolve the claim or dispute through unassisted or assisted negotiations within thirty (30) Calendar Days of the other Party's receipt of the Notice of Dispute, such claim or dispute may, upon mutual agreement of the Parties, be submitted to arbitration and resolved in accordance with the arbitration procedures set forth below. In the event the Parties do not agree to submit such claim or dispute to arbitration, each Party may exercise whatever rights and remedies it may have in equity or at law consistent with the terms of this LGIA.
- 27.2 **External Arbitration Procedures.** Any arbitration initiated under this LGIA shall be conducted before a single neutral arbitrator appointed by the Parties. If the Parties fail to agree upon a single arbitrator within ten (10) Calendar Days of the submission of the dispute to arbitration, each Party shall choose one arbitrator who shall sit on a three-member arbitration panel. The two arbitrators so chosen shall within twenty (20) Calendar Days select a third arbitrator to chair the arbitration panel. In either case, the arbitrators shall be knowledgeable in electric utility

matters, including electric transmission and bulk power issues, and shall not have any current or past substantial business or financial relationships with any party to the arbitration (except prior arbitration). The arbitrator(s) shall provide each of the Parties an opportunity to be heard and, except as otherwise provided herein, shall conduct the arbitration in accordance with the Commercial Arbitration Rules of the American Arbitration Association ("Arbitration Rules") and any applicable FERC regulations or RTO rules; provided, however, in the event of a conflict between the Arbitration Rules and the terms of this Article 27, the terms of this Article 27 shall prevail.

- 27.3 Arbitration Decisions. Unless otherwise agreed by the Parties, the arbitrator(s) shall render a decision within ninety (90) Calendar Days of appointment and shall notify the Parties in writing of such decision and the reasons therefor. The arbitrator(s) shall be authorized only to interpret and apply the provisions of this LGIA and shall have no power to modify or change any provision of this Agreement in any manner. The decision of the arbitrator(s) shall be final and binding upon the Parties, and judgment on the award may be entered in any court having jurisdiction. The decision of the arbitrator(s) may be appealed solely on the grounds that the conduct of the arbitrator(s), or the decision itself, violated the standards set forth in the Federal Arbitration Act or the Administrative Dispute Resolution Act. The final decision of the arbitrator must also be filed with FERC if it affects jurisdictional rates, terms and conditions of service, Interconnection Facilities, or Network Upgrades.
- 27.4 Costs. Each Party shall be responsible for its own costs incurred during the arbitration process and for the following costs, if applicable: (1) the cost of the arbitrator chosen by the Party to sit on the three member panel and one half of the cost of the third arbitrator chosen; or (2) one half the cost of the single arbitrator jointly chosen by the Parties.

Article 28. Representations, Warranties, and Covenants

28.1 General. Each Party makes the following representations, warranties and covenants:

28.1.1 Good Standing. Such Party is duly organized, validly existing and in good standing under the laws of the state in which it is organized, formed, or incorporated, as applicable; that it is qualified to do business in the state or states in which the Large Generating Facility, Interconnection Facilities and Network Upgrades owned by such Party, as applicable, are located; and that it has the corporate power and authority to own its properties, to carry on its business as now being conducted and to enter into this LGIA and carry out the transactions contemplated hereby and perform and carry out all covenants and obligations on its part to be performed under and pursuant to this LGIA.

28.1.2 Authority. Such Party has the right, power and authority to enter into this LGIA, to become a Party hereto and to perform its obligations hereunder. This LGIA is a legal, valid and binding obligation of such Party, enforceable against such Party in accordance with its terms, except as the enforceability thereof may be limited by applicable bankruptcy, insolvency, reorganization or other similar laws affecting creditors' rights generally and by general equitable principles (regardless of whether enforceability is sought in a proceeding in equity or at law).

28.1.3 No Conflict. The execution, delivery and performance of this LGIA does not violate or conflict with the organizational or formation documents, or bylaws or operating agreement, of such Party, or any judgment, license, permit, order, material agreement or instrument applicable to or binding upon such Party or any of its assets.

28.1.4 Consent and Approval. Such Party has sought or obtained, or, in accordance with this LGIA will seek or obtain, each consent,

approval, authorization, order, or acceptance by any Governmental Authority in connection with the execution, delivery and performance of this LGIA, and it will provide to any Governmental Authority notice of any actions under this LGIA that are required by Applicable Laws and Regulations.

Article 29. Joint Operating Committee

29.1 Joint Operating Committee. Except in the case of ISOs and RTOs, Transmission Provider shall constitute a Joint Operating Committee to coordinate operating and technical considerations of Interconnection Service. At least six (6) months prior to the expected Initial Synchronization Date, Interconnection Customer and Transmission Provider shall each appoint one representative and one alternate to the Joint Operating Committee. Each Interconnection Customer shall notify Transmission Provider of its appointment in writing. Such appointments may be changed at any time by similar notice. The Joint Operating Committee shall meet as necessary, but not less than once each calendar year, to carry out the duties set forth herein. The Joint Operating Committee shall hold a meeting at the request of either Party, at a time and place agreed upon by the representatives. The Joint Operating Committee shall perform all of its duties consistent with the provisions of this LGIA. Each Party shall cooperate in providing to the Joint Operating Committee all information required in the performance of the Joint Operating Committee's duties. All decisions and agreements, if any, made by the Joint Operating Committee, shall be evidenced in writing. The duties of the Joint Operating Committee shall include the following:

29.1.1 Establish data requirements and operating record requirements.

29.1.2 Review the requirements, standards, and procedures for data acquisition equipment, protective equipment, and any other equipment or software.

- 29.1.3** Annually review the one (1) year forecast of maintenance and planned outage schedules of Transmission Provider's and Interconnection Customer's facilities at the Point of Interconnection.
- 29.1.4** Coordinate the scheduling of maintenance and planned outages on the Interconnection Facilities, the Large Generating Facility and other facilities that impact the normal operation of the interconnection of the Large Generating Facility to the Transmission System.
- 29.1.5** Ensure that information is being provided by each Party regarding equipment availability.
- 29.1.6** Perform such other duties as may be conferred upon it by mutual agreement of the Parties.

Article 30. Miscellaneous

- 30.1 **Binding Effect.** This LGIA and the rights and obligations hereof, shall be binding upon and shall inure to the benefit of the successors and assigns of the Parties hereto.
- 30.2 **Conflicts.** In the event of a conflict between the body of this LGIA and any attachment, appendices or exhibits hereto, the terms and provisions of the body of this LGIA shall prevail and be deemed the final intent of the Parties.
- 30.3 **Rules of Interpretation.** This LGIA, unless a clear contrary intention appears, shall be construed and interpreted as follows: (1) the singular number includes the plural number and vice versa; (2) reference to any person includes such person's successors and assigns but, in the case of a Party, only if such successors and

assigns are permitted by this LGIA, and reference to a person in a particular capacity excludes such person in any other capacity or individually; (3) reference to any agreement (including this LGIA), document, instrument or tariff means such agreement, document, instrument, or tariff as amended or modified and in effect from time to time in accordance with the terms thereof and, if applicable, the terms hereof; (4) reference to any Applicable Laws and Regulations means such Applicable Laws and Regulations as amended, modified, codified, or reenacted, in whole or in part, and in effect from time to time, including, if applicable, rules and regulations promulgated thereunder; (5) unless expressly stated otherwise, reference to any Article, Section or Appendix means such Article of this LGIA or such Appendix to this LGIA, or such Section to the LGIP or such Appendix to the LGIP, as the case may be; (6) “hereunder”, “hereof”, “herein”, “hereto” and words of similar import shall be deemed references to this LGIA as a whole and not to any particular Article or other provision hereof or thereof; (7) “including” (and with correlative meaning “include”) means including without limiting the generality of any description preceding such term; and (8) relative to the determination of any period of time, “from” means “from and including,” “to” means “to but excluding” and “through” means “through and including.”

30.4 Entire Agreement. This LGIA, including all Appendices and Schedules attached hereto, constitutes the entire agreement between the Parties with reference to the subject matter hereof, and supersedes all prior and contemporaneous understandings or agreements, oral or written, between the Parties with respect to the subject matter of this LGIA. There are no other agreements, representations, warranties, or covenants which constitute any part of the consideration for, or any condition to, either Party’s compliance with its obligations under this LGIA.

30.5 No Third Party Beneficiaries. This LGIA is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and, where permitted, their assigns.

- 30.6 Waiver. The failure of a Party to this LGIA to insist, on any occasion, upon strict performance of any provision of this LGIA will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

Any waiver at any time by either Party of its rights with respect to this LGIA shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this LGIA. Termination or Default of this LGIA for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this LGIA shall, if requested, be provided in writing.

- 30.7 Headings. The descriptive headings of the various Articles of this LGIA have been inserted for convenience of reference only and are of no significance in the interpretation or construction of this LGIA.
- 30.8 Multiple Counterparts. This LGIA may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.
- 30.9 Amendment. The Parties may by mutual agreement amend this LGIA by a written instrument duly executed by the Parties.
- 30.10 Modification by the Parties. The Parties may by mutual agreement amend the Appendices to this LGIA by a written instrument duly executed by the Parties. Such amendment shall become effective and a part of this LGIA upon satisfaction of all Applicable Laws and Regulations.
- 30.11 Reservation of Rights. Transmission Provider shall have the right to make a unilateral filing with FERC to modify this LGIA with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules

and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this LGIA pursuant to section 206 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this LGIA shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations thereunder, except to the extent that the Parties otherwise mutually agree as provided herein.

- 30.12 No Partnership. This LGIA shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power, or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

IN WITNESS WHEREOF, the Parties have executed this LGIA in duplicate originals, each of which shall constitute and be an original effective Agreement between the Parties.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

Appendix A to LGIA
Interconnection Facilities, Network Upgrades and Distribution Upgrades

1. Interconnection Facilities:

(a) {insert Interconnection Customer's Interconnection Facilities}:

(b) {insert Transmission Provider's Interconnection Facilities}:

2. Network Upgrades:

(a) {insert Stand Alone Network Upgrades}:

(b) {insert Substation Network Upgrades}:

(c) {insert System Network Upgrades}:

3. Distribution Upgrades:

Appendix B to LGIA Milestones

Site Control

Check box if applicable { }

Interconnection Customer with qualifying regulatory limitations must demonstrate 100% Site Control by {Transmission Provider to insert date one hundred eighty (180) Calendar Days from the effective date of this LGIA} or the LGIA may be terminated per Article 17 (Default) of this LGIA and Interconnection Customer may be subject to Withdrawal Penalties per Section 3.7.1.1 of Transmission Provider's LGIP (Calculation of the Withdrawal Penalty).

Appendix C to LGIA
Interconnection Details

Appendix D to LGIA

Security Arrangements Details

Infrastructure security of Transmission System equipment and operations and control hardware and software is essential to ensure day-to-day Transmission System reliability and operational security. FERC will expect all Transmission Providers, market participants, and Interconnection Customers interconnected to the Transmission System to comply with the recommendations offered by the President's Critical Infrastructure Protection Board and, eventually, best practice recommendations from the electric reliability authority. All public utilities will be expected to meet basic standards for system infrastructure and operational security, including physical, operational, and cyber-security practices.

**Appendix E to LGIA
Commercial Operation Date**

This Appendix E is a part of the LGIA between Transmission Provider and Interconnection Customer.

{Date}

{Transmission Provider Address}

Re: _____ Large Generating Facility

Dear _____:

On **{Date}** **{Interconnection Customer}** has completed Trial Operation of Unit No. _____. This letter confirms that **{Interconnection Customer}** commenced Commercial Operation of Unit No. _____ at the Large Generating Facility, effective as of **{Date plus one day}**.

Thank you.

{Signature}

{Interconnection Customer Representative}

Appendix F to LGIA
Addresses for Delivery of Notices and Billings

Notices:

Transmission Provider:

{To be supplied.}

Interconnection Customer:

{To be supplied.}

Billings and Payments:

Transmission Provider:

{To be supplied.}

Interconnection Customer:

{To be supplied.}

Alternative Forms of Delivery of Notices (telephone, facsimile or email):

Transmission Provider:

{To be supplied.}

Interconnection Customer:

{To be supplied.}

APPENDIX G

INTERCONNECTION REQUIREMENTS FOR A WIND GENERATING PLANT

Appendix G sets forth requirements and provisions specific to a wind generating plant or a Generating Facility that contains a wind generating plant. All other requirements of this LGIA continue to apply to wind generating plant interconnections.

A. Technical Standards Applicable to a Wind Generating Plant

i. Low Voltage Ride-Through (LVRT) Capability

A wind generating plant shall be able to remain online during voltage disturbances up to the time periods and associated voltage levels set forth in the standard below. The LVRT standard provides for a transition period standard and a post-transition period standard.

Transition Period LVRT Standard

The transition period standard applies to wind generating plants subject to FERC Order 661 that have either: (i) interconnection agreements signed and filed with the Commission, filed with the Commission in unexecuted form, or filed with the Commission as non-conforming agreements between January 1, 2006 and December 31, 2006, with a scheduled in-service date no later than December 31, 2007, or (ii) wind

generating turbines subject to a wind turbine procurement contract executed prior to December 31, 2005, for delivery through 2007.

1. Wind generating plants are required to remain in-service during three-phase faults with normal clearing (which is a time period of approximately 4 – 9 cycles) and single line to ground faults with delayed clearing, and subsequent post-fault voltage recovery to prefault voltage unless clearing the fault effectively disconnects the generator from the system. The clearing time requirement for a three-phase fault will be specific to the wind generating plant substation location, as determined by and documented by transmission provider. The maximum clearing time the wind generating plant shall be required to withstand for a three-phase fault shall be 9 cycles at a voltage as low as 0.15 p.u., as measured at the high side of the wind generating plant step-up transformer (i.e. the transformer that steps the voltage up to the transmission interconnection voltage or “GSU”), after which, if the fault remains following the location-specific normal clearing time for three-phase faults, the wind generating plant may disconnect from the transmission system.
2. This requirement does not apply to faults that would occur between the wind generator terminals and the high side of the GSU or to faults that would result in a voltage lower than 0.15 per unit on the high side of the GSU serving the facility.
3. Wind generating plants may be tripped after the fault period if this action is intended as part of a special protection system.
4. Wind generating plants may meet the LVRT requirements of this standard by the

performance of the generators or by installing additional equipment (e.g., Static VAR Compensator, etc.) within the wind generating plant or by a combination of generator performance and additional equipment.

5. Existing individual generator units that are, or have been, interconnected to the network at the same location at the effective date of the Appendix G LVRT Standard are exempt from meeting the Appendix G LVRT Standard for the remaining life of the existing generation equipment. Existing individual generator units that are replaced are required to meet the Appendix G LVRT Standard.

Post-transition Period LVRT Standard

All wind generating plants subject to FERC Order No. 661 and not covered by the transition period described above must meet the following requirements:

1. Wind generating plants are required to remain in-service during three-phase faults with normal clearing (which is a time period of approximately 4 – 9 cycles) and single line to ground faults with delayed clearing, and subsequent post-fault voltage recovery to pre-fault voltage unless clearing the fault effectively disconnects the generator from the system. The clearing time requirement for a three-phase fault will be specific to the wind generating plant substation location, as determined by and documented by transmission provider. The maximum clearing time the wind generating plant shall be required to withstand for a three-phase fault shall be 9 cycles after which, if the fault remains following the

location-specific normal clearing time for three-phase faults, the wind generating plant may disconnect from the transmission system. A wind generating plant shall remain interconnected during such a fault on the transmission system for a voltage level as low as zero volts, as measured at the high voltage side of the wind GSU.

2. This requirement does not apply to faults that would occur between the wind generator terminals and the high side of the GSU.
3. Wind generating plants may be tripped after the fault period if this action is intended as part of a special protection system.
4. Wind generating plants may meet the LVRT requirements of this standard by the performance of the generators or by installing additional equipment (e.g., Static VAR Compensator) within the wind generating plant or by a combination of generator performance and additional equipment.

Existing individual generator units that are, or have been, interconnected to the network at the same location at the effective date of the Appendix G LVRT Standard are exempt from meeting the Appendix G LVRT Standard for the remaining life of the existing generation equipment. Existing individual generator units that are replaced are required to meet the Appendix G LVRT Standard.

ii. Power Factor Design Criteria (Reactive Power)

The following reactive power requirements apply only to a newly interconnecting wind generating plant that has executed a Facilities Study Agreement as of the effective

date of the Final Rule establishing the reactive power requirements for non-synchronous generators in article 9.6.1 of this LGIA (Order No. 827). A wind generating plant to which this provision applies shall maintain a power factor within the range of 0.95 leading to 0.95 lagging, measured at the Point of Interconnection as defined in this LGIA, if Transmission Provider's Cluster Study shows that such a requirement is necessary to ensure safety or reliability. The power factor range standard can be met by using, for example, power electronics designed to supply this level of reactive capability (taking into account any limitations due to voltage level, real power output, etc.) or fixed and switched capacitors if agreed to by Transmission Provider, or a combination of the two. Interconnection Customer shall not disable power factor equipment while the wind plant is in operation. Wind plants shall also be able to provide sufficient dynamic voltage support in lieu of the power system stabilizer and automatic voltage regulation at the generator excitation system if the Cluster Study shows this to be required for system safety or reliability.

iii. Supervisory Control and Data Acquisition (SCADA) Capability

The wind plant shall provide SCADA capability to transmit data and receive instructions from Transmission Provider to protect system reliability. Transmission Provider and the wind plant Interconnection Customer shall determine what SCADA information is essential for the proposed wind plant, taking into account the size of the plant and its characteristics, location, and importance in maintaining generation resource

adequacy and transmission system reliability in its area.

Appendix H to LGIA

Operating Assumptions for Generating Facility

Check box if applicable { }

Operating Assumptions:

{insert operating assumptions that reflect the charging behavior of the Generating Facility that includes at least one electric storage resource}

..

ATTACHMENT O

Small Generator Interconnection Procedures (SGIP)

**SMALL GENERATOR
INTERCONNECTION PROCEDURES (SGIP)**

(For Generating Facilities No Larger Than 20 MW)

TABLE OF CONTENTS

	Page No.
Section 1. Application.....	1
1.1 Applicability.....	1
1.2 Pre-Application	2
1.3 Interconnection Request	5
1.4 Modification of the Interconnection Request	6
1.5 Site Control	6
1.6 Queue Position	6
1.7 Interconnection Requests Submitted Prior to the Effective Date of the SGIP	7
Section 2. Fast Track Process.....	7
2.1 Applicability.....	7
2.2 Initial Review	8
2.3 Customer Options Meeting.....	12
2.4 Supplemental Review	12
Section 3. Study Process	17
3.1 Applicability.....	17
3.2 Scoping Meeting	17
3.3 Feasibility Study.....	18
3.4 System Impact Study	19
3.5 Facilities Study.....	21
Section 4. Provisions that Apply to All Interconnection Requests	22
4.1 Reasonable Efforts	22
4.2 Disputes	22
4.3 Interconnection Metering.....	23
4.4 Commissioning.....	23
4.5 Confidentiality.....	23
4.6 Comparability.....	24
4.7 Record Retention.....	25

4.8 Interconnection Agreement..... 25

4.9 Coordination with Affected Systems 25

4.10 Capacity of the Small Generating Facility 25

Attachment 1 – Glossary of Terms

Attachment 2 – Small Generator Interconnection Request

Attachment 3 – Certification Codes and Standards

Attachment 4 – Certification of Small Generator Equipment Packages

Attachment 5 – Application, Procedures, and Terms and Conditions for Interconnecting a Certified Inverter-Based Small Generating Facility No Larger than 10 kW (“10 kW Inverter Process”).

Attachment 6 – Feasibility Study Agreement

Attachment 7 – System Impact Study Agreement

Attachment 8 – Facilities Study Agreement

Section 1. Application

1.1 Applicability

- 1.1.1 A request to interconnect a certified Small Generating Facility (See Attachments 3 and 4 for description of certification criteria) to Transmission Provider's Distribution System shall be evaluated under the section 2 Fast Track Process if the eligibility requirements of section 2.1 are met. A request to interconnect a certified inverter-based Small Generating Facility no larger than 10 kilowatts (kW) shall be evaluated under the Attachment 5 10 kW Inverter Process. A request to interconnect a Small Generating Facility no larger than 20 megawatts (MW) that does not meet the eligibility requirements of section 2.1, or does not pass the Fast Track Process or the 10 kW Inverter Process, shall be evaluated under the section 3 Study Process. If Interconnection Customer wishes to interconnect its Small Generating Facility using Network Resource Interconnection Service, it must do so under the Standard Large Generator Interconnection Procedures and execute the Standard Large Generator Interconnection Agreement.
- 1.1.2 Capitalized terms used herein shall have the meanings specified in the Glossary of Terms in Attachment 1 or the body of these procedures.
- 1.1.3 Neither these procedures nor the requirements included hereunder apply to Small Generating Facilities interconnected or approved for interconnection prior to sixty (60) Business Days after the effective date of these procedures.
- 1.1.4 Prior to submitting its Interconnection Request (Attachment 2), Interconnection Customer may ask Transmission Provider's interconnection contact employee or office whether the proposed interconnection is subject to these procedures. Transmission Provider shall respond within fifteen (15) Business Days.
- 1.1.5 Infrastructure security of electric system equipment and operations and control hardware and software is essential to ensure day-to-day reliability and operational security. The Federal Energy Regulatory Commission expects all Transmission Providers, market participants, and Interconnection Customers interconnected with electric systems to comply

with the recommendations offered by the President's Critical Infrastructure Protection Board and best practice recommendations from the electric reliability authority. All public utilities are expected to meet basic standards for electric system infrastructure and operational security, including physical, operational, and cyber-security practices.

- 1.1.6 References in these procedures to interconnection agreement are to the Small Generator Interconnection Agreement (SGIA).

1.2 Pre-Application

- 1.2.1 Transmission Provider shall designate an employee or office from which information on the application process and on an Affected System can be obtained through informal requests from Interconnection Customer presenting a proposed project for a specific site. The name, telephone number, and e-mail address of such contact employee or office shall be made available on Transmission Provider's Internet web site. Electric system information provided to Interconnection Customer should include relevant system studies, interconnection studies, and other materials useful to an understanding of an interconnection at a particular point on Transmission Provider's Transmission System, to the extent such provision does not violate confidentiality provisions of prior agreements or critical infrastructure requirements. Transmission Provider shall comply with reasonable requests for such information.
- 1.2.2 In addition to the information described in section 1.2.1, which may be provided in response to an informal request, an Interconnection Customer may submit a formal written request form along with a non-refundable fee of \$300 for a pre-application report on a proposed project at a specific site. Transmission Provider shall provide the pre-application data described in section 1.2.3 to Interconnection Customer within twenty (20) Business Days of receipt of the completed request form and payment of the \$300 fee. The pre-application report produced by Transmission Provider is non-binding, does not confer any rights, and Interconnection Customer must still successfully apply to interconnect to Transmission Provider's system. The written pre-application report request form shall include the

information in sections 1.2.2.1 through 1.2.2.8 below to clearly and sufficiently identify the location of the proposed Point of Interconnection.

- 1.2.2.1 Project contact information, including name, address, phone number, and email address.
 - 1.2.2.2 Project location (street address with nearby cross streets and town)
 - 1.2.2.3 Meter number, pole number, or other equivalent information identifying proposed Point of Interconnection, if available.
 - 1.2.2.4 Generator Type (e.g., solar, wind, combined heat and power, etc.)
 - 1.2.2.5 Size (alternating current kW)
 - 1.2.2.6 Single or three phase generator configuration
 - 1.2.2.7 Stand-alone generator (no onsite load, not including station service – Yes or No?)
 - 1.2.2.8 Is new service requested? Yes or No? If there is existing service, include the customer account number, site minimum and maximum current or proposed electric loads in kW (if available) and specify if the load is expected to change.
- 1.2.3. Using the information provided in the pre-application report request form in section 1.2.2, Transmission Provider will identify the substation/area bus, bank or circuit likely to serve the proposed Point of Interconnection. This selection by Transmission Provider does not necessarily indicate, after application of the screens and/or study, that this would be the circuit the project ultimately connects to. Interconnection Customer must request additional pre-application reports if information about multiple Points of Interconnection is requested. Subject to section 1.2.4, the pre-application report will include the following information:
- 1.2.3.1 Total capacity (in MW) of substation/area bus, bank or circuit based on normal or operating ratings likely to serve the proposed Point of Interconnection.

- 1.2.3.2 Existing aggregate generation capacity (in MW) interconnected to a substation/area bus, bank or circuit (i.e., amount of generation online) likely to serve the proposed Point of Interconnection.
- 1.2.3.3 Aggregate queued generation capacity (in MW) for a substation/area bus, bank or circuit (i.e., amount of generation in the queue) likely to serve the proposed Point of Interconnection.
- 1.2.3.4 Available capacity (in MW) of substation/area bus or bank and circuit likely to serve the proposed Point of Interconnection (i.e., total capacity less the sum of existing aggregate generation capacity and aggregate queued generation capacity).
- 1.2.3.5 Substation nominal distribution voltage and/or transmission nominal voltage if applicable.
- 1.2.3.6 Nominal distribution circuit voltage at the proposed Point of Interconnection.
- 1.2.3.7 Approximate circuit distance between the proposed Point of Interconnection and the substation.
- 1.2.3.8 Relevant line section(s) actual or estimated peak load and minimum load data, including daytime minimum load as described in section 2.4.4.1.1 below and absolute minimum load, when available.
- 1.2.3.9 Number and rating of protective devices and number and type (standard, bi-directional) of voltage regulating devices between the proposed Point of Interconnection and the substation/area. Identify whether the substation has a load tap changer.
- 1.2.3.10 Number of phases available at the proposed Point of Interconnection. If a single phase, distance from the three-phase circuit.
- 1.2.3.11 Limiting conductor ratings from the proposed Point of Interconnection to the distribution substation.

- 1.2.3.12 Whether the Point of Interconnection is located on a spot network, grid network, or radial supply.
- 1.2.3.13 Based on the proposed Point of Interconnection, existing or known constraints such as, but not limited to, electrical dependencies at that location, short circuit interrupting capacity issues, power quality or stability issues on the circuit, capacity constraints, or secondary networks.
- 1.2.4 The pre-application report need only include existing data. A pre-application report request does not obligate Transmission Provider to conduct a study or other analysis of the proposed generator in the event that data is not readily available. If Transmission Provider cannot complete all or some of a pre-application report due to lack of available data, the Transmission Provider shall provide Interconnection Customer with a pre-application report that includes the data that is available. The provision Of information on “available capacity” pursuant to section 1.2.3.4 does not imply that an interconnection up to this level may be completed without impacts since there are many variables studied as part of the interconnection review process, and data provided in the pre-application report may become outdated at the time of the submission of the complete Interconnection Request. Notwithstanding any of the provisions of this section, Transmission Provider shall, in good faith, include data in the pre-application report that represents the best available information at the time of reporting.

1.3 Interconnection Request

Interconnection Customer shall submit its Interconnection Request to Transmission Provider, together with the processing fee or deposit specified in the Interconnection Request. The Interconnection Request shall be date- and time-stamped upon receipt. The original date- and time-stamp applied to the Interconnection Request at the time of its original submission shall be accepted as the qualifying date- and time-stamp for the purposes of any timetable in these procedures. Interconnection Customer shall be notified of receipt by Transmission Provider within three (3) Business Days of receiving the Interconnection Request. Transmission Provider shall notify Interconnection Customer within ten (10) Business Days of the receipt of the Interconnection Request as to whether the Interconnection Request is

complete or incomplete. If the Interconnection Request is incomplete, Transmission Provider shall provide along with the notice that the Interconnection Request is incomplete, a written list detailing all information that must be provided to complete the Interconnection Request. Interconnection Customer will have ten (10) Business Days after receipt of the notice to submit the listed information or to request an extension of time to provide such information. If Interconnection Customer does not provide the listed information or a request for an extension of time within the deadline, the Interconnection Request will be deemed withdrawn. An Interconnection Request will be deemed complete upon submission of the listed information to Transmission Provider.

1.4 Modification of the Interconnection Request

Any modification to machine data or equipment configuration or to the interconnection site of the Small Generating Facility not agreed to in writing by Transmission Provider and Interconnection Customer may be deemed a withdrawal of the Interconnection Request and may require submission of a new Interconnection Request, unless proper notification of each Party by the other and a reasonable time to cure the problems created by the changes are undertaken. Any such modification of the Interconnection Request must be accompanied by any resulting updates to the models described in Attachment 2 of this SGIP.

1.5 Site Control

Documentation of site control must be submitted with the Interconnection Request. Site control may be demonstrated through:

- 1.5.1 Ownership of, a leasehold interest in, or a right to develop a site for the purpose of constructing the Small Generating Facility;
- 1.5.2 An option to purchase or acquire a leasehold site for such purpose; or
- 1.5.3 An exclusivity or other business relationship between Interconnection Customer and the entity having the right to sell, lease, or grant Interconnection Customer the right to possess or occupy a site for such purpose.

1.6 Queue Position

Transmission Provider shall assign a Queue Position based upon the date- and time-stamp of the Interconnection Request. The Queue Position of each Interconnection Request will be used to determine the cost responsibility for the Upgrades necessary to accommodate the interconnection. Transmission Provider shall maintain a single queue per geographic region. At Transmission Provider's option, Interconnection Requests may be studied serially or in clusters for the purpose of the system impact study.

1.7 Interconnection Requests Submitted Prior to the Effective Date of the SGIP

Nothing in this SGIP affects an Interconnection Customer's Queue Position assigned before the effective date of this SGIP. The Parties agree to complete work on any interconnection study agreement executed prior the effective date of this SGIP in accordance with the terms and conditions of that interconnection study agreement. Any new studies or other additional work will be completed pursuant to this SGIP.

Section 2. Fast Track Process

2.1 Applicability

The Fast Track Process is available to an Interconnection Customer proposing to interconnect its Small Generating Facility with Transmission Provider's Distribution System if the Small Generating Facility's capacity does not exceed the size limits identified in the table below. Small Generating Facilities below these limits are eligible for Fast Track review. However, Fast Track eligibility is distinct from the Fast Track Process itself, and eligibility does not imply or indicate that a Small Generating Facility will pass the Fast Track screens in section 2.2.1 below or the Supplemental Review screens in section 2.4.4 below.

Fast Track eligibility is determined based upon the generator type, the size of the generator, voltage of the line and the location of and the type of line at the Point of Interconnection. All Small Generating Facilities connecting to lines greater than 69 kilovolt (kV) are ineligible for the Fast Track Process regardless of size. All synchronous and induction machines must be no larger than 2 MW to be eligible for the Fast Track Process, regardless of location. For certified inverter-based systems, the size limit varies according to the voltage of the line at the proposed Point of Interconnection. Certified inverter-based Small Generating Facilities

located within 2.5 electrical circuit miles of a substation and on a mainline (as defined in the table below) are eligible for the Fast Track Process under the higher thresholds according to the table below. In addition to the size threshold, Interconnection Customer's proposed Small Generating Facility must meet the codes, standards, and certification requirements of Attachments 3 and 4 of these procedures, or Transmission Provider has to have reviewed the design or tested the proposed Small Generating Facility and is satisfied that it is safe to operate.

Fast Track Eligibility for Inverter-Based Systems		
Line Voltage	Fast Track Eligibility Regardless of Location	Fast Track Eligibility on a Mainline ¹ and ≤ 2.5 Electrical Circuit Miles from Substation ²
< 5 kV	≤ 500 kW	≤ 500 kW
≥ 5 kV and < 15 kV	≤ 2 MW	≤ 3 MW
≥ 15 kV and < 30 kV	≤ 3 MW	≤ 4 MW
≥ 30 kV and ≤ 69 kV	≤ 4 MW	≤ 5 MW

2.2 Initial Review

¹ For purposes of this table, a mainline is the three-phase backbone of a circuit. It will typically constitute lines with wire sizes of 4/0 American wire gauge, 336.4 kcmil, 397.5 kcmil, 477 kcmil and 795 kcmil.

² An Interconnection Customer can determine this information about its proposed interconnection location in advance by requesting a pre-application report pursuant to section 1.2.

Within fifteen (15) Business Days after Transmission Provider notifies Interconnection Customer it has received a complete Interconnection Request, Transmission Provider shall perform an initial review using the screens set forth below, shall notify Interconnection Customer of the results, and include with the notification copies of the analysis and data underlying Transmission Provider's determinations under the screens.

2.2.1 Screens

- 2.2.1.1 The proposed Small Generating Facility's Point of Interconnection must be on a portion of Transmission Provider's Distribution System that is subject to the Tariff.
- 2.2.1.2 For interconnection of a proposed Small Generating Facility to a radial distribution circuit, the aggregated generation, including the proposed Small Generating Facility, on the circuit shall not exceed 15 % of the line section annual peak load as most recently measured at the substation. A line section is that portion of a Transmission Provider's electric system connected to a customer bounded by automatic sectionalizing devices or the end of the distribution line.
- 2.2.1.3 For interconnection of a proposed Small Generating Facility to the load side of spot network protectors, the proposed Small Generating Facility must utilize an inverter-based equipment package and, together with the aggregated other inverter-based generation, shall not exceed the smaller of 5 % of a spot network's maximum load or 50 kW.³
- 2.2.1.4 The proposed Small Generating Facility, in aggregation with other generation on the distribution circuit, shall not contribute more than 10 % to the distribution circuit's maximum fault current at the point on the high voltage

³ A spot network is a type of distribution system found within modern commercial buildings to provide high reliability of service to a single customer. (Standard Handbook for Electrical Engineers, 11th edition, Donald Fink, McGraw Hill Book Company)

(primary) level nearest the proposed point of change of ownership.

2.2.1.5 The proposed Small Generating Facility, in aggregate with other generation on the distribution circuit, shall not cause any distribution protective devices and equipment (including, but not limited to, substation breakers, fuse cutouts, and line reclosers), or Interconnection Customer equipment on the system to exceed 87.5 % of the short circuit interrupting capability; nor shall the interconnection be proposed for a circuit that already exceeds 87.5 % of the short circuit interrupting capability.

2.2.1.6 Using the table below, determine the type of interconnection to a primary distribution line. This screen includes a review of the type of electrical service provided to the Interconnecting Customer, including line configuration and the transformer connection to limit the potential for creating over-voltages on Transmission Provider’s electric power system due to a loss of ground during the operating time of any anti-islanding function.

Primary Distribution Line Type	Type of Interconnection to Primary Distribution Line	Result/Criteria
Three-phase, three wire	3-phase or single phase, phase-to-phase	Pass screen
Three-phase, four wire	Effectively-grounded 3 phase or Single-phase, line-to-neutral	Pass screen

2.2.1.7 If the proposed Small Generating Facility is to be interconnected on single-phase shared secondary, the aggregate generation capacity on the shared secondary, including the proposed Small Generating Facility, shall not exceed 20 kW.

- 2.2.1.8 If the proposed Small Generating Facility is single-phase and is to be interconnected on a center tap neutral of a 240 volt service, its addition shall not create an imbalance between the two sides of the 240 volt service of more than 20 % of the nameplate rating of the service transformer.
- 2.2.1.9 The Small Generating Facility, in aggregate with other generation interconnected to the transmission side of a substation transformer feeding the circuit where the Small Generating Facility proposes to interconnect shall not exceed 10 MW in an area where there are known, or posted, transient stability limitations to generating units located in the general electrical vicinity (e.g., three or four transmission busses from the point of interconnection).
- 2.2.1.10 No construction of facilities by Transmission Provider on its own system shall be required to accommodate the Small Generating Facility.
- 2.2.2 If the proposed interconnection passes the screens, the Interconnection Request shall be approved and Transmission Provider will provide Interconnection Customer an executable interconnection agreement within five (5) Business Days after the determination.
- 2.2.3 If the proposed interconnection fails the screens, but Transmission Provider determines that the Small Generating Facility may nevertheless be interconnected consistent with safety, reliability, and power quality standards, Transmission Provider shall provide Interconnection Customer an executable interconnection agreement within five (5) Business Days after the determination.
- 2.2.4 If the proposed interconnection fails the screens, and Transmission Provider does not or cannot determine from the initial review that the Small Generating Facility may nevertheless be interconnected consistent with safety, reliability, and power quality standards unless Interconnection Customer is willing to consider minor modifications or further study, Transmission Provider shall provide

Interconnection Customer with the opportunity to attend a customer options meeting.

2.3 Customer Options Meeting

If Transmission Provider determines the Interconnection Request cannot be approved without (1) minor modifications at minimal cost, (2) a supplemental study or other additional studies or actions, or (3) incurring significant cost to address safety, reliability, or power quality problems, Transmission Provider shall notify Interconnection Customer of that determination within five (5) Business Days after the determination and provide copies of all data and analyses underlying its conclusion. Within ten (10) Business Days of Transmission Provider's determination, Transmission Provider shall offer to convene a customer options meeting with Transmission Provider to review possible Interconnection Customer facility modifications or the screen analysis and related results, to determine what further steps are needed to permit the Small Generating Facility to be connected safely and reliably. At the time of notification of Transmission Provider's determination, or at the customer options meeting, Transmission Provider shall:

- 2.3.1 Offer to perform facility modifications or minor modifications to Transmission Provider's electric system (e.g., changing meters, fuses, relay settings) and provide a non-binding good faith estimate of the limited cost to make such modifications to Transmission Provider's electric system. If Interconnection Customer agrees to pay for the modifications to the Transmission Provider's electric system, the Transmission Provider will provide the Interconnection Customer with an executable interconnection agreement within ten (10) Business Days of the customer options meeting; or
- 2.3.2 Offer to perform a supplemental review in accordance with section 2.4 and provide a non-binding good faith estimate of the costs of such review; or
- 2.3.3 Obtain Interconnection Customer's agreement to continue evaluating the Interconnection Request under the section 3 Study Process.

2.4 Supplemental Review

- 2.4.1 To accept the offer of a supplemental review, Interconnection Customer shall agree in writing and submit a deposit for the

estimated costs of the supplemental review in the amount of Transmission Provider's good faith estimate of the costs of such review, both within fifteen (15) Business Days of the offer. If the written agreement and deposit have not been received by Transmission Provider within that timeframe, the Interconnection Request shall continue to be evaluated under the section 3 Study Process unless it is withdrawn by Interconnection Customer.

- 2.4.2 Interconnection Customer may specify the order in which Transmission Provider will complete the screens in section 2.4.4.
- 2.4.3 Interconnection Customer shall be responsible for Transmission Provider's actual costs for conducting the supplemental review. Interconnection Customer must pay any review costs that exceed the deposit within twenty (20) Business Days of receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced costs, Transmission Provider will return such excess within twenty (20) Business Days of the invoice without interest.
- 2.4.4 Within thirty (30) Business Days following receipt of the deposit for a supplemental review, Transmission Provider shall (1) perform a supplemental review using the screens set forth below; (2) notify in writing Interconnection Customer of the results; and (3) include with the notification copies of the analysis and data underlying Transmission Provider's determinations under the screens. Unless Interconnection Customer provided instructions for how to respond to the failure of any of the supplemental review screens below at the time Interconnection Customer accepted the offer of supplemental review, Transmission Provider shall notify Interconnection Customer following the failure of any of the screens, or if it is unable to perform the screen in section 2.4.4.1, within two (2) Business Days of making such determination to obtain Interconnection Customer's permission to: (1) continue evaluating the proposed interconnection under this section 2.4.4; (2) terminate the supplemental review and continue evaluating the Small Generating Facility under section 3; or (3) terminate the supplemental review upon withdrawal of the Interconnection Request by Interconnection Customer.

- 2.4.4.1 Minimum Load Screen: Where 12 months of line section minimum load data (including onsite load but not station service load served by the proposed Small Generating Facility) are available, can be calculated, can be estimated from existing data, or determined from a power flow model, the aggregate Generating Facility capacity on the line section is less than 100% of the minimum load for all line sections bounded by automatic sectionalizing devices upstream of the proposed Small Generating Facility. If minimum load data is not available, or cannot be calculated, estimated or determined, Transmission Provider shall include the reason(s) that it is unable to calculate, estimate or determine minimum load in its supplemental review results notification under section 2.4.4.
- 2.4.4.1.1 The type of generation used by the proposed Small Generating Facility will be taken into account when calculating, estimating, or determining circuit or line section minimum load relevant for the application of screen 2.4.4.1. Solar photovoltaic (PV) generation systems with no battery storage use daytime minimum load (i.e. 10 a.m. to 4 p.m. for fixed panel systems and 8 a.m. to 6 p.m. for PV systems utilizing tracking systems), while all other generation uses absolute minimum load.
- 2.4. 4.1.2 When this screen is being applied to a Small Generating Facility that serves some station service load, only the net injection into Transmission Provider's electric system will be considered as part of the aggregate generation.
- 2.4. 4.1.3 Transmission Provider will not consider as part of the aggregate generation for purposes of this

screen generating facility capacity known to be already reflected in the minimum load data.

- 2.4.4.2 Voltage and Power Quality Screen: In aggregate with existing generation on the line section: (1) the voltage regulation on the line section can be maintained in compliance with relevant requirements under all system conditions; (2) the voltage fluctuation is within acceptable limits as defined by Institute of Electrical and Electronics Engineers (IEEE) Standard 1453, or utility practice similar to IEEE Standard 1453; and (3) the harmonic levels meet IEEE Standard 519 limits.
- 2.4.4.3 Safety and Reliability Screen: The location of the proposed Small Generating Facility and the aggregate generation capacity on the line section do not create impacts to safety or reliability that cannot be adequately addressed without application of the Study Process. Transmission Provider shall give due consideration to the following and other factors in determining potential impacts to safety and reliability in applying this screen.
- 2.4.4.3.1 Whether the line section has significant minimum loading levels dominated by a small number of customers (e.g., several large commercial customers).
- 2.4.4.3.2 Whether the loading along the line section is uniform or even.
- 2.4.4.3.3 Whether the proposed Small Generating Facility is located in close proximity to the substation (i.e., less than 2.5 electrical circuit miles), and whether the line section from the substation to the Point of Interconnection is a Mainline rated for normal and emergency ampacity.
- 2.4.4.3.4 Whether the proposed Small Generating Facility incorporates a time delay function to prevent reconnection of the generator to the

system until system voltage and frequency are within normal limits for a prescribed time.

2.4.4.3.5 Whether operational flexibility is reduced by the proposed Small Generating Facility, such that transfer of the line section(s) of the Small Generating Facility to a neighboring distribution circuit/substation may trigger overloads or voltage issues.

2.4.4.3.6 Whether the proposed Small Generating Facility employs equipment or systems certified by a recognized standards organization to address technical issues such as, but not limited to, islanding, reverse power flow, or voltage quality.

2.4.5 If the proposed interconnection passes the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above, the Interconnection Request shall be approved and Transmission Provider will provide Interconnection Customer with an executable interconnection agreement within the timeframes established in sections 2.4.5.1 and 2.4.5.2 below. If the proposed interconnection fails any of the supplemental review screens and Interconnection Customer does not withdraw its Interconnection Request, it shall continue to be evaluated under the section 3 Study Process consistent with section 2.4.5.3 below.

2.4.5.1 If the proposed interconnection passes the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above and does not require construction of facilities by Transmission Provider on its own system, the interconnection agreement shall be provided within ten (10) Business Days after the notification of the supplemental review results.

2.4.5.2 If interconnection facilities or minor modifications to Transmission Provider's system are required for the proposed interconnection to pass the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above, and Interconnection Customer agrees to pay for the modifications to Transmission Provider's electric system, the interconnection agreement,

along with a non-binding good faith estimate for the interconnection facilities and/or minor modifications, shall be provided to Interconnection Customer within fifteen (15) Business Days after receiving written notification of the supplemental review results.

- 2.4.5.3 If the proposed interconnection would require more than interconnection facilities or minor modifications to Transmission Provider's system to pass the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above, Transmission Provider shall notify Interconnection Customer, at the same time it notifies Interconnection Customer with the supplemental review results, that the Interconnection Request shall be evaluated under the section 3 Study Process unless Interconnection Customer withdraws its Small Generating Facility.

Section 3. Study Process

3.1 Applicability

The Study Process shall be used by an Interconnection Customer proposing to interconnect its Small Generating Facility with Transmission Provider's Transmission System or Distribution System if the Small Generating Facility (1) is larger than 2 MW but no larger than 20 MW, (2) is not certified, or (3) is certified but did not pass the Fast Track Process or the 10 kW Inverter Process.

3.2 Scoping Meeting

3.2.1 A scoping meeting will be held within ten (10) Business Days after the Interconnection Request is deemed complete, or as otherwise mutually agreed to by the Parties. Transmission Provider and Interconnection Customer will bring to the meeting personnel, including system engineers and other resources as may be reasonably required to accomplish the purpose of the meeting.

3.2.2 The purpose of the scoping meeting is to discuss the Interconnection Request and review existing studies relevant to the Interconnection Request. The Parties shall further discuss whether Transmission Provider

should perform a feasibility study or proceed directly to a system impact study, or a facilities study, or an interconnection agreement. If the Parties agree that a feasibility study should be performed, Transmission Provider shall provide Interconnection Customer, as soon as possible, but not later than five (5) Business Days after the scoping meeting, a feasibility study agreement (Attachment 6) including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study.

- 3.2.3 The scoping meeting may be omitted by mutual agreement. In order to remain in consideration for interconnection, an Interconnection Customer who has requested a feasibility study must return the executed feasibility study agreement within fifteen (15) Business Days. If the Parties agree not to perform a feasibility study, Transmission Provider shall provide Interconnection Customer, no later than five (5) Business Days after the scoping meeting, a system impact study agreement (Attachment 7) including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study.

3.3 Feasibility Study

- 3.3.1 The feasibility study shall identify any potential adverse system impacts that would result from the interconnection of the Small Generating Facility.
- 3.3.2 A deposit of the lesser of 50 percent of the good faith estimated feasibility study costs or earnest money of \$1,000 may be required from Interconnection Customer.
- 3.3.3 The scope of and cost responsibilities for the feasibility study are described in the attached feasibility study agreement (Attachment 6).
- 3.3.4 If the feasibility study shows no potential for adverse system impacts, Transmission Provider shall send Interconnection Customer a facilities study agreement, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study. If no additional facilities are required, Transmission Provider shall send Interconnection Customer an executable interconnection agreement within five (5) Business Days.
- 3.3.5 If the feasibility study shows the potential for adverse system impacts, the review process shall proceed to the appropriate system impact study(s).

3.3.6 The feasibility study shall evaluate static synchronous compensators, static VAR compensators, advanced power flow control devices, transmission switching, synchronous condensers, voltage source converters, advanced conductors, and tower lifting. Transmission Provider shall evaluate each identified alternative transmission technology and determine whether it should be used, consistent with Good Utility Practice, Applicable Reliability Standards, and Applicable Laws and Regulations. Transmission Provider shall include an explanation of the results of Transmission Provider's evaluation for each technology in the feasibility study report.

3.4 System Impact Study

3.4.1 A system impact study shall identify and detail the electric system impacts that would result if the proposed Small Generating Facility were interconnected without project modifications or electric system modifications, focusing on the adverse system impacts identified in the feasibility study, or to study potential impacts, including but not limited to those identified in the scoping meeting. A system impact study shall evaluate the impact of the proposed interconnection on the reliability of the electric system.

3.4.2 If no transmission system impact study is required, but potential electric power Distribution System adverse system impacts are identified in the scoping meeting or shown in the feasibility study, a distribution system impact study must be performed. Transmission Provider shall send Interconnection Customer a distribution system impact study agreement within fifteen (15) Business Days of transmittal of the feasibility study report, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study, or following the scoping meeting if no feasibility study is to be performed.

3.4.3 In instances where the feasibility study or the distribution system impact study shows potential for transmission system adverse system impacts, within five (5) Business Days following transmittal of the feasibility study report, Transmission Provider shall send Interconnection Customer a transmission system impact study agreement, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study, if such a study is required.

- 3.4.4 If a transmission system impact study is not required, but electric power Distribution System adverse system impacts are shown by the feasibility study to be possible and no distribution system impact study has been conducted, Transmission Provider shall send Interconnection Customer a distribution system impact study agreement.
- 3.4.5 If the feasibility study shows no potential for transmission system or Distribution System adverse system impacts, Transmission Provider shall send Interconnection Customer either a facilities study agreement (Attachment 8), including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study, or an executable interconnection agreement, as applicable.
- 3.4.6 In order to remain under consideration for interconnection, Interconnection Customer must return executed system impact study agreements, if applicable, within thirty (30) Business Days.
- 3.4.7 A deposit of the good faith estimated costs for each system impact study may be required from Interconnection Customer.
- 3.4.8 The scope of and cost responsibilities for a system impact study are described in the attached system impact study agreement.
- 3.4.9 Where transmission systems and Distribution Systems have separate owners, such as is the case with transmission-dependent utilities (“TDUs”) – whether investor-owned or not – Interconnection Customer may apply to the nearest Transmission Provider (Transmission Owner, Regional Transmission Operator, or Independent Transmission Provider) providing transmission service to the TDU to request project coordination. Affected Systems shall participate in the study and provide all information necessary to prepare the study.
- 3.4.10 The system impact study shall evaluate static synchronous compensators, static VAR compensators, advanced power flow control devices, transmission switching, synchronous condensers, voltage source converters, advanced conductors, and tower lifting. Transmission Provider shall evaluate each identified alternative transmission technology and determine whether it should be used, consistent with Good Utility Practice, Applicable Reliability Standards, and Applicable Laws and Regulations. Transmission Provider shall include an explanation of the results of Transmission

Provider's evaluation for each technology in the system impact study report.

3.5 Facilities Study

- 3.5.1 Once the required system impact study(s) is completed, a system impact study report shall be prepared and transmitted to Interconnection Customer along with a facilities study agreement within five (5) Business Days, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the facilities study. In the case where one or both impact studies are determined to be unnecessary, a notice of the fact shall be transmitted to Interconnection Customer within the same timeframe.
- 3.5.2 In order to remain under consideration for interconnection, or, as appropriate, in Transmission Provider's interconnection queue, Interconnection Customer must return the executed facilities study agreement or a request for an extension of time within thirty (30) Business Days.
- 3.5.3 The facilities study shall specify and estimate the cost of the equipment, engineering, procurement and construction work (including overheads) needed to implement the conclusions of the system impact study(s).
- 3.5.4 Design for any required Interconnection Facilities and/or Upgrades shall be performed under the facilities study agreement. Transmission Provider may contract with consultants to perform activities required under the facilities study agreement. Interconnection Customer and Transmission Provider may agree to allow Interconnection Customer to separately arrange for the design of some of the Interconnection Facilities. In such cases, facilities design will be reviewed and/or modified prior to acceptance by Transmission Provider, under the provisions of the facilities study agreement. If the Parties agree to separately arrange for design and construction, and provided security and confidentiality requirements can be met, Transmission Provider shall make sufficient information available to Interconnection Customer in accordance with confidentiality and critical infrastructure requirements to permit Interconnection Customer to obtain an independent design and cost estimate for any necessary facilities.

- 3.5.5 A deposit of the good faith estimated costs for the facilities study may be required from Interconnection Customer.
- 3.5.6 The scope of and cost responsibilities for the facilities study are described in the attached facilities study agreement.
- 3.5.7 Upon completion of the facilities study, and with the agreement of Interconnection Customer to pay for Interconnection Facilities and Upgrades identified in the facilities study, Transmission Provider shall provide Interconnection Customer an executable interconnection agreement within five (5) Business Days.

Section 4. Provisions that Apply to All Interconnection Requests

1.1 Reasonable Efforts

Transmission Provider shall make reasonable efforts to meet all time frames provided in these procedures unless Transmission Provider and Interconnection Customer agree to a different schedule. If Transmission Provider cannot meet a deadline provided herein, it shall notify Interconnection Customer, explain the reason for the failure to meet the deadline, and provide an estimated time by which it will complete the applicable interconnection procedure in the process.

4.2 Disputes

- 4.2.1 The Parties agree to attempt to resolve all disputes arising out of the interconnection process according to the provisions of this article.
- 4.2.2 In the event of a dispute, either Party shall provide the other Party with a written Notice of Dispute. Such Notice shall describe in detail the nature of the dispute.
- 4.2.3 If the dispute has not been resolved within two (2) Business Days after receipt of the Notice, either Party may contact FERC's Dispute Resolution Service (DRS) for assistance in resolving the dispute.
- 4.2.4 The DRS will assist the Parties in either resolving their dispute or in selecting an appropriate dispute resolution venue (e.g., mediation, settlement judge, early neutral evaluation, or technical expert) to assist the

Parties in resolving their dispute. DRS can be reached at 1-877-337-2237 or via the internet at <http://www.ferc.gov/legal/adr.asp>.

- 4.2.5 Each Party agrees to conduct all negotiations in good faith and will be responsible for one-half of any costs paid to neutral third-parties.
- 4.2.6 If neither Party elects to seek assistance from the DRS, or if the attempted dispute resolution fails, then either Party may exercise whatever rights and remedies it may have in equity or law consistent with the terms of these procedures.

4.3 Interconnection Metering

Any metering necessitated by the use of the Small Generating Facility shall be installed at Interconnection Customer's expense in accordance with Federal Energy Regulatory Commission, state, or local regulatory requirements or Transmission Provider's specifications.

4.4 Commissioning

Commissioning tests of Interconnection Customer's installed equipment shall be performed pursuant to applicable codes and standards. Transmission Provider must be given at least five (5) Business Days written notice, or as otherwise mutually agreed to by the Parties, of the tests and may be present to witness the commissioning tests.

4.5. Confidentiality

4.5.1 Confidential information shall mean any confidential and/or proprietary information provided by one Party to the other Party that is clearly marked or otherwise designated "Confidential." For purposes of these procedures all design, operating specifications, and metering data provided by Interconnection Customer shall be deemed confidential information regardless of whether it is clearly marked or otherwise designated as such.

4.5.2 Confidential Information does not include information previously in the public domain, required to be publicly submitted or divulged by Governmental Authorities (after notice to the other Party and after exhausting any opportunity to oppose such publication or release), or necessary to be divulged in an action to enforce these procedures. Each Party receiving Confidential Information shall hold such information in

confidence and shall not disclose it to any third party nor to the public without the prior written authorization from the Party providing that information, except to fulfill obligations under these procedures, or to fulfill legal or regulatory requirements.

4.5.2.1 Each Party shall employ at least the same standard of care to protect Confidential Information obtained from the other Party as it employs to protect its own Confidential Information.

4.5.2.2 Each Party is entitled to equitable relief, by injunction or otherwise, to enforce its rights under this provision to prevent the release of Confidential Information without bond or proof of damages, and may seek other remedies available at law or in equity for breach of this provision.

4.5.3 Notwithstanding anything in this article to the contrary, and pursuant to 18 CFR § 1b.20, if FERC, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to these procedures, the Party shall provide the requested information to FERC, within the time provided for in the request for information. In providing the information to FERC, the Party may, consistent with 18 CFR § 388.112, request that the information be treated as confidential and non-public by FERC and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party prior to the release of the Confidential Information to FERC. The Party shall notify the other Party when it is notified by FERC that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR § 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

4.6 Comparability

Transmission Provider shall receive, process and analyze all Interconnection Requests in a timely manner as set forth in this document. Transmission Provider shall use the same reasonable efforts in processing and analyzing Interconnection

Requests from all Interconnection Customers, whether the Small Generating Facility is owned or operated by Transmission Provider, its subsidiaries or affiliates, or others.

4.7 Record Retention

Transmission Provider shall maintain for three years records, subject to audit, of all Interconnection Requests received under these procedures, the times required to complete Interconnection Request approvals and disapprovals, and justification for the actions taken on the Interconnection Requests.

4.8 Interconnection Agreement

After receiving an interconnection agreement from Transmission Provider, Interconnection Customer shall have thirty (30) Business Days or another mutually agreeable timeframe to sign and return the interconnection agreement or request that Transmission Provider file an unexecuted interconnection agreement with the Federal Energy Regulatory Commission. If Interconnection Customer does not sign the interconnection agreement, or ask that it be filed unexecuted by Transmission Provider within thirty (30) Business Days, the Interconnection Request shall be deemed withdrawn. After the interconnection agreement is signed by the Parties, the interconnection of the Small Generating Facility shall proceed under the provisions of the interconnection agreement.

4.9 Coordination with Affected Systems

Transmission Provider shall coordinate the conduct of any studies required to determine the impact of the Interconnection Request on Affected Systems with Affected System operators and, if possible, include those results (if available) in its applicable interconnection study within the time frame specified in these procedures. Transmission Provider will include such Affected System operators in all meetings held with Interconnection Customer as required by these procedures. Interconnection Customer will cooperate with Transmission Provider in all matters related to the conduct of studies and the determination of modifications to Affected Systems. A Transmission Provider which may be an Affected System shall cooperate with Transmission Provider with whom interconnection has been requested in all matters related to the conduct of studies and the determination of modifications to Affected Systems.

4.10 Capacity of the Small Generating Facility

- 4.10.1 If the Interconnection Request is for an increase in capacity for an existing Small Generating Facility, the Interconnection Request shall be evaluated on the basis of the new total capacity of the Small Generating Facility.
- 4.10.2 If the Interconnection Request is for a Small Generating Facility that includes multiple energy production devices at a site for which Interconnection Customer seeks a single Point of Interconnection, the Interconnection Request shall be evaluated on the basis of the aggregate capacity of the multiple devices.
- 4.10.3 The Interconnection Request shall be evaluated using the maximum capacity that the Small Generating Facility is capable of injecting into Transmission Provider's electric system. However, if the maximum capacity that the Small Generating Facility is capable of injecting into Transmission Provider's electric system is limited (e.g., through use of a control system, power relay(s), or other similar device settings or adjustments), then Interconnection Customer must obtain Transmission Provider's agreement, with such agreement not to be unreasonably withheld, that the manner in which Interconnection Customer proposes to implement such a limit will not adversely affect the safety and reliability of Transmission Provider's system. If Transmission Provider does not so agree, then the Interconnection Request must be withdrawn or revised to specify the maximum capacity that the Small Generating Facility is capable of injecting into Transmission Provider's electric system without such limitations. Furthermore, nothing in this section shall prevent a Transmission Provider from considering an output higher than the limited output, if appropriate, when evaluating system protection impacts.

Attachment 1

Glossary of Terms

10 kW Inverter Process – The procedure for evaluating an Interconnection Request for a certified inverter-based Small Generating Facility no larger than 10 kW that uses the section 2 screens. The application process uses an all-in-one document that includes a simplified Interconnection Request, simplified procedures, and a brief set of terms and conditions. See SGIP Attachment 5.

Affected System – An electric system other than Transmission Provider’s Transmission System that may be affected by the proposed interconnection.

Applicable Reliability Standards – The requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Applicable Laws and Regulations – All duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Business Day – Monday through Friday, excluding Federal Holidays.

Distribution System – Transmission Provider’s facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which Distribution Systems operate differ among areas.

Distribution Upgrades – The additions, modifications, and upgrades to Transmission Provider’s Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Small Generating Facility and render the transmission service necessary to effect Interconnection Customer’s wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Fast Track Process – The procedure for evaluating an Interconnection Request for a certified Small Generating Facility that meets the eligibility requirements of section 2.1 and includes the section 2 screens, customer options meeting, and optional supplemental review.

Good Utility Practice – Any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and act which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Interconnection Customer – Any entity, including Transmission Provider, the Transmission Owner or any of the affiliates or subsidiaries of either, that proposes to interconnect its Small Generating Facility with Transmission Provider’s Transmission System.

Interconnection Facilities – Transmission Provider’s Interconnection Facilities and Interconnection Customer’s Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Small Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Small Generating Facility to Transmission Provider’s Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades or Network Upgrades.

Interconnection Request – Interconnection Customer’s request, in accordance with the Tariff, to interconnect a new Small Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Small Generating Facility that is interconnected with Transmission Provider’s Transmission System.

Material Modification – A modification that has a material impact on the cost or timing of any Interconnection Request with a later queue priority date.

Network Resource – Any designated generating resource owned, purchased, or leased by a Network Customer under the Network Integration Transmission Service Tariff. Network Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Network Customer’s Network Load on a non-interruptible basis.

Network Resource Interconnection Service – An Interconnection Service that allows Interconnection Customer to integrate its Generating Facility with Transmission Provider’s System (1) in a manner comparable to that in which Transmission Provider

integrates its generating facilities to serve native load customers; or (2) in an RTO or ISO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service in and of itself does not convey transmission service.

Network Upgrades – Additions, modifications, and upgrades to Transmission Provider’s Transmission System required at or beyond the point at which the Small Generating Facility interconnects with Transmission Provider’s Transmission System to accommodate the interconnection with the Small Generating Facility to Transmission Provider’s Transmission System. Network Upgrades do not include Distribution Upgrades.

Party or Parties – Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Point of Interconnection – The point where the Interconnection Facilities connect with Transmission Provider’s Transmission System.

Queue Position – The order of a valid Interconnection Request, relative to all other pending valid Interconnection Requests, that is established based upon the date and time of receipt of the valid Interconnection Request by Transmission Provider.

Small Generating Facility – Interconnection Customer’s device for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer’s Interconnection Facilities.

Study Process – The procedure for evaluating an Interconnection Request that includes the section 3 scoping meeting, feasibility study, system impact study, and facilities study.

Transmission Owner – The entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Small Generator Interconnection Agreement to the extent necessary.

Transmission Provider – The public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission System – The facilities owned, controlled or operated by Transmission Provider or the Transmission Owner that are used to provide transmission service under the Tariff.

Upgrades – The required additions and modifications to Transmission Provider’s Transmission System at or beyond the Point of Interconnection. Upgrades may be Network Upgrades or Distribution Upgrades. Upgrades do not include Interconnection Facilities.

Attachment 2
SMALL GENERATOR INTERCONNECTION REQUEST
(Application Form)

Transmission Provider: _____

Designated Contact Person: _____

Address: _____

Telephone Number: _____

Fax: _____

E-Mail Address: _____

An Interconnection Request is considered complete when it provides all applicable and correct information required below. Per SGIP section 1.5, documentation of site control must be submitted with the Interconnection Request.

Preamble and Instructions

An Interconnection Customer who requests a Federal Energy Regulatory Commission jurisdictional interconnection must submit this Interconnection Request by hand delivery, mail, e-mail, or fax to Transmission Provider.

Processing Fee or Deposit:

If the Interconnection Request is submitted under the Fast Track Process, the non-refundable processing fee is \$500.

If the Interconnection Request is submitted under the Study Process, whether a new submission or an Interconnection Request that did not pass the Fast Track Process, Interconnection Customer shall submit to Transmission Provider a deposit not to exceed \$1,000 towards the cost of the feasibility study.

Interconnection Customer Information

Legal Name of Interconnection Customer (or, if an individual, individual's name)

Name: _____

Contact Person: _____

Mailing Address:

City: _____ State: _____ Zip: _____

Facility Location (if different from above):

Telephone (Day): _____ Telephone (Evening): _____

Fax: _____ E-Mail Address: _____

Alternative Contact Information (if different from Interconnection Customer)

Contact Name: _____

Title: _____

Address: _____

Telephone (Day): _____ Telephone (Evening): _____

Fax: _____ E-Mail Address: _____

Application is for: _____ New Small Generating Facility

_____ Capacity addition to Existing Small Generating Facility

If capacity addition to existing facility, please describe: _____

Will the Small Generating Facility be used for any of the following?

Net Metering? Yes ___ No ___

To Supply Power to Interconnection Customer? Yes ___ No ___

To Supply Power to Others? Yes ___ No ___

For installations at locations with existing electric service to which the proposed Small Generating Facility will interconnect, provide:

(Local Electric Service Provider*)

(Existing Account Number*)

{*To be provided by Interconnection Customer if the local electric service provider is different from Transmission Provider}

Contact Name:

Title:

Address:

Telephone (Day): _____ Telephone (Evening): _____

Fax: _____ E-Mail Address: _____

Requested Point of Interconnection:

Interconnection Customer's Requested In-Service Date:

Small Generating Facility Information

Data apply only to the Small Generating Facility, not the Interconnection Facilities.

Energy Source: ___ Solar ___ Wind ___ Hydro ___ Hydro Type (e.g. Run-of-River): _____
___ Diesel ___ Natural Gas ___ Fuel Oil Other (state type)

Prime Mover: ___ Fuel Cell ___ Recip Engine ___ Gas Turb ___ Steam Turb

Microturbine PV Other

Type of Generator: Synchronous Induction Inverter

Generator Nameplate Rating: _____ kW (Typical) Generator Nameplate kVAR:

Interconnection Customer or Customer-Site Load: _____ kW (if none, so state)

Typical Reactive Load (if known): _____

Maximum Physical Export Capability Requested: _____ kW

List components of the Small Generating Facility equipment package that are currently certified:

	Equipment Type	Certifying Entity
1.	_____	_____
2.	_____	_____
3.	_____	_____
4.	_____	_____
5.	_____	_____

Is the prime mover compatible with the certified protective relay package? Yes
 No

Generator (or solar collector) Manufacturer, Model Name & Number:

Version Number: _____

Nameplate Output Power Rating in kW: (Summer) _____ (Winter)

Nameplate Output Power Rating in kVA: (Summer) _____ (Winter)

Individual Generator Power Factor

Rated Power Factor: Leading: _____ Lagging: _____

Total Number of Generators in wind farm to be interconnected pursuant to this

Interconnection Request: _____ Elevation: _____ Single phase _____ Three phase

Inverter Manufacturer, Model Name & Number (if used): _____

List of adjustable set points for the protective equipment or software:

Note: A completed Power Systems Load Flow data sheet must be supplied with the Interconnection Request.

Small Generating Facility Characteristic Data (for inverter-based machines)

Max design fault contribution current: _____ Instantaneous or RMS _____?

Harmonics Characteristics:

Start-up requirements:

Small Generating Facility Characteristic Data (for rotating machines)

RPM Frequency: _____

(*) Neutral Grounding Resistor (If Applicable): _____

Synchronous Generators:

Direct Axis Synchronous Reactance, X_d : _____ P.U.

Direct Axis Transient Reactance, X'_d : _____ P.U.

Direct Axis Subtransient Reactance, X''_d : _____ P.U.

Negative Sequence Reactance, X_2 : _____ P.U.

Zero Sequence Reactance, X_0 : _____ P.U.

KVA Base: _____

Field Volts: _____

Field Amperes: _____

Induction Generators:

Motoring Power (kW): _____

I²t or K (Heating Time Constant): _____

Rotor Resistance, R_r : _____

Stator Resistance, R_s : _____

Stator Reactance, X_s : _____

Rotor Reactance, X_r : _____

Magnetizing Reactance, X_m : _____

Short Circuit Reactance, X_d'' : _____

Exciting Current: _____

Temperature Rise: _____

Frame Size: _____

Design Letter: _____

Reactive Power Required In Vars (No Load): _____

Reactive Power Required In Vars (Full Load): _____

Total Rotating Inertia, H: _____ Per Unit on kVA Base

Note: Please contact Transmission Provider prior to submitting the Interconnection Request to determine if the specified information above is required.

Excitation and Governor System Data for Synchronous Generators Only

Provide appropriate IEEE model block diagram of excitation system, governor system and power system stabilizer (PSS) in accordance with the regional reliability council criteria. A PSS may be determined to be required by applicable studies. A copy of the manufacturer’s block diagram may not be substituted.

Models for Non-synchronous Small Generating Facilities

For a non-synchronous Small Generating Facility, Interconnection Customer shall provide (1) a validated user-defined root mean squared (RMS) positive sequence dynamics model; (2) an appropriately parameterized generic library RMS positive sequence dynamics model, including model block diagram of the inverter control and plant control systems, as defined by the selection in Table 1 or a model otherwise approved by the Western Electricity Coordinating Council, that corresponds to Interconnection Customer’s Small Generating Facility; and (3) if applicable, a validated electromagnetic transient model if Transmission Provider performs an electromagnetic transient study as part of the interconnection study process. A user-defined model is a set of programming code created by equipment manufacturers or developers that captures the latest features of controllers that are mainly software based and represents the entities’ control strategies but does not necessarily correspond to any generic library model. Interconnection Customer must also demonstrate that the model is validated by providing evidence that the equipment behavior is consistent with the model behavior (e.g., an attestation from Interconnection Customer that the model accurately represents the entire Small Generating Facility; attestations from each equipment manufacturer that the user defined model accurately represents the component of the Small Generating Facility; or test data).

Table 1: Acceptable Generic Library RMS Positive Sequence Dynamics Models

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
pvd1		PVD1	Distributed PV system model
der_a	DERAU1	DER_A	Distributed energy resource model
regc_a	REGCAU1, REGCA1	REGC_A	Generator/converter model
regc_b	REGCBU1	REGC_B	Generator/converter model
wtlg	WT1G1	WT1G and WT1G1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
wt2g	WT2G1	WT2G and WT2G1	Generator model for generic Type-2 wind turbines
wt2e	WT2E1	WT2E and WT2E1	Rotor resistance control model for wound-rotor induction wind-turbine generator wt2g
reec_a	REECAU1, REECA1	REEC_A	Renewable energy electrical control model
reec_c	REECCU1	REEC_C	Electrical control model for battery energy storage system
reec_d	REECDU1	REEC_D	Renewable energy electrical control model
wt1t	WT12T1	WT1T and WT12T1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)
wt1p_b	wt1p_b	WT12A1U_B	Generic wind turbine pitch controller for WTGs of Types 1 and 2
wt2t	WT12T1	WT2T	Wind turbine model for Type-2 wind turbines (directly connected induction generator wind turbines with an external rotor resistance)
wtgt_a	WTDTAU1, WTDTA1	WTGT_A	Wind turbine drive train model
wtga_a	WTARAU1, WTARA1	WTGA_A	Simple aerodynamic model
wtgp_a	WTPTAU1, WTPTA1	WTGPT_A	Wind Turbine Generator Pitch controller
wtgq_a	WTTQAU1, WTTQA1	WTGTRQ_A	Wind Turbine Generator Torque controller
wtgwgo_a	WTGWGOAU	WTGWGO_A	Supplementary control model for Weak Grids
wtgibffr_a	WTGIBFFRA	WTGIBFFR_A	Inertial-base fast frequency response control
wtgp_b	WTPTBU1	WTGPT_B	Wind Turbine Generator Pitch controller
wtgt_b	WTDTBUI	WTGT_B	Drive train model

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
repc_a	Type 4: REPCAU1 (v33), REPCA1 (v34) Type 3: REPCTAU1 (v33), REPCTA1 (v34)	REPC_A	Power Plant Controller
repc_b	PLNTBU1	REPC_B	Power Plant Level Controller for controlling several plants/devices In regard to Siemens PSS/E*: Names of other models for interface with other devices: REA3XBU1, REAX4BU1- for interface with Type 3 and 4 renewable machines SWSAXBU1- for interface with SVC (modeled as switched shunt in powerflow) SYNAXBU1- for interface with synchronous condenser FCTAXBUI- for interface with FACTS device
repc_c	REPCCU	REPC_C	Power plant controller

Interconnection Facilities Information

Will a transformer be used between the generator and the point of common coupling?

Yes No

Will the transformer be provided by Interconnection Customer? Yes No

Transformer Data (If Applicable, for Interconnection Customer-Owned Transformer):

Is the transformer: single phase three phase? Size:
 kVA

Transformer Impedance: _____% on _____kVA Base

If Three Phase:

Transformer Primary: _____ Volts _____ Delta _____ Wye _____ Wye Grounded

Transformer Secondary: _____ Volts _____ Delta _____ Wye _____ Wye Grounded

Transformer Tertiary: _____ Volts _____ Delta _____ Wye _____ Wye Grounded

Transformer Fuse Data (If Applicable, for Interconnection Customer-Owned Fuse):

(Attach copy of fuse manufacturer’s Minimum Melt and Total Clearing Time-Current Curves)

Manufacturer: _____ Type: _____ Size: _____ Speed: _____

Interconnecting Circuit Breaker (if applicable):

Manufacturer: _____ Type: _____

Load Rating (Amps): _____ Interrupting Rating (Amps): _____ Trip Speed (Cycles): _____

Interconnection Protective Relays (If Applicable):

If Microprocessor-Controlled:

List of Functions and Adjustable Setpoints for the protective equipment or software:

	Setpoint Function	Minimum	Maximum
1.	_____	_____	_____
2.	_____	_____	_____
3.	_____	_____	_____
4.	_____	_____	_____
5.	_____	_____	_____
6.	_____	_____	_____

If Discrete Components:

(Enclose Copy of any Proposed Time-Overcurrent Coordination Curves)

Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____

Current Transformer Data (If Applicable):

(Enclose Copy of Manufacturer's Excitation and Ratio Correction Curves)

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection: _____

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection: _____

Potential Transformer Data (If Applicable):

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection:

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection:

General Information

Enclose copy of site electrical one-line diagram showing the configuration of all Small Generating Facility equipment, current and potential circuits, and protection and control schemes. This one-line diagram must be signed and stamped by a licensed Professional Engineer if the Small Generating Facility is larger than 50 kW. Is One-Line Diagram Enclosed? ___ Yes ___ No

Enclose copy of any site documentation that indicates the precise physical location of the proposed Small Generating Facility (e.g., USGS topographic map or other diagram or documentation).

Proposed location of protective interface equipment on property (include address if different from Interconnection Customer’s address) _____

Enclose copy of any site documentation that describes and details the operation of the protection and control schemes. Is Available Documentation Enclosed? ___ Yes ___ No

Enclose copies of schematic drawings for all protection and control circuits, relay current circuits, relay potential circuits, and alarm/monitoring circuits (if applicable).

Are Schematic Drawings Enclosed? ___ Yes ___ No

Applicant Signature

I hereby certify that, to the best of my knowledge, all the information provided in this Interconnection Request is true and correct.

For Interconnection Customer: _____ Date:

Attachment 3

Certification Codes and Standards

IEEE1547 Standard for Interconnecting Distributed Resources with Electric Power Systems (including use of IEEE 1547.1 testing protocols to establish conformity)

UL 1741 Inverters, Converters, and Controllers for Use in Independent Power Systems

IEEE Std 929-2000 IEEE Recommended Practice for Utility Interface of Photovoltaic (PV) Systems

NFPA 70 (2002), National Electrical Code

IEEE Std C37.90.1-1989 (R1994), IEEE Standard Surge Withstand Capability (SWC) Tests for Protective Relays and Relay Systems

IEEE Std C37.90.2 (1995), IEEE Standard Withstand Capability of Relay Systems to Radiated Electromagnetic Interference from Transceivers

IEEE Std C37.108-1989 (R2002), IEEE Guide for the Protection of Network Transformers

IEEE Std C57.12.44-2000, IEEE Standard Requirements for Secondary Network Protectors

IEEE Std C62.41.2-2002, IEEE Recommended Practice on Characterization of Surges in Low Voltage (1000V and Less) AC Power Circuits

IEEE Std C62.45-1992 (R2002), IEEE Recommended Practice on Surge Testing for Equipment Connected to Low-Voltage (1000V and Less) AC Power Circuits

ANSI C84.1-1995 Electric Power Systems and Equipment – Voltage Ratings (60 Hertz)

IEEE Std 100-2000, IEEE Standard Dictionary of Electrical and Electronic Terms

NEMA MG 1-1998, Motors and Small Resources, Revision 3

IEEE Std 519-1992, IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems

NEMA MG 1-2003 (Rev 2004), Motors and Generators, Revision 1

Attachment 4

Certification of Small Generator Equipment Packages

- 1.0 Small Generating Facility equipment proposed for use separately or packaged with other equipment in an interconnection system shall be considered certified for interconnected operation if (1) it has been tested in accordance with industry standards for continuous utility interactive operation in compliance with the appropriate codes and standards referenced below by any Nationally Recognized Testing Laboratory (NRTL) recognized by the United States Occupational Safety and Health Administration to test and certify interconnection equipment pursuant to the relevant codes and standards listed in SGIP Attachment 3, (2) it has been labeled and is publicly listed by such NRTL at the time of the interconnection application, and (3) such NRTL makes readily available for verification all test standards and procedures it utilized in performing such equipment certification, and, with consumer approval, the test data itself. The NRTL may make such information available on its website and by encouraging such information to be included in the manufacturer's literature accompanying the equipment.
- 2.0 Interconnection Customer must verify that the intended use of the equipment falls within the use or uses for which the equipment was tested, labeled, and listed by the NRTL.
- 3.0 Certified equipment shall not require further type-test review, testing, or additional equipment to meet the requirements of this interconnection procedure; however, nothing herein shall preclude the need for an on-site commissioning test by the parties to the interconnection nor follow-up production testing by the NRTL.
- 4.0 If the certified equipment package includes only interface components (switchgear, inverters, or other interface devices), then an Interconnection Customer must show that the generator or other electric source being utilized with the equipment package is compatible with the equipment package and is consistent with the testing and listing specified for this type of interconnection equipment.
- 5.0 Provided the generator or electric source, when combined with the equipment package, is within the range of capabilities for which it was tested by the NRTL, and does not violate the interface components' labeling and listing performed by the NRTL, no further design review, testing or additional equipment on the

customer side of the point of common coupling shall be required to meet the requirements of this interconnection procedure.

6.0 An equipment package does not include equipment provided by the utility.

7.0 Any equipment package approved and listed in a state by that state's regulatory body for interconnected operation in that state prior to the effective date of these small generator interconnection procedures shall be considered certified under these procedures for use in that state.

Attachment 5

Application, Procedures, and Terms and Conditions for Interconnecting a Certified Inverter-Based Small Generating Facility No Larger than 10 kW (“10 kW Inverter Process”)

- 1.0 Interconnection Customer (“Customer”) completes the Interconnection Request (“Application”) and submits it to Transmission Provider (“Company”).
- 2.0 The Company acknowledges to the Customer receipt of the Application within three (3) Business Days of receipt.
- 3.0 The Company evaluates the Application for completeness and notifies the Customer within ten (10) Business Days of receipt that the Application is or is not complete and, if not, advises what material is missing.
- 4.0 The Company verifies that the Small Generating Facility can be interconnected safely and reliably using the screens contained in the Fast Track Process in the Small Generator Interconnection Procedures (SGIP). The Company has fifteen (15) Business Days to complete this process. Unless the Company determines and demonstrates that the Small Generating Facility cannot be interconnected safely and reliably, the Company approves the Application and returns it to the Customer. Note to Customer: Please check with the Company before submitting the Application if disconnection equipment is required.
- 5.0 After installation, the Customer returns the Certificate of Completion to the Company. Prior to parallel operation, the Company may inspect the Small Generating Facility for compliance with standards which may include a witness test, and may schedule appropriate metering replacement, if necessary.
- 6.0 The Company notifies the Customer in writing that interconnection of the Small Generating Facility is authorized. If the witness test is not satisfactory, the Company has the right to disconnect the Small Generating Facility. The Customer has no right to operate in parallel until a witness test has been performed, or previously waived on the Application. The Company is obligated to complete this witness test within ten (10) Business Days of the receipt of the Certificate of Completion. If the Company does not inspect within ten (10) Business Days or by mutual agreement of the Parties, the witness test is deemed waived.

- 7.0 Contact Information – The Customer must provide the contact information for the legal applicant (i.e., Interconnection Customer). If another entity is responsible for interfacing with the Company, that contact information must be provided on the Application.
- 8.0 Ownership Information – Enter the legal names of the owner(s) of the Small Generating Facility. Include the percentage ownership (if any) by any utility or public utility holding company, or by any entity owned by either.
- 9.0 UL1741 Listed – This standard (“Inverters, Converters, and Controllers for Use in Independent Power Systems”) addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL1741. This “listing” is then marked on the equipment and supporting documentation.

Application for Interconnecting a Certified Inverter-Based Small Generating Facility No Larger than 10kW

This Application is considered complete when it provides all applicable and correct information required below. Per SGIP section 1.5, documentation of site control must be submitted with the Interconnection Request. Additional information to evaluate the Application may be required.

Processing Fee

A non-refundable processing fee of \$100 must accompany this Application.

Interconnection Customer

Name:

Contact Person:

Address:

City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

Contact (if different from Interconnection Customer)

Name:

Contact Person:

Address:

City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

Owner of the facility (include % ownership by any electric utility):

____ Small Generating Facility Information

Location (if different from above):

Electric Service Company:

Account Number:

Inverter Manufacturer: _____ Model: _____
Nameplate Rating: _____ (kW) _____ (kVA) _____ (AC Volts)

Single Phase ____ Three Phase ____

System Design Capacity: _____ (kW) _____ (kVA)

Prime Mover: ____ Photovoltaic ____ Reciprocating Engine ____ Fuel Cell
____ Turbine ____ Other (describe) _____

Energy Source: ____ Solar ____ Wind ____ Hydro ____ Diesel ____ Natural Gas
____ Fuel Oil ____ Other (describe) _____

Is the equipment UL1741 Listed? ____ Yes ____ No

If Yes, attach manufacturer's cut-sheet showing UL1741 listing

Estimated Installation Date: _____ Estimated In-Service Date:

The 10 kW Inverter Process is available only for inverter-based Small Generating Facilities no larger than 10 kW that meet the codes, standards, and certification requirements of Attachments 3 and 4 of the Small Generator Interconnection Procedures (SGIP), or Transmission Provider has reviewed the design or tested the proposed Small Generating Facility and is satisfied that it is safe to operate.

List components of the Small Generating Facility equipment package that are currently certified:

	Equipment Type	Certifying Entity
1.	_____	_____
2.	_____	_____
3.	_____	_____
4.	_____	_____
5.	_____	_____

Interconnection Customer Signature

I hereby certify that, to the best of my knowledge, the information provided in this Application is true. I agree to abide by the Terms and Conditions for Interconnecting an Inverter-Based Small Generating Facility No Larger than 10kW and return the Certificate of Completion when the Small Generating Facility has been installed.

Signed:

Title: _____

Date:

.....
.....

Contingent Approval to Interconnect the Small Generating Facility

(For Company use only)

Interconnection of the Small Generating Facility is approved contingent upon the Terms and Conditions for Interconnecting an Inverter-Based Small Generating Facility No Larger than 10kW and return of the Certificate of Completion.

Company Signature:

Title: _____

Date:

Application ID number: _____

Company waives inspection/witness test? Yes ___ No ___

Small Generating Facility Certificate of Completion

Is the Small Generating Facility owner-installed? Yes _____ No _____

Interconnection Customer:

Contact Person:

Address:

Location of the Small Generating Facility (if different from above):

_____ City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

Electrician:

Name:

Address:

Location of the Small Generating Facility (if different from above):

_____ City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

License number: _____

Date Approval to Install Facility granted by the Company: _____

Application ID number: _____

Inspection:

The Small Generating Facility has been installed and inspected in compliance with the local

building/electrical code of:

Signed (Local electrical wiring inspector, or attach signed electrical inspection):

Print Name: _____

Date: _____

As a condition of interconnection, you are required to send/fax a copy of this form along with a copy of the signed electrical permit to (insert Company information below):

Name: _____

Company: _____

Address: _____

City, State ZIP: _____

Fax: _____

.....
.....

Approval to Energize the Small Generating Facility (For Company use only)

Energizing the Small Generating Facility is approved contingent upon the Terms and Conditions for Interconnecting an Inverter-Based Small Generating Facility No Larger than 10kW

Company Signature: _____

Title: _____ Date: _____

Terms and Conditions for Interconnecting an Inverter-Based Small Generating Facility No Larger than 10kW

1.0 Construction of the Facility

Interconnection Customer (the “Customer”) may proceed to construct (including operational testing not to exceed two hours) the Small Generating Facility when Transmission Provider (the “Company”) approves the Interconnection Request (the “Application”) and returns it to the Customer.

2.0 Interconnection and Operation

The Customer may operate Small Generating Facility and interconnect with the Company’s electric system once all of the following have occurred:

- 2.1 Upon completing construction, the Customer will cause the Small Generating Facility to be inspected or otherwise certified by the appropriate local electrical wiring inspector with jurisdiction, and
- 2.2 The Customer returns the Certificate of Completion to the Company, and
- 2.3 The Company has either:
 - 2.3.1 Completed its inspection of the Small Generating Facility to ensure that all equipment has been appropriately installed and that all electrical connections have been made in accordance with applicable codes. All inspections must be conducted by the Company, at its own expense, within ten (10) Business Days after receipt of the Certificate of Completion and shall take place at a time agreeable to the Parties. The Company shall provide a written statement that the Small Generating Facility has passed inspection or shall notify the Customer of what steps it must take to pass inspection as soon as practicable after the inspection takes place; or
 - 2.3.2 If the Company does not schedule an inspection of the Small Generating Facility within ten (10) Business Days after receiving the Certificate of Completion, the witness test is deemed waived (unless the Parties agree otherwise); or
 - 2.3.3 The Company waives the right to inspect the Small Generating Facility.

- 2.4 The Company has the right to disconnect the Small Generating Facility in the event of improper installation or failure to return the Certificate of Completion.
- 2.5 Revenue quality metering equipment must be installed and tested in accordance with applicable ANSI standards.

3.0 Safe Operations and Maintenance

The Customer shall be fully responsible to operate, maintain, and repair the Small Generating Facility as required to ensure that it complies at all times with the interconnection standards to which it has been certified.

4.0 Access

The Company shall have access to the disconnect switch (if the disconnect switch is required) and metering equipment of the Small Generating Facility at all times. The Company shall provide reasonable notice to the Customer when possible prior to using its right of access.

5.0 Disconnection

The Company may temporarily disconnect the Small Generating Facility upon the following conditions:

- 5.1 For scheduled outages upon reasonable notice.
- 5.2 For unscheduled outages or emergency conditions.
- 5.3 If the Small Generating Facility does not operate in the manner consistent with these Terms and Conditions.
- 5.4 The Company shall inform the Customer in advance of any scheduled disconnection, or as is reasonable after an unscheduled disconnection.

6.0 Indemnification

The Parties shall at all times indemnify, defend, and save the other Party harmless from, any and all damages, losses, claims, including claims and actions relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's action or inactions of its obligations under this agreement on behalf of the indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the indemnified Party.

7.0 Insurance

The Parties agree to follow all applicable insurance requirements imposed by the state in which the Point of Interconnection is located. All insurance policies must be maintained with insurers authorized to do business in that state.

8.0 Limitation of Liability

Each party's liability to the other party for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall either party be liable to the other party for any indirect, incidental, special, consequential, or punitive damages of any kind whatsoever, except as allowed under paragraph 6.0.

9.0 Termination

The agreement to operate in parallel may be terminated under the following conditions:

9.1 By the Customer

By providing written notice to the Company.

9.2 By the Company

If the Small Generating Facility fails to operate for any consecutive 12 month period or the Customer fails to remedy a violation of these Terms and Conditions.

9.3 Permanent Disconnection

In the event this Agreement is terminated, the Company shall have the right to disconnect its facilities or direct the Customer to disconnect its Small Generating Facility.

9.4 Survival Rights

This Agreement shall continue in effect after termination to the extent necessary to allow or require either Party to fulfill rights or obligations that arose under the Agreement.

10.0 Assignment/Transfer of Ownership of the Facility

This Agreement shall survive the transfer of ownership of the Small Generating Facility to a new owner when the new owner agrees in writing to comply with the terms of this Agreement and so notifies the Company.

Attachment 6
Feasibility Study Agreement

THIS AGREEMENT is made and entered into this ____ day of _____
20__ by and between _____,
a _____ organized and existing under the laws of the State of _____,
_____, (“Interconnection Customer,”) and _____,
a _____ organized and existing under the laws of the State of _____,
_____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party, ” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Small Generating Facility or generating capacity addition to an existing Small Generating Facility consistent with the Interconnection Request completed by Interconnection Customer on _____; and

WHEREAS, Interconnection Customer desires to interconnect the Small Generating Facility with Transmission Provider’s Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a feasibility study to assess the feasibility of interconnecting the proposed Small Generating Facility with Transmission Provider’s Transmission System, and of any Affected Systems;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated or the meanings specified in the standard Small Generator Interconnection Procedures.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be performed an interconnection feasibility study consistent the standard Small

Generator Interconnection Procedures in accordance with the Open Access Transmission Tariff.

- 3.0 The scope of the feasibility study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The feasibility study shall be based on the technical information provided by Interconnection Customer in the Interconnection Request, as may be modified as the result of the scoping meeting. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the feasibility study and as designated in accordance with the standard Small Generator Interconnection Procedures. If Interconnection Customer modifies its Interconnection Request, the time to complete the feasibility study may be extended by agreement of the Parties.
- 5.0 In performing the study, Transmission Provider shall rely, to the extent reasonably practicable, on existing studies of recent vintage. Interconnection Customer shall not be charged for such existing studies; however, Interconnection Customer shall be responsible for charges associated with any new study or modifications to existing studies that are reasonably necessary to perform the feasibility study.
- 6.0 The feasibility study report shall provide the following analyses for the purpose of identifying any potential adverse system impacts that would result from the interconnection of the Small Generating Facility as proposed:
 - 6.1 Initial identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - 6.2 Initial identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - 6.3 Initial review of grounding requirements and electric system protection;and
 - 6.4 Description and non-binding estimated cost of facilities required to interconnect the proposed Small Generating Facility and to address the identified short circuit and power flow issues.

- 7.0 The feasibility study shall model the impact of the Small Generating Facility regardless of purpose in order to avoid the further expense and interruption of operation for reexamination of feasibility and impacts if Interconnection Customer later changes the purpose for which the Small Generating Facility is being installed.
- 8.0 The study shall include the feasibility of any interconnection at a proposed project site where there could be multiple potential Points of Interconnection, as requested by Interconnection Customer and at Interconnection Customer's cost.
- 9.0 A deposit of the lesser of 50 percent of good faith estimated feasibility study costs or earnest money of \$1,000 may be required from Interconnection Customer.
- 10.0 Once the feasibility study is completed, a feasibility study report shall be prepared and transmitted to Interconnection Customer. Barring unusual circumstances, the feasibility study must be completed and the feasibility study report transmitted within thirty (30) Business Days of Interconnection Customer's agreement to conduct a feasibility study.
- 11.0 Any study fees shall be based on Transmission Provider's actual costs and will be invoiced to Interconnection Customer after the study is completed and delivered and will include a summary of professional time.
- 12.0 Interconnection Customer must pay any study costs that exceed the deposit without interest within thirty (30) Calendar Days on receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced fees, Transmission Provider shall refund such excess within thirty (30) Calendar Days of the invoice without interest.
- 13.0 Governing Law, Regulatory Authority, and Rules
- The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____ (where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.
- 14.0 Amendment

The Parties may amend this Agreement by a written instrument duly executed by both Parties.

15.0 No Third-Party Beneficiaries

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

16.0 Waiver

16.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

16.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

17.0 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

18.0 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

19.0 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

20.0 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

20.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

20.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

21.0 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral

filing with FERC to modify this Agreement under any applicable provision of the Federal Power Act and FERC's rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider} {Insert name of Interconnection Customer}

Signed: _____

Signed: _____

Name (Printed):

Name (Printed):

Title: _____

Title: _____

**Attachment A to
Feasibility Study Agreement
Assumptions Used in Conducting the Feasibility Study**

The feasibility study will be based upon the information set forth in the Interconnection Request and agreed upon in the scoping meeting held on _____:

- 1) Designation of Point of Interconnection and configuration to be studied.

- 2) Designation of alternative Points of Interconnection and configuration.

1) and 2) are to be completed by the Interconnection Customer. Other assumptions (listed below) are to be provided by Interconnection Customer and Transmission Provider.

Attachment 7

System Impact Study Agreement

THIS AGREEMENT is made and entered into this ____ day of _____
 20__ by and between _____,
 a _____ organized and existing under the laws of the State of
 _____, (“Interconnection Customer,”) and
 _____, a _____
 organized and existing under the laws of the State
 of _____,
 (“Transmission Provider”). Interconnection Customer and Transmission Provider each
 may be referred to as a “Party, ” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Small Generating Facility or generating capacity addition to an existing Small Generating Facility consistent with the Interconnection Request completed by Interconnection Customer on _____; and

WHEREAS, Interconnection Customer desires to interconnect the Small Generating Facility with Transmission Provider’s Transmission System;

WHEREAS, Transmission Provider has completed a feasibility study and provided the results of said study to Interconnection Customer (This recital to be omitted if the Parties have agreed to forego the feasibility study.); and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a system impact study(s) to assess the impact of interconnecting the Small Generating Facility with Transmission Provider’s Transmission System, and of any Affected Systems;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated or the meanings specified in the standard Small Generator Interconnection Procedures.

- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be performed a system impact study(s) consistent with the standard Small Generator Interconnection Procedures in accordance with the Open Access Transmission Tariff.
- 3.0 The scope of a system impact study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 A system impact study will be based upon the results of the feasibility study and the technical information provided by Interconnection Customer in the Interconnection Request. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the system impact study. If Interconnection Customer modifies its designated Point of Interconnection, Interconnection Request, or the technical information provided therein is modified, the time to complete the system impact study may be extended.
- 5.0 A system impact study shall consist of a short circuit analysis, a stability analysis, a power flow analysis, voltage drop and flicker studies, protection and set point coordination studies, and grounding reviews, as necessary. A system impact study shall state the assumptions upon which it is based, state the results of the analyses, and provide the requirement or potential impediments to providing the requested interconnection service, including a preliminary indication of the cost and length of time that would be necessary to correct any problems identified in those analyses and implement the interconnection. A system impact study shall provide a list of facilities that are required as a result of the Interconnection Request and non-binding good faith estimates of cost responsibility and time to construct.
- 6.0 A distribution system impact study shall incorporate a distribution load flow study, an analysis of equipment interrupting ratings, protection coordination study, voltage drop and flicker studies, protection and set point coordination studies, grounding reviews, and the impact on electric system operation, as necessary.
- 7.0 Affected Systems may participate in the preparation of a system impact study, with a division of costs among such entities as they may agree. All Affected Systems shall be afforded an opportunity to review and comment upon a system impact study that covers potential adverse system impacts on their electric

systems, and Transmission Provider has twenty (20) additional Business Days to complete a system impact study requiring review by Affected Systems.

- 8.0 If Transmission Provider uses a queuing procedure for sorting or prioritizing projects and their associated cost responsibilities for any required Network Upgrades, the system impact study shall consider all generating facilities (and with respect to paragraph 8.3 below, any identified Upgrades associated with such higher queued interconnection) that, on the date the system impact study is commenced –
- 8.1 Are directly interconnected with Transmission Provider’s electric system;
- or
- 8.2 Are interconnected with Affected Systems and may have an impact on the proposed interconnection; and
- 8.3 Have a pending higher queued Interconnection Request to interconnect with Transmission Provider’s electric system.
- 9.0 A distribution system impact study, if required, shall be completed and the results transmitted to Interconnection Customer within thirty (30) Business Days after this Agreement is signed by the Parties. A transmission system impact study, if required, shall be completed and the results transmitted to Interconnection Customer within forty-five (45) Business Days after this Agreement is signed by the Parties, or in accordance with Transmission Provider’s queuing procedures.
- 10.0 A deposit of the equivalent of the good faith estimated cost of a distribution system impact study and the one half the good faith estimated cost of a transmission system impact study may be required from Interconnection Customer.
- 11.0 Any study fees shall be based on Transmission Provider’s actual costs and will be invoiced to Interconnection Customer after the study is completed and delivered and will include a summary of professional time.
- 12.0 Interconnection Customer must pay any study costs that exceed the deposit without interest within thirty (30) Calendar Days on receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced fees, Transmission Provider shall refund such excess within thirty (30) Calendar Days of the invoice without interest.
- 13.0 Governing Law, Regulatory Authority, and Rules

The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____ (where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.

14.0 Amendment

The Parties may amend this Agreement by a written instrument duly executed by both Parties.

15.0 No Third-Party Beneficiaries

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

16.0 Waiver

16.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

16.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

17.0 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

18.0 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

19.0 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

20.0 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

20.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

20.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

21.0 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement under any applicable provision of the

Federal Power Act and FERC’s rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC’s rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider} {Insert name of Interconnection Customer}

Signed: _____

Signed: _____

Name (Printed):

Name (Printed):

Title: _____

Title: _____

**Attachment A to System
Impact Study Agreement
Assumptions Used in Conducting the System Impact Study**

The system impact study shall be based upon the results of the feasibility study, subject to any modifications in accordance with the standard Small Generator Interconnection Procedures, and the following assumptions:

1) Designation of Point of Interconnection and configuration to be studied.

2) Designation of alternative Points of Interconnection and configuration.

1) and 2) are to be completed by Interconnection Customer. Other assumptions (listed below) are to be provided by Interconnection Customer and Transmission Provider.

Attachment 8
Facilities Study Agreement

THIS AGREEMENT is made and entered into this ____ day of _____
20__ by and between _____,
a _____ organized and existing under the laws of the State of
_____, (“Interconnection Customer,”) and
_____, a _____
organized and existing under the laws of the State
of _____,
 (“Transmission Provider”). Interconnection Customer and Transmission Provider each
may be referred to as a “Party, ” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Small Generating Facility or generating capacity addition to an existing Small Generating Facility consistent with the Interconnection Request completed by Interconnection Customer on _____; and

WHEREAS, Interconnection Customer desires to interconnect the Small Generating Facility with Transmission Provider’s Transmission System;

WHEREAS, Transmission Provider has completed a system impact study and provided the results of said study to Interconnection Customer; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a facilities study to specify and estimate the cost of the equipment, engineering, procurement and construction work needed to implement the conclusions of the system impact study in accordance with Good Utility Practice to physically and electrically connect the Small Generating Facility with Transmission Provider’s Transmission System.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated or the meanings specified in the standard Small Generator Interconnection Procedures.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause a facilities study consistent with the standard Small Generator Interconnection Procedures to be performed in accordance with the Open Access Transmission Tariff.
- 3.0 The scope of the facilities study shall be subject to data provided in Attachment A to this Agreement.
- 4.0 The facilities study shall specify and estimate the cost of the equipment, engineering, procurement and construction work (including overheads) needed to implement the conclusions of the system impact study(s). The facilities study shall also identify (1) the electrical switching configuration of the equipment, including, without limitation, transformer, switchgear, meters, and other station equipment, (2) the nature and estimated cost of Transmission Provider's Interconnection Facilities and Upgrades necessary to accomplish the interconnection, and (3) an estimate of the time required to complete the construction and installation of such facilities.
- 5.0 Transmission Provider may propose to group facilities required for more than one Interconnection Customer in order to minimize facilities costs through economies of scale, but any Interconnection Customer may require the installation of facilities required for its own Small Generating Facility if it is willing to pay the costs of those facilities.
- 6.0 A deposit of the good faith estimated facilities study costs may be required from Interconnection Customer.
- 7.0 In cases where Upgrades are required, the facilities study must be completed within forty-five (45) Business Days of the receipt of this Agreement. In cases where no Upgrades are necessary, and the required facilities are limited to Interconnection Facilities, the facilities study must be completed within thirty (30) Business Days.
- 8.0 Once the facilities study is completed, a "draft" facilities study report shall be prepared and transmitted to Interconnection Customer. Barring unusual circumstances, the facilities study must be completed and the "draft" facilities

study report transmitted within thirty (30) Business Days of Interconnection Customer's agreement to conduct a facilities study.

- 9.0 Interconnection Customer may, within thirty (30) Calendar Days after receipt of the draft report, provide written comments to Transmission Provider, which Transmission Provider shall include in the final report. Transmission Provider shall issue the final Interconnection Facilities Study report within fifteen (15) Business Days of receiving Interconnection Customer's comments or promptly upon receiving Interconnection Customer's statement that it will not provide comments. Transmission Provider may reasonably extend such fifteen-day period upon notice to Interconnection Customer if Interconnection Customer's comments require Transmission Provider to perform additional analyses or make other significant modifications prior to the issuance of the final Interconnection Facilities Report. Upon request, Transmission Provider shall provide Interconnection Customer supporting documentation, workpapers, and databases or data developed in the preparation of the Interconnection Facilities Study, subject to confidentiality arrangements consistent with Section 4.5 of the standard Small Generator Interconnection Procedures.
- 10.0 Within ten (10) Business Days of providing a draft Interconnection Facilities Study report to Interconnection Customer, Transmission Provider and Interconnection Customer shall meet to discuss the results of the Interconnection Facilities Study.
- 11.0 Any study fees shall be based on Transmission Provider's actual costs and will be invoiced to Interconnection Customer after the study is completed and delivered and will include a summary of professional time.
- 12.0 Interconnection Customer must pay any study costs that exceed the deposit without interest within thirty (30) Calendar Days on receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced fees, Transmission Provider shall refund such excess within thirty (30) Calendar Days of the invoice without interest.
- 13.0 Governing Law, Regulatory Authority, and Rules
- The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____

(where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.

14.0 Amendment

The Parties may amend this Agreement by a written instrument duly executed by both Parties.

15.0 No Third-Party Beneficiaries

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

16.0 Waiver

16.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

16.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

17.0 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

18.0 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

19.0 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

20.0 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

20.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

20.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

21.0 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement under any applicable provision of the Federal Power Act and FERC's rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider} {Insert name of Interconnection Customer}

Signed _____

Signed _____

Name (Printed):

Name (Printed):

Title _____

Title _____

**Attachment A to
Facilities Study Agreement
Data to Be Provided by Interconnection Customer
with the Facilities Study Agreement**

Provide location plan and simplified one-line diagram of the plant and station facilities. For staged projects, please indicate future generation, transmission circuits, etc.

On the one-line diagram, indicate the generation capacity attached at each metering location. (Maximum load on CT/PT)

On the one-line diagram, indicate the location of auxiliary power. (Minimum load on CT/PT) Amps

One set of metering is required for each generation connection to the new ring bus or existing Transmission Provider station. Number of generation connections:

Will an alternate source of auxiliary power be available during CT/PT maintenance?

Yes ____ No ____

Will a transfer bus on the generation side of the metering require that each meter set be designed for the total plant generation? Yes ____ No ____

(Please indicate on the one-line diagram).

What type of control system or PLC will be located at the Small Generating Facility?

What protocol does the control system or PLC use?

Please provide a 7.5-minute quadrangle map of the site. Indicate the plant, station, transmission line, and property lines.

Physical dimensions of the proposed interconnection station:

_____ Bus length from generation to interconnection station:

_____ Line length from interconnection station to Transmission Provider's Transmission System.

_____ Tower number observed in the field. (Painted on tower leg)*:

_____ Number of third party easements required for transmission lines*:

_____ * To be completed in coordination with Transmission Provider.

Is the Small Generating Facility located in Transmission Provider's service area?

Yes _____ No _____ If No, please provide name of local provider:

Please provide the following proposed schedule dates:

Begin Construction Date: _____

Generator step-up transformers Date: _____

receive back feed power

Generation Testing

Date: _____

Commercial Operation

Date: _____

ATTACHMENT P

Small Generator Interconnection Agreement

**SMALL GENERATOR
INTERCONNECTION AGREEMENT (SGIA)**

(For Generating Facilities No Larger Than 20 MW)

TABLE OF CONTENTS

Page No.

Article 1. Scope and Limitations of Agreement..... - 2 -

 1.5 Responsibilities of the Parties..... - 2 -

 1.6 Parallel Operation Obligations - 5 -

 1.7 Metering - 5 -

 1.8 Reactive Power and Primary Frequency Response - 5 -

 1.8.1 Power Factor Design Criteria..... - 5 -

 1.8.4 Primary Frequency Response. - 7 -

Article 2. Inspection, Testing, Authorization, and Right of Access - 10 -

 2.1 Equipment Testing and Inspection - 10 -

 2.2 Authorization Required Prior to Parallel Operation - 11 -

 2.3 Right of Access - 11 -

Article 3. Effective Date, Term, Termination, and Disconnection - 12 -

 3.1 Effective Date - 12 -

 3.2 Term of Agreement - 12 -

 3.3 Termination..... - 13 -

 3.4 Temporary Disconnection - 13 -

 3.4.1 Emergency Conditions - 13 -

 3.4.2 Routine Maintenance, Construction, and Repair - 14 -

 3.4.3 Forced Outages..... - 14 -

 3.4.4 Adverse Operating Effects..... - 15 -

 3.4.5 Modification of the Small Generating Facility - 15 -

 3.4.6 Reconnection..... - 15 -

Article 4. Cost Responsibility for Interconnection Facilities and Distribution Upgrades - 15 -

 4.1 Interconnection Facilities - 16 -

 4.2 Distribution Upgrades - 16 -

Article 5. Cost Responsibility for Network Upgrades..... - 16 -

 5.1 Applicability - 16 -

 5.2 Network Upgrades - 16 -

 5.2.1 Repayment of Amounts Advanced for Network Upgrades..... - 17 -

 5.3 Special Provisions for Affected Systems - 18 -

 5.4 Rights Under Other Agreements..... - 18 -

Article 6. Billing, Payment, Milestones, and Financial Security..... - 18 -

6.1 Billing and Payment Procedures and Final Accounting - 18 -

6.2 Milestones..... - 19 -

6.3 Financial Security Arrangements..... - 20 -

Article 7. Assignment, Liability, Indemnity, Force Majeure, Consequential Damages, and Default - 20 -

7.1 Assignment - 20 -

7.2 Limitation of Liability - 21 -

7.3 Indemnity - 21 -

7.4 Consequential Damages - 22 -

7.5 Force Majeure - 23 -

7.6 Default - 23 -

Article 8. Insurance - 24 -

Article 9. Confidentiality - 25 -

Article 10. Disputes - 26 -

Article 11. Taxes - 27 -

Article 12. Miscellaneous - 27 -

12.1 Governing Law, Regulatory Authority, and Rules - 27 -

12.2 Amendment..... - 27 -

12.3 No Third-Party Beneficiaries..... - 27 -

12.4 Waiver - 28 -

12.5 Entire Agreement - 28 -

12.6 Multiple Counterparts - 28 -

12.7 No Partnership - 29 -

12.8 Severability - 29 -

12.9 Security Arrangements..... - 29 -

12.10 Environmental Releases - 29 -

12.11 Subcontractors - 30 -

12.12 Reservation of Rights - 30 -

Article 13. Notices - 31 -

13.1 General - 31 -

13.2 Billing and Payment - 32 -

13.3 Alternative Forms of Notice - 32 -

13.4 Designated Operating Representative - 33 -

13.5 Changes to the Notice Information - 34 -

Article 14. Signatures - 34 -

[Attachment 1](#) – Glossary of Terms

[Attachment 2](#) – Description and Costs of the Small Generating Facility, Interconnection Facilities, and Metering Equipment

[Attachment 3](#) – One-line Diagram Depicting the Small Generating Facility, Interconnection Facilities, Metering Equipment, and Upgrades

[Attachment 4](#) – Milestones

[Attachment 5](#) – Additional Operating Requirements for Transmission Provider’s Transmission System and Affected Systems Needed to Support Interconnection Customer’s Needs

[Attachment 6](#) – Transmission Provider’s Description of its Upgrades and Best Estimate of Upgrade Costs

This Interconnection Agreement (“Agreement”) is made and entered into this _____ day of _____, 20__ , by

 (“Transmission Provider”), and

 (“Interconnection Customer”) each hereinafter sometimes referred to individually as “Party” or both referred to collectively as the “Parties.”

Transmission Provider Information

Transmission Provider: _____

Attention: _____

Address: _____

City: _____ State: _____ Zip: _____

Phone: _____ Fax: _____

Interconnection Customer Information

Interconnection Customer: _____

Attention: _____

Address: _____

City: _____ State: _____ Zip: _____

Phone: _____ Fax: _____

Interconnection Customer Application No: _____

In consideration of the mutual covenants set forth herein, the Parties agree as follows:

Article 1. Scope and Limitations of Agreement

1.1 Applicability

This Agreement shall be used for all Interconnection Requests submitted under the Small Generator Interconnection Procedures (SGIP) except for those submitted under the 10 kW Inverter Process contained in SGIP Attachment 5.

1.2 Purpose

This Agreement governs the terms and conditions under which Interconnection Customer's Small Generating Facility will interconnect with, and operate in parallel with, Transmission Provider's Transmission System.

1.3 No Agreement to Purchase or Deliver Power

This Agreement does not constitute an agreement to purchase or deliver Interconnection Customer's power. The purchase or delivery of power and other services that Interconnection Customer may require will be covered under separate agreements, if any. Interconnection Customer will be responsible for separately making all necessary arrangements (including scheduling) for delivery of electricity with the applicable Transmission Provider.

1.4 Limitations

Nothing in this Agreement is intended to affect any other agreement between Transmission Provider and Interconnection Customer.

1.5 Responsibilities of the Parties

1.5.1 The Parties shall perform all obligations of this Agreement in accordance with all Applicable Laws and Regulations, Operating Requirements, and Good Utility Practice.

1.5.2 Interconnection Customer shall construct, interconnect, operate and maintain its Small Generating Facility and construct, operate, and maintain its Interconnection Facilities in accordance with the applicable

manufacturer's recommended maintenance schedule, and in accordance with this Agreement, and with Good Utility Practice.

- 1.5.3 Transmission Provider shall construct, operate, and maintain its Transmission System and Interconnection Facilities in accordance with this Agreement, and with Good Utility Practice.
- 1.5.4 Interconnection Customer agrees to construct its facilities or systems in accordance with applicable specifications that meet or exceed those provided by the National Electrical Safety Code, the American National Standards Institute, IEEE, Underwriter's Laboratory, and Operating Requirements in effect at the time of construction and other applicable national and state codes and standards. Interconnection Customer agrees to design, install, maintain, and operate its Small Generating Facility so as to reasonably minimize the likelihood of a disturbance adversely affecting or impairing the system or equipment of Transmission Provider and any Affected Systems.
- 1.5.5 Each Party shall operate, maintain, repair, and inspect, and shall be fully responsible for the facilities that it now or subsequently may own unless otherwise specified in the Attachments to this Agreement. Each Party shall be responsible for the safe installation, maintenance, repair and condition of their respective lines and appurtenances on their respective sides of the point of change of ownership. Transmission Provider and Interconnection Customer, as appropriate, shall provide Interconnection Facilities that adequately protect Transmission Provider's Transmission System, personnel, and other persons from damage and injury. The allocation of responsibility for the design, installation, operation, maintenance and ownership of Interconnection Facilities shall be delineated in the Attachments to this Agreement.
- 1.5.6 Transmission Provider shall coordinate with all Affected Systems to support the interconnection.

1.5.7 Interconnection Customer shall ensure “frequency ride through” capability and “voltage ride through” capability of its Small Generating Facility. Interconnection Customer shall enable these capabilities such that its Small Generating Facility shall not disconnect automatically or instantaneously from the system or equipment of Transmission Provider and any Affected Systems for a defined under-frequency or over-frequency condition, or an under-voltage or over-voltage condition, as tested pursuant to Section 2.1 of this agreement. The defined conditions shall be in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. The Small Generating Facility’s protective equipment settings shall comply with Transmission Provider’s automatic load-shed program. Transmission Provider shall review the protective equipment settings to confirm compliance with the automatic load-shed program. The term “ride through” as used herein shall mean the ability of a Small Generating Facility to stay connected to and synchronized with the system or equipment of Transmission Provider and any Affected Systems during system disturbances within a range of conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. The term “frequency ride through” as used herein shall mean the ability of a Small Generating Facility to stay connected to and synchronized with the system or equipment of Transmission Provider and any Affected Systems during system disturbances within a range of under-frequency and over-frequency conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. The term “voltage ride through” as used herein shall mean the ability of a Small Generating Facility to stay connected to and synchronized with the system or equipment of Transmission Provider and any Affected Systems during system disturbances within a range of under-voltage and over-voltage conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. For abnormal frequency conditions and voltage conditions within the “no trip zone” defined by Reliability Standard PRC-024-3 or successor mandatory ride through Applicable Reliability Standards, the non-synchronous Small Generating Facility must ensure that, within any physical limitations of the Small Generating Facility, its control and protection settings are configured or set to (1) continue active power

production during disturbance and post disturbance periods at pre-disturbance levels unless reactive power priority mode is enabled or unless providing primary frequency response or fast frequency response; (2) minimize reductions in active power and remain within dynamic voltage and current limits, if reactive power priority mode is enabled, unless providing primary frequency response or fast frequency response; (3) not artificially limit dynamic reactive power capability during disturbances; and (4) return to pre-disturbance active power levels without artificial ramp rate limits if active power is reduced, unless providing primary frequency response or fast frequency response.

1.6 Parallel Operation Obligations

Once the Small Generating Facility has been authorized to commence parallel operation, Interconnection Customer shall abide by all rules and procedures pertaining to the parallel operation of the Small Generating Facility in the applicable Balancing Authority Area, including, but not limited to; 1) the rules and procedures concerning the operation of generation set forth in the Tariff or by the applicable system operator(s) for Transmission Provider's Transmission System and; 2) the Operating Requirements set forth in Attachment 5 of this Agreement.

1.7 Metering

Interconnection Customer shall be responsible for Transmission Provider's reasonable and necessary cost for the purchase, installation, operation, maintenance, testing, repair, and replacement of metering and data acquisition equipment specified in Attachments 2 and 3 of this Agreement. Interconnection Customer's metering (and data acquisition, as required) equipment shall conform to applicable industry rules and Operating Requirements.

1.8 Reactive Power and Primary Frequency Response

1.8.1 Power Factor Design Criteria

1.8.1.1 Synchronous Generation. Interconnection Customer shall design its Small Generating Facility to maintain a composite power delivery at continuous rated power output at the Point of Interconnection at a power factor within the range of 0.95 leading to 0.95 lagging, unless

Transmission Provider has established different requirements that apply to all similarly situated synchronous generators in the Balancing Authority Area on a comparable basis.

1.8.1.2 Non-Synchronous Generation. Interconnection Customer shall design its Small Generating Facility to maintain a composite power delivery at continuous rated power output at the high-side of the generator substation at a power factor within the range of 0.95 leading to 0.95 lagging, unless Transmission Provider has established a different power factor range that applies to all similarly situated non-synchronous generators in the Balancing Authority Area on a comparable basis. This power factor range standard shall be dynamic and can be met using, for example, power electronics designed to supply this level of reactive capability (taking into account any limitations due to voltage level, real power output, etc.) or fixed and switched capacitors, or a combination of the two. This requirement shall only apply to newly interconnecting non-synchronous generators that have not yet executed a Facilities Study Agreement as of the effective date of the Final Rule establishing this requirement (Order No. 827).

1.8.2 Transmission Provider is required to pay Interconnection Customer for reactive power that Interconnection Customer provides or absorbs from the Small Generating Facility when Transmission Provider requests Interconnection Customer to operate its Small Generating Facility outside the range specified in Article 1.8.1. In addition, if Transmission Provider pays its own or affiliated generators for reactive power service within the specified range, it must also pay Interconnection Customer.

1.8.3 Payments shall be in accordance with Interconnection Customer's applicable rate schedule then in effect unless the provision of such service(s) is subject to a regional transmission organization or independent system operator FERC-approved rate schedule. To the extent that no rate schedule is in effect at the time Interconnection Customer is required to provide or absorb reactive power under this Agreement, the Parties agree to expeditiously file such rate schedule and agree to support any request for

waiver of the Commission's prior notice requirement in order to compensate Interconnection Customer from the time service commenced.

- 1.8.4 Primary Frequency Response. Interconnection Customer shall ensure the primary frequency response capability of its Small Generating Facility by installing, maintaining, and operating a functioning governor or equivalent controls. The term "functioning governor or equivalent controls" as used herein shall mean the required hardware and/or software that provides frequency responsive real power control with the ability to sense changes in system frequency and autonomously adjust the Small Generating Facility's real power output in accordance with the droop and deadband parameters and in the direction needed to correct frequency deviations.

Interconnection Customer is required to install a governor or equivalent controls with the capability of operating: (1) with a maximum 5 percent droop and ± 0.036 Hz deadband; or (2) in accordance with the relevant droop, deadband, and timely and sustained response settings from an approved Electric Reliability Organization reliability standard providing for equivalent or more stringent parameters. The droop characteristic shall be: (1) based on the nameplate capacity of the Small Generating Facility, and shall be linear in the range of frequencies between 59 to 61 Hz that are outside of the deadband parameter; or (2) based on an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter. The deadband parameter shall be: the range of frequencies above and below nominal (60 Hz) in which the governor or equivalent controls is not expected to adjust the Small Generating Facility's real power output in response to frequency deviations. The deadband shall be implemented: (1) without a step to the droop curve, that is, once the frequency deviation exceeds the deadband parameter, the expected change in the Small Generating Facility's real power output in response to frequency deviations shall start from zero and then increase (for under-frequency deviations) or decrease (for over-frequency deviations) linearly in proportion to the magnitude of the frequency deviation; or (2) in accordance with an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter.

Interconnection Customer shall notify Transmission Provider that the primary frequency response capability of the Small Generating Facility has been tested and confirmed during commissioning. Once Interconnection Customer has synchronized the Small Generating Facility with the Transmission System, Interconnection Customer shall operate the Small

Generating Facility consistent with the provisions specified in Sections 1.8.4.1 and 1.8.4.2 of this Agreement. The primary frequency response requirements contained herein shall apply to both synchronous and non-synchronous Small Generating Facilities.

1.8.4.1 Governor or Equivalent Controls. Whenever the Small Generating Facility is operated in parallel with the Transmission System, Interconnection Customer shall operate the Small Generating Facility with its governor or equivalent controls in service and responsive to frequency. Interconnection Customer shall: (1) in coordination with Transmission Provider and/or the relevant Balancing Authority, set the deadband parameter to: (1) a maximum of ± 0.036 Hz and set the droop parameter to a maximum of 5 percent; or (2) implement the relevant droop and deadband settings from an approved Electric Reliability Organization reliability standard that provides for equivalent or more stringent parameters. Interconnection Customer shall be required to provide the status and settings of the governor or equivalent controls to Transmission Provider and/or the relevant Balancing Authority upon request. If Interconnection Customer needs to operate the Small Generating Facility with its governor or equivalent controls not in service, Interconnection Customer shall immediately notify Transmission Provider and the relevant Balancing Authority, and provide both with the following information: (1) the operating status of the governor or equivalent controls (i.e., whether it is currently out of service or when it will be taken out of service); (2) the reasons for removing the governor or equivalent controls from service; and (3) a reasonable estimate of when the governor or equivalent controls will be returned to service. Interconnection Customer shall make Reasonable Efforts to return its governor or equivalent controls into service as soon as practicable. Interconnection Customer shall make Reasonable Efforts to keep outages of the Small Generating Facility's governor or equivalent controls to a minimum whenever the Small Generating Facility is operated in parallel with the Transmission System.

1.8.4.2 Timely and Sustained Response. Interconnection Customer shall ensure that the Small Generating Facility's real power response to sustained frequency deviations outside of the deadband setting is automatically provided and shall begin immediately after frequency deviates outside of the deadband, and to the extent the Small

Generating Facility has operating capability in the direction needed to correct the frequency deviation. Interconnection Customer shall not block or otherwise inhibit the ability of the governor or equivalent controls to respond and shall ensure that the response is not inhibited, except under certain operational constraints including, but not limited to, ambient temperature limitations, physical energy limitations, outages of mechanical equipment, or regulatory requirements. The Small Generating Facility shall sustain the real power response at least until system frequency returns to a value within the deadband setting of the governor or equivalent controls. A Commission-approved Reliability Standard with equivalent or more stringent requirements shall supersede the above requirements.

1.8.4.3 Exemptions. Small Generating Facilities that are regulated by the United States Nuclear Regulatory Commission shall be exempt from Sections 1.8.4, 1.8.4.1, and 1.8.4.2 of this Agreement. Small Generating Facilities that are behind the meter generation that is sized-to-load (i.e., the thermal load and the generation are near-balanced in real-time operation and the generation is primarily controlled to maintain the unique thermal, chemical, or mechanical output necessary for the operating requirements of its host facility) shall be required to install primary frequency response capability in accordance with the droop and deadband capability requirements specified in Section 1.8.4, but shall be otherwise exempt from the operating requirements in Sections 1.8.4, 1.8.4.1, 1.8.4.2, and 1.8.4.4 of this Agreement.

1.8.4.4 Electric Storage Resources. Interconnection Customer interconnecting an electric storage resource shall establish an operating range in Attachment 5 of its SGIA that specifies a minimum state of charge and a maximum state of charge between which the electric storage resource will be required to provide primary frequency response consistent with the conditions set forth in Sections 1.8.4, 1.8.4.1, 1.8.4.2 and 1.8.4.3 of this Agreement. Attachment 5 shall specify whether the operating range is static or dynamic, and shall consider: (1) the expected magnitude of frequency deviations in the interconnection; (2) the expected duration that system frequency will remain outside of the deadband parameter in the interconnection; (3) the expected incidence of frequency deviations outside of the deadband parameter in the interconnection; (4) the physical capabilities of the electric storage resource; (5) operational limitations of the electric storage resource due to manufacturer specifications; and (6) any other relevant factors

agreed to by Transmission Provider and Interconnection Customer, and in consultation with the relevant transmission owner or Balancing Authority as appropriate. If the operating range is dynamic, then Attachment 5 must establish how frequently the operating range will be reevaluated and the factors that may be considered during its reevaluation.

Interconnection Customer's electric storage resource is required to provide timely and sustained primary frequency response consistent with Section 1.8.4.2 of this Agreement when it is online and dispatched to inject electricity to the Transmission System and/or receive electricity from the Transmission System. This excludes circumstances when the electric storage resource is not dispatched to inject electricity to the Transmission System and/or dispatched to receive electricity from the Transmission System. If Interconnection Customer's electric storage resource is charging at the time of a frequency deviation outside of its deadband parameter, it is to increase (for over-frequency deviations) or decrease (for under-frequency deviations) the rate at which it is charging in accordance with its droop parameter. Interconnection Customer's electric storage resource is not required to change from charging to discharging, or vice versa, unless the response necessitated by the droop and deadband settings requires it to do so and it is technically capable of making such a transition.

- 1.9 Capitalized terms used herein shall have the meanings specified in the Glossary of Terms in Attachment 1 or the body of this Agreement.

Article 2. Inspection, Testing, Authorization, and Right of Access

2.1 Equipment Testing and Inspection

- 2.1.1 Interconnection Customer shall test and inspect its Small Generating Facility and Interconnection Facilities prior to interconnection. Interconnection Customer shall notify Transmission Provider of such activities no fewer than five (5) Business Days (or as may be agreed to by the Parties) prior to such testing and inspection. Testing and inspection shall occur on a Business Day. Transmission Provider may, at its own expense, send qualified personnel to the Small Generating Facility site to

inspect the interconnection and observe the testing. Interconnection Customer shall provide Transmission Provider a written test report when such testing and inspection is completed.

2.1.2 Transmission Provider shall provide Interconnection Customer written acknowledgment that it has received Interconnection Customer's written test report. Such written acknowledgment shall not be deemed to be or construed as any representation, assurance, guarantee, or warranty by Transmission Provider of the safety, durability, suitability, or reliability of the Small Generating Facility or any associated control, protective, and safety devices owned or controlled by Interconnection Customer or the quality of power produced by the Small Generating Facility.

2.2 Authorization Required Prior to Parallel Operation

2.2.1 Transmission Provider shall use Reasonable Efforts to list applicable parallel operation requirements in Attachment 5 of this Agreement. Additionally, Transmission Provider shall notify Interconnection Customer of any changes to these requirements as soon as they are known. Transmission Provider shall make Reasonable Efforts to cooperate with Interconnection Customer in meeting requirements necessary for Interconnection Customer to commence parallel operations by the in-service date.

2.2.2 Interconnection Customer shall not operate its Small Generating Facility in parallel with Transmission Provider's Transmission System without prior written authorization of Transmission Provider. Transmission Provider will provide such authorization once Transmission Provider receives notification that Interconnection Customer has complied with all applicable parallel operation requirements. Such authorization shall not be unreasonably withheld, conditioned, or delayed.

2.3 Right of Access

- 2.3.1 Upon reasonable notice, Transmission Provider may send a qualified person to the premises of Interconnection Customer at or immediately before the time the Small Generating Facility first produces energy to inspect the interconnection, and observe the commissioning of the Small Generating Facility (including any required testing), startup, and operation for a period of up to three (3) Business Days after initial start-up of the unit. In addition, Interconnection Customer shall notify Transmission Provider at least five (5) Business Days prior to conducting any on-site verification testing of the Small Generating Facility.
- 2.3.2 Following the initial inspection process described above, at reasonable hours, and upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition, Transmission Provider shall have access to Interconnection Customer's premises for any reasonable purpose in connection with the performance of the obligations imposed on it by this Agreement or if necessary to meet its legal obligation to provide service to its customers.
- 2.3.3 Each Party shall be responsible for its own costs associated with following this article.

Article 3. Effective Date, Term, Termination, and Disconnection

3.1 Effective Date

This Agreement shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by the FERC. Transmission Provider shall promptly file this Agreement with the FERC upon execution, if required.

3.2 Term of Agreement

This Agreement shall become effective on the Effective Date and shall remain in effect for a period of ten years from the Effective Date or such other longer period as Interconnection Customer may request and shall be automatically renewed for each successive one-year period thereafter, unless terminated earlier in accordance with article 3.3 of this Agreement.

3.3 Termination

No termination shall become effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination, including the filing with FERC of a notice of termination of this Agreement (if required), which notice has been accepted for filing by FERC.

3.3.1 Interconnection Customer may terminate this Agreement at any time by giving Transmission Provider twenty (20) Business Days written notice.

3.3.2 Either Party may terminate this Agreement after Default pursuant to article 7.6.

3.3.3 Upon termination of this Agreement, the Small Generating Facility will be disconnected from Transmission Provider's Transmission System. All costs required to effectuate such disconnection shall be borne by the terminating Party, unless such termination resulted from the non-terminating Party's Default of this SGIA or such non-terminating Party otherwise is responsible for these costs under this SGIA.

3.3.4 The termination of this Agreement shall not relieve either Party of its liabilities and obligations, owed or continuing at the time of the termination.

3.3.5 The provisions of this article shall survive termination or expiration of this Agreement.

3.4 Temporary Disconnection

Temporary disconnection shall continue only for so long as reasonably necessary under Good Utility Practice.

3.4.1 Emergency Conditions – “Emergency Condition” shall mean a condition or situation: (1) that in the judgment of the Party making the claim is imminently likely to endanger life or property; or (2) that, in the case of

Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to the Transmission System, Transmission Provider's Interconnection Facilities or the Transmission Systems of others to which the Transmission System is directly connected; or (3) that, in the case of Interconnection Customer, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Small Generating Facility or Interconnection Customer's Interconnection Facilities. Under Emergency Conditions, Transmission Provider may immediately suspend interconnection service and temporarily disconnect the Small Generating Facility. Transmission Provider shall notify Interconnection Customer promptly when it becomes aware of an Emergency Condition that may reasonably be expected to affect Interconnection Customer's operation of the Small Generating Facility. Interconnection Customer shall notify Transmission Provider promptly when it becomes aware of an Emergency Condition that may reasonably be expected to affect Transmission Provider's Transmission System or any Affected Systems. To the extent information is known, the notification shall describe the Emergency Condition, the extent of the damage or deficiency, the expected effect on the operation of both Parties' facilities and operations, its anticipated duration, and the necessary corrective action.

3.4.2 Routine Maintenance, Construction, and Repair

Transmission Provider may interrupt interconnection service or curtail the output of the Small Generating Facility and temporarily disconnect the Small Generating Facility from Transmission Provider's Transmission System when necessary for routine maintenance, construction, and repairs on Transmission Provider's Transmission System. Transmission Provider shall provide Interconnection Customer with five (5) Business Days notice prior to such interruption. Transmission Provider shall use Reasonable Efforts to coordinate such reduction or temporary disconnection with Interconnection Customer.

3.4.3 Forced Outages

During any forced outage, Transmission Provider may suspend interconnection service to effect immediate repairs on Transmission Provider's Transmission System. Transmission Provider shall use Reasonable Efforts to provide Interconnection Customer with prior notice.

If prior notice is not given, Transmission Provider shall, upon request, provide Interconnection Customer written documentation after the fact explaining the circumstances of the disconnection.

3.4.4 Adverse Operating Effects

Transmission Provider shall notify Interconnection Customer as soon as practicable if, based on Good Utility Practice, operation of the Small Generating Facility may cause disruption or deterioration of service to other customers served from the same electric system, or if operating the Small Generating Facility could cause damage to Transmission Provider's Transmission System or Affected Systems. Supporting documentation used to reach the decision to disconnect shall be provided to Interconnection Customer upon request. If, after notice, Interconnection Customer fails to remedy the adverse operating effect within a reasonable time, Transmission Provider may disconnect the Small Generating Facility. Transmission Provider shall provide Interconnection Customer with five Business Day notice of such disconnection, unless the provisions of article 3.4.1 apply.

3.4.5 Modification of the Small Generating Facility

Interconnection Customer must receive written authorization from Transmission Provider before making any change to the Small Generating Facility that may have a material impact on the safety or reliability of the Transmission System. Such authorization shall not be unreasonably withheld. Modifications shall be done in accordance with Good Utility Practice. If Interconnection Customer makes such modification without Transmission Provider's prior written authorization, the latter shall have the right to temporarily disconnect the Small Generating Facility.

3.4.6 Reconnection

The Parties shall cooperate with each other to restore the Small Generating Facility, Interconnection Facilities, and Transmission Provider's Transmission System to their normal operating state as soon as reasonably practicable following a temporary disconnection.

Article 4. Cost Responsibility for Interconnection Facilities and Distribution

Upgrades

4.1 Interconnection Facilities

4.1.1 Interconnection Customer shall pay for the cost of the Interconnection Facilities itemized in Attachment 2 of this Agreement. Transmission Provider shall provide a best estimate cost, including overheads, for the purchase and construction of its Interconnection Facilities and provide a detailed itemization of such costs. Costs associated with Interconnection Facilities may be shared with other entities that may benefit from such facilities by agreement of Interconnection Customer, such other entities, and Transmission Provider.

4.1.2 Interconnection Customer shall be responsible for its share of all reasonable expenses, including overheads, associated with (1) owning, operating, maintaining, repairing, and replacing its own Interconnection Facilities, and (2) operating, maintaining, repairing, and replacing Transmission Provider's Interconnection Facilities.

4.2 Distribution Upgrades

Transmission Provider shall design, procure, construct, install, and own the Distribution Upgrades described in Attachment 6 of this Agreement. If Transmission Provider and Interconnection Customer agree, Interconnection Customer may construct Distribution Upgrades that are located on land owned by Interconnection Customer. The actual cost of the Distribution Upgrades, including overheads, shall be directly assigned to Interconnection Customer.

Article 5. Cost Responsibility for Network Upgrades

5.1 Applicability

No portion of this article 5 shall apply unless the interconnection of the Small Generating Facility requires Network Upgrades.

5.2 Network Upgrades

Transmission Provider or the Transmission Owner shall design, procure, construct, install, and own the Network Upgrades described in Attachment 6 of this Agreement. If Transmission Provider and Interconnection Customer agree, Interconnection Customer may construct Network Upgrades that are located on land owned by Interconnection Customer. Unless Transmission Provider elects to pay for Network Upgrades, the actual cost of the Network Upgrades, including overheads, shall be borne initially by Interconnection Customer.

5.2.1 Repayment of Amounts Advanced for Network Upgrades
Interconnection Customer shall be entitled to a cash repayment, equal to the total amount paid to Transmission Provider and Affected System operator, if any, for Network Upgrades, including any tax gross-up or other tax-related payments associated with the Network Upgrades, and not otherwise refunded to Interconnection Customer, to be paid to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, as payments are made under Transmission Provider's Tariff and Affected System's Tariff for transmission services with respect to the Small Generating Facility. Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 C.F.R. § 35.19a(a)(2)(iii) from the date of any payment for Network Upgrades through the date on which Interconnection Customer receives a repayment of such payment pursuant to this subparagraph. Interconnection Customer may assign such repayment rights to any person.

5.2.1.1 Notwithstanding the foregoing, Interconnection Customer, Transmission Provider, and any applicable Affected System operators may adopt any alternative payment schedule that is mutually agreeable so long as Transmission Provider and said Affected System operators take one of the following actions no later than five years from the Commercial Operation Date: (1) return to Interconnection Customer any amounts advanced for Network Upgrades not previously repaid, or (2) declare in writing that Transmission Provider or any applicable Affected System operators will continue to provide payments to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, or develop an alternative schedule that is mutually agreeable and provides for the return of all amounts advanced for Network Upgrades not previously repaid; however, full

reimbursement shall not extend beyond twenty (20) years from the commercial operation date.

5.2.1.2 If the Small Generating Facility fails to achieve commercial operation, but it or another generating facility is later constructed and requires use of the Network Upgrades, Transmission Provider and Affected System operator shall at that time reimburse Interconnection Customer for the amounts advanced for the Network Upgrades. Before any such reimbursement can occur, Interconnection Customer, or the entity that ultimately constructs the generating facility, if different, is responsible for identifying the entity to which reimbursement must be made.

5.3 Special Provisions for Affected Systems

Unless Transmission Provider provides, under this Agreement, for the repayment of amounts advanced to any applicable Affected System operators for Network Upgrades, Interconnection Customer and Affected System operator shall enter into an agreement that provides for such repayment. The agreement shall specify the terms governing payments to be made by Interconnection Customer to Affected System operator as well as the repayment by Affected System operator.

5.4 Rights Under Other Agreements

Notwithstanding any other provision of this Agreement, nothing herein shall be construed as relinquishing or foreclosing any rights, including but not limited to firm transmission rights, capacity rights, transmission congestion rights, or transmission credits, that Interconnection Customer shall be entitled to, now or in the future, under any other agreement or tariff as a result of, or otherwise associated with, the transmission capacity, if any, created by the Network Upgrades, including the right to obtain cash reimbursements or transmission credits for transmission service that is not associated with the Small Generating Facility.

Article 6. Billing, Payment, Milestones, and Financial Security

6.1 Billing and Payment Procedures and Final Accounting

- 6.1.1 Transmission Provider shall bill Interconnection Customer for the design, engineering, construction, and procurement costs of Interconnection Facilities and Upgrades contemplated by this Agreement on a monthly basis, or as otherwise agreed by the Parties. Interconnection Customer shall pay each bill within thirty (30) Calendar Days of receipt, or as otherwise agreed to by the Parties.
- 6.1.2 Within three months of completing the construction and installation of Transmission Provider's Interconnection Facilities and/or Upgrades described in the Attachments to this Agreement, Transmission Provider shall provide Interconnection Customer with a final accounting report of any difference between (1) Interconnection Customer's cost responsibility for the actual cost of such facilities or Upgrades, and (2) Interconnection Customer's previous aggregate payments to Transmission Provider for such facilities or Upgrades. If Interconnection Customer's cost responsibility exceeds its previous aggregate payments, Transmission Provider shall invoice Interconnection Customer for the amount due and Interconnection Customer shall make payment to Transmission Provider within thirty (30) Calendar Days. If Interconnection Customer's previous aggregate payments exceed its cost responsibility under this Agreement, Transmission Provider shall refund to Interconnection Customer an amount equal to the difference within thirty (30) Calendar Days of the final accounting report.

6.2 Milestones

The Parties shall agree on milestones for which each Party is responsible and list them in Attachment 4 of this Agreement. A Party's obligations under this provision may be extended by agreement. If a Party anticipates that it will be unable to meet a milestone for any reason other than a Force Majeure Event, it shall immediately notify the other Party of the reason(s) for not meeting the milestone and (1) propose the earliest reasonable alternate date by which it can attain this and future milestones, and (2) requesting appropriate amendments to Attachment 4. The Party affected by the failure to meet a milestone shall not unreasonably withhold agreement to such an amendment unless it will suffer significant uncompensated economic or operational harm from the delay, (2) attainment of the same milestone has previously been delayed, or (3) it has reason to believe that the delay in meeting the milestone is intentional or unwarranted notwithstanding the circumstances explained by the Party proposing the amendment.

6.3 Financial Security Arrangements

At least twenty (20) Business Days prior to the commencement of the design, procurement, installation, or construction of a discrete portion of Transmission Provider's Interconnection Facilities and Upgrades, Interconnection Customer shall provide Transmission Provider, at Interconnection Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to Transmission Provider and is consistent with the Uniform Commercial Code of the jurisdiction where the Point of Interconnection is located. Such security for payment shall be in an amount sufficient to cover the costs for constructing, designing, procuring, and installing the applicable portion of Transmission Provider's Interconnection Facilities and Upgrades and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider under this Agreement during its term. In addition:

6.3.1 The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider, and contain terms and conditions that guarantee payment of any amount that may be due from Interconnection Customer, up to an agreed-to maximum amount.

6.3.2 The letter of credit or surety bond must be issued by a financial institution or insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.

Article 7. Assignment, Liability, Indemnity, Force Majeure, Consequential Damages, and Default

7.1 Assignment

This Agreement may be assigned by either Party upon fifteen (15) Business Days prior written notice and opportunity to object by the other Party; provided that:

7.1.1 Either Party may assign this Agreement without the consent of the other Party to any affiliate of the assigning Party with an equal or greater credit rating and with the legal authority and operational ability to satisfy the obligations of the assigning Party under this Agreement, provided that

Interconnection Customer promptly notifies Transmission Provider of any such assignment;

7.1.2 Interconnection Customer shall have the right to assign this Agreement, without the consent of Transmission Provider, for collateral security purposes to aid in providing financing for the Small Generating Facility, provided that Interconnection Customer will promptly notify Transmission Provider of any such assignment.

7.1.3 Any attempted assignment that violates this article is void and ineffective. Assignment shall not relieve a Party of its obligations, nor shall a Party's obligations be enlarged, in whole or in part, by reason thereof. An assignee is responsible for meeting the same financial, credit, and insurance obligations as Interconnection Customer. Where required, consent to assignment will not be unreasonably withheld, conditioned or delayed.

7.2 Limitation of Liability

Each Party's liability to the other Party for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall either Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized by this Agreement.

7.3 Indemnity

7.3.1 This provision protects each Party from liability incurred to third parties as a result of carrying out the provisions of this Agreement. Liability under this provision is exempt from the general limitations on liability found in article 7.2.

7.3.2 The Parties shall at all times indemnify, defend, and hold the other Party harmless from, any and all damages, losses, claims, including claims and actions relating to injury to or death of any person or damage to property,

demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's action or failure to meet its obligations under this Agreement on behalf of the indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the indemnified Party.

7.3.3 If an indemnified person is entitled to indemnification under this article as a result of a claim by a third party, and the indemnifying Party fails, after notice and reasonable opportunity to proceed under this article, to assume the defense of such claim, such indemnified person may at the expense of the indemnifying Party contest, settle or consent to the entry of any judgment with respect to, or pay in full, such claim.

7.3.4 If an indemnifying party is obligated to indemnify and hold any indemnified person harmless under this article, the amount owing to the indemnified person shall be the amount of such indemnified person's actual loss, net of any insurance or other recovery.

7.3.5 Promptly after receipt by an indemnified person of any claim or notice of the commencement of any action or administrative or legal proceeding or investigation as to which the indemnity provided for in this article may apply, the indemnified person shall notify the indemnifying party of such fact. Any failure of or delay in such notification shall not affect a Party's indemnification obligation unless such failure or delay is materially prejudicial to the indemnifying party.

7.4 Consequential Damages

Other than as expressly provided for in this Agreement, neither Party shall be liable under any provision of this Agreement for any losses, damages, costs or expenses for any special, indirect, incidental, consequential, or punitive damages, including but not limited to loss of profit or revenue, loss of the use of equipment, cost of capital, cost of temporary equipment or services, whether based in whole or in part in contract, in tort, including negligence, strict liability, or any other theory of liability; provided, however, that damages for which a Party may be liable to the other Party under another agreement will not be considered to be special, indirect, incidental, or consequential damages hereunder.

7.5 Force Majeure

- 7.5.1 As used in this article, a Force Majeure Event shall mean "any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, breakage or accident to machinery or equipment, any order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, or any other cause beyond a Party's control. A Force Majeure Event does not include an act of negligence or intentional wrongdoing."
- 7.5.2 If a Force Majeure Event prevents a Party from fulfilling any obligations under this Agreement, the Party affected by the Force Majeure Event (Affected Party) shall promptly notify the other Party, either in writing or via the telephone, of the existence of the Force Majeure Event. The notification must specify in reasonable detail the circumstances of the Force Majeure Event, its expected duration, and the steps that the Affected Party is taking to mitigate the effects of the event on its performance. The Affected Party shall keep the other Party informed on a continuing basis of developments relating to the Force Majeure Event until the event ends. The Affected Party will be entitled to suspend or modify its performance of obligations under this Agreement (other than the obligation to make payments) only to the extent that the effect of the Force Majeure Event cannot be mitigated by the use of Reasonable Efforts. The Affected Party will use Reasonable Efforts to resume its performance as soon as possible.

7.6 Default

- 7.6.1 No Default shall exist where such failure to discharge an obligation (other than the payment of money) is the result of a Force Majeure Event as defined in this Agreement or the result of an act or omission of the other Party. Upon a Default, the non-defaulting Party shall give written notice of such Default to the defaulting Party. Except as provided in article 7.6.2, the defaulting Party shall have sixty (60) Calendar Days from receipt of the Default notice within which to cure such Default; provided however, if such Default is not capable of cure within sixty (60) Calendar Days, the

defaulting Party shall commence such cure within twenty (20) Calendar Days after notice and continuously and diligently complete such cure within six months from receipt of the Default notice; and, if cured within such time, the Default specified in such notice shall cease to exist.

7.6.2 If a Default is not cured as provided in this article, or if a Default is not capable of being cured within the period provided for herein, the non-defaulting Party shall have the right to terminate this Agreement by written notice at any time until cure occurs, and be relieved of any further obligation hereunder and, whether or not that Party terminates this Agreement, to recover from the defaulting Party all amounts due hereunder, plus all other damages and remedies to which it is entitled at law or in equity. The provisions of this article will survive termination of this Agreement.

Article 8. Insurance

8.1 Interconnection Customer shall, at its own expense, maintain in force general liability insurance without any exclusion for liabilities related to the interconnection undertaken pursuant to this Agreement. The amount of such insurance shall be sufficient to insure against all reasonably foreseeable direct liabilities given the size and nature of the generating equipment being interconnected, the interconnection itself, and the characteristics of the system to which the interconnection is made. Interconnection Customer shall obtain additional insurance only if necessary as a function of owning and operating a generating facility. Such insurance shall be obtained from an insurance provider authorized to do business in the State where the interconnection is located. Certification that such insurance is in effect shall be provided upon request of Transmission Provider, except that Interconnection Customer shall show proof of insurance to Transmission Provider no later than ten (10) Business Days prior to the anticipated commercial operation date. An Interconnection Customer of sufficient credit-worthiness may propose to self-insure for such liabilities, and such a proposal shall not be unreasonably rejected.

8.2 Transmission Provider agrees to maintain general liability insurance or self-insurance consistent with Transmission Provider's commercial practice. Such

insurance or self-insurance shall not exclude coverage for Transmission Provider's liabilities undertaken pursuant to this Agreement.

- 8.3 The Parties further agree to notify each other whenever an accident or incident occurs resulting in any injuries or damages that are included within the scope of coverage of such insurance, whether or not such coverage is sought.

Article 9. Confidentiality

- 9.1 Confidential Information shall mean any confidential and/or proprietary information provided by one Party to the other Party that is clearly marked or otherwise designated "Confidential." For purposes of this Agreement all design, operating specifications, and metering data provided by Interconnection Customer shall be deemed Confidential Information regardless of whether it is clearly marked or otherwise designated as such.
- 9.2 Confidential Information does not include information previously in the public domain, required to be publicly submitted or divulged by Governmental Authorities (after notice to the other Party and after exhausting any opportunity to oppose such publication or release), or necessary to be divulged in an action to enforce this Agreement. Each Party receiving Confidential Information shall hold such information in confidence and shall not disclose it to any third party nor to the public without the prior written authorization from the Party providing that information, except to fulfill obligations under this Agreement, or to fulfill legal or regulatory requirements.
- 9.2.1 Each Party shall employ at least the same standard of care to protect Confidential Information obtained from the other Party as it employs to protect its own Confidential Information.
- 9.2.2 Each Party is entitled to equitable relief, by injunction or otherwise, to enforce its rights under this provision to prevent the release of Confidential Information without bond or proof of damages, and may seek other remedies available at law or in equity for breach of this provision.

- 9.3 Notwithstanding anything in this article to the contrary, and pursuant to 18 CFR § 1b.20, if FERC, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to this Agreement, the Party shall provide the requested information to FERC, within the time provided for in the request for information. In providing the information to FERC, the Party may, consistent with 18 CFR § 388.112, request that the information be treated as confidential and non-public by FERC and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party to this Agreement prior to the release of the Confidential Information to FERC. The Party shall notify the other Party to this Agreement when it is notified by FERC that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR § 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

Article 10. Disputes

- 10.1 The Parties agree to attempt to resolve all disputes arising out of the interconnection process according to the provisions of this article.
- 10.2 In the event of a dispute, either Party shall provide the other Party with a written Notice of Dispute. Such Notice shall describe in detail the nature of the dispute.
- 10.3 If the dispute has not been resolved within two (2) Business Days after receipt of the Notice, either Party may contact FERC's Dispute Resolution Service (DRS) for assistance in resolving the dispute.
- 10.4 The DRS will assist the Parties in either resolving their dispute or in selecting an appropriate dispute resolution venue (e.g., mediation, settlement judge, early neutral evaluation, or technical expert) to assist the Parties in resolving their dispute. DRS can be reached at 1-877-337-2237 or via the internet at <http://www.ferc.gov/legal/adr.asp>.

- 10.5 Each Party agrees to conduct all negotiations in good faith and will be responsible for one-half of any costs paid to neutral third-parties.
- 10.6 If neither Party elects to seek assistance from the DRS, or if the attempted dispute resolution fails, then either Party may exercise whatever rights and remedies it may have in equity or law consistent with the terms of this Agreement.

Article 11. Taxes

- 11.1 The Parties agree to follow all applicable tax laws and regulations, consistent with FERC policy and Internal Revenue Service requirements.
- 11.2 Each Party shall cooperate with the other to maintain the other Party's tax status. Nothing in this Agreement is intended to adversely affect Transmission Provider's tax exempt status with respect to the issuance of bonds including, but not limited to, local furnishing bonds.

Article 12. Miscellaneous

- 12.1 **Governing Law, Regulatory Authority, and Rules**
The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____ (where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.
- 12.2 **Amendment**
The Parties may amend this Agreement by a written instrument duly executed by both Parties, or under article 12.12 of this Agreement.
- 12.3 **No Third-Party Beneficiaries**

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

12.4 Waiver

12.4.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

12.4.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

12.5 Entire Agreement

This Agreement, including all Attachments, constitutes the entire agreement between the Parties with reference to the subject matter hereof, and supersedes all prior and contemporaneous understandings or agreements, oral or written, between the Parties with respect to the subject matter of this Agreement. There are no other agreements, representations, warranties, or covenants which constitute any part of the consideration for, or any condition to, either Party's compliance with its obligations under this Agreement.

12.6 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

12.7 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

12.8 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

12.9 Security Arrangements

Infrastructure security of electric system equipment and operations and control hardware and software is essential to ensure day-to-day reliability and operational security. FERC expects all Transmission Providers, market participants, and Interconnection Customers interconnected to electric systems to comply with the recommendations offered by the President's Critical Infrastructure Protection Board and, eventually, best practice recommendations from the electric reliability authority. All public utilities are expected to meet basic standards for system infrastructure and operational security, including physical, operational, and cyber-security practices.

12.10 Environmental Releases

Each Party shall notify the other Party, first orally and then in writing, of the release of any hazardous substances, any asbestos or lead abatement activities, or any type of remediation activities related to the Small Generating Facility or the Interconnection Facilities, each of which may reasonably be expected to affect the other Party. The notifying Party shall (1) provide the notice as soon as practicable, provided such Party makes a good faith effort to provide the notice no later than 24 hours after such Party becomes aware of the occurrence, and (2) promptly

furnish to the other Party copies of any publicly available reports filed with any governmental authorities addressing such events.

12.11 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

12.11.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

12.11.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

12.12 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement under any applicable provision of the Federal Power Act and FERC's rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be

considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

Article 13. Notices

13.1 General

Unless otherwise provided in this Agreement, any written notice, demand, or request required or authorized in connection with this Agreement ("Notice") shall be deemed properly given if delivered in person, delivered by recognized national courier service, or sent by first class mail, postage prepaid, to the person specified below:

If to Interconnection Customer:

Interconnection Customer:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

If to Transmission Provider:

Transmission Provider:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

13.2 Billing and Payment

Billings and payments shall be sent to the addresses set out below:

Interconnection Customer: _____

Attention: _____

Address: _____

City: _____ State: _____

Zip: _____

Transmission Provider: _____

Attention: _____

Address: _____

City: _____ State: _____

Zip: _____

13.3 Alternative Forms of Notice

Any notice or request required or permitted to be given by either Party to the other and not required by this Agreement to be given in writing may be so given by telephone, facsimile or e-mail to the telephone numbers and e-mail addresses set out below:

If to Interconnection Customer:

Interconnection Customer: _____

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

If to Transmission Provider:

Transmission Provider:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

13.4 Designated Operating Representative

The Parties may also designate operating representatives to conduct the communications which may be necessary or convenient for the administration of this Agreement. This person will also serve as the point of contact with respect to operations and maintenance of the Party’s facilities.

Interconnection Customer’s Operating Representative:

Interconnection Customer:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

Transmission Provider's Operating Representative:

Transmission Provider:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

13.5 Changes to the Notice Information

Either Party may change this information by giving five (5) Business Days written notice prior to the effective date of the change.

Article 14. Signatures

IN WITNESS WHEREOF, the Parties have caused this Agreement to be executed by their respective duly authorized representatives.

For Transmission Provider

Name: _____

Title: _____

Date: _____

For Interconnection Customer

Name: _____

Title: _____

Date: _____

Attachment 1**Glossary of Terms**

Affected System – An electric system other than Transmission Provider’s Transmission System that may be affected by the proposed interconnection.

Applicable Laws and Regulations – All duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Applicable Reliability Standards - The requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Balancing Authority – An entity that integrates resource plans ahead of time, maintains demand and resource balance within a Balancing Authority Area, and supports interconnection frequency in real time.

Balancing Authority Area – The collection of generation, transmission, and loads within the metered boundaries of the Balancing Authority. The Balancing Authority maintains load-resource balance within this area.

Business Day – Monday through Friday, excluding Federal Holidays.

Default – The failure of a breaching Party to cure its breach under the Small Generator Interconnection Agreement.

Distribution System – Transmission Provider’s facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which Distribution Systems operate differ among areas.

Distribution Upgrades – The additions, modifications, and upgrades to Transmission Provider’s Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Small Generating Facility and render the transmission service necessary to effect Interconnection Customer’s wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Good Utility Practice – Any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Governmental Authority – Any federal, state, local or other governmental regulatory or administrative agency, court, commission, department, board, or other governmental subdivision, legislature, rulemaking board, tribunal, or other governmental authority having jurisdiction over the Parties, their respective facilities, or the respective services they provide, and exercising or entitled to exercise any administrative, executive, police, or taxing authority or power; provided, however, that such term does not include Interconnection Customer, the Interconnection Provider, or any Affiliate thereof.

Interconnection Customer – Any entity, including Transmission Provider, the Transmission Owner or any of the affiliates or subsidiaries of either, that proposes to interconnect its Small Generating Facility with Transmission Provider's Transmission System.

Interconnection Facilities – Transmission Provider's Interconnection Facilities and Interconnection Customer's Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Small Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Small Generating Facility to Transmission Provider's Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades or Network Upgrades.

Interconnection Request – Interconnection Customer's request, in accordance with the Tariff, to interconnect a new Small Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Small Generating Facility that is interconnected with Transmission Provider's Transmission System.

Material Modification – A modification that has a material impact on the cost or timing of any Interconnection Request with a later queue priority date.

Network Upgrades – Additions, modifications, and upgrades to Transmission Provider's Transmission System required at or beyond the point at which the Small Generating Facility interconnects with Transmission Provider's Transmission System to accommodate the interconnection of the Small Generating Facility with Transmission

Provider's Transmission System. Network Upgrades do not include Distribution Upgrades.

Operating Requirements – Any operating and technical requirements that may be applicable due to Regional Transmission Organization, Independent System Operator, Balancing Authority Area, or Transmission Provider's requirements, including those set forth in the Small Generator Interconnection Agreement.

Party or Parties – Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Point of Interconnection – The point where the Interconnection Facilities connect with Transmission Provider's Transmission System.

Reasonable Efforts – With respect to an action required to be attempted or taken by a Party under the Small Generator Interconnection Agreement, efforts that are timely and consistent with Good Utility Practice and are otherwise substantially equivalent to those a Party would use to protect its own interests.

Small Generating Facility – Interconnection Customer's device for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer's Interconnection Facilities.

Tariff – Transmission Provider or Affected System's Tariff through which open access transmission service and Interconnection Service are offered, as filed with the FERC, and as amended or supplemented from time to time, or any successor tariff.

Transmission Owner – The entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Small Generator Interconnection Agreement to the extent necessary.

Transmission Provider – The public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission System – The facilities owned, controlled or operated by Transmission Provider or the Transmission Owner that are used to provide transmission service under the Tariff.

Upgrades – The required additions and modifications to Transmission Provider's Transmission System at or beyond the Point of Interconnection. Upgrades may be Network Upgrades or Distribution Upgrades. Upgrades do not include Interconnection Facilities.

Attachment 2**Description and Costs of the Small Generating Facility,
Interconnection Facilities, and Metering Equipment**

Equipment, including the Small Generating Facility, Interconnection Facilities, and metering equipment shall be itemized and identified as being owned by Interconnection Customer, Transmission Provider, or the Transmission Owner. Transmission Provider will provide a best estimate itemized cost, including overheads, of its Interconnection Facilities and metering equipment, and a best estimate itemized cost of the annual operation and maintenance expenses associated with its Interconnection Facilities and metering equipment.

Docket No. RM22-14-001

- 2 -

Attachment 3

**One-line Diagram Depicting the Small Generating Facility, Interconnection
Facilities, Metering Equipment, and Upgrades**

Docket No. RM22-14-001

- 3 -

Attachment 4

Milestones

In-Service Date: _____

Critical milestones and responsibility as agreed to by the Parties:

	Milestone/Date	Responsible Party
(1)	_____	_____
(2)	_____	_____
(3)	_____	_____
(4)	_____	_____
(5)	_____	_____
(6)	_____	_____
(7)	_____	_____

Docket No. RM22-14-001

- 4 -

(8) _____

(9) _____

(10) _____

Agreed to by:

For Transmission Provider _____ Date _____

For Transmission Owner (If Applicable) _____
Date _____

For Interconnection Customer _____ Date _____

Docket No. RM22-14-001

- 5 -

Attachment 5

**Additional Operating Requirements for Transmission Provider's
Transmission System and Affected Systems Needed to Support
Interconnection Customer's Needs**

Transmission Provider shall also provide requirements that must be met by Interconnection Customer prior to initiating parallel operation with Transmission Provider's Transmission System.

Docket No. RM22-14-001

- 6 -

Attachment 6**Transmission Provider's Description of its Upgrades
and Best Estimate of Upgrade Costs**

Transmission Provider shall describe Upgrades and provide an itemized best estimate of the cost, including overheads, of the Upgrades and annual operation and maintenance expenses associated with such Upgrades. Transmission Provider shall functionalize Upgrade costs and annual expenses as either transmission or distribution related.

ATTACHMENT M

STANDARD LARGE GENERATOR

INTERCONNECTION PROCEDURES (LGIP)

Standard Large Generator

Interconnection Procedures (LGIP)

(Applicable to Generating Facilities that exceed 20 MW)

TABLE OF CONTENTS

	Page No.
Section 1. Definitions.....	- 1 -
Section 2. Scope and Application.....	- 13 -
2.1 Application of Standard Large Generator Interconnection Procedures.....	- 13 -
2.2 Comparability.....	- 14 -
2.3 Base Case Data.....	- 14 -
2.4 No Applicability to Transmission Service.....	- 14 -
Section 3. Interconnection Requests.....	- 15 -
3.1 Interconnection Requests.....	- 15 -
3.2 Identification of Types of Interconnection Services.....	- 17 -
3.3 Utilization of Surplus Interconnection Service.....	- 20 -
3.4 Valid Interconnection Request.....	- 22 -
3.5. OASIS Posting.	- 28 -
3.6 Coordination with Affected Systems.	- 36 -
3.7 Withdrawal.....	- 37 -
3.8 Identification of Contingent Facilities.....	- 50 -
3.9 Penalties for Failure to Meet Study Deadlines.	- 52 -
Section 4. Interconnection Request Evaluation Process.....	- 54 -
4.1 Queue Position.	- 55 -
4.2. General Study Process.	- 55 -
4.3 Transferability of Queue Position.	- 57 -
4.4 Modifications.	- 57 -
Section 5. Procedures for Interconnection Requests Submitted Prior to Effective Date of the Cluster Study Revisions.....	- 61 -
5.1 Procedures for Transitioning to the Cluster Study Process.....	- 61 -
5.2 New Transmission Provider.....	- 67 -
Section 6. Interconnection Information Access.....	- 68 -
6.1 Publicly Posted Interconnection Information.	- 68 -
Section 7. Cluster Study.....	- 69 -
7.1 Cluster Study Agreement.....	- 69 -
7.2 Execution of Cluster Study Agreement.....	- 69 -

- 7.3 Scope of Cluster Study. - 69 -
- 7.4 Cluster Study Procedures..... - 71 -
- 7.5 Cluster Study Restudies..... - 72 -
- Section 8. Interconnection Facilities Study..... - 75 -
 - 8.1 Interconnection Facilities Study Agreement. - 75 -
 - 8.2 Scope of Interconnection Facilities Study. - 76 -
 - 8.3 Interconnection Facilities Study Procedures. - 76 -
 - 8.4 Meeting with Transmission Provider. - 78 -
 - 8.5 Restudy. - 78 -
- Section 9. Affected System Study. - 78 -
 - 9.1 Applicability..... - 78 -
 - 9.2 Response to Notifications. - 78 -
 - 9.3 Affected System Queue Position. - 79 -
 - 9.4 Affected System Study Agreement/Multiparty Affected System
Study Agreement..... - 80 -
 - 9.5 Execution of Affected System Study Agreement/Multiparty Affected
System Study Agreement. - 80 -
 - 9.6 Scope of Affected System Study..... - 81 -
 - 9.7 Affected System Study Procedures..... - 82 -
 - 9.8 Meeting with Transmission Provider. - 83 -
 - 9.9 Affected System Cost Allocation..... - 83 -
 - 9.10 Tender of Affected Systems Facilities Construction
Agreement/Multiparty Affected System Facilities Construction
Agreement..... - 84 -
 - 9.11 Restudy. - 84 -
- Section 10. Optional Interconnection Study - 84 -
 - 10.1 Optional Interconnection Study Agreement. - 84 -
 - 10.2 Scope of Optional Interconnection Study..... - 85 -
 - 10.3 Optional Interconnection Study Procedures. - 86 -
- Section 11. Standard Large Generator Interconnection Agreement (LGIA).. - 86 -
 - 11.1 Tender. - 86 -
 - 11.2 Negotiation..... - 87 -
 - 11.3 Execution and Filing..... - 88 -
 - 11.4 Commencement of Interconnection Activities. - 89 -
- Section 12. Construction of Transmission Provider’s Interconnection Facilities
and Network Upgrades - 90 -
 - 12.1 Schedule..... - 90 -
 - 12.2 Construction Sequencing. - 90 -
- Section 13. Miscellaneous..... - 92 -
 - 13.1 Confidentiality..... - 92 -
 - 13.2 Delegation of Responsibility..... - 97 -
 - 13.3 Obligation for Study Costs. - 97 -
 - 13.4 Third Parties Conducting Studies..... - 98 -

13.5 Disputes. - 99 -
13.6 Local Furnishing Bonds..... - 102 -
13.7 Engineering & Procurement ('E&P') Agreement..... - 103 -

Appendix 1 – Interconnection Request for a Large Generating Facility

Appendix 2 – Cluster Study Agreement

Appendix 3 – Interconnection Facilities Study Agreement

Appendix 4 – Optional Interconnection Study Agreement

Appendix 5 – Standard Large Generator Interconnection Agreement

Appendix 6 – Interconnection Procedures for a Wind Generating Plant

Appendix 7 – Transitional Cluster Study Agreement

Appendix 8 – Transitional Serial Interconnection Facilities Study Agreement

Appendix 9 – Two-Party Affected System Study Agreement

Appendix 10 – Multiparty Affected System Study Agreement

Appendix 11 – Two-Party Affected System Facilities Construction Agreement

Appendix 12 – Multiparty Affected System Facilities Construction Agreement

Section 1. Definitions

Adverse System Impact shall mean the negative effects due to technical or operational limits on conductors or equipment being exceeded that may compromise the safety and reliability of the electric system.

Affected System shall mean an electric system other than Transmission Provider's Transmission System that may be affected by the proposed interconnection.

Affected System Facilities Construction Agreement shall mean the agreement contained in Appendix 11 to this LGIP that is made between Transmission Provider and Affected System Interconnection Customer to facilitate the construction of and to set forth cost responsibility for necessary Affected System Network Upgrades on Transmission Provider's Transmission System.

Affected System Interconnection Customer shall mean any entity that submits an interconnection request for a generating facility to a transmission system other than Transmission Provider's Transmission System that may cause the need for Affected System Network Upgrades on Transmission Provider's Transmission System.

Affected System Network Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Transmission System required to accommodate Affected System Interconnection Customer's proposed interconnection to a transmission system other than Transmission Provider's Transmission System.

Affected System Operator shall mean the entity that operates an Affected System.

Affected System Queue Position shall mean the queue position of an Affected System Interconnection Customer in Transmission Provider's interconnection queue relative to Transmission Provider's Interconnection Customers' Queue Positions.

Affected System Study shall mean the evaluation of Affected System Interconnection Customers' proposed interconnection(s) to a transmission system other than Transmission Provider's Transmission System that have an impact on Transmission Provider's Transmission System, as described in Section 9 of this LGIP.

Affected System Study Agreement shall mean the agreement contained in Appendix 9 to this LGIP that is made between Transmission Provider and Affected System Interconnection Customer to conduct an Affected System Study pursuant to Section 9 of this LGIP.

Affected System Study Report shall mean the report issued following completion of an Affected System Study pursuant to Section 9.7 of this LGIP.

Affiliate shall mean, with respect to a corporation, partnership or other entity, each such other corporation, partnership or other entity that directly or indirectly, through one or more intermediaries, controls, is controlled by, or is under common control with, such corporation, partnership or other entity.

Ancillary Services shall mean those services that are necessary to support the transmission of capacity and energy from resources to loads while maintaining reliable operation of Transmission Provider's Transmission System in accordance with Good Utility Practice.

Applicable Laws and Regulations shall mean all duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Applicable Reliability Standards shall mean the requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Balancing Authority shall mean an entity that integrates resource plans ahead of time, maintains demand and resource balance within a Balancing Authority Area, and supports interconnection frequency in real time.

Balancing Authority Area shall mean the collection of generation, transmission, and loads within the metered boundaries of the Balancing Authority. The Balancing Authority maintains load-resource balance within this area.

Base Case shall mean the base case power flow, short circuit, and stability data bases used for the Interconnection Studies by Transmission Provider or Interconnection Customer.

Breach shall mean the failure of a Party to perform or observe any material term or condition of the Standard Large Generator Interconnection Agreement.

Breaching Party shall mean a Party that is in Breach of the Standard Large Generator Interconnection Agreement.

Business Day shall mean Monday through Friday, excluding Federal Holidays.

Calendar Day shall mean any day including Saturday, Sunday or a Federal Holiday.

Cluster shall mean a group of one or more Interconnection Requests that are studied together for the purpose of conducting a Cluster Study.

Cluster Request Window shall mean the time period set forth in Section 3.4.1 of this LGIP.

Cluster Restudy shall mean a restudy of a Cluster Study conducted pursuant to Section 7.5 of this LGIP.

Cluster Restudy Report shall mean the report issued following completion of a Cluster Restudy pursuant to Section 7.5 of this LGIP.

Cluster Restudy Report Meeting shall mean the meeting held to discuss the results of a Cluster Restudy pursuant to Section 7.5 of this LGIP.

Cluster Study shall mean the evaluation of one or more Interconnection Requests within a Cluster as described in Section 7 of this LGIP.

Cluster Study Agreement shall mean the agreement contained in Appendix 2 to this LGIP for conducting the Cluster Study.

Cluster Study Process shall mean the following processes, conducted in sequence: the Cluster Request Window; the Customer Engagement Window and Scoping Meetings therein; the Cluster Study; any needed Cluster Restudies; and the Interconnection Facilities Study.

Cluster Study Report shall mean the report issued following completion of a Cluster Study pursuant to Section 7 of this LGIP.

Cluster Study Report Meeting shall mean the meeting held to discuss the results of a Cluster Study pursuant to Section 7 of this LGIP.

Clustering shall mean the process whereby one or more Interconnection Requests are studied together, instead of serially, as described in Section 7 of this LGIP.

Commercial Operation shall mean the status of a Generating Facility that has commenced generating electricity for sale, excluding electricity generated during Trial Operation.

Commercial Operation Date of a unit shall mean the date on which the Generating Facility commences Commercial Operation as agreed to by the Parties pursuant to Appendix E to the Standard Large Generator Interconnection Agreement.

Commercial Readiness Deposit shall mean a deposit paid as set forth in Sections 3.4.2, 7.5, and 8.1 of this LGIP.

Confidential Information shall mean any confidential, proprietary or trade secret information of a plan, specification, pattern, procedure, design, device, list, concept, policy or compilation relating to the present or planned business of a Party, which is

designated as confidential by the Party supplying the information, whether conveyed orally, electronically, in writing, through inspection, or otherwise.

Contingent Facilities shall mean those unbuilt Interconnection Facilities and Network Upgrades upon which the Interconnection Request's costs, timing, and study findings are dependent, and if delayed or not built, could cause a need for restudies of the Interconnection Request or a reassessment of the Interconnection Facilities and/or Network Upgrades and/or costs and timing.

Customer Engagement Window shall mean the time period set forth in Section 3.4.5 of this LGIP.

Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 17 of the Standard Large Generator Interconnection Agreement.

Dispute Resolution shall mean the procedure for resolution of a dispute between the Parties in which they will first attempt to resolve the dispute on an informal basis.

Distribution System shall mean Transmission Provider's facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which distribution systems operate differ among areas.

Distribution Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Generating Facility and render the transmission service necessary to effect Interconnection Customer's wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Effective Date shall mean the date on which the Standard Large Generator Interconnection Agreement becomes effective upon execution by the Parties subject to acceptance by FERC, or if filed unexecuted, upon the date specified by FERC.

Electric Reliability Organization shall mean the North American Electric Reliability Corporation (NERC) or its successor organization.

Emergency Condition shall mean a condition or situation: (1) that in the judgment of the Party making the claim is imminently likely to endanger life or property; or (2) that, in the case of a Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to Transmission Provider's Transmission System, Transmission Provider's Interconnection Facilities or the electric systems of others to which Transmission Provider's Transmission System is directly connected; or (3) that, in the case of

Interconnection Customer, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Generating Facility or Interconnection Customer's Interconnection Facilities. System restoration and black start shall be considered Emergency Conditions; provided that Interconnection Customer is not obligated by the Standard Large Generator Interconnection Agreement to possess black start capability.

Energy Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to connect its Generating Facility to Transmission Provider's Transmission System to be eligible to deliver the Generating Facility's electric output using the existing firm or nonfirm capacity of Transmission Provider's Transmission System on an as available basis. Energy Resource Interconnection Service in and of itself does not convey transmission service.

Engineering & Procurement (E&P) Agreement shall mean an agreement that authorizes Transmission Provider to begin engineering and procurement of long lead-time items necessary for the establishment of the interconnection in order to advance the implementation of the Interconnection Request.

Environmental Law shall mean Applicable Laws or Regulations relating to pollution or protection of the environment or natural resources.

Federal Power Act shall mean the Federal Power Act, as amended, 16 U.S.C. §§ 791a et seq.

FERC shall mean the Federal Energy Regulatory Commission (Commission) or its successor.

Force Majeure shall mean any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, breakage or accident to machinery or equipment, any order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, or any other cause beyond a Party's control. A Force Majeure event does not include acts of negligence or intentional wrongdoing by the Party claiming Force Majeure.

Generating Facility shall mean Interconnection Customer's device(s) for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer's Interconnection Facilities.

Generating Facility Capacity shall mean the net capacity of the Generating Facility or the aggregate net capacity of the Generating Facility where it includes more than one device for the production and/or storage for later injection of electricity.

Good Utility Practice shall mean any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Governmental Authority shall mean any federal, state, local or other governmental regulatory or administrative agency, court, commission, department, board, or other governmental subdivision, legislature, rulemaking board, tribunal, or other governmental authority having jurisdiction over the Parties, their respective facilities, or the respective services they provide, and exercising or entitled to exercise any administrative, executive, police, or taxing authority or power; provided, however, that such term does not include Interconnection Customer, Transmission Provider, or any Affiliate thereof.

Hazardous Substances shall mean any chemicals, materials or substances defined as or included in the definition of “hazardous substances,” “hazardous wastes,” “hazardous materials,” “hazardous constituents,” “restricted hazardous materials,” “extremely hazardous substances,” “toxic substances,” “radioactive substances,” “contaminants,” “pollutants,” “toxic pollutants” or words of similar meaning and regulatory effect under any applicable Environmental Law, or any other chemical, material or substance, exposure to which is prohibited, limited or regulated by any applicable Environmental Law.

Initial Synchronization Date shall mean the date upon which the Generating Facility is initially synchronized and upon which Trial Operation begins.

In-Service Date shall mean the date upon which Interconnection Customer reasonably expects it will be ready to begin use of Transmission Provider’s Interconnection Facilities to obtain back feed power.

Interconnection Customer shall mean any entity, including Transmission Provider, Transmission Owner or any of the Affiliates or subsidiaries of either, that proposes to interconnect its Generating Facility with Transmission Provider’s Transmission System.

Interconnection Customer’s Interconnection Facilities shall mean all facilities and equipment, as identified in Appendix A of the Standard Large Generator Interconnection Agreement, that are located between the Generating Facility and the

Point of Change of Ownership, including any modification, addition, or upgrades to such facilities and equipment necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Customer's Interconnection Facilities are sole use facilities.

Interconnection Facilities shall mean Transmission Provider's Interconnection Facilities and Interconnection Customer's Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Interconnection Facilities Study shall mean a study conducted by Transmission Provider or a third party consultant for Interconnection Customer to determine a list of facilities (including Transmission Provider's Interconnection Facilities and Network Upgrades as identified in the Cluster Study), the cost of those facilities, and the time required to interconnect the Generating Facility with Transmission Provider's Transmission System. The scope of the study is defined in Section 8 of this LGIP.

Interconnection Facilities Study Agreement shall mean the form of agreement contained in Appendix 3 of this LGIP for conducting the Interconnection Facilities Study.

Interconnection Facilities Study Report shall mean the report issued following completion of an Interconnection Facilities Study pursuant to Section 8 of this LGIP.

Interconnection Request shall mean an Interconnection Customer's request, in the form of Appendix 1 to this LGIP, in accordance with the Tariff, to interconnect a new Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Generating Facility that is interconnected with Transmission Provider's Transmission System.

Interconnection Service shall mean the service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling it to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Standard Large Generator Interconnection Agreement and, if applicable, Transmission Provider's Tariff.

Interconnection Study shall mean any of the following studies: the Cluster Study, the Cluster Restudy, the Surplus Interconnection Service Study, the

Interconnection Facilities Study, the Affected System Study, Optional Interconnection Study, and Material Modification assessment, described in this LGIP.

IRS shall mean the Internal Revenue Service.

Joint Operating Committee shall be a group made up of representatives from Interconnection Customers and Transmission Provider to coordinate operating and technical considerations of Interconnection Service.

Large Generating Facility shall mean a Generating Facility having a Generating Facility Capacity of more than 20 MW.

LGIA Deposit shall mean the deposit Interconnection Customer submits when returning the executed LGIA, or within ten (10) Business Days of requesting that the LGIA be filed unexecuted at the Commission, in accordance with Section 11.3 of this LGIP.

Loss shall mean any and all losses relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's performance, or non-performance of its obligations under the Standard Large Generator Interconnection Agreement on behalf of the Indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the Indemnifying Party.

Material Modification shall mean those modifications that have a material impact on the cost or timing of any Interconnection Request with an equal or later Queue Position.

Metering Equipment shall mean all metering equipment installed or to be installed at the Generating Facility pursuant to the Standard Large Generator Interconnection Agreement at the metering points, including but not limited to instrument transformers, MWh-meters, data acquisition equipment, transducers, remote terminal unit, communications equipment, phone lines, and fiber optics.

Multiparty Affected System Facilities Construction Agreement shall mean the agreement contained in Appendix 12 to this LGIP that is made among Transmission Provider and multiple Affected System Interconnection Customers to facilitate the construction of and to set forth cost responsibility for necessary Affected System Network Upgrades on Transmission Provider's Transmission System.

Multiparty Affected System Study Agreement shall mean the agreement contained in Appendix 10 to this LGIP that is made among Transmission Provider and multiple Affected System Interconnection Customers to conduct an Affected System Study pursuant to Section 9 of this LGIP.

Network Resource shall mean any designated generating resource owned, purchased, or leased by a Network Customer under the Network Integration Transmission Service Tariff. Network Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Network Customer's Network Load on a non-interruptible basis.

Network Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to integrate its Large Generating Facility with Transmission Provider's Transmission System (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an RTO or ISO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service in and of itself does not convey transmission service.

Network Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Transmission System required at or beyond the point at which the Interconnection Facilities connect to Transmission Provider's Transmission System to accommodate the interconnection of the Large Generating Facility to Transmission Provider's Transmission System.

Notice of Dispute shall mean a written notice of a dispute or claim that arises out of or in connection with the Standard Large Generator Interconnection Agreement or its performance.

Optional Interconnection Study shall mean a sensitivity analysis based on assumptions specified by Interconnection Customer in the Optional Interconnection Study Agreement.

Optional Interconnection Study Agreement shall mean the form of agreement contained in Appendix 4 of this LGIP for conducting the Optional Interconnection Study.

Party or Parties shall mean Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Permissible Technological Advancement shall mean a new, upgraded, updated or improved technology that an Interconnection Customer intends to utilize in the design, construction or operation of generation or transmission facilities but does not (a) include a change in the generation technology or fuel type or (b) constitute a Material Modification.

Point of Change of Ownership shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where

Interconnection Customer's Interconnection Facilities connect to Transmission Provider's Interconnection Facilities.

Point of Interconnection shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where the Interconnection Facilities connect to Transmission Provider's Transmission System.

Proportional Impact Method shall mean a technical analysis conducted by Transmission Provider to determine the degree to which each Generating Facility in the Cluster Study contributes to the need for a specific System Network Upgrade.

Provisional Interconnection Service shall mean Interconnection Service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling that Transmission System to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Provisional Large Generator Interconnection Agreement and, if applicable, the Tariff.

Provisional Large Generator Interconnection Agreement shall mean the interconnection agreement for Provisional Interconnection Service established between Transmission Provider and/or Transmission Owner and Interconnection Customer. This agreement shall take the form of the Standard Large Generator Interconnection Agreement, modified for provisional purposes.

Queue Position shall mean the order of a valid Interconnection Request, relative to all other pending valid Interconnection Requests, established pursuant to Section 4.1 of this LGIP.

Reasonable Efforts shall mean, with respect to an action required to be attempted or taken by a Party under the Standard Large Generator Interconnection Agreement, efforts that are timely and consistent with Good Utility Practice and are otherwise substantially equivalent to those a Party would use to protect its own interests.

Scoping Meeting shall mean the meeting between representatives of Interconnection Customer(s) and Transmission Provider conducted for the purpose of discussing the proposed Interconnection Request and any alternative interconnection options, exchanging information including any transmission data and earlier study evaluations that would be reasonably expected to impact such interconnection options, refining information and models provided by Interconnection Customer(s), discussing the Cluster Study materials posted to OASIS pursuant to Section 3.5 of this LGIP, and analyzing such information.

Site Control shall mean the exclusive land right to develop, construct, operate, and maintain the Generating Facility over the term of expected operation of the

Generating Facility. Site Control may be demonstrated by documentation establishing: (1) ownership of, a leasehold interest in, or a right to develop a site of sufficient size to construct and operate the Generating Facility; (2) an option to purchase or acquire a leasehold site of sufficient size to construct and operate the Generating Facility; or (3) any other documentation that clearly demonstrates the right of Interconnection Customer to exclusively occupy a site of sufficient size to construct and operate the Generating Facility. Transmission Provider will maintain acreage requirements for each Generating Facility type on its OASIS or public website.

Small Generating Facility shall mean a Generating Facility that has a Generating Facility Capacity of no more than 20 MW.

Stand Alone Network Upgrades shall mean Network Upgrades that are not part of an Affected System that Interconnection Customer may construct without affecting day-to-day operations of the Transmission System during their construction. Both Transmission Provider and Interconnection Customer must agree as to what constitutes Stand Alone Network Upgrades and identify them in Appendix A to the Standard Large Generator Interconnection Agreement. If Transmission Provider and Interconnection Customer disagree about whether a particular Network Upgrade is a Stand Alone Network Upgrade, Transmission Provider must provide Interconnection Customer a written technical explanation outlining why Transmission Provider does not consider the Network Upgrade to be a Stand Alone Network Upgrade within fifteen (15) Business Days of its determination.

Standard Large Generator Interconnection Agreement (LGIA) shall mean the form of interconnection agreement applicable to an Interconnection Request pertaining to a Large Generating Facility that is included in Transmission Provider's Tariff.

Standard Large Generator Interconnection Procedures (LGIP) shall mean the interconnection procedures applicable to an Interconnection Request pertaining to a Large Generating Facility that are included in Transmission Provider's Tariff.

Substation Network Upgrades shall mean Network Upgrades that are required at the substation located at the Point of Interconnection.

Surplus Interconnection Service shall mean any unneeded portion of Interconnection Service established in a Standard Large Generator Interconnection Agreement, such that if Surplus Interconnection Service is utilized, the total amount of Interconnection Service at the Point of Interconnection would remain the same.

System Network Upgrades shall mean Network Upgrades that are required beyond the substation located at the Point of Interconnection.

System Protection Facilities shall mean the equipment, including necessary protection signal communications equipment, required to protect (1) Transmission Provider's Transmission System from faults or other electrical disturbances occurring at the Generating Facility and (2) the Generating Facility from faults or other electrical system disturbances occurring on Transmission Provider's Transmission System or on other delivery systems or other generating systems to which Transmission Provider's Transmission System is directly connected.

Tariff shall mean Transmission Provider's Tariff through which open access transmission service and Interconnection Service are offered, as filed with FERC, and as amended or supplemented from time to time, or any successor tariff.

Transitional Cluster Study shall mean an Interconnection Study evaluating a Cluster of Interconnection Requests during the transition to the Cluster Study Process, as set forth in Section 5.1.1.2 of this LGIP.

Transitional Cluster Study Agreement shall mean the agreement contained in Appendix 7 to this LGIP that is made between Transmission Provider and Interconnection Customer to conduct a Transitional Cluster Study pursuant to Section 5.1.1.2 of this LGIP.

Transitional Cluster Study Report shall mean the report issued following completion of a Transitional Cluster Study pursuant to Section 5.1.1.2 of this LGIP.

Transitional Serial Interconnection Facilities Study shall mean an Interconnection Facilities Study evaluating an Interconnection Request on a serial basis during the transition to the Cluster Study Process, as set forth in Section 5.1.1.1 of this LGIP.

Transitional Serial Interconnection Facilities Study Agreement shall mean the agreement contained in Appendix 8 to this LGIP that is made between Transmission Provider and Interconnection Customer to conduct a Transitional Serial Interconnection Facilities Study pursuant to Section 5.1.1.1 of this LGIP.

Transitional Serial Interconnection Facilities Study Report shall mean the report issued following completion of a Transitional Serial Interconnection Facilities Study pursuant to Section 5.1.1.1 of this LGIP.

Transitional Withdrawal Penalty shall mean the penalty assessed by Transmission Provider to Interconnection Customer that has entered the Transitional Cluster Study or Transitional Serial Interconnection Facilities Study and chooses to withdraw or is deemed withdrawn from Transmission Provider's interconnection queue or whose Generating Facility does not otherwise reach Commercial Operation. The

calculation of the Transitional Withdrawal Penalty is set forth in Sections 5.1.1.1 and 5.1.1.2 of this LGIP.

Transmission Owner shall mean an entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Standard Large Generator Interconnection Agreement to the extent necessary.

Transmission Provider shall mean the public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission Provider's Interconnection Facilities shall mean all facilities and equipment owned, controlled, or operated by Transmission Provider from the Point of Change of Ownership to the Point of Interconnection as identified in Appendix A to the Standard Large Generator Interconnection Agreement, including any modifications, additions or upgrades to such facilities and equipment. Transmission Provider's Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Transmission System shall mean the facilities owned, controlled or operated by Transmission Provider or Transmission Owner that are used to provide transmission service under the Tariff.

Trial Operation shall mean the period during which Interconnection Customer is engaged in on-site test operations and commissioning of the Generating Facility prior to Commercial Operation.

Withdrawal Penalty shall mean the penalty assessed by Transmission Provider to an Interconnection Customer that chooses to withdraw or is deemed withdrawn from Transmission Provider's interconnection queue or whose Generating Facility does not otherwise reach Commercial Operation. The calculation of the Withdrawal Penalty is set forth in Section 3.7.1 of this LGIP.

Section 2. Scope and Application

2.1 Application of Standard Large Generator Interconnection Procedures. Sections 2 through 13 of this LGIP apply to processing an Interconnection Request pertaining to a Large Generating Facility.

2.2 Comparability.

Transmission Provider shall receive, process and analyze all Interconnection Requests in a timely manner as set forth in this LGIP. Transmission Provider shall process and analyze Interconnection Requests from all Interconnection Customers comparably, regardless of whether the Generating Facilities are owned by Transmission Provider, its subsidiaries or Affiliates or others.

2.3 Base Case Data.

Transmission Provider shall maintain base power flow, short circuit and stability databases, including all underlying assumptions, and contingency list on either its OASIS site or a password-protected website, subject to confidentiality provisions in LGIP Section 13.1. In addition, Transmission Provider shall maintain network models and underlying assumptions on either its OASIS site or a password-protected website. Such network models and underlying assumptions should reasonably represent those used during the most recent Interconnection Study and be representative of current system conditions. If Transmission Provider posts this information on a password-protected website, a link to the information must be provided on Transmission Provider's OASIS site. Transmission Provider is permitted to require that Interconnection Customers, OASIS site users and password-protected website users sign a confidentiality agreement before the release of commercially sensitive information or Critical Energy Infrastructure Information in the Base Case data. Such databases and lists, hereinafter referred to as Base Cases, shall include all (1) generation projects and (2) transmission projects, including merchant transmission projects that are proposed for the Transmission System for which a transmission expansion plan has been submitted and approved by the applicable authority.

2.4 No Applicability to Transmission Service.

Nothing in this LGIP shall constitute a request for transmission service or confer upon an Interconnection Customer any right to receive transmission service.

Section 3. Interconnection Requests

3.1 Interconnection Requests.

3.1.1 Study Deposits.

3.1.1.1 Study Deposit. Interconnection Customer shall submit to Transmission Provider, during a Cluster Request Window, an Interconnection Request in the form of Appendix 1 to this LGIP, a non-refundable application fee of \$5,000, and a refundable study deposit of:

(a) \$35,000 plus \$1,000 per MW for Interconnection Requests < 80 MW; or

(b) \$150,000 for Interconnection Requests \geq 80 MW < 200 MW; or

(c) \$250,000 for Interconnection Requests \geq 200 MW.

Transmission Provider shall apply the study deposit toward the cost of the Cluster Study Process.

3.1.2 Submission.

Interconnection Customer shall submit a separate Interconnection Request for each site. Where multiple Generating Facilities share a site, Interconnection Customer(s) may submit separate Interconnection Requests or a single Interconnection Request. An Interconnection Request to evaluate one site at two different voltage levels shall be treated as two Interconnection Requests.

At Interconnection Customer's option, Transmission Provider and Interconnection Customer will identify alternative Point(s) of Interconnection and configurations at a Scoping Meeting within the Customer Engagement Window to evaluate in this process and attempt to eliminate alternatives in a reasonable fashion given resources and information available. Interconnection Customer will select the definitive Point of Interconnection to be studied no later than the execution of the Cluster Study Agreement. For purposes of clustering Interconnection Requests, Transmission Provider may propose changes to the requested Point of Interconnection to facilitate efficient interconnection of Interconnection Customers at common Point(s) of Interconnection. Transmission Provider shall notify Interconnection Customers in writing of any intended changes to the requested Point of Interconnection within the Customer Engagement Window, and the Point of Interconnection shall only change upon mutual agreement.

Transmission Provider shall have a process in place to consider requests for Interconnection Service below the Generating Facility Capacity. These requests for Interconnection Service shall be studied at the level of Interconnection Service requested for purposes of Interconnection Facilities, Network Upgrades, and associated costs, but may be subject to other studies at the full Generating Facility Capacity to ensure safety and reliability of the system, with the study costs borne by Interconnection Customer. If after the additional studies are complete, Transmission Provider determines that additional Network Upgrades are necessary, then Transmission Provider must: (1) specify which additional Network Upgrade costs are based on which studies; and (2) provide a detailed explanation of why the additional Network Upgrades are necessary. Any Interconnection Facility and/or Network Upgrade costs required for safety and reliability also would be borne by Interconnection Customer. Interconnection Customers may be subject to additional control technologies as well as testing and validation of those technologies consistent with Article 6 of the LGIA. The necessary control technologies and protection systems shall be established in Appendix C of that executed, or requested to be filed unexecuted, LGIA.

Transmission Provider shall have a process in place to study Generating Facilities that include at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect the proposed charging behavior of the Generating Facility as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions. If Transmission Provider finds Interconnection Customer's requested operating assumptions conflict with Good Utility Practice, Transmission Provider must provide Interconnection Customer an explanation in writing of why the submitted operating assumptions are insufficient or inappropriate by no later than thirty (30) Calendar Days before the end of the Customer Engagement Window and allow Interconnection Customer to revise and resubmit requested operating assumptions one time at least ten (10) Calendar Days prior to the end of the Customer Engagement Window. Transmission Provider shall study these requests for Interconnection Service, with the study costs borne by Interconnection Customer, using the submitted operating assumptions for purposes of Interconnection Facilities, Network Upgrades, and associated costs. These requests for Interconnection Service also may be subject to other studies at the full Generating Facility Capacity to ensure safety and reliability of the system, with the study costs borne by Interconnection Customer. Interconnection Customer's Generating Facility may be subject to additional control technologies as well as testing and validation of such additional control technologies consistent with Article 6 of the LGIA. The necessary control technologies and protection systems shall be set forth in Appendix C of Interconnection Customer's LGIA.

3.2 Identification of Types of Interconnection Services.

At the time the Interconnection Request is submitted, Interconnection Customer must request either Energy Resource Interconnection Service or Network Resource Interconnection Service, as described; provided, however, any Interconnection Customer requesting Network Resource Interconnection Service may also request that it be concurrently studied for

Energy Resource Interconnection Service, up to the point when an Interconnection Facilities Study Agreement is executed. Interconnection Customer may then elect to proceed with Network Resource Interconnection Service or to proceed under a lower level of interconnection service to the extent that only certain upgrades will be completed.

3.2.1 Energy Resource Interconnection Service.

3.2.1.1 The Product. Energy Resource Interconnection Service allows Interconnection Customer to connect the Large Generating Facility to the Transmission System and be eligible to deliver the Large Generating Facility's output using the existing firm or non-firm capacity of the Transmission System on an "as available" basis. Energy Resource Interconnection Service does not in and of itself convey any right to deliver electricity to any specific customer or Point of Delivery.

3.2.1.2 The Study. The study consists of short circuit/fault duty, steady state (thermal and voltage) and stability analyses. The short circuit/fault duty analysis would identify direct Interconnection Facilities required and the Network Upgrades necessary to address short circuit issues associated with the Interconnection Facilities. The stability and steady state studies would identify necessary upgrades to allow full output of the proposed Large Generating Facility, except for Generating Facilities that include at least one electric storage resource that request to use operating assumptions pursuant to Section 3.1.2, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions, and would also identify the maximum allowed output, at the time the study is performed, of

the interconnecting Large Generating Facility without requiring additional Network Upgrades.

3.2.2 Network Resource Interconnection Service.

3.2.2.1 The Product. Transmission Provider must conduct the necessary studies and construct the Network Upgrades needed to integrate the Large Generating Facility (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an ISO or RTO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service allows Interconnection Customer's Large Generating Facility to be designated as a Network Resource, up to the Large Generating Facility's full output, on the same basis as existing Network Resources interconnected to Transmission Provider's Transmission System, and to be studied as a Network Resource on the assumption that such a designation will occur.

3.2.2.2 The Study. The Interconnection Study for Network Resource Interconnection Service shall assure that Interconnection Customer's Large Generating Facility meets the requirements for Network Resource Interconnection Service and as a general matter, that such Large Generating Facility's interconnection is also studied with Transmission Provider's Transmission System at peak load, under a variety of severely stressed conditions, to determine whether, with the Large Generating Facility at full output, except for Generating Facilities that include at least one electric storage resource that request to use, and for which Transmission Provider approves, operating assumptions pursuant to Section 3.1.2, the aggregate of generation in the local area can be delivered to the aggregate of load on Transmission Provider's

Transmission System, consistent with Transmission Provider's reliability criteria and procedures. This approach assumes that some portion of existing Network Resources are displaced by the output of Interconnection Customer's Large Generating Facility. Network Resource Interconnection Service in and of itself does not convey any right to deliver electricity to any specific customer or Point of Delivery. Transmission Provider may also study the Transmission System under non-peak load conditions. However, upon request by Interconnection Customer, Transmission Provider must explain in writing to Interconnection Customer why the study of non-peak load conditions is required for reliability purposes.

3.3 Utilization of Surplus Interconnection Service.

Transmission Provider must provide a process that allows an Interconnection Customer to utilize or transfer Surplus Interconnection Service at an existing Point of Interconnection. The original Interconnection Customer or one of its affiliates shall have priority to utilize Surplus Interconnection Service. If the existing Interconnection Customer or one of its affiliates does not exercise its priority, then that service may be made available to other potential Interconnection Customers.

3.3.1 Surplus Interconnection Service Requests.

Surplus Interconnection Service requests may be made by the existing Interconnection Customer or one of its affiliates or may be submitted once Interconnection Customer has executed the LGIA or requested that the LGIA be filed unexecuted. Surplus Interconnection Service requests also may be made by another Interconnection Customer. Transmission Provider shall provide a process for evaluating Interconnection Requests for Surplus Interconnection Service. Studies for Surplus Interconnection Service shall consist of reactive power, short circuit/fault duty, stability analyses, and any other appropriate studies. Steady-state (thermal/voltage) analyses may be performed as necessary to ensure that all required reliability conditions are studied. If the Surplus

Interconnection Service was not studied under off-peak conditions, off-peak steady state analyses shall be performed to the required level necessary to demonstrate reliable operation of the Surplus Interconnection Service. If the original system impact study report or Cluster Study Report is not available for the Surplus Interconnection Service, both off-peak and peak analysis may need to be performed for the existing Generating Facility associated with the request for Surplus Interconnection Service. The reactive power, short circuit/fault duty, stability, and steady-state analyses for Surplus Interconnection Service will identify any additional Interconnection Facilities and/or Network Upgrades necessary.

Transmission Provider shall study Surplus Interconnection Service requests for a Generating Facility that includes at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect the proposed charging behavior of the Generating Facility as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions.

3.3.2 Process for Surplus Interconnection Service

A request for Surplus Interconnection Service may be initiated by transmitting information to the Transmission Provider specifying the Large Generator Interconnection for which such service is requested, and that the request be treated pursuant to Section 3.3 of the LGIP. The cover transmittal should also indicate whether or not the request is related to service provided to the original Interconnection Customer or its affiliate's Large Generator Interconnection.

Should the Transmission Provider receive a request for Surplus Interconnection Service at a Point of Interconnection from a third party relating to an existing Large Generator Interconnection, the original Interconnection Customer or its affiliates shall have priority. Transmission Provider will notify the original Interconnection Customer of any competing request, and that original Interconnection Customer will have ten (10) days to exercise its priority rights. The prospective Interconnection Customer with the competing request will be notified within ten (10) days of any exercise of priority rights. Failure to exercise priority rights by the original Interconnection Customer will result in all excess capacity available through Surplus Interconnection Service being

released to other potential Interconnection Customers for a period up to one hundred and eighty (180) days.

Nothing in this Section 3.3.2 should be construed as limiting the right of the original Large Generator Interconnection Customer to either release all claims to priority on a permanent basis or to transfer its priority right to Surplus Interconnection Service to a third party.

Once the priority right of the original Interconnection Customer or its affiliates has been properly exercised, waived (either expressly or through the expiration of the ten (10) day window set out above), released or transferred, the request for Surplus Interconnection Service shall be studied pursuant to the criteria set forth in Section 3.3.1. The timeline and requirements for the study process shall be as follows:

1. The surplus Interconnection Customer must execute an appropriate study agreement and provide a study deposit in the amount of \$10,000 within five (5) Business Days after execution of the agreement.
2. The \$10,000 deposit will be applied to the actual cost of all studies referenced in Section 3.3.1. Any difference in actual cost will be paid by, or refunded to, the surplus Interconnection Customer.
3. In the event that the Transmission Provider and Interconnection Customer cannot agree upon the study agreement, the agreement may be filed on an unexecuted basis with the Commission.
4. Studies performed under Section 3.3.1 shall be completed outside the interconnection study queue set out in Section 3 to the LGIP, and completed within sixty (60) calendar days after execution of a study agreement and receipt of the study deposit.
5. Results of all studies required under Section 3.3.1 shall be communicated to the potential Interconnection Customer as soon as practicable.

Surplus Interconnection Service shall be documented in an agreement between the original Interconnection Customer, surplus Interconnection Customer and Transmission Provider and shall be executed prior to the commencement of service. All agreements shall be filed in accordance with the Commission's regulations governing service agreements under the Transmission Provider's Tariff.

3.4 Valid Interconnection Request.

3.4.1 Cluster Request Window.

Transmission Provider shall accept Interconnection Requests during a forty-five (45) Calendar Day period (the Cluster Request

Window). The initial Cluster Request Window shall open for Interconnection Requests beginning one hundred eighty (180) Calendar Days after the conclusion of the transition process set out in Section 5.1 of this LGIP and successive Cluster Request Windows shall open annually every February 1 thereafter.

3.4.2 Initiating an Interconnection Request.

An Interconnection Customer seeking to join a Cluster shall submit its Interconnection Request to Transmission Provider within, and no later than the close of, the Cluster Request Window. Interconnection Requests submitted outside of the Cluster Request Window will not be considered. To initiate an Interconnection Request, Interconnection Customer must submit all of the following:

- (i) Applicable study deposit amount, pursuant to Section 3.1.1.1 of this LGIP,
- (ii) A completed application in the form of Appendix 1,
- (iii) Demonstration of no less than ninety percent (90%) Site Control or (1) a signed affidavit from an officer of the company indicating that Site Control is unobtainable due to regulatory limitations as such term is defined by Transmission Provider; and (2) documentation sufficiently describing and explaining the source and effects of such regulatory limitations, including a description of any conditions that must be met to satisfy the regulatory limitations and the anticipated time by which Interconnection Customer expects to satisfy the regulatory requirements and (3) a deposit in lieu of Site Control of \$10,000 per MW, subject to a minimum of \$500,000 and a maximum of \$2,000,000. Interconnection Requests from multiple Interconnection Customers for multiple Generating Facilities that share a site must include a contract or other agreement that allows for shared land use,
- (iv) Generating Facility Capacity (MW) (and requested Interconnection Service level if the requested Interconnection Service is less than the Generating Facility Capacity),

(v) If applicable, (1) the requested operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) to be used by Transmission Provider that reflect the proposed charging behavior of the Generating Facility that includes at least one electric storage resource, and (2) a description of any control technologies (software and/or hardware) that will limit the operation of the Generating Facility to the operating assumptions submitted by Interconnection Customer,

(vi) A Commercial Readiness Deposit equal to two times the study deposit described in Section 3.1.1.1 of this LGIP in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider. This Commercial Readiness Deposit is refunded to Interconnection Customer according to Section 3.7 of this LGIP,

(vii) A Point of Interconnection, and

(viii) Whether the Interconnection Request shall be studied for Network Resource Interconnection Service or for Energy Resource Interconnection Service, consistent with Section 3.2 of this LGIP.

An Interconnection Customer that submits a deposit in lieu of Site Control due to demonstrated regulatory limitations must demonstrate that it is taking identifiable steps to secure the necessary regulatory approvals from the applicable federal, state, and/or tribal entities before execution of the Cluster Study Agreement. Such deposit will be held by Transmission Provider until Interconnection Customer provides the required Site Control demonstration for its point in the Cluster Study Process. Interconnection Customers facing qualifying regulatory limitations must demonstrate one hundred percent (100%) Site Control within one hundred eighty (180) Calendar Days of the effective date of the LGIA.

Interconnection Customer shall promptly inform Transmission Provider of any material change to Interconnection Customer's demonstration of Site Control under Section 3.4.2(iii) of this LGIP. If Transmission Provider determines, based on Interconnection Customer's information, that Interconnection Customer no longer

satisfies the Site Control requirement, Transmission Provider shall give Interconnection Customer ten (10) Business Days to demonstrate satisfaction with the applicable requirement subject to Transmission Provider's approval. Absent such, Transmission Provider shall deem the Interconnection Request withdrawn pursuant to Section 3.7 of this LGIP.

The expected In-Service Date of the new Large Generating Facility or increase in capacity of the existing Generating Facility shall be no more than the process window for the regional expansion planning period (or in the absence of a regional planning process, the process window for Transmission Provider's expansion planning period) not to exceed seven (7) years from the date the Interconnection Request is received by Transmission Provider, unless Interconnection Customer demonstrates that engineering, permitting and construction of the new Large Generating Facility or increase in capacity of the existing Generating Facility will take longer than the regional expansion planning period. The In-Service Date may succeed the date the Interconnection Request is received by Transmission Provider by a period up to ten (10) years, or longer where Interconnection Customer and Transmission Provider agree, such agreement not to be unreasonably withheld.

3.4.3 Acknowledgment of Interconnection Request.

Transmission Provider shall acknowledge receipt of the Interconnection Request within five (5) Business Days of receipt of the request and attach a copy of the received Interconnection Request to the acknowledgement.

3.4.4 Deficiencies in Interconnection Request.

An Interconnection Request will not be considered to be a valid request until all items in Section 3.4.2 of this LGIP have been received by Transmission Provider during the Cluster Request Window. If an Interconnection Request fails to meet the requirements set forth in Section 3.4.2 of this LGIP, Transmission Provider shall notify Interconnection Customer within five (5) Business Days of receipt of the initial Interconnection Request of the reasons for such failure and that the Interconnection Request does

not constitute a valid request. Interconnection Customer shall provide Transmission Provider the additional requested information needed to constitute a valid request within ten (10) Business Days after receipt of such notice but no later than the close of the Cluster Request Window. At any time, if Transmission Provider finds that the technical data provided by Interconnection Customer is incomplete or contains errors, Interconnection Customer and Transmission Provider shall work expeditiously and in good faith to remedy such issues. In the event that Interconnection Customer fails to comply with this Section 3.4.4 of this LGIP, Transmission Provider shall deem the Interconnection Request withdrawn (without the cure period provided under Section 3.7 of this LGIP), the application fee is forfeited to Transmission Provider, and the study deposit and Commercial Readiness Deposit shall be returned to Interconnection Customer.

3.4.5 Customer Engagement Window.

Upon the close of each Cluster Request Window, Transmission Provider shall open a sixty (60) Calendar Day period (Customer Engagement Window). During the Customer Engagement Window, Transmission Provider shall hold a Scoping Meeting with all interested Interconnection Customers. Notwithstanding the preceding requirements and upon written consent of all Interconnection Customers within the Cluster, Transmission Provider may shorten the Customer Engagement Window and begin the Cluster Study. Within ten (10) Business Days of the opening of the Customer Engagement Window, Transmission Provider shall post on its OASIS a list of Interconnection Requests for that Cluster. The list shall identify, for each anonymized Interconnection Request: (1) the requested amount of Interconnection Service; (2) the location by county and state; (3) the station or transmission line or lines where the interconnection will be made; (4) the projected In-Service Date; (5) the type of Interconnection Service requested; and (6) the type of Generating Facility or Facilities to be constructed, including fuel types, such as coal, natural gas, solar, or wind. Transmission Provider must ensure that project information is anonymized and does not reveal the identity or commercial information of Interconnection Customers with submitted requests. During the

Customer Engagement Window, Transmission Provider shall provide to Interconnection Customer a non-binding updated good faith estimate of the cost and timeframe for completing the cluster Study and a Cluster Study Agreement to be executed prior to the close of the Customer Engagement Window.

At the end of the Customer Engagement Window, all Interconnection Requests deemed valid that have executed a Cluster Study Agreement in the form of Appendix 2 to this LGIP shall be included in the Cluster Study. Any Interconnection Requests for which Interconnection Customer has not executed a Cluster Study Agreement shall be deemed withdrawn (without the cure period provided under Section 3.7 of this LGIP) by Transmission Provider, the application fee shall be forfeited to Transmission Provider, and Transmission Provider shall return the study deposit and Commercial Readiness Deposit to Interconnection Customer. Immediately following the Customer Engagement Window, Transmission Provider shall initiate the Cluster Study described in Section 7 of this LGIP.

3.4.6 Cluster Study Scoping Meeting.

During the Customer Engagement Window, Transmission Provider shall hold a Scoping Meeting with all Interconnection Customers whose valid Interconnection Requests were received in that Cluster Request Window.

The purpose of the Cluster Study Scoping Meeting shall be to discuss alternative interconnection options, to exchange information including any transmission data and earlier study evaluations that would reasonably be expected to impact such interconnection options, to discuss the Cluster Study materials posted to OASIS pursuant to Section 3.5 of this LGIP, if applicable, and to analyze such information. Transmission Provider and Interconnection Customer(s) will bring to the meeting such technical data, including, but not limited to: (i) general facility loadings, (ii) general instability issues, (iii) general short circuit issues, (iv) general

voltage issues, and (v) general reliability issues as may be reasonably required to accomplish the purpose of the meeting. Transmission Provider and Interconnection Customer(s) will also bring to the meeting personnel and other resources as may be reasonably required to accomplish the purpose of the meeting in the time allocated for the meeting. On the basis of the meeting, Interconnection Customer(s) shall designate its Point of Interconnection. The duration of the meeting shall be sufficient to accomplish its purpose. If the Cluster Study Scoping Meeting consists of more than one Interconnection Customer, Transmission Provider shall issue, no later than fifteen (15) Business Days after the commencement of the Customer Engagement Window, and Interconnection Customer shall execute a non-disclosure agreement prior to a group Cluster Study Scoping Meeting, which will provide for confidentiality of identifying information or commercially sensitive information pertaining to any other Interconnection Customers.

3.5. OASIS Posting.

3.5.1 OASIS Posting.

Transmission Provider will maintain on its OASIS a list of all Interconnection Requests. The list will identify, for each Interconnection Request: (i) the maximum summer and winter megawatt electrical output; (ii) the location by county and state; (iii) the station or transmission line or lines where the interconnection will be made; (iv) the projected In-Service Date; (v) the status of the Interconnection Request, including Queue Position; (vi) the type of Interconnection Service being requested; (vii) the availability of any studies related to the Interconnection Request; (viii) the date of the Interconnection Request; (ix) the type of Generating Facility to be constructed; and (x) for Interconnection Requests that have not resulted in a completed interconnection, an explanation as to why it was not completed. Except in the case of an Affiliate, the list will not disclose the identity of Interconnection Customer until Interconnection Customer executes an LGIA or requests that Transmission Provider file an unexecuted LGIA with FERC. Before holding a Scoping Meeting with its Affiliate, Transmission Provider

shall post on OASIS an advance notice of its intent to do so. Transmission Provider shall post to its OASIS site any deviations from the study timelines set forth herein. Interconnection Study reports and Optional Interconnection Study reports shall be posted to Transmission Provider's OASIS site subsequent to the meeting between Interconnection Customer and Transmission Provider to discuss the applicable study results. Transmission Provider shall also post any known deviations in the Large Generating Facility's In-Service Date.

3.5.2 Requirement to Post Interconnection Study Metrics.

Transmission Provider will maintain on its OASIS or its website summary statistics related to processing Interconnection Studies pursuant to Interconnection Requests, updated quarterly. If Transmission Provider posts this information on its website, a link to the information must be provided on Transmission Provider's OASIS site. For each calendar quarter, Transmission Provider must calculate and post the information detailed in Sections 3.5.2.1 through 3.5.2.4 of this LGIP.

3.5.2.1 Interconnection Cluster Study Processing Time.

(A) Number of Interconnection Requests that had Cluster Studies completed within Transmission Provider's coordinated region during the reporting quarter,

(B) Number of Interconnection Requests that had Cluster Studies completed within Transmission Provider's coordinated region during the reporting quarter that were completed more than one hundred fifty (150) Calendar Days after the close of the Customer Engagement Window,

(C) At the end of the reporting quarter, the number of active valid Interconnection Requests with ongoing incomplete Cluster Studies where such Interconnection Requests had executed a Cluster Study Agreement received by Transmission Provider more than one hundred fifty (150) Calendar Days before the reporting quarter end,

(D) Mean time (in days), Cluster Studies completed within Transmission Provider's coordinated region during the reporting quarter, from the commencement of the Cluster Study to the date when Transmission Provider provided the completed Cluster Study Report to Interconnection Customer,

(E) Mean time (in days), Cluster Studies were completed within Transmission Provider's coordinated region during the reporting quarter, from the close of the Cluster Request Window to the date when Transmission Provider provided the completed Cluster Study Report to Interconnection Customer,

(F) Percentage of Cluster Studies exceeding one hundred fifty (150) Calendar Days to complete this reporting quarter, calculated as the sum of Section 3.5.2.1(B) plus Section 3.5.2.1(C) divided by the sum of Section 3.5.2.1(A) plus Section 3.5.2.1(C) of this LGIP.

3.5.2.2 Cluster Restudies Processing Time.

(A) Number of Interconnection Requests that had Cluster Restudies completed within Transmission

Provider's coordinated region during the reporting quarter,

(B) Number of Interconnection Requests that had Cluster Restudies completed within Transmission Provider's coordinated region during the reporting quarter that were completed more than one hundred fifty (150) Calendar Days after Transmission Provider notifies Interconnection Customers in the Cluster that a Cluster Restudy is required pursuant to Section 7.5(4) of this LGIP,

(C) At the end of the reporting quarter, the number of active valid Interconnection Requests with ongoing incomplete Cluster Restudies where Transmission Provider notified Interconnection Customers in the Cluster that a Cluster Restudy is required pursuant to Section 7.5(4) of this LGIP more than one hundred fifty (150) Calendar Days before the reporting quarter end,

(D) Mean time (in days), Cluster Restudies completed within Transmission Provider's coordinated region during the reporting quarter, from the date when Transmission Provider notifies Interconnection Customers in the Cluster that a Cluster Restudy is required pursuant to Section 7.5(4) of this LGIP to the date when Transmission Provider provided the completed Cluster Restudy Report to Interconnection Customer,

(E) Mean time (in days), Cluster Restudies completed within Transmission Provider's coordinated region during the reporting quarter, from the close of the Cluster Request Window to the date when

Transmission Provider provided the completed Cluster Restudy Report to Interconnection Customer,

(F) Percentage of Cluster Restudies exceeding one hundred fifty (150) Calendar Days to complete this reporting quarter, calculated as the sum of Section 3.5.2.2(B) plus Section 3.5.2.2(C) divided by the sum of Section 3.5.2.2(A) plus Section 3.5.2.2(C) of this LGIP.

3.5.2.3 Interconnection Facilities Studies Processing Time.

(A) Number of Interconnection Requests that had Interconnection Facilities Studies that are completed within Transmission Provider's coordinated region during the reporting quarter,

(B) Number of Interconnection Requests that had Interconnection Facilities Studies that are completed within Transmission Provider's coordinated region during the reporting quarter that were completed more than 90 days with a cost variance of 20% or 180 days with a cost variance of 10% after receipt by Transmission Provider of Interconnection Customer's executed Interconnection Facilities Study Agreement,

(C) At the end of the reporting quarter, the number of active valid Interconnection Service requests with ongoing incomplete Interconnection Facilities Studies where such Interconnection Requests had executed Interconnection Facilities Studies Agreement received by Transmission Provider more than 90 days with a cost variance of 20% or 180 days with a cost variance of 10% before the reporting quarter end,

(D) Mean time (in days), for Interconnection Facilities Studies completed within Transmission Provider's coordinated region during the reporting quarter, calculated from the date when Transmission Provider received the executed Interconnection Facilities Study Agreement to the date when Transmission Provider provided the completed Interconnection Facilities Study to Interconnection Customer,

(E) Mean time (in days), Interconnection Facilities Studies completed within Transmission Provider's coordinated region during the reporting quarter, from the close of the Cluster Request Window to the date when Transmission Provider provided the completed Interconnection Facilities Study to Interconnection Customer,

(F) Percentage of delayed Interconnection Facilities Studies this reporting quarter, calculated as the sum of Section 3.5.2.3(B) plus Section 3.5.2.3(C) divided by the sum of Section 3.5.2.3(A) plus Section 3.5.2.3(C) of this LGIP.

3.5.2.4 Interconnection Service Requests Withdrawn from Interconnection Queue.

(A) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue during the reporting quarter,

(B) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue during the reporting quarter before completion of any Interconnection Studies or execution of any Interconnection Study agreements,

(C) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue during the reporting quarter before completion of a Cluster Study,

(D) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue during the reporting quarter before completion of an Interconnection Facilities Study,

(E) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue after completion of an Interconnection Facilities Study but before execution of an LGIA or Interconnection Customer requests the filing of an unexecuted, new LGIA,

(F) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue after execution of an LGIA or Interconnection Customer requests the filing of an unexecuted, new LGIA

(G) Mean time (in days), for all withdrawn Interconnection Requests, from the date when the request was determined to be valid to when Transmission Provider received the request to withdraw from the queue.

3.5.3

Transmission Provider is required to post on OASIS or its website the measures in Section 3.5.2.1(A) through Section 3.5.2.4(G) for each calendar quarter within thirty (30) Calendar Days of the end of

the calendar quarter. Transmission Provider will keep the quarterly measures posted on OASIS or its website for three (3) calendar years with the first required report to be in the first quarter of 2020. If Transmission Provider retains this information on its website, a link to the information must be provided on Transmission Provider's OASIS site.

3.5.4

In the event that any of the values calculated in Sections 3.5.2.1(E), 3.5.2.2(E) or 3.5.2.3(E) exceeds twenty-five percent (25%) for two (2) consecutive calendar quarters, Transmission Provider will have to comply with the measures below for the next four (4) consecutive calendar quarters and must continue reporting this information until Transmission Provider reports four (4) consecutive calendar quarters without the values calculated in Sections 3.5.2.1(E), 3.5.2.2(E) or 3.5.2.3(E) exceeding twenty-five percent (25%) for two (2) consecutive calendar quarters:

(i) Transmission Provider must submit a report to the Commission describing the reason for each Cluster Study, Cluster Restudy, or individual Interconnection Facilities Study pursuant to one or more Interconnection Request(s) that exceeded its deadline (i.e., 150, 90 or 180 Calendar Days) for completion. Transmission Provider must describe the reasons for each study delay and any steps taken to remedy these specific issues and, if applicable, prevent such delays in the future. The report must be filed at the Commission within forty-five (45) Calendar Days of the end of the calendar quarter.

(ii) Transmission Provider shall aggregate the total number of employee-hours and third party consultant hours expended towards Interconnection Studies within its coordinated region that quarter and post on OASIS or its website. If Transmission Provider posts this information on its website, a link to the information must be provided on Transmission Provider's OASIS site. This information is to be posted

within thirty (30) Calendar Days of the end of the calendar quarter.

3.6 Coordination with Affected Systems.

Transmission Provider will coordinate the conduct of any studies required to determine the impact of the Interconnection Request on Affected Systems with Affected System Operators. Interconnection Customer will cooperate with Transmission Provider and Affected System Operator in all matters related to the conduct of studies and the determination of modifications to Affected Systems.

A Transmission Provider whose system may be impacted by a proposed interconnection on another transmission provider's transmission system shall cooperate with transmission provider with whom interconnection has been requested in all matters related to the conduct of studies and the determination of modifications to Transmission Provider's Transmission System.

3.6.1 Initial Notification.

Transmission Provider must notify Affected System Operator of a potential Affected System impact caused by an Interconnection Request within ten (10) Business Days of the completion of the Cluster Study.

At the time of initial notification, Transmission Provider must provide Interconnection Customer with a list of potential Affected Systems, along with relevant contact information.

3.6.2 Notification of Cluster Restudy.

Transmission Provider must notify Affected System Operator of a Cluster Restudy concurrently with its notification of such Cluster Restudy to Interconnection Customers.

3.6.3 Notification of Cluster Restudy Completion.

Upon the completion of Transmission Provider's Cluster Restudy, Transmission Provider will notify Affected System Operator of a

potential Affected System impact caused by an Interconnection Request within ten (10) Business Days of the completion of the Cluster Restudy, regardless of whether that potential Affected System impact was previously identified. At the time of the notification of the completion of the Cluster Restudy to the Affected System Operator, Transmission Provider must provide Interconnection Customer with a list of potential Affected System Operators, along with relevant contact information.

3.7 Withdrawal.

Interconnection Customer may withdraw its Interconnection Request at any time by written notice of such withdrawal to Transmission Provider. In addition, if Interconnection Customer fails to adhere to all requirements of this LGIP, except as provided in Section 13.5 (Disputes), Transmission Provider shall deem the Interconnection Request to be withdrawn and shall provide written notice to Interconnection Customer of the deemed withdrawal and an explanation of the reasons for such deemed withdrawal. Upon receipt of such written notice, Interconnection Customer shall have fifteen (15) Business Days in which to either respond with information or actions that cures the deficiency or to notify Transmission Provider of its intent to pursue Dispute Resolution.

Withdrawal shall result in the loss of Interconnection Customer's Queue Position. If an Interconnection Customer disputes the withdrawal and loss of its Queue Position, then during Dispute Resolution, Interconnection Customer's Interconnection Request is eliminated from the queue until such time that the outcome of Dispute Resolution would restore its Queue Position. An Interconnection Customer that withdraws or is deemed to have withdrawn its Interconnection Request shall pay to Transmission Provider all costs that Transmission Provider prudently incurs with respect to that Interconnection Request prior to Transmission Provider's receipt of notice described above. Interconnection Customer must pay all monies due to Transmission Provider before it is allowed to obtain any Interconnection Study data or results.

If Interconnection Customer withdraws its Interconnection Request or is deemed withdrawn by Transmission Provider under Section 3.7 of this

LGIP, Transmission Provider shall (i) update the OASIS Queue Position posting; (ii) impose the Withdrawal Penalty described in Section 3.7.1 of this LGIP; and (iii) refund to Interconnection Customer any portion of the refundable portion of Interconnection Customer's study deposit that exceeds the costs that Transmission Provider has incurred, including interest calculated in accordance with Section 35.19a(a)(2) of FERC's regulations. Transmission Provider shall also refund any portion of the Commercial Readiness Deposit not applied to the Withdrawal Penalty and, if applicable, the deposit in lieu of site control. In the event of such withdrawal, Transmission Provider, subject to the confidentiality provisions of Section 13.1 of this LGIP, shall provide, at Interconnection Customer's request, all information that Transmission Provider developed for any completed study conducted up to the date of withdrawal of the Interconnection Request.

3.7.1 Withdrawal Penalty.

Interconnection Customer shall be subject to a Withdrawal Penalty if it withdraws its Interconnection Request or is deemed withdrawn, or the Generating Facility does not otherwise reach Commercial Operation unless: (1) the withdrawal does not have a material impact on the cost or timing of any Interconnection Request in the same Cluster; (2) Interconnection Customer withdraws after receiving Interconnection Customer's most recent Cluster Restudy Report and the Network Upgrade costs assigned to the Interconnection Request identified in that report have increased by more than twenty-five percent (25%) compared to costs identified in Interconnection Customer's preceding Cluster Study Report or Cluster Restudy Report; or (3) Interconnection Customer withdraws after receiving Interconnection Customer's Interconnection Facilities Study Report and the Network Upgrade costs assigned to the Interconnection Request identified in that report have increased by more than one hundred percent (100%) compared to costs identified in the Cluster Study Report or Cluster Restudy Report.

3.7.1.1 Calculation of the Withdrawal Penalty.

If Interconnection Customer withdraws its Interconnection Request or is deemed withdrawn

prior to the commencement of the initial Cluster Study, Interconnection Customer shall not be subject to a Withdrawal Penalty. If Interconnection Customer withdraws, is deemed withdrawn, or otherwise does not reach Commercial Operation at any point after the commencement of the initial Cluster Study, that Interconnection Customer's Withdrawal Penalty will be the greater of: (1) Interconnection Customer's study deposit required under Section 3.1.1.1 of this LGIP; or (2) as follows in (a)–(d):

(a) If Interconnection Customer withdraws or is deemed withdrawn during the Cluster Study or after receipt of a Cluster Study Report, but prior to commencement of the Cluster Restudy or Interconnection Facilities Study if no Cluster Restudy is required, Interconnection Customer shall be charged two (2) times its actual allocated cost of all studies performed for Interconnection Customers in the Cluster up until that point in the Interconnection Study process.

(b) If Interconnection Customer withdraws or is deemed withdrawn during the Cluster Restudy or after receipt of any applicable restudy reports issued pursuant to Section 7.5 of this LGIP, but prior to commencement of the Interconnection Facilities Study, Interconnection Customer shall be charged five percent (5%) its estimated Network Upgrade costs.

(c) If Interconnection Customer withdraws or is deemed withdrawn during the Interconnection Facilities Study, after receipt of the Interconnection Facilities Study Report issued pursuant to Section 8.3 of this LGIP, or after

receipt of the draft LGIA but before Interconnection Customer has executed an LGIA or has requested that its LGIA be filed unexecuted, and has satisfied the other requirements described in Section 11.3 of this LGIP (i.e., Site Control demonstration, LGIA Deposit, reasonable evidence of one or more milestones in the development of the Generating Facility), Interconnection Customer shall be charged ten percent (10%) its estimated Network Upgrade costs.

(d) If Interconnection Customer has executed an LGIA or has requested that its LGIA be filed unexecuted and has satisfied the other requirements described in Section 11.3 of this LGIP (i.e., Site Control demonstration, LGIA Deposit, reasonable evidence of one or more milestones in the development of the Generating Facility) and subsequently withdraws its Interconnection Request or if Interconnection Customer's Generating Facility otherwise does not reach Commercial Operation, that Interconnection Customer's Withdrawal Penalty shall be twenty percent (20%) its estimated Network Upgrade costs.

3.7.1.2 Distribution of the Withdrawal Penalty.

3.7.1.2.1 Initial Distribution of Withdrawal Penalties Prior to Assessment of Network Upgrade Costs Previously Shared with Withdrawn Interconnection Customers in the Same Cluster.

For a single Cluster, Transmission Provider shall hold all Withdrawal Penalty funds until all Interconnection Customers in that Cluster have either: (1) withdrawn

or been deemed withdrawn; (2) executed an LGIA; or (3) requested an LGIA to be filed unexecuted. Any Withdrawal Penalty funds collected from the Cluster shall first be used to fund studies conducted under the Cluster Study Process for Interconnection Customers in the same Cluster that have executed the LGIA or requested the LGIA to be filed unexecuted. Next, after the Withdrawal Penalty funds are applied to relevant study costs in the same Cluster, Transmission Provider will apply the remaining Withdrawal Penalty funds to reduce net increases, for Interconnection Customers in the same Cluster, in Interconnection Customers' Network Upgrade cost assignment and associated financial security requirements under Article 11.5 of the pro forma LGIA attributable to the impacts of withdrawn Interconnection Customers that shared an obligation with the remaining Interconnection Customers to fund a Network Upgrade, as described in more detail in Sections 3.7.1.2.3 and 3.7.1.2.4. The total amount of funds used to fund these studies under the Cluster Study Process or those applied to any net increases in Network Upgrade costs for Interconnection Customers in the same Cluster shall not exceed the total amount of Withdrawal Penalty funds collected from the Cluster.

Withdrawal Penalty funds shall first be applied as a refund to invoiced study costs for Interconnection Customers in the same Cluster that did not withdraw within thirty (30) Calendar Days of such Interconnection Customers executing their LGIA or requesting to have their LGIA filed unexecuted. Distribution of Withdrawal Penalty funds within one specific Cluster for study costs shall not exceed the total actual Cluster Study Process costs for the Cluster. Withdrawal Penalty funds applied to study costs shall be allocated within the same Cluster to Interconnection Customers in a manner consistent with Transmission Provider's method in Section 13.3 of this LGIP for

allocating the costs of Interconnection Studies conducted on a clustered basis. Transmission Provider shall post the balance of Withdrawal Penalty funds held by Transmission Provider but not yet dispersed on its OASIS site and update this posting on a quarterly basis.

If an Interconnection Customer withdraws after it executes, or requests the unexecuted filing of, its LGIA, Transmission Provider shall first apply such Interconnection Customer's Withdrawal Penalty funds to any restudy costs required due to Interconnection Customer's withdrawal as a credit to as-yet-to be invoiced study costs to be charged to the remaining Interconnection Customers in the same Cluster in a manner consistent with Transmission Provider's method in Section 13.3 of this LGIP for allocating the costs of Interconnection Studies conducted on a clustered basis. Distribution of the Withdrawal Penalty funds for such restudy costs shall not exceed the total actual restudy costs.

3.7.1.2.2 Assessment of Network Upgrade Costs Previously Shared with Withdrawn Interconnection Customers in the Same Cluster.

If Withdrawal Penalty funds remain for the same Cluster after the Withdrawal Penalty funds are applied to relevant study costs, Transmission Provider will determine if the withdrawn Interconnection Customers, at any point in the Cluster Study Process, shared cost assignment for one or more Network Upgrades with any remaining Interconnection Customers in the same Cluster based on the Cluster Study Report, Cluster Restudy Report(s), Interconnection Facilities Study Report, and any subsequent issued restudy report issued for the Cluster.

In Section 3.7.1.2 of this LGIP, shared cost assignments for Network Upgrades refers to the cost of Network Upgrades still needed for the same Cluster for which an Interconnection Customer, prior to withdrawing its Interconnection Request, shared the obligation to fund along with Interconnection Customers that have executed an LGIA, or requested the LGIA to be filed unexecuted.

If Transmission Provider's assessment determines that there are no shared cost assignments for any Network Upgrades in the same Cluster for the withdrawn Interconnection Customer, or determines that the withdrawn Interconnection Customer's withdrawal did not cause a net increase in the shared cost assignment for any remaining Interconnection Customers' Network Upgrade(s) in the same Cluster, Transmission Provider will return any remaining Withdrawal Penalty funds to the withdrawn Interconnection Customer(s). Such remaining Withdrawal Penalty funds will be returned to withdrawn Interconnection Customers based on the proportion of each withdrawn Interconnection Customer's contribution to the total amount of Withdrawal Penalty funds collected for the Cluster (i.e., the total amount before the initial disbursement required under Section 3.7.1.2.1 of this LGIP). Transmission Provider must make such disbursement within sixty (60) Calendar Days of the date on which all Interconnection Customers in the same Cluster have either: (1) withdrawn or been deemed withdrawn; (2) executed an LGIA; or (3) requested an LGIA to be filed unexecuted. For the withdrawn Interconnection Customers that Transmission Provider determines have caused a net increase in the shared cost assignment for one or more Network Upgrade(s) in the same Cluster under Section 3.7.1.2.3(a) of this LGIP, Transmission Provider will determine each such withdrawn Interconnection Customers' Withdrawal Penalty funds remaining

balance that will be applied toward net increases in Network Upgrade shared costs calculated under Sections 3.7.1.2.3(a) and 3.7.1.2.3(b) of this LGIP based on each such withdrawn Interconnection Customer's proportional contribution to the total amount of Withdrawal Penalty funds collected for the same Cluster (i.e., the total amount before the initial disbursement requirement under Section 3.7.1.2.1 of this LGIP).

If Transmission Provider's assessment determines that there are shared cost assignments for Network Upgrades in the same Cluster, Transmission Provider will calculate the remaining Interconnection Customers' net increase in cost assignment for Network Upgrades due to a shared cost assignment for Network Upgrades with the withdrawn Interconnection Customer and distribute Withdrawal Penalty funds as described in Section 3.7.1.2.3, depending on whether the withdrawal occurred before the withdrawing Interconnection Customer executed the LGIA (or filed unexecuted), as described in Section 3.7.1.2.3(a) of this LGIP, or after such execution (or filing unexecuted) of an LGIA, as described in Section 3.7.1.2.3(b) of this LGIP.

As discussed in Section 3.7.1.2.4 of this LGIP, Transmission Provider will amend executed (or filed unexecuted) LGIAs of the remaining Interconnection Customers in the same Cluster to apply the remaining Withdrawal Penalty funds to reduce net increases in Interconnection Customers' Network Upgrade cost assignment and associated financial security requirements under Article 11.5 of the pro forma LGIA attributable to the impacts of withdrawn Interconnection Customers on Interconnection Customers remaining in the same Cluster that had a

shared cost assignment for Network Upgrades with the withdrawn Interconnection Customers.

3.7.1.2.3 Impact Calculations.

3.7.1.2.3(a) Impact Calculation for Withdrawals During the Cluster Study Process.

If an Interconnection Customer withdraws before it executes, or requests the unexecuted filing of, its LGIA, Transmission Provider will distribute in the following manner the Withdrawal Penalty funds to reduce the Network Upgrade cost impact on the remaining Interconnection Customers in the same Cluster who had a shared cost assignment for a Network Upgrade with the withdrawn Interconnection Customer.

To calculate the reduction in the remaining Interconnection Customers' net increase in Network Upgrade costs and associated financial security requirements under Article 11.5 of the pro forma LGIA, Transmission Provider will determine the financial impact of a withdrawing Interconnection Customer on other Interconnection Customers in the same Cluster that shared an obligation to fund the same Network Upgrade(s). Transmission Provider shall calculate this financial impact once all Interconnection Customers in the same Cluster either: (1) have withdrawn or have been deemed withdrawn; (2) executed an LGIA; or (3) request an LGIA to be filed unexecuted. Transmission Provider will perform the financial impact calculation using the following steps.

First, Transmission Provider must determine which withdrawn Interconnection Customers shared an obligation to fund Network Upgrades with Interconnection Customers from the same Cluster that have LGIAs that are executed or have been requested to be filed unexecuted. Next, Transmission Provider shall perform the calculation of the financial impact of a withdrawal on another Interconnection Request in the same Cluster by performing a comparison of the Network Upgrade cost estimates between each of the following:

- (1) Cluster Study phase to Cluster Restudy phase (if Cluster Restudy was necessary);
- (2) Cluster Restudy phase to Interconnection Facilities Study phase (if a Cluster Restudy was necessary);
- (3) Cluster Study phase to Interconnection Facilities Study phase (if no Cluster Restudy was performed);
- (4) Interconnection Facilities Study phase to any subsequent restudy that was performed before the execution or filing of an unexecuted LGIA;
- (5) the restudy to the executed, or filed unexecuted, LGIA (if a restudy was performed after the Interconnection Facilities Study phase and before the execution or filing of an unexecuted LGIA).

If, based on the above calculations, Transmission Provider determines:

(i) that the costs assigned to an Interconnection Customer in the same Cluster for Network Upgrades that a withdrawn Interconnection Customer shared cost assignment for increased between any two studies, and

(ii) after the impacted Interconnection Customer's LGIA was executed or filed unexecuted, Interconnection Customer's cost assignment for the relevant Network Upgrade is greater than it was prior to the withdrawal of Interconnection Customer in the same Cluster that shared cost assignment for the Network Upgrade,

then Transmission Provider shall apply the withdrawn Interconnection Customer's Withdrawal Penalty funds that has not already been applied to study costs in the amount of the financial impact by reducing, in the same Cluster, the remaining Interconnection Customer's Network Upgrade costs and associated financial security requirements under Article 11.5 of the pro forma LGIA.

If Transmission Provider determines that more than one Interconnection Customer in the same Cluster was financially impacted by the same withdrawn Interconnection Customer, Transmission Provider will apply the relevant withdrawn Interconnection Customer's Withdrawal Penalty funds that has not already been applied to study costs to reduce the financial impact to each Interconnection Customer based on each Interconnection Customer's proportional share of the financial impact, as determined by either the Proportional Impact Method if it is a System Network Upgrade or on a per capita basis if it is a Substation Network Upgrade, as described under Section 4.2.1 of this LGIP.

3.7.1.2.3(b) Impact Calculation for Withdrawals in the Same Cluster After the Cluster Study Process.

If an Interconnection Customer withdraws after it executes, or requests the unexecuted filing of, its LGIA, Transmission Provider will distribute in the following manner the remaining Withdrawal Penalty funds to reduce the Network Upgrade cost impact on the remaining Interconnection Customers in the same Cluster who had a shared cost assignment with the withdrawn Interconnection Customer for one or more Network Upgrades.

Transmission Provider will determine the financial impact on the remaining Interconnection Customers in the same Cluster within thirty (30) Calendar Days after the withdrawal occurs. Transmission Provider will determine that financial impact by comparing the Network Upgrade cost funding obligations Interconnection Customers shared with the withdrawn Interconnection Customer before the withdrawal of Interconnection Customer and after the withdrawal of Interconnection Customer. If that comparison indicates an increase in Network Upgrade costs for an Interconnection Customer, Transmission Provider shall apply the withdrawn Interconnection Customer's Withdrawal Penalty funds to the increased costs each impacted Interconnection Customer in the same Cluster experienced associated with such Network Upgrade(s) in proportion to each Interconnection Customer's increased cost assignment, as determined by Transmission Provider.

3.7.1.2.4 Amending LGIA to Apply Reductions to Interconnection Customer's Assigned Network Upgrade Costs and Associated Financial Security

Requirement with Respect to Withdrawals in the Same Cluster.

Within thirty (30) Calendar Days of all Interconnection Customers in the same Cluster having: (1) withdrawn or been deemed withdrawn; (2) executed an LGIA; or (3) requested an LGIA to be filed unexecuted, Transmission Provider must perform the calculations described in Section 3.7.1.2.3(a) of this LGIP and provide such Interconnection Customers with an amended LGIA that provides the reduction in Network Upgrade cost assignment and associated reduction to Interconnection Customer's financial security requirements, under Article 11.5 of the pro forma LGIA, due from Interconnection Customer to Transmission Provider.

Where an Interconnection Customer executes the LGIA (or requests the filing of an unexecuted LGIA) and is later withdrawn or its LGIA is terminated, Transmission Provider must, within thirty (30) Calendar Days of such withdrawal or termination, perform the calculations described in Section 3.7.1.2.3(b) of this LGIP and provide such Interconnection Customers in the same Cluster with an amended LGIA that provides the reduction in Network Upgrade cost assignment and associated reduction to Interconnection Customer's financial security requirements, under Article 11.5 of the pro forma LGIA, due from Interconnection Customer to Transmission Provider.

Any repayment by Transmission Provider to Interconnection Customer under Article 11.4 of the pro forma LGIA of amounts advanced for Network Upgrades after the Generating Facility achieves Commercial Operation shall be limited to Interconnection Customer's total amount of Network

Upgrade costs paid and associated financial security provided to Transmission Provider under Article 11.5 of the pro forma LGIA.

3.7.1.2.5

Final Distribution of Withdrawal Penalty Funds.

If Withdrawal Penalty funds remain for the Cluster after the Withdrawal Penalty funds are applied to relevant study costs and net increases in shared cost assignments for Network Upgrades to remaining Interconnection Customers, Transmission Provider will return any remaining Withdrawal Penalty funds to the withdrawn Interconnection Customers in the same Cluster net of the amount of each withdrawn Interconnection Customer's Withdrawal Penalty funds applied to study costs and net increases in shared cost assignments for Network Upgrades to remaining Interconnection Customers.

3.8 Identification of Contingent Facilities.

Transmission Provider shall post in this section a method for identifying the Contingent Facilities to be provided to Interconnection Customer at the conclusion of the Cluster Study and included in Interconnection Customer's Large Generator Interconnection Agreement. The method shall be sufficiently transparent to determine why a specific Contingent Facility was identified and how it relates to the Interconnection Request. Transmission Provider shall also provide, upon request of Interconnection Customer, the estimated Interconnection Facility and/or Network Upgrade costs and estimated in-service completion time of each identified Contingent Facility when this information is readily available and not commercially sensitive.

3.8 Identification of Contingent Facilities. The Cluster Study shall identify any Contingent Facilities that may impact the results of the Cluster Study and explain how each Contingent Facility was identified and how it relates to the Interconnection Request.

3.8.1 Method for Identifying Contingent Facilities

The following process, outlined below, is to be followed by Transmission

Provider to identify Contingent Facilities, if any, upon which the Interconnection Customer's costs, timing, and study findings are dependent. Any Contingent Facilities that are identified will be provided to Interconnection Customer within the LGIP Interconnection Cluster Study.

- i) During each Cluster Study, Transmission Provider will review higher queued interconnection requests to determine whether any of the request(s) have unbuilt Interconnection Facilities and/or Network Upgrades that may be necessary to provide the Interconnection Customer's requested interconnection. Such unbuilt facilities and/or upgrades will be noted as potential Contingent Facilities and used in various impact studies (as described in Section 3.8.1.ii).
- ii) Near completion of the Cluster Study, the Transmission Provider will finalize the list of Contingent Facilities by removing each previously identified potential Contingent Facility and, if applicable, any Affected System facility modifications from the study cases, and perform steady state, short circuit, voltage stability, and/or transient stability analyses to determine if the Transmission System is unable to demonstrate acceptable system performance. Acceptable system performance, as used in this context for purposes of identifying Contingent Facilities, is determined during the analysis by meeting the performance requirements outlined in Table 1 of NERC standard TPL-001-4. The studied system shall remain stable, cascading and uncontrolled islanding shall not occur and applicable facility ratings shall not be exceeded during pre and post contingency for all study cases/seasonal models. Acceptable system performance shall also mean that system operating limits shall not be exceeded for all pre and post contingency scenarios and the system must demonstrate compliance with the "SPP 2019 TPL-001-4 Planning Assessment Scope" (or its annual successor), which requires pre-contingency voltage between .95 and 1.05 per unit of nominal, post-contingency voltage between .90 and 1.05 per unit of nominal, no post-contingency voltage deviation greater than .10 per unit, and no transmission lines/ conductors are overloaded (greater than 100% of the modeled line rating) during pre and post-contingency scenarios.
- iii) If the Transmission System fails to demonstrate acceptable system performance (based on the analysis performed for each potential Contingent Facility as described in Section 3.8.1.ii), the potential contingent facility will be confirmed as a Contingent Facility. Potential contingent facilities that are associated with communications, protection, and automation systems necessary for

the operation of the Generating Facility or associated with delivery of its output, are also deemed Contingent Facilities.

- iv) In the Cluster Study report, Transmission Provider will list each Contingent Facility and why it was identified as such.

3.8.2. Estimates Available for Contingent Facilities. Upon request of the Interconnection Customer, the Transmission Provider shall provide the estimated costs of Interconnection Facilities and/or Network Upgrades and estimated in-service completion times of each Contingent Facility identified in the Cluster Study performed pursuant to Section 7.3 of the LGIP, if, and to the extent, Transmission Provider determines such information is readily available and not commercially sensitive.

3.8.3 Inclusion of Contingent Facilities in LGIA. Any Contingent Facilities identified for Interconnection Customer at the conclusion of a Cluster Study, performed pursuant to Section 7.3 of this LGIP, will subsequently be included in such Interconnection Customer's Large Generator Interconnection Agreement, to the extent they are still applicable.

3.9 Penalties for Failure to Meet Study Deadlines.

(1) Transmission Provider shall be subject to a penalty if it fails to complete a Cluster Study, Cluster Restudy, Interconnection Facilities Study, or Affected Systems Study by the applicable deadline set forth in this LGIP. Transmission Provider must pay the penalty for each late Cluster Study, Cluster Restudy, and Interconnection Facilities Study on a pro rata basis per Interconnection Request to all Interconnection Customer(s) included in the relevant study that did not withdraw, or were not deemed withdrawn, from Transmission Provider's interconnection queue before the missed study deadline, in proportion to each Interconnection Customer's final study cost. Transmission Provider must pay the penalty for a late Affected Systems Study on a pro rata basis per interconnection request to all Affected System Interconnection Customer(s) included in the relevant Affected System Study that did not withdraw, or were not deemed withdrawn, from the host transmission provider's interconnection queue before the missed study deadline, in proportion to each Interconnection Customer's final study cost. The study delay penalty for each late study shall be distributed no later than forty-five (45) Calendar Days after the late study has been completed.

(2) For penalties assessed in accordance with this Section, the penalty amount will be equal to: \$1,000 per Business Day for delays of Cluster Studies beyond the applicable deadline set forth in this LGIP; \$2,000 per Business Day for delays of Cluster Restudies beyond the applicable deadline set forth in this LGIP; \$2,000 per Business Day for delays of Affected System Studies beyond the applicable deadline set forth in this LGIP; and \$2,500 per Business Day for delays of Interconnection Facilities Studies beyond the applicable deadline set forth in this LGIP. The total amount of a penalty assessed under this Section shall not exceed: (a) one hundred percent (100%) of the initial study deposit(s) received for all of the Interconnection Requests in the Cluster for Cluster Studies and Cluster Restudies; (b) one hundred percent (100%) of the initial study deposit received for the single Interconnection Request in the study for Interconnection Facilities Studies; and (c) one hundred percent (100%) of the study deposit(s) that Transmission Provider collects for conducting the Affected System Study.

(3) Transmission Provider may appeal to the Commission any penalties imposed under this Section. Any such appeal must be filed no later than forty-five (45) Calendar Days after the late study has been completed. While an appeal to the Commission is pending, Transmission Provider shall remain liable for the penalty, but need not distribute the penalty until forty-five (45) Calendar Days after (1) the deadline for filing a rehearing request has ended, if no requests for rehearing of the appeal have been filed, or (2) the date that any requests for rehearing of the Commission's decision on the appeal are no longer pending before the Commission. The Commission may excuse Transmission Provider from penalties under this Section for good cause.

(4) No penalty will be assessed under this Section where a study is delayed by ten (10) Business Days or less. If the study is delayed by more than ten (10) Business Days, the penalty amount will be calculated from the first Business Day Transmission Provider misses the applicable study deadline.

(5) If (a) Transmission Provider needs to extend the deadline for a particular study subject to penalties under this Section and (b) all Interconnection Customers or Affected System Interconnection Customers included in the relevant study mutually agree to such an extension, the deadline for that study shall be extended thirty (30) Business Days from the original deadline. In such a scenario, no penalty will be assessed for Transmission Provider missing the original deadline.

(6) No penalties shall be assessed until the third Cluster Study cycle (including any Transitional Cluster Study cycle, but not Transitional Serial Interconnection Facilities Studies) after the Commission-approved effective date of Transmission Provider's filing made in compliance with the Final Rule in Docket No. RM22-14-000.

(7) Transmission Provider must maintain on its OASIS or its public website summary statistics related to penalties assessed under this Section, updated quarterly. For each calendar quarter, Transmission Provider must calculate and post (1) the total amount of penalties assessed under this Section during the previous reporting quarter and (2) the highest penalty assessed under this Section paid to a single Interconnection Customer or Affected System Interconnection Customer during the previous reporting quarter. Transmission Provider must post on its OASIS or its website these penalty amounts for each calendar quarter within thirty (30) Calendar Days of the end of the calendar quarter. Transmission Provider must maintain the quarterly measures posted on its OASIS or its website for three (3) calendar years with the first required posting to be the third Cluster Study cycle (including any Transitional Cluster Study cycle, but not Transitional Serial Interconnection Facilities Studies) after Transmission Provider transitions to the Cluster Study Process.

Section 4. Interconnection Request Evaluation Process.

an Interconnection Customer has submitted a valid Interconnection Request pursuant to Section 3.4 of this LGIP, such Interconnection Request shall become part of Transmission Provider's interconnection queue for further processing pursuant to the following procedures.

4.1 Queue Position.

4.1.1 Assignment of Queue Position.

Transmission Provider shall assign a Queue Position as follows: the Queue Position within the queue shall be assigned based upon the date and time of receipt of all items required pursuant to the provisions of Section 3.4 of this LGIP. All Interconnection Requests submitted and validated in a single Cluster Request Window shall be considered equally queued.

4.1.2 Higher Queue Position.

A higher Queue Position assigned to an Interconnection Request is one that has been placed “earlier” in the queue in relation to another Interconnection Request that is assigned a lower Queue Position. All requests studied in a single Cluster shall be considered equally queued. Interconnection Customers that are part of Clusters initiated earlier in time than an instant queue shall be considered to have a higher Queue Position than Interconnection Customers that are part of Clusters initiated later than an instant queue.

4.2. General Study Process.

Interconnection Studies performed within the Cluster Study Process shall be conducted in such a manner to ensure the efficient implementation of the applicable regional transmission expansion plan in light of the Transmission System’s capabilities at the time of each study and consistent with Good Utility Practice.

Transmission Provider may use subgroups in the Cluster Study Process. In all instances in which Transmission Provider elects to use subgroups in the Cluster Study Process, Transmission Provider must publish the criteria used to define and determine subgroups on its OASIS or public website.

4.2.1 Cost Allocation for Interconnection Facilities and Network Upgrades.

(1) For Network Upgrades identified in Cluster Studies, Transmission Provider shall calculate each Interconnection Customer's share of the costs as follows:

(a) Substation Network Upgrades, including all switching stations, shall be allocated first per capita to Interconnection Facilities interconnecting to the substation at the same voltage level, and then per capita to each Generating Facility sharing the Interconnection Facility.

(b) System Network Upgrades shall be allocated based on the proportional impact of each individual Generating Facility in the Cluster Study on the need for a specific System Network Upgrade. The proportional impact of such Network Upgrades shall be calculated as follows: All transmission lines and transformers identified as Network Upgrades shall be allocated using distribution factor or similar analysis. Voltage support related Network Upgrades shall be allocated using a voltage impact analysis which will identify each Generating Facility's contribution to the voltage violation. Network Upgrades associated with upgrading existing breakers due to short circuit current exceeding breaker capability shall be allocated proportionally based on the short circuit current contribution of each request.

(c) An Interconnection Customer that funds Substation Network Upgrades and/or System Network Upgrades shall be entitled to transmission credits as provided in Article 11.4 of the LGIA.

(2) The costs of any needed Interconnection Facilities identified in the Cluster Study Process will be directly assigned to Interconnection Customer(s) using such facilities. Where Interconnection Customers in the Cluster agree to share

Interconnection Facilities, the cost of such Interconnection Facilities shall be allocated based on the number of Generating Facilities sharing use of such Interconnection Facilities on a per capita basis (i.e., on a per Generating Facility basis), unless Parties mutually agree to a different cost sharing arrangement.

4.3 Transferability of Queue Position.

An Interconnection Customer may transfer its Queue Position to another entity only if such entity acquires the specific Generating Facility identified in the Interconnection Request and the Point of Interconnection does not change.

4.4 Modifications.

Interconnection Customer shall submit to Transmission Provider, in writing, modifications to any information provided in the Interconnection Request. Interconnection Customer shall retain its Queue Position if the modifications are in accordance with Sections 4.4.1, 4.4.2, or 4.4.5 of this LGIP, or are determined not to be Material Modifications pursuant to Section 4.4.3 of this LGIP.

Notwithstanding the above, during the course of the Interconnection Studies, either Interconnection Customer or Transmission Provider may identify changes to the planned interconnection that may improve the costs and benefits (including reliability) of the interconnection, and the ability of the proposed change to accommodate the Interconnection Request. To the extent the identified changes are acceptable to Transmission Provider and Interconnection Customer, such acceptance not to be unreasonably withheld, Transmission Provider shall modify the Point of Interconnection prior to return of the executed Cluster Study Agreement, and Interconnection Customer shall retain its Queue Position.

4.4.1 Prior to the return of the executed Cluster Study Agreement to Transmission Provider, modifications permitted under this Section shall include specifically: (a) a decrease of up to sixty percent (60%) of electrical output (MW) of the proposed project, through either (1) a decrease in plant size or (2) a decrease in Interconnection

Service level (consistent with the process described in Section 3.1 of this LGIP) accomplished by applying Transmission Provider-approved injection-limiting equipment; (b) modifying the technical parameters associated with the Large Generating Facility technology or the Large Generating Facility step-up transformer impedance characteristics; and (c) modifying the interconnection configuration. For plant increases, the incremental increase in plant output will go in the next Cluster Request Window for the purposes of cost allocation and study analysis.

4.4.2 Prior to the return of the executed Interconnection Facilities Study Agreement to Transmission Provider, the modifications permitted under this Section shall include specifically: (a) additional fifteen percent (15%) decrease of electrical output of the proposed project through either (1) a decrease in plant size (MW) or (2) a decrease in Interconnection Service level (consistent with the process described in Section 3.1) accomplished by applying Transmission Provider-approved injection-limiting equipment; (b) Large Generating Facility technical parameters associated with modifications to Large Generating Facility technology and transformer impedances; provided, however, the incremental costs associated with those modifications are the responsibility of the requesting Interconnection Customer; and (c) a Permissible Technological Advancement for the Large Generating Facility after the submission of the Interconnection Request. Section 4.4.6 of this LGIP specifies a separate technological change procedure including the requisite information and process that will be followed to assess whether Interconnection Customer's proposed technological advancement under Section 4.4.2(c) of this LGIP is a Material Modification. Section 1 of this LGIP contains a definition of Permissible Technological Advancement.

4.4.3 Prior to making any modification other than those specifically permitted by Sections 4.4.1, 4.4.2, and 4.4.5 of this LGIP, Interconnection Customer may first request that Transmission Provider evaluate whether such modification is a Material Modification. In response to Interconnection Customer's request, Transmission Provider shall evaluate the proposed modifications

prior to making them and inform Interconnection Customer in writing of whether the modifications would constitute a Material Modification. Any change to the Point of Interconnection, except those deemed acceptable under Sections 3.1.2 or 4.4 of this LGIP or so allowed elsewhere, shall constitute a Material Modification. Interconnection Customer may then withdraw the proposed modification or proceed with a new Interconnection Request for such modification. Transmission Provider shall study the addition of a Generating Facility that includes at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect the proposed charging behavior of the Generating Facility as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions.

4.4.3.1 Section Omitted.

- 4.4.4 Upon receipt of Interconnection Customer's request for modification permitted under this Section 4.4 of this LGIP, Transmission Provider shall commence and perform any necessary additional studies as soon as practicable, but in no event shall Transmission Provider commence such studies later than thirty (30) Calendar Days after receiving notice of Interconnection Customer's request. Any additional studies resulting from such modification shall be done at Interconnection Customer's cost. Any such request for modification of the Interconnection Request must be accompanied by any resulting updates to the models described in Attachment A to Appendix 1 of this LGIP.
- 4.4.5 Extensions of less than three (3) cumulative years in the Commercial Operation Date of the Large Generating Facility to which the Interconnection Request relates are not material and should be handled through construction sequencing. For purposes of this section, the Commercial Operation Date reflected in the initial Interconnection Request shall be used to calculate the permissible

extension prior to Interconnection Customer executing an LGIA or requesting that the LGIA be filed unexecuted. After an LGIA is executed or requested to be filed unexecuted, the Commercial Operation Date reflected in the LGIA shall be used to calculate the permissible extension. Such cumulative extensions may not exceed three years including both extensions requested after execution of the LGIA by Interconnection Customer or the filing of an unexecuted LGIA by Transmission Provider and those requested prior to execution of the LGIA by Interconnection Customer or the filing of an unexecuted LGIA by Transmission Provider.

4.4.6 Technological Change Procedure. In accordance with Section 4.4.2, at any time prior to the execution of the Interconnection Facilities Study Agreement the Interconnection Customer may submit a request if it seeks to incorporate technological advancements into its proposed Large Generating Facility. The technological advancement request should include an analysis and other supporting information to explain how it affects its original Interconnection Request, including a demonstration that (i) the technological advancement request will result in equal to or better than the electrical performance expected prior to the technology change, and (ii) would not cause any reliability standard criteria (including any applicable TPL or PRC standards), short circuit capability limits, steady-state thermal and voltage limits, or dynamic system stability and response impacts. If the Transmission Provider determines that additional studies are needed to evaluate whether a technological advancement is a material modification, a deposit in the amount of \$10,000 will be required to reimburse the Transmission Provider for the time and effort needed to complete the study. The Transmission Provider shall describe to the Interconnection Customer any costs incurred to conduct any necessary additional studies, provide its costs to the Interconnection Customer, and either refund any overage or charge for any shortage for costs that exceed the deposit amount. If it is determined that the technological advancement request does not change the specifications for the Large Generating Facility submitted by the Interconnection Customer to the Transmission Provider, the request shall be deemed a Permissible Technological Advancement and no further action shall be required. If the study results changes the submitted specifications, the request to change the Large Generating Facility's technology shall be deemed a Material Modification in

accordance with Section 4.4.3. The Transmission Provider will make a determination regarding the proposed technological advancement request and provide a written explanation within thirty (30) days of receiving the request.

Section 5. Procedures for Interconnection Requests Submitted Prior to Effective Date of the Cluster Study Revisions

5.1 Procedures for Transitioning to the Cluster Study Process.

5.1.1 Any Interconnection Customer assigned a Queue Position as of thirty (30) Calendar Days after May 16, 2024 (the filing date of this LGIP) shall retain that Queue Position subject to the requirements in Sections 5.1.1.1 and 5.1.1.2 of this LGIP. Any Interconnection Customer that fails to meet these requirements shall have its Interconnection Request deemed withdrawn by Transmission Provider pursuant to Section 3.7 of this LGIP. In such case, Transmission Provider shall not assess Interconnection Customer any Withdrawal Penalty.

Any Interconnection Customer that has received a final Interconnection Facilities Study Report before the commencement of the studies under the transition process set forth in this Section shall be tendered an LGIA pursuant to Section 11 of this LGIP, and shall not be required to enter this transition process.

5.1.1.1 Transitional Serial Study.

An Interconnection Customer that has been tendered an Interconnection Facilities Study Agreement as of thirty (30) Calendar Days after May 16, 2024 (the filing date of this LGIP) may opt to proceed with an Interconnection Facilities Study. Transmission Provider shall tender each eligible Interconnection Customer a Transitional Serial Interconnection Facilities Study Agreement, in the form of Appendix 8 to this LGIP, no later than the Commission-approved effective date of this LGIP. Transmission Provider

shall proceed with the Interconnection Facilities Study, provided that Interconnection Customer: (1) meets each of the following requirements; and (2) executes the Transitional Serial Interconnection Facilities Study Agreement within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP. If an eligible Interconnection Customer does not meet these requirements, its Interconnection Request shall be deemed withdrawn without penalty. Transmission Provider must commence the Transitional Serial Interconnection Facilities Study at the conclusion of this sixty (60) Calendar Day period. Transitional Serial Interconnection Facilities Study costs shall be allocated according to the method described in Section 13.3 of this LGIP.

All of the following must be included when an Interconnection Customer returns the Transitional Serial Interconnection Facilities Study Agreement:

(1) A deposit equal to one hundred percent (100%) of the costs identified for Transmission Provider's Interconnection Facilities and Network Upgrades in Interconnection Customer's system impact study report. If Interconnection Customer does not withdraw, the deposit shall be trued up to actual costs once they are known and applied to future construction costs described in Interconnection Customer's eventual LGIA. Any amounts in excess of the actual construction costs shall be returned to Interconnection Customer within thirty (30) Calendar Days of the issuance of a final invoice for construction costs, in accordance with Article 12.2 of the pro forma LGIA. If Interconnection Customer withdraws or otherwise does not reach Commercial Operation, Transmission Provider shall refund the remaining deposit after the final invoice for study costs and Transitional Withdrawal Penalty is settled. The deposit shall be in

the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider, where cash deposits shall be treated according to Section 3.7 of this LGIP.

(2) Exclusive Site Control for 100% of the proposed Generating Facility.

Transmission Provider shall conduct each Transitional Serial Interconnection Facilities Study and issue the associated Transitional Serial Interconnection Facilities Study Report within one hundred fifty (150) Calendar Days of the Commission-approved effective date of this LGIP.

After Transmission Provider issues each Transitional Interconnection Facilities Study Report, Interconnection Customer shall proceed pursuant to Section 11 of this LGIP. If Interconnection Customer withdraws its Interconnection Request or if Interconnection Customer's Generating Facility otherwise does not reach Commercial Operation, a Transitional Withdrawal Penalty shall be imposed on Interconnection Customer equal to nine (9) times Interconnection Customer's total study cost incurred since entering Transmission Provider's interconnection queue (including the cost of studies conducted under Section 5 of this LGIP).

5.1.1.2

Transitional Cluster Study.

An Interconnection Customer with an assigned Queue Position as of thirty (30) Calendar Days after May 16, 2024 (the filing date of this LGIP) may opt to proceed with a Transitional Cluster Study. Transmission Provider shall tender each eligible Interconnection

Customer a Transitional Cluster Study Agreement, in the form of Appendix 7 to this LGIP, no later than the Commission-approved effective date of this LGIP. Transmission Provider shall proceed with the Transitional Cluster Study that includes each Interconnection Customer that: (1) meets each of the following requirements listed as (1)–(3) in this section; and (2) executes the Transitional Cluster Study Agreement within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP. All Interconnection Requests that enter the Transitional Cluster Study shall be considered to have an equal Queue Position that is lower than Interconnection Customer(s) proceeding with Transitional Serial Interconnection Facilities Study. If an eligible Interconnection Customer does not meet these requirements, its Interconnection Request shall be deemed withdrawn without penalty. Transmission Provider must commence the Transitional Cluster Study at the conclusion of this sixty (60) Calendar Day period. All identified Transmission Provider's Interconnection Facilities and Network Upgrade costs shall be allocated according to Section 4.2.1 of this LGIP. Transitional Cluster Study costs shall be allocated according to the method described in Section 13.3 of this LGIP.

Interconnection Customer may make a one-time extension to its requested Commercial Operation Date upon entry into the Transitional Cluster Study, where any such extension shall not result in a Commercial Operation Date later than December 31, 2027.

All of the following must be included when an Interconnection Customer returns the Transitional Cluster Study Agreement:

(1) A selection of either Energy Resource Interconnection Service or Network Resource Interconnection Service.

(2) A deposit of five million dollars (\$5,000,000) in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider, where cash deposits will be treated according to Section 3.7 of this LGIP. If Interconnection Customer does not withdraw, the deposit shall be reconciled with and applied towards future construction costs described in the LGIA. Any amounts in excess of the actual construction costs shall be returned to Interconnection Customer within thirty (30) Calendar Days of the issuance of a final invoice for construction costs, in accordance with Article 12.2 of the pro forma LGIA. If Interconnection Customer withdraws or otherwise does not reach Commercial Operation, Transmission Provider must refund the remaining deposit once the final invoice for study costs and Transitional Withdrawal Penalty is settled.

(3) Exclusive Site Control for 100% of the proposed Generating Facility.

Transmission Provider shall conduct the Transitional Cluster Study and issue both an associated interim Transitional Cluster Study Report and an associated final Transitional Cluster Study Report. The interim Transitional Cluster Study Report shall provide the following information:

- identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;

- identification of any thermal overload or voltage limit violations resulting from the interconnection;

- identification of any instability or inadequately damped response to system disturbances resulting from the interconnection; and

- Transmission Provider's Interconnection Facilities and Network Upgrades that are expected to be required as a result of the Interconnection Request(s) and a non-binding, good faith estimate of cost responsibility and a non-binding, good faith estimated time to construct.

In addition to the information provided in the interim Transitional Cluster Study Report, the final Transitional Cluster Study Report shall provide a description of, estimated cost of, and schedule for construction of Transmission Provider's Interconnection Facilities and Network Upgrades required to interconnect the Generating Facility to the Transmission System that resolve issues identified in the interim Transitional Cluster Study Report.

The interim and final Transitional Cluster Study Reports shall be issued within three hundred (300) and three hundred sixty (360) Calendar Days of the Commission-approved effective date of this LGIP, respectively, and shall be posted on Transmission Provider's OASIS consistent with the posting of other study results pursuant to Section 3.5.1 of this LGIP. Interconnection Customer shall have thirty (30) Calendar Days to comment on the interim Transitional Cluster Study Report, once it has been received.

After Transmission Provider issues the final Transitional Cluster Study Report, Interconnection Customer shall proceed pursuant to Section 11 of this LGIP. If Interconnection Customer withdraws its Interconnection Request or if Interconnection Customer's Generating Facility otherwise does not reach Commercial Operation, a Transitional Withdrawal Penalty will be imposed on Interconnection Customer equal to nine (9) times Interconnection Customer's total study cost incurred since entering Transmission Provider's interconnection queue (including the cost of studies conducted under Section 5 of this LGIP).

5.1.2 Transmission Providers with Existing Cluster Study Processes or Currently in Transition

If Transmission Provider is not conducting a transition process under Section 5.1.1, it will continue processing Interconnection Requests under its current Cluster Study Process. Within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP, Interconnection Customers that have not executed an LGIA or requested an LGIA to be filed unexecuted must meet the requirements of Sections 3.4.2, 7.5, or 8.1 of this LGIP, based on Interconnection Customer's Queue Position.

Any Interconnection Customer that fails to meet these requirements within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP shall have its Interconnection Request deemed withdrawn by Transmission Provider pursuant to Section 3.7 of this LGIP. In such case, Transmission Provider shall not assess Interconnection Customer any Withdrawal Penalty.

5.2 New Transmission Provider.

If Transmission Provider transfers control of its Transmission System to a successor Transmission Provider during the period when an Interconnection Request is pending, the original Transmission Provider shall transfer to the successor Transmission Provider any amount of the deposit or payment with interest thereon that exceeds the cost that it incurred to evaluate the request for interconnection. Any difference between such net amount and

the deposit or payment required by this LGIP shall be paid by or refunded to Interconnection Customer, as appropriate. The original Transmission Provider shall coordinate with the successor Transmission Provider to complete any Interconnection Study, as appropriate, that the original Transmission Provider has begun but has not completed. If Transmission Provider has tendered a draft LGIA to Interconnection Customer but Interconnection Customer has not either executed the LGIA or requested the filing of an unexecuted LGIA with FERC, unless otherwise provided, Interconnection Customer must complete negotiations with the successor Transmission Provider.

Section 6. Interconnection Information Access

6.1 Publicly Posted Interconnection Information.

Transmission Provider shall maintain and make publicly available: (1) an interactive visual representation of the estimated incremental injection capacity (in megawatts) available at each point of interconnection in Transmission Provider's footprint under N-1 conditions, and (2) a table of metrics concerning the estimated impact of a potential Generating Facility on Transmission Provider's Transmission System based on a user-specified addition of a particular number of megawatts at a particular voltage level at a particular point of interconnection. At a minimum, for each transmission facility impacted by the user-specified megawatt addition, the following information will be provided in the table: (1) the distribution factor; (2) the megawatt impact (based on the megawatt values of the proposed Generating Facility and the distribution factor); (3) the percentage impact on each impacted transmission facility (based on the megawatt values of the proposed Generating Facility and the facility rating); (4) the percentage of power flow on each impacted transmission facility before the injection of the proposed project; (5) the percentage power flow on each impacted transmission facility after the injection of the proposed Generating Facility. These metrics must be calculated based on the power flow model of the Transmission System with the transfer simulated from each point of interconnection to the whole Transmission Provider's footprint (to approximate Network Resource Interconnection Service), and with the incremental capacity at each point of interconnection decremented by the existing and queued Generating Facilities (based on the existing or

requested interconnection service limit of the generation). These metrics must be updated within thirty (30) Calendar Days after the completion of each Cluster Study and Cluster Restudy. This information must be publicly posted, without a password or a fee. The website will define all underlying assumptions, including the name of the most recent Cluster Study or Restudy used in the Base Case.

Section 7. Cluster Study

7.1 Cluster Study Agreement.

No later than five (5) Business Days after the close of a Cluster Request Window, Transmission Provider shall tender to each Interconnection Customer that submitted a valid Interconnection Request a Cluster Study Agreement in the form of Appendix 2 to this LGIP. The Cluster Study Agreement shall require Interconnection Customer to compensate Transmission Provider for the actual cost of the Cluster Study pursuant to Section 13.3 of this LGIP. The specifications, assumptions, or other provisions in the appendices of the Cluster Study Agreement provided pursuant to Section 7.1 of this LGIP shall be subject to change by Transmission Provider following the conclusion of the Scoping Meeting.

7.2 Execution of Cluster Study Agreement.

Interconnection Customer shall execute the Cluster Study Agreement and deliver the executed Cluster Study Agreement to Transmission Provider no later than the close of the Customer Engagement Window.

If Interconnection Customer does not provide all required technical data when it delivers the Cluster Study Agreement, Transmission Provider shall notify Interconnection Customer of the deficiency within five (5) Business Days of the receipt of the executed Cluster Study Agreement and Interconnection Customer shall cure the deficiency within ten (10) Business Days of receipt of the notice, provided, however, such deficiency does not include failure to deliver the executed Cluster Study Agreement or study deposit.

7.3 Scope of Cluster Study.

The Cluster Study shall evaluate the impact of the proposed interconnection on the reliability of the Transmission System. The Cluster Study will consider the Base Case as well as all Generating Facilities (and with respect

to (iii) below, any identified Network Upgrades associated with such higher queued interconnection) that, on the date the Cluster Study is commenced: (i) are directly interconnected to the Transmission System; (ii) are interconnected to Affected Systems and may have an impact on the Interconnection Request; (iii) have a pending higher queued Interconnection Request to interconnect to the Transmission System; and (iv) have no Queue Position but have executed an LGIA or requested that an unexecuted LGIA be filed with FERC.

For purposes of determining necessary Interconnection Facilities and Network Upgrades, the Cluster Study shall use the level of Interconnection Service requested by Interconnection Customers in the Cluster, except where Transmission Provider otherwise determines that it must study the full Generating Facility Capacity due to safety or reliability concerns.

The Cluster Study will consist of power flow, stability, and short circuit analyses, the results of which are documented in a single Cluster Study Report, as applicable. At the conclusion of the Cluster Study, Transmission Provider shall issue a Cluster Study Report. The Cluster Study Report will state the assumptions upon which it is based; state the results of the analyses; and provide the requirements or potential impediments to providing the requested Interconnection Service, including a preliminary indication of the cost and length of time that would be necessary to correct any problems identified in those analyses and implement the interconnection. The Cluster Study Report shall identify the Interconnection Facilities and Network Upgrades expected to be required to reliably interconnect the Generating Facilities in that Cluster Study at the requested Interconnection Service level and shall provide non-binding cost estimates for required Network Upgrades. The Cluster Study Report shall identify each Interconnection Customer's estimated allocated costs for Interconnection Facilities and Network Upgrades pursuant to the method in Section 4.2.1 of this LGIP. Transmission Provider shall hold an open stakeholder meeting pursuant to Section 7.4 of this LGIP.

For purposes of determining necessary Interconnection Facilities and Network Upgrades, the Cluster Study shall use operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at

peak load) that reflect the proposed charging behavior of a Generating Facility that includes at least one electric storage resource as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions. Transmission Provider may require the inclusion of control technologies sufficient to limit the operation of the Generating Facility per the operating assumptions as set forth in the Interconnection Request and to respond to dispatch instructions by Transmission Provider. As determined by Transmission Provider, Interconnection Customer may be subject to testing and validation of those control technologies consistent with Article 6 of the LGIA.

The Cluster Study shall evaluate the use of static synchronous compensators, static VAR compensators, advanced power flow control devices, transmission switching, synchronous condensers, voltage source converters, advanced conductors, and tower lifting. Transmission Provider shall evaluate each identified alternative transmission technology and determine whether the above technologies should be used, consistent with Good Utility Practice, Applicable Reliability Standards, and Applicable Laws and Regulations. Transmission Provider shall include an explanation of the results of Transmission Provider's evaluation for each technology in the Cluster Study Report.

The Cluster Study Report will provide a list of facilities that are required as a result of the Interconnection Requests within the Cluster and a non-binding good faith estimate of cost responsibility and a non-binding good faith estimated time to construct.

7.4 Cluster Study Procedures.

Transmission Provider shall coordinate the Cluster Study with any Affected System Operator that is affected by the Interconnection Request pursuant to Section 3.6 of this LGIP. Transmission Provider shall utilize existing studies to the extent practicable when it performs the Cluster Study. Interconnection Requests for a Cluster Study may be submitted only within the Cluster Request Window and Transmission Provider shall initiate the Cluster Study Process pursuant to Section 7 of this LGIP.

Transmission Provider shall complete the Cluster Study within one hundred fifty (150) Calendar Days of the close of the Customer Engagement Window.

Within ten (10) Business Days of simultaneously furnishing a Cluster Study Report to each Interconnection Customer within the Cluster and posting such report on OASIS, Transmission Provider shall convene a Cluster Study Report Meeting.

At the request of Interconnection Customer or at any time Transmission Provider determines that it will not meet the required time frame for completing the Cluster Study, Transmission Provider shall notify Interconnection Customers as to the schedule status of the Cluster Study. If Transmission Provider is unable to complete the Cluster Study within the time period, it shall notify Interconnection Customers and provide an estimated completion date with an explanation of the reasons why additional time is required. Upon request, Transmission Provider shall provide Interconnection Customers all supporting documentation, workpapers and relevant pre-Interconnection Request and post-Interconnection Request power flow, short circuit and stability databases for the Cluster Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

7.5 Cluster Study Restudies.

(1) Within twenty (20) Calendar Days after the Cluster Study Report Meeting, Interconnection Customer must provide the following:

(a) Demonstration of continued Site Control pursuant to Section 3.4.2(iii) of this LGIP; and

(b) An additional deposit that brings the total Commercial Readiness Deposit submitted to Transmission Provider to five percent (5%) of Interconnection Customer's Network Upgrade cost assignment identified in the Cluster Study in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is

reasonably acceptable to Transmission Provider. Transmission Provider shall refund the deposit to Interconnection Customer upon withdrawal in accordance with Section 3.7 of this LGIP.

Interconnection Customer shall promptly inform Transmission Provider of any material change to Interconnection Customer's demonstration of Site Control under Section 3.4.2(iii) of this LGIP. Upon Transmission Provider determining that Interconnection Customer no longer satisfies the Site Control requirement, Transmission Provider shall notify Interconnection Customer. Within ten (10) Business Days of such notification, Interconnection Customer must demonstrate compliance with the applicable requirement subject to Transmission Provider's approval, not to be unreasonably withheld. Absent such demonstration, Transmission Provider shall deem the subject Interconnection Request withdrawn pursuant to Section 3.7 of this LGIP.

(2) If no Interconnection Customer withdraws from the Cluster after completion of the Cluster Study or Cluster Restudy or is deemed withdrawn pursuant to Section 3.7 of this LGIP after completion of the Cluster Study or Cluster Restudy, Transmission Provider shall notify Interconnection Customers in the Cluster that a Cluster Restudy is not required.

(3) If one or more Interconnection Customers withdraw from the Cluster or are deemed withdrawn pursuant to Section 3.7 of this LGIP, Transmission Provider shall determine if a Cluster Restudy is necessary within thirty (30) Calendar Days after the Cluster Study Report Meeting. If Transmission Provider determines a Cluster Restudy is not necessary, Transmission Provider shall notify Interconnection Customers in the Cluster that a Cluster Restudy is not required and Transmission Provider shall provide an updated Cluster Study Report within thirty (30) Calendar Days of such determination.

(4) If one or more Interconnection Customers withdraws from the Cluster or is deemed withdrawn pursuant to Section 3.7 of this LGIP, and Transmission Provider determines a Cluster Restudy is necessary as a result, Transmission Provider shall notify Interconnection Customers in the Cluster and post on OASIS that a Cluster Restudy is required within thirty

(30) Calendar Days after the Cluster Study Report Meeting. Transmission Provider shall continue with such restudies until Transmission Provider determines that no further restudies are required. If an Interconnection Customer withdraws or is deemed withdrawn pursuant to Section 3.7 of this LGIP during the Interconnection Facilities Study, or after other Interconnection Customers in the same Cluster have executed LGIAs, or requested that unexecuted LGIAs be filed, and Transmission Provider determines a Cluster Restudy is necessary, the Cluster shall be restudied. If a Cluster Restudy is required due to a higher queued project withdrawing from the queue, or a modification of a higher or equally queued project subject to Section 4.4 of this LGIP, Transmission Provider shall so notify affected Interconnection Customers in writing. Except as provided in Section 3.7 of this LGIP in the case of withdrawing Interconnection Customers, any cost of Restudy shall be borne by Interconnection Customers being restudied.

(5) The scope of any Cluster Restudy shall be consistent with the scope of an initial Cluster Study pursuant to Section 7.3 of this LGIP. Transmission Provider shall complete the Cluster Restudy within one hundred fifty (150) Calendar Days of Transmission Provider informing Interconnection Customers in the Cluster that restudy is needed. The results of the Cluster Restudy shall be combined into a single report (Cluster Restudy Report). Transmission Provider shall hold a meeting with Interconnection Customers in the Cluster (Cluster Restudy Report Meeting) within ten (10) Business Days of simultaneously furnishing the Cluster Restudy Report to each Interconnection Customer in the Cluster Restudy and publishing the Cluster Restudy Report on OASIS.

If additional restudies are required, Interconnection Customer and Transmission Provider shall follow the procedures of this Section 7.5 of this LGIP until such time that Transmission Provider determines that no further restudies are required. Transmission Provider shall notify each Interconnection Customer within the Cluster when no further restudies are required.

Section 8. Interconnection Facilities Study

8.1 Interconnection Facilities Study Agreement.

Within five (5) Business Days following Transmission Provider notifying each Interconnection Customer within the Cluster that no further Cluster Restudy is required (per Section 7.5 of this LGIP), Transmission Provider shall provide to Interconnection Customer an Interconnection Facilities Study Agreement in the form of Appendix 3 to this LGIP. Interconnection Customer shall compensate Transmission Provider for the actual cost of the Interconnection Facilities Study. Within five (5) Business Days following the Cluster Report Meeting or Cluster Restudy Report Meeting if applicable, Transmission Provider shall provide to Interconnection Customer a non-binding good faith estimate of the cost and timeframe for completing the Interconnection Facilities Study. Interconnection Customer shall execute the Interconnection Facilities Study Agreement and deliver the executed Interconnection Facilities Study Agreement to Transmission Provider within thirty (30) Calendar Days after its receipt, together with:

- (1) any required technical data;
- (2) Demonstration of one-hundred percent (100%) Site Control or demonstration of a regulatory limitation and applicable deposit in lieu of Site Control provided to Transmission Provider in accordance with Section 3.4.2 of this LGIP; and
- (3) An additional deposit that brings the total Commercial Readiness Deposit submitted to Transmission Provider to ten percent (10%) of Interconnection Customer's Network Upgrade cost assignment identified in the Cluster Study or Cluster Restudy, if applicable, in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider. Transmission Provider shall refund the deposit to Interconnection Customer upon withdrawal in accordance with Section 3.7 of this LGIP.

Interconnection Customer shall promptly inform Transmission Provider of any material change to Interconnection Customer's demonstration of Site Control under Section 3.4.2(iii) of this LGIP. Upon Transmission Provider

determining separately that Interconnection Customer no longer satisfies the Site Control requirement, Transmission Provider shall notify Interconnection Customer. Within ten (10) Business Days of such notification, Interconnection Customer must demonstrate compliance with the applicable requirement subject to Transmission Provider's approval, not to be unreasonably withheld. Absent such demonstration, Transmission Provider shall deem the subject Interconnection Request withdrawn pursuant to Section 3.7 of this LGIP.

8.2 Scope of Interconnection Facilities Study.

The Interconnection Facilities Study shall be specific to each Interconnection Request and performed on an individual, i.e., non-clustered, basis. The Interconnection Facilities Study shall specify and provide a non-binding estimate of the cost of the equipment, engineering, procurement and construction work needed to implement the conclusions of the Cluster Study Report (and any associated restudies) in accordance with Good Utility Practice to physically and electrically connect the Interconnection Facilities to the Transmission System. The Interconnection Facilities Study shall also identify the electrical switching configuration of the connection equipment, including, without limitation: the transformer, switchgear, meters, and other station equipment; the nature and estimated cost of any Transmission Provider's Interconnection Facilities and Network Upgrades necessary to accomplish the interconnection; and an estimate of the time required to complete the construction and installation of such facilities. The Interconnection Facilities Study will also identify any potential control equipment for (1) requests for Interconnection Service that are lower than the Generating Facility Capacity, and/or (2) requests to study a Generating Facility that includes at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect its proposed charging behavior, as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise require the use of different operating assumptions.

8.3 Interconnection Facilities Study Procedures.

Transmission Provider shall coordinate the Interconnection Facilities Study with any Affected System Operator pursuant to Section 3.6 of this LGIP.

Transmission Provider shall utilize existing studies to the extent practicable in performing the Interconnection Facilities Study. Transmission Provider shall complete the study and issue a draft Interconnection Facilities Study Report to Interconnection Customer within the following number of days after receipt of an executed Interconnection Facilities Study Agreement: ninety (90) Calendar Days after receipt of an executed Interconnection Facilities Study Agreement, with no more than a +/- twenty percent (20%) cost estimate contained in the report; or one hundred eighty (180) Calendar Days, if Interconnection Customer requests a +/- ten percent (10%) cost estimate.

At the request of Interconnection Customer or at any time Transmission Provider determines that it will not meet the required time frame for completing the Interconnection Facilities Study, Transmission Provider shall notify Interconnection Customer as to the schedule status of the Interconnection Facilities Study. If Transmission Provider is unable to complete the Interconnection Facilities Study and issue a draft Interconnection Facilities Study Report within the time required, it shall notify Interconnection Customer and provide an estimated completion date and an explanation of the reasons why additional time is required.

Interconnection Customer may, within thirty (30) Calendar Days after receipt of the draft Interconnection Facilities Study Report, provide written comments to Transmission Provider, which Transmission Provider shall include in completing the final Interconnection Facilities Study Report. Transmission Provider shall issue the final Interconnection Facilities Study Report within fifteen (15) Business Days of receiving Interconnection Customer's comments or promptly upon receiving Interconnection Customer's statement that it will not provide comments. Transmission Provider may reasonably extend such fifteen (15) Business Day period upon notice to Interconnection Customer if Interconnection Customer's comments require Transmission Provider to perform additional analyses or make other significant modifications prior to the issuance of the final Interconnection Facilities Study Report. Upon request, Transmission Provider shall provide Interconnection Customer supporting documentation, workpapers, and databases or data developed in the preparation of the Interconnection Facilities Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

8.4 Meeting with Transmission Provider.

Within ten (10) Business Days of providing a draft Interconnection Facilities Study Report to Interconnection Customer, Transmission Provider and Interconnection Customer shall meet to discuss the results of the Interconnection Facilities Study.

8.5 Restudy.

If restudy of the Interconnection Facilities Study is required due to a higher or equally queued project withdrawing from the queue or a modification of a higher or equally queued project pursuant to Section 4.4 of this LGIP, Transmission Provider shall so notify Interconnection Customer in writing. Transmission Provider shall ensure that such restudy takes no longer than sixty (60) Calendar Days from the date of notice. Except as provided in Section 3.7 of this LGIP in the case of withdrawing Interconnection Customers, any cost of restudy shall be borne by Interconnection Customer being restudied.

Section 9. Affected System Study.**9.1 Applicability.**

This Section 9 outlines the duties of Transmission Provider when it receives notification that an Affected System Interconnection Customer's proposed interconnection to its host transmission provider may impact Transmission Provider's Transmission System.

9.2 Response to Notifications.**9.2.1 Response to Initial Notification.**

When Transmission Provider receives initial notification either following the Cluster Study or a Cluster Restudy that an Affected System Interconnection Customer's proposed interconnection to its host transmission provider may impact Transmission Provider's Transmission System, Transmission Provider must respond in

writing within twenty (20) Business Days whether it intends to conduct an Affected System Study.

By fifteen (15) Business Days after Transmission Provider responds with its affirmative intent to conduct an Affected System Study, Transmission Provider shall share with Affected System Interconnection Customer(s) and the Affected System Interconnection Customer's host transmission provider a non-binding good faith estimate of the cost and the schedule to complete the Affected System Study.

9.2.2 Response to Notification of Cluster Restudy.

Within five (5) Business Days of receipt of notification of Cluster Restudy, Transmission Provider will send written notification to Affected System Interconnection Customer(s) involved in the Cluster Restudy and the host transmission provider that Transmission Provider intends to delay a planned or in-progress Affected System Study until after completion of the Cluster Restudy. If Transmission Provider decides to delay the Affected System Study, it is not required to meet its obligations under Section 9 of this LGIP until the time that it receives notification from the host transmission provider that the Cluster Restudy is complete. If Transmission Provider decides to move forward with its Affected System Study despite the Cluster Restudy, then it must meet all requirements under Section 9 of this LGIP.

9.3 Affected System Queue Position.

Transmission Provider must assign an Affected System Queue Position to Affected System Interconnection Customer(s) that require(s) an Affected System Study. Such Affected System Queue Position shall be assigned based upon the date of execution of the Affected System Study Agreement. Relative to Transmission Provider's Interconnection Customers, this Affected System Queue Position shall be higher-queued than any Cluster that has not yet received its Cluster Study Report and shall be lower-queued than any Cluster that has already received its Cluster Study Report. Consistent with Section 9.7 of this LGIP, Transmission Provider shall study the Affected System Interconnection Customer(s) via Clustering, and all Affected System Interconnection Customers studied in the same Cluster under Section 9.7 of this LGIP shall be equally queued. For Affected

System Interconnection Customers that are equally queued, the Affected System Queue Position shall have no bearing on the assignment of Affected System Network Upgrades identified in the applicable Affected System Study. The costs of the Affected System Network Upgrades shall be allocated among the Affected System Interconnection Customers in accordance with Section 9.9 of this LGIP.

9.4 Affected System Study Agreement/Multiparty Affected System Study Agreement.

Unless otherwise agreed, Transmission Provider shall provide to Affected System Interconnection Customer(s) an Affected System Study Agreement/Multiparty Affected System Study Agreement, in the form of Appendix 9 or Appendix 10 to this LGIP, as applicable, within ten (10) Business Days of Transmission Provider sharing the schedule for the Affected System Study per Section 9.2.1 of this LGIP.

Upon Affected System Interconnection Customer(s)' receipt of the Affected System Study Report, Affected System Interconnection Customer(s) shall compensate Transmission Provider for the actual cost of the Affected System Study. Any difference between the study deposit and the actual cost of the Affected System Study shall be paid by or refunded to the Affected System Interconnection Customer(s). Any invoices for the Affected System Study shall include a detailed and itemized accounting of the cost of the study. Affected System Interconnection Customer(s) shall pay any excess costs beyond the already-paid Affected System Study deposit or be reimbursed for any costs collected over the actual cost of the Affected System Study within thirty (30) Calendar Days of receipt of an invoice thereof. If Affected System Interconnection Customer(s) fail to pay such undisputed costs within the time allotted, it shall lose its Affected System Queue Position. Transmission Provider shall notify Affected System Interconnection Customer's host transmission provider of such failure to pay.

9.5 Execution of Affected System Study Agreement/Multiparty Affected System Study Agreement.

Affected System Interconnection Customer(s) shall execute the Affected System Study Agreement/Multiparty Affected System Study Agreement,

deliver the executed Affected System Study Agreement/Multiparty Affected System Study Agreement to Transmission Provider, and provide the Affected System Study deposit within ten (10) Business Days of receipt. If Transmission Provider notifies Affected System Interconnection Customer(s) that it will delay the Affected System Study pursuant to Section 9.2.2 of this LGIP, Affected System Interconnection Customer(s) are neither required to execute and return the previously tendered Affected System Study/Multiparty Affected System Study Agreement nor provide the Affected System Study deposit for the previously tendered Affected System Study/Multiparty Affected System Study Agreement.

If Affected System Interconnection Customer does not provide all required technical data when it delivers the Affected System Study Agreement/Multiparty Affected System Study Agreement, Transmission Provider shall notify the deficient Affected System Interconnection Customer, as well as the host transmission provider with which Affected System Interconnection Customer seeks to interconnect, of the technical data deficiency within five (5) Business Days of the receipt of the executed Affected System Study Agreement/Multiparty Affected System Study Agreement and the deficient Affected System Interconnection Customer shall cure the technical deficiency within ten (10) Business Days of receipt of the notice: provided, however, that such deficiency does not include failure to deliver the executed Affected System Study Agreement/Multiparty Affected System Study Agreement or deposit for the Affected System Study Agreement/Multiparty Affected System Study Agreement. If Affected System Interconnection Customer does not cure the technical data deficiency within the cure period or fails to execute the Affected System Study Agreement/Multiparty Affected System Study Agreement or provide the deposit, the Affected System Interconnection Customer shall lose its Affected System Queue Position.

9.6 Scope of Affected System Study.

The Affected System Study shall evaluate the impact that any Affected System Interconnection Customer's proposed interconnection to another transmission provider's transmission system will have on the reliability of Transmission Provider's Transmission System. The Affected System Study shall consider the Base Case as well as all Generating Facilities (and with respect to (iii) below, any identified Affected System Network

Upgrades associated with such higher-queued Interconnection Request) that, on the date the Affected System Study is commenced: (i) are directly interconnected to Transmission Provider's Transmission System; (ii) are directly interconnected to another transmission provider's transmission system and may have an impact on Affected System Interconnection Customer's interconnection request; (iii) have a pending higher-queued Interconnection Request to interconnect to Transmission Provider's Transmission System; and (iv) have no queue position but have executed an LGIA or requested that an unexecuted LGIA be filed with FERC. Transmission Provider has no obligation to study impacts of Affected System Interconnection Customers of which it is not notified.

The Affected System Study shall consist of a power flow, stability, and short circuit analysis. The Affected System Study Report will: state the assumptions upon which it is based; state the results of the analyses; and provide the potential impediments to Affected System Interconnection Customer's receipt of interconnection service on its host transmission provider's transmission system, including a preliminary indication of the cost and length of time that would be necessary to correct any problems identified in those analyses and implement the interconnection. For purposes of determining necessary Affected System Network Upgrades, the Affected System Study shall consider the level of interconnection service requested in megawatts by Affected System Interconnection Customer, unless otherwise required to study the full generating facility capacity due to safety or reliability concerns. The Affected System Study Report shall provide a list of facilities that are required as a result of Affected System Interconnection Customer's proposed interconnection to another transmission provider's system, a non-binding good faith estimate of cost responsibility, and a non-binding good faith estimated time to construct. The Affected System Study may consist of a system impact study, a facilities study, or some combination thereof.

9.7 Affected System Study Procedures.

Transmission Provider shall use Clustering in conducting the Affected System Study and shall use existing studies to the extent practicable, when multiple Affected System Interconnection Customers that are part of a single Cluster may cause the need for Affected System Network Upgrades. Transmission Provider shall complete the Affected System Study and

provide the Affected System Study Report to Affected System Interconnection Customer(s) and the host transmission provider with whom interconnection has been requested within one hundred fifty (150) Calendar Days after the receipt of the Affected System Study Agreement and deposit.

At the request of Affected System Interconnection Customer, Transmission Provider shall notify Affected System Interconnection Customer as to the status of the Affected System Study. If Transmission Provider is unable to complete the Affected System Study within the requisite time period, it shall notify Affected System Interconnection Customer(s), as well as transmission provider with which Affected System Interconnection Customer seeks to interconnect, and shall provide an estimated completion date with an explanation of the reasons why additional time is required. If Transmission Provider does not meet the deadlines in this Section, Transmission Provider shall be subject to the financial penalties as described in Section 3.9 of this LGIP. Upon request, Transmission Provider shall provide Affected System Interconnection Customer(s) with all supporting documentation, workpapers and relevant power flow, short circuit and stability databases for the Affected System Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

Transmission Provider must study an Affected System Interconnection Customer using the Energy Resource Interconnection Service modeling standard used for Interconnection Requests on its own Transmission System, regardless of the level of interconnection service that Affected System Interconnection Customer is seeking from the host transmission provider with whom it seeks to interconnect.

9.8 Meeting with Transmission Provider.

Within ten (10) Business Days of providing the Affected System Study Report to Affected System Interconnection Customer(s), Transmission Provider and Affected System Interconnection Customer(s) shall meet to discuss the results of the Affected System Study.

9.9 Affected System Cost Allocation.

Transmission Provider shall allocate Affected System Network Upgrade costs identified during the Affected System Study to Affected System Interconnection Customer(s) using a proportional impact method, consistent with Section 4.2.1(1)(b) of this LGIP.

9.10 Tender of Affected Systems Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement.

Transmission Provider shall tender to Affected System Interconnection Customer(s) an Affected System Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement, as applicable, in the form of Appendix 11 or 12 to this LGIP, within thirty (30) Calendar Days of providing the Affected System Study Report. Within ten (10) Business Days of the receipt of the Affected System Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement, the Affected System Interconnection Customer(s) must execute the agreement or request the agreement to be filed unexecuted with FERC. Transmission Provider shall execute the agreement or file the agreement unexecuted within five (5) Business Days after receiving direction from Affected System Interconnection Customer(s). Affected System Interconnection Customer's failure to execute the Affected System Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement, or failure to request the agreement to be filed unexecuted with FERC, shall result in the loss of its Affected System Queue Position.

9.11 Restudy.

If restudy of the Affected System Study is required, Transmission Provider shall notify Affected System Interconnection Customer(s) in writing within thirty (30) Calendar Days of discovery of the need for restudy. Such restudy shall take no longer than sixty (60) Calendar Days from the date of notice. Any cost of restudy shall be borne by the Affected System Interconnection Customer(s) being restudied.

Section 10. Optional Interconnection Study

10.1 Optional Interconnection Study Agreement.

On or after the date when Interconnection Customer receives Cluster Study results, Interconnection Customer may request, and Transmission Provider shall perform a reasonable number of Optional Interconnection Studies. The request shall describe the assumptions that Interconnection Customer wishes Transmission Provider to study within the scope described in Section 10.2 of this LGIP. Within five (5) Business Days after receipt of a request for an Optional Interconnection Study, Transmission Provider shall provide to Interconnection Customer an Optional Interconnection Study Agreement in the form of Appendix 4.

The Optional Interconnection Study Agreement shall: (i) specify the technical data that Interconnection Customer must provide for each phase of the Optional Interconnection Study, (ii) specify Interconnection Customer's assumptions as to which Interconnection Requests with earlier queue priority dates will be excluded from the Optional Interconnection Study case and assumptions as to the type of Interconnection Service for Interconnection Requests remaining in the Optional Interconnection Study case, and (iii) Transmission Provider's estimate of the cost of the Optional Interconnection Study. To the extent known by Transmission Provider, such estimate shall include any costs expected to be incurred by any Affected System Operator whose participation is necessary to complete the Optional Interconnection Study. Notwithstanding the above, Transmission Provider shall not be required as a result of an Optional Interconnection Study request to conduct any additional Interconnection Studies with respect to any other Interconnection Request.

Interconnection Customer shall execute the Optional Interconnection Study Agreement within ten (10) Business Days of receipt and deliver the Optional Interconnection Study Agreement, the technical data and a \$10,000 deposit to Transmission Provider.

10.2 Scope of Optional Interconnection Study.

The Optional Interconnection Study will consist of a sensitivity analysis based on the assumptions specified by Interconnection Customer in the Optional Interconnection Study Agreement. The Optional Interconnection Study will also identify Transmission Provider's Interconnection Facilities and the Network Upgrades, and the estimated cost thereof, that may be

required to provide transmission service or Interconnection Service based upon the results of the Optional Interconnection Study. The Optional Interconnection Study shall be performed solely for informational purposes. Transmission Provider shall use Reasonable Efforts to coordinate the study with any Affected Systems that may be affected by the types of Interconnection Services that are being studied. Transmission Provider shall utilize existing studies to the extent practicable in conducting the Optional Interconnection Study.

10.3 Optional Interconnection Study Procedures.

The executed Optional Interconnection Study Agreement, the prepayment, and technical and other data called for therein must be provided to Transmission Provider within ten (10) Business Days of Interconnection Customer receipt of the Optional Interconnection Study Agreement. Transmission Provider shall use Reasonable Efforts to complete the Optional Interconnection Study within a mutually agreed upon time period specified within the Optional Interconnection Study Agreement. If Transmission Provider is unable to complete the Optional Interconnection Study within such time period, it shall notify Interconnection Customer and provide an estimated completion date and an explanation of the reasons why additional time is required. Any difference between the study payment and the actual cost of the study shall be paid to Transmission Provider or refunded to Interconnection Customer, as appropriate. Upon request, Transmission Provider shall provide Interconnection Customer supporting documentation and workpapers and databases or data developed in the preparation of the Optional Interconnection Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

Section 11. Standard Large Generator Interconnection Agreement (LGIA)

11.1 Tender.

Interconnection Customer shall tender comments on the draft Interconnection Facilities Study Report within thirty (30) Calendar Days of receipt of the report. Within thirty (30) Calendar Days after the comments are submitted or after Interconnection Customer notifies Transmission Provider that it will not provide comments, Transmission Provider shall tender a draft LGIA, together with draft appendices. The draft LGIA shall

be in the form of Transmission Provider's FERC-approved standard form LGIA, which is in Appendix 5. Interconnection Customer shall execute and return the LGIA and completed draft appendices within thirty (30) Calendar Days, unless (1) the sixty (60) Calendar Day negotiation period under Section 11.2 of this LGIP has commenced, or (2) LGIA execution, or filing unexecuted, has been delayed to await the Affected System Study Report pursuant to Section 11.2.1 of this LGIP.

11.2 Negotiation.

Notwithstanding Section 11.1 of this LGIP, at the request of Interconnection Customer, Transmission Provider shall begin negotiations with Interconnection Customer concerning the appendices to the LGIA at any time after Interconnection Customer executes the Interconnection Facilities Study Agreement. Transmission Provider and Interconnection Customer shall negotiate concerning any disputed provisions of the appendices to the draft LGIA for not more than sixty (60) Calendar Days after tender of the final Interconnection Facilities Study Report. If Interconnection Customer determines that negotiations are at an impasse, it may request termination of the negotiations at any time after tender of the draft LGIA pursuant to Section 11.1 of this LGIP and request submission of the unexecuted LGIA with FERC or initiate Dispute Resolution procedures pursuant to Section 13.5 of this LGIP. If Interconnection Customer requests termination of the negotiations, but within sixty (60) Calendar Days thereafter fails to request either the filing of the unexecuted LGIA or initiate Dispute Resolution, it shall be deemed to have withdrawn its Interconnection Request. Unless otherwise agreed by the Parties, if Interconnection Customer has not executed the LGIA, requested filing of an unexecuted LGIA, or initiated Dispute Resolution procedures pursuant to Section 13.5 of this LGIP within sixty (60) Calendar Days of tender of draft LGIA, it shall be deemed to have withdrawn its Interconnection Request. Transmission Provider shall provide to Interconnection Customer a final LGIA within fifteen (15) Business Days after the completion of the negotiation process.

11.2.1 Delay in LGIA Execution, or Filing Unexecuted, to Await Affected System Study Report.

If Interconnection Customer has not received its Affected System Study Report from the Affected System Operator prior to the date

that it would be required to execute its LGIA (or request that its LGIA be filed unexecuted) pursuant to Section 11.1 of this LGIP, Transmission Provider shall, upon request of Interconnection Customer, extend this deadline to thirty (30) Calendar Days after Interconnection Customer's receipt of the Affected System Study Report. If Interconnection Customer, after delaying LGIA execution, or requesting unexecuted filing, to await Affected System Study Report, decides to proceed to LGIA execution, or request unexecuted filing, without those results, it may notify Transmission Provider of its intent to proceed with LGIA execution (or request that its LGIA be filed unexecuted) pursuant to Section 11.1 of this LGIP. If Transmission Provider determines that further delay to the LGIA execution date would cause a material impact on the cost or timing of an equal- or lower-queued Interconnection Customer, Transmission Provider must notify Interconnection Customer of such impacts and set the deadline to execute the LGIA (or request that the LGIA be filed unexecuted) to thirty (30) Calendar Days after such notice is provided.

11.3 Execution and Filing.

Simultaneously with submitting the executed LGIA to Transmission Provider, or within ten (10) Business Days after Interconnection Customer requests that Transmission Provider file the LGIA unexecuted at the Commission, Interconnection Customer shall provide Transmission Provider with the following: (1) demonstration of continued Site Control pursuant to Section 8.1(2) of this LGIP; and (2) the LGIA Deposit equal to twenty percent (20%) of Interconnection Customer's estimated Network Upgrade costs identified in the draft LGIA minus the total amount of Commercial Readiness Deposits that Interconnection Customer has provided to Transmission Provider for its Interconnection Request. Transmission Provider shall use LGIA Deposit as (or as a portion of) Interconnection Customer's security required under LGIA Article 11.5. Interconnection Customer may not request to suspend its LGIA under LGIA Article 5.16 until Interconnection Customer has provided (1) and (2) to Transmission Provider. If Interconnection Customer fails to provide (1) and (2) to Transmission Provider within the thirty (30) Calendar Days allowed for returning the executed LGIA and appendices under LGIP Section 11.1, or within ten (10) Business Days after Interconnection Customer requests that Transmission Provider file the LGIA unexecuted at

the Commission as allowed in this Section 11.3 of this LGIP, the Interconnection Request will be deemed withdrawn pursuant to Section 3.7 of this LGIP.

At the same time, Interconnection Customer also shall provide reasonable evidence that one or more of the following milestones in the development of the Large Generating Facility, at Interconnection Customer election, has been achieved (unless such milestone is inapplicable due to the characteristics of the Generating Facility): (i) the execution of a contract for the supply or transportation of fuel to the Large Generating Facility; (ii) the execution of a contract for the supply of cooling water to the Large Generating Facility; (iii) execution of a contract for the engineering for, procurement of major equipment for, or construction of, the Large Generating Facility; (iv) execution of a contract (or comparable evidence) for the sale of electric energy or capacity from the Large Generating Facility; or (v) application for an air, water, or land use permit.

Interconnection Customer shall either: (i) execute two originals of the tendered LGIA and return them to Transmission Provider; or (ii) request in writing that Transmission Provider file with FERC an LGIA in unexecuted form. As soon as practicable, but not later than ten (10) Business Days after receiving either the two executed originals of the tendered LGIA (if it does not conform with a FERC-approved Standard Large Generator Interconnection Agreement) or the request to file an unexecuted LGIA, Transmission Provider shall file the LGIA with FERC, together with its explanation of any matters as to which Interconnection Customer and Transmission Provider disagree and support for the costs that Transmission Provider proposes to charge to Interconnection Customer under the LGIA. An unexecuted LGIA should contain terms and conditions deemed appropriate by Transmission Provider for the Interconnection Request. If the Parties agree to proceed with design, procurement, and construction of facilities and upgrades under the agreed-upon terms of the unexecuted LGIA, they may proceed pending FERC action.

11.4 Commencement of Interconnection Activities.

If Interconnection Customer executes the final LGIA, Transmission Provider and Interconnection Customer shall perform their respective

obligations in accordance with the terms of the LGIA, subject to modification by FERC. Upon submission of an unexecuted LGIA, Interconnection Customer and Transmission Provider shall promptly comply with the unexecuted LGIA, subject to modification by FERC.

Section 12. Construction of Transmission Provider's Interconnection Facilities and Network Upgrades

12.1 Schedule.

Transmission Provider and Interconnection Customer shall negotiate in good faith concerning a schedule for the construction of Transmission Provider's Interconnection Facilities and the Network Upgrades.

12.2 Construction Sequencing.

12.2.1 General.

In general, the In-Service Date of an Interconnection Customer seeking interconnection to the Transmission System will determine the sequence of construction of Network Upgrades.

12.2.2 Advance Construction of Network Upgrades that are an Obligation of an Entity other than Interconnection Customer.

An Interconnection Customer with an LGIA, in order to maintain its In-Service Date, may request that Transmission Provider advance to the extent necessary the completion of Network Upgrades that: (i) were assumed in the Interconnection Studies for such Interconnection Customer, (ii) are necessary to support such In-Service Date, and (iii) would otherwise not be completed, pursuant to a contractual obligation of an entity other than Interconnection Customer that is seeking interconnection to the Transmission System, in time to support such In-Service Date. Upon such request, Transmission Provider will use Reasonable Efforts to advance the construction of such Network Upgrades to accommodate

such request; provided that Interconnection Customer commits to pay Transmission Provider: (i) any associated expediting costs and (ii) the cost of such Network Upgrades.

Transmission Provider will refund to Interconnection Customer both the expediting costs and the cost of Network Upgrades, in accordance with Article 11.4 of the LGIA. Consequently, the entity with a contractual obligation to construct such Network Upgrades shall be obligated to pay only that portion of the costs of the Network Upgrades that Transmission Provider has not refunded to Interconnection Customer. Payment by that entity shall be due on the date that it would have been due had there been no request for advance construction. Transmission Provider shall forward to Interconnection Customer the amount paid by the entity with a contractual obligation to construct the Network Upgrades as payment in full for the outstanding balance owed to Interconnection Customer. Transmission Provider then shall refund to that entity the amount that it paid for the Network Upgrades, in accordance with Article 11.4 of the LGIA.

12.2.3

Advancing Construction of Network Upgrades that are Part of an Expansion Plan of Transmission Provider.

An Interconnection Customer with an LGIA, in order to maintain its In-Service Date, may request that Transmission Provider advance to the extent necessary the completion of Network Upgrades that: (i) are necessary to support such In-Service Date and (ii) would otherwise not be completed, pursuant to an expansion plan of Transmission Provider, in time to support such In-Service Date. Upon such request, Transmission Provider will use Reasonable Efforts to advance the construction of such Network Upgrades to accommodate such request; provided that Interconnection Customer commits to pay Transmission Provider any associated expediting costs. Interconnection Customer shall be entitled to transmission credits, if any, for any expediting costs paid.

12.2.4 Amended Interconnection Cluster Study Report.

An Interconnection Cluster Study Report will be amended to determine the facilities necessary to support the requested In-Service Date. This amended study report will include those transmission and Large Generating Facilities that are expected to be in service on or before the requested In-Service Date.

Section 13. Miscellaneous**13.1 Confidentiality.**

Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied by either of the Parties to the other prior to the execution of an LGIA.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential.

If requested by either Party, the other Party shall provide in writing, the basis for asserting that the information referred to in this Article warrants confidential treatment, and the requesting Party may disclose such writing to the appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

13.1.1 Scope.

Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the

receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a third party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of the LGIA; or (6) is required, in accordance with Section 13.1.6 of this LGIP, Order of Disclosure, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under the

LGIA. Information designated as Confidential Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the other Party that it no longer is confidential.

13.1.2

Release of Confidential Information.

Neither Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), employees, consultants, or to parties who may be or considering providing financing to or equity participation with Interconnection Customer, or to potential purchasers or assignees of Interconnection Customer, on a need-to-know basis in connection with these procedures, unless such person has first been advised of the confidentiality provisions of this Section 13.1 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Section 13.1.

13.1.3 Rights.

Each Party retains all rights, title, and interest in the Confidential Information that each Party discloses to the other Party. The disclosure by each Party to the other Party of Confidential Information shall not be deemed a waiver by either Party or any other person or entity of the right to protect the Confidential Information from public disclosure.

13.1.4 No Warranties.

By providing Confidential Information, neither Party makes any warranties or representations as to its accuracy or completeness. In addition, by supplying Confidential Information, neither Party obligates itself to provide any particular information or Confidential Information to the other Party nor to enter into any further agreements or proceed with any other relationship or joint venture.

13.1.5 Standard of Care.

Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under these procedures or its regulatory requirements.

13.1.6 Order of Disclosure.

If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires either Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the other Party with prompt notice of such request(s) or requirement(s) so that the other Party may seek an appropriate protective order or waive compliance with the terms of the LGIA. Notwithstanding the absence of a protective order or waiver, the Party may disclose such

Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance that confidential treatment will be accorded any Confidential Information so furnished.

13.1.7

Remedies.

The Parties agree that monetary damages would be inadequate to compensate a Party for the other Party's Breach of its obligations under this Section 13.1. Each Party accordingly agrees that the other Party shall be entitled to equitable relief, by way of injunction or otherwise, if the first Party Breaches or threatens to Breach its obligations under this Section 13.1, which equitable relief shall be granted without bond or proof of damages, and the receiving Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Section 13.1, but shall be in addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. No Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Section 13.1.

13.1.8

Disclosure to FERC, its Staff, or a State.

Notwithstanding anything in this Section 13.1 to the contrary, and pursuant to 18 CFR section 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to the LGIP, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information. In providing the information to FERC or its staff, the Party must, consistent with 18 CFR section 388.112, request that the information be treated as confidential and non-public by FERC and its staff and that the information be

withheld from public disclosure. Parties are prohibited from notifying the other Party prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Party to the LGIA when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR section 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner, consistent with applicable state rules and regulations.

- 13.1.9 Subject to the exception in Section 13.1.8 of this LGIP, any information that a Party claims is competitively sensitive, commercial or financial information (“Confidential Information”) shall not be disclosed by the other Party to any person not employed or retained by the other Party, except to the extent disclosure is (i) required by law; (ii) reasonably deemed by the disclosing Party to be required to be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (iii) otherwise permitted by consent of the other Party, such consent not to be unreasonably withheld; or (iv) necessary to fulfill its obligations under this LGIP or as a transmission service provider or a Balancing Authority Area operator including disclosing the Confidential Information to an RTO or ISO or to a subregional, regional or national reliability organization or planning group. The Party asserting confidentiality shall notify the other Party in writing of the information it claims is confidential. Prior to any disclosures of the other Party’s Confidential Information under this subparagraph, or if any third party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the disclosing Party agrees to promptly notify the other Party in writing and agrees to assert confidentiality and cooperate with the other Party in seeking to protect the Confidential Information from public disclosure by confidentiality agreement, protective order or other reasonable measures.

13.1.10 This provision shall not apply to any information that was or is hereafter in the public domain (except as a result of a Breach of this provision).

13.1.11 Transmission Provider shall, at Interconnection Customer's election, destroy, in a confidential manner, or return the Confidential Information provided at the time of Confidential Information is no longer needed.

13.2 Delegation of Responsibility.

Transmission Provider may use the services of subcontractors as it deems appropriate to perform its obligations under this LGIP. Transmission Provider shall remain primarily liable to Interconnection Customer for the performance of such subcontractors and compliance with its obligations of this LGIP. The subcontractor shall keep all information provided confidential and shall use such information solely for the performance of such obligation for which it was provided and no other purpose.

13.3 Obligation for Study Costs.

In the event an Interconnection Customer withdraws its Interconnection Request prior to the commencement of the Cluster Study, Interconnection Customer must pay Transmission Provider the actual costs of processing its Interconnection Request. In the event an Interconnection Customer withdraws after the commencement of the Cluster Study, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Interconnection Studies. The costs of any interconnection study conducted on a clustered basis shall be allocated among each Interconnection Customer within the cluster as follows:

Transmission Provider shall determine each Interconnection Customer's share of the costs of the Cluster Study by allocating: (1) fifty percent (50%) of the applicable study costs to Interconnection Customers on a per capita basis based on number of Interconnection Requests included in the applicable Cluster; and (2) fifty percent (50%) of the applicable study costs

to Interconnection Customers on a pro-rata basis based on requested megawatts included in the applicable Cluster. The Interconnection Facilities Study portion of the Definitive Interconnection Study Process is an individual study and costs for each Interconnection Facilities Study are directly assigned to the Interconnection Customer associated with such study.

Any difference between the study deposit and the actual cost of the Interconnection Studies shall be paid by or refunded to, except as otherwise provided herein, to Interconnection Customers. Any invoices for Interconnection Studies shall include a detailed and itemized accounting of the cost of each Interconnection Study. Interconnection Customers shall pay any such undisputed costs within thirty (30) Calendar Days of receipt of an invoice therefor. If Interconnection Customer fails to pay such undisputed costs within the time allotted, its Interconnection Request shall be deemed withdrawn from the Cluster Study Process and will be subject to Withdrawal Penalties pursuant to Section 3.7 of this LGIP.

13.4 Third Parties Conducting Studies.

If (i) at the time of the signing of an Interconnection Study Agreement there is disagreement as to the estimated time to complete an Interconnection Study, (ii) Interconnection Customer receives notice pursuant to Sections 6.3, 7.4 or 8.3 of this LGIP that Transmission Provider will not complete an Interconnection Study within the applicable timeframe for such Interconnection Study, or (iii) Interconnection Customer receives neither the Interconnection Study nor a notice under Sections 6.3, 7.4 or 8.3 of this LGIP within the applicable timeframe for such Interconnection Study, then Interconnection Customer may require Transmission Provider to utilize a third party consultant reasonably acceptable to Interconnection Customer and Transmission Provider to perform such Interconnection Study under the direction of Transmission Provider. At other times, Transmission Provider may also utilize a third party consultant to perform such Interconnection Study, either in response to a general request of Interconnection Customer, or on its own volition.

In all cases, use of a third party consultant shall be in accord with Article 26 of the LGIA (Subcontractors) and limited to situations where Transmission

Provider determines that doing so will help maintain or accelerate the study process for Interconnection Customer's pending Interconnection Request and not interfere with Transmission Provider's progress on Interconnection Studies for other pending Interconnection Requests. In cases where Interconnection Customer requests use of a third party consultant to perform such Interconnection Study, Interconnection Customer and Transmission Provider shall negotiate all of the pertinent terms and conditions, including reimbursement arrangements and the estimated study completion date and study review deadline. Transmission Provider shall convey all workpapers, data bases, study results and all other supporting documentation prepared to date with respect to the Interconnection Request as soon as soon as practicable upon Interconnection Customer's request subject to the confidentiality provision in Section 13.1 of this LGIP. In any case, such third party contract may be entered into with either Interconnection Customer or Transmission Provider at Transmission Provider's discretion. In the case of (iii) Interconnection Customer maintains its right to submit a claim to Dispute Resolution to recover the costs of such third party study. Such third party consultant shall be required to comply with this LGIP, Article 26 of the LGIA (Subcontractors), and the relevant Tariff procedures and protocols as would apply if Transmission Provider were to conduct the Interconnection Study and shall use the information provided to

it solely for purposes of performing such services and for no other purposes. Transmission Provider shall cooperate with such third party consultant and Interconnection Customer to complete and issue the Interconnection Study in the shortest reasonable time.

13.5 Disputes.

13.5.1 Submission.

In the event either Party has a dispute, or asserts a claim, that arises out of or in connection with the LGIA, the LGIP, or their performance, such Party (the "disputing Party") shall provide the other Party with written notice of the dispute or claim ("Notice of Dispute"). Such dispute or claim shall be referred to a designated senior representative of each Party for resolution on an informal basis as promptly as practicable after receipt of the Notice of Dispute by the other Party. In

the event the designated representatives are unable to resolve the claim or dispute through unassisted or assisted negotiations within thirty (30) Calendar Days of the other Party's receipt of the Notice of Dispute, such claim or dispute may, upon mutual agreement of the Parties, be submitted to arbitration and resolved in accordance with the arbitration procedures set forth below. In the event the Parties do not agree to submit such claim or dispute to arbitration, each Party may exercise whatever rights and remedies it may have in equity or at law consistent with the terms of this LGIA.

13.5.2 External Arbitration Procedures.

Any arbitration initiated under these procedures shall be conducted before a single neutral arbitrator appointed by the Parties. If the Parties fail to agree upon a single arbitrator within ten (10) Calendar Days of the submission of the dispute to arbitration, each Party shall choose one arbitrator who shall sit on a three-member arbitration panel. The two arbitrators so chosen shall within twenty (20) Calendar Days select a third arbitrator to chair the arbitration panel. In either case, the arbitrators shall be knowledgeable in electric utility matters, including electric transmission and bulk power issues, and shall not have any current or past substantial business or financial relationships with any party to the arbitration (except prior arbitration). The arbitrator(s) shall provide each of the Parties an opportunity to be heard and, except as otherwise provided herein, shall conduct the arbitration in accordance with the Commercial Arbitration Rules of the American Arbitration Association ("Arbitration Rules") and any applicable FERC regulations or RTO rules; provided, however, in the event of a conflict between the Arbitration Rules and the terms of this Section 13, the terms of this Section 13 shall prevail.

13.5.3 Arbitration Decisions.

Unless otherwise agreed by the Parties, the arbitrator(s) shall render a decision within ninety (90) Calendar Days of appointment and shall notify the Parties in writing of such

decision and the reasons therefor. The arbitrator(s) shall be authorized only to interpret and apply the provisions of the LGIA and LGIP and shall have no power to modify or change any provision of the LGIA and LGIP in any manner. The decision of the arbitrator(s) shall be final and binding upon the Parties, and judgment on the award may be entered in any court having jurisdiction. The decision of the arbitrator(s) may be appealed solely on the grounds that the conduct of the arbitrator(s), or the decision itself, violated the standards set forth in the Federal Arbitration Act or the Administrative Dispute Resolution Act. The final decision of the arbitrator must also be filed with FERC if it affects jurisdictional rates, terms and conditions of service, Interconnection Facilities, or Network Upgrades.

13.5.4

Costs.

Each Party shall be responsible for its own costs incurred during the arbitration process and for the following costs, if applicable: (1) the cost of the arbitrator chosen by the Party to sit on the three member panel and one half of the cost of the third arbitrator chosen; or (2) one half the cost of the single arbitrator jointly chosen by the Parties.

13.5.5

Non-binding dispute resolution procedures.

If a Party has submitted a Notice of Dispute pursuant to Section 13.5.1 of this LGIP, and the Parties are unable to resolve the claim or dispute through unassisted or assisted negotiations within the thirty (30) Calendar Days provided in that section, and the Parties cannot reach mutual agreement to pursue the Section 13.5 arbitration process, a Party may request that Transmission Provider engage in Non-binding Dispute Resolution pursuant to this Section by providing written notice to Transmission Provider (“Request for Non-binding Dispute Resolution”). Conversely, either Party may file a Request for Non-binding Dispute Resolution pursuant to this Section without first seeking mutual agreement to pursue the Section 13.5 arbitration process. The process in this Section 13.5.5 shall serve as an alternative to, and not a

replacement of, the Section 13.5 arbitration process. Pursuant to this process, a Transmission Provider must within thirty (30) Calendar Days of receipt of the Request for Non-binding Dispute Resolution appoint a neutral decision-maker that is an independent subcontractor that shall not have any current or past substantial business or financial relationships with either Party. Unless otherwise agreed by the Parties, the decision-maker shall render a decision within sixty (60) Calendar Days of appointment and shall notify the Parties in writing of such decision and reasons therefore. This decision-maker shall be authorized only to interpret and apply the provisions of the LGIP and LGIA and shall have no power to modify or change any provision of the LGIP and LGIA in any manner. The result reached in this process is not binding, but, unless otherwise agreed, the Parties may cite the record and decision in the non-binding dispute resolution process in future dispute resolution processes, including in a Section 13.5 arbitration, or in a Federal Power Act section 206 complaint. Each Party shall be responsible for its own costs incurred during the process and the cost of the decision-maker shall be divided equally among each Party to the dispute.

13.6 Local Furnishing Bonds.

13.6.1 Transmission Providers That Own Facilities Financed by Local Furnishing Bonds.

This provision is applicable only to a Transmission Provider that has financed facilities for the local furnishing of electric energy with tax-exempt bonds, as described in Section 142(f) of the Internal Revenue Code (“local furnishing bonds”). Notwithstanding any other provision of this LGIA and LGIP, Transmission Provider shall not be required to provide Interconnection Service to Interconnection Customer pursuant to this LGIA and LGIP if the provision of such Transmission Service would jeopardize the tax-exempt status of any local furnishing bond(s) used to finance Transmission Provider’s facilities that would be used in providing such Interconnection Service.

13.6.2 Alternative Procedures for Requesting Interconnection Service.

If Transmission Provider determines that the provision of Interconnection Service requested by Interconnection Customer would jeopardize the tax-exempt status of any local furnishing bond(s) used to finance its facilities that would be used in providing such Interconnection Service, it shall advise Interconnection Customer within thirty (30) Calendar Days of receipt of the Interconnection Request.

Interconnection Customer thereafter may renew its request for interconnection using the process specified in Section 5.2(ii) of Transmission Provider's Tariff.

13.7 Engineering & Procurement ('E&P') Agreement.

Prior to executing an LGIA, an Interconnection Customer may, in order to advance the implementation of its interconnection, request and Transmission Provider shall offer Interconnection Customer, an E&P Agreement that authorizes Transmission Provider to begin engineering and procurement of long lead-time items necessary for the establishment of the interconnection. However, Transmission Provider shall not be obligated to offer an E&P Agreement if Interconnection Customer is in Dispute Resolution as a result of an allegation that Interconnection Customer has failed to meet any milestones or comply with any prerequisites specified in other parts of the LGIP. The E&P Agreement is an optional procedure and it will not alter Interconnection Customer's Queue Position or In-Service Date. The E&P Agreement shall provide for Interconnection Customer to pay the cost of all activities authorized by Interconnection Customer and to make advance payments or provide other satisfactory security for such costs.

Interconnection Customer shall pay the cost of such authorized activities and any cancellation costs for equipment that is already ordered for its interconnection, which cannot be mitigated as hereafter described, whether or not such items or equipment later become unnecessary. If

Interconnection Customer withdraws its Interconnection Request or either Party terminates the E&P Agreement, to the extent the equipment ordered can be canceled under reasonable terms, Interconnection Customer shall be obligated to pay the associated cancellation costs. To the extent that the equipment cannot be reasonably canceled, Transmission Provider may elect: (i) to take title to the equipment, in which event Transmission Provider shall refund Interconnection Customer any amounts paid by Interconnection Customer for such equipment and shall pay the cost of delivery of such equipment, or (ii) to transfer title to and deliver such equipment to Interconnection Customer, in which event Interconnection Customer shall pay any unpaid balance and cost of delivery of such equipment.

APPENDIX 1 to LGIP
INTERCONNECTION REQUEST FOR A
LARGE GENERATING FACILITY

1. The undersigned Interconnection Customer submits this request to interconnect its Large Generating Facility with Transmission Provider's Transmission System pursuant to a Tariff.

2. This Interconnection Request is for (check one):
 A proposed new Large Generating Facility.
 An increase in the generating capacity or a Material Modification of an existing Generating Facility.

3. The type of interconnection service requested (check one):
 Energy Resource Interconnection Service
 Network Resource Interconnection Service

4. Check here only if Interconnection Customer requesting Network Resource Interconnection Service also seeks to have its Generating Facility studied for Energy Resource Interconnection Service

5. Interconnection Customer provides the following information:
 - a. Address or location of the proposed new Large Generating Facility site (to the extent known) or, in the case of an existing Generating Facility, the name and specific location of the existing Generating Facility;

- b. Maximum summer at _____ degrees C and winter at _____ degrees C megawatt electrical output of the proposed new Large Generating Facility or the amount of megawatt increase in the generating capacity of an existing Generating Facility;
 - c. General description of the equipment configuration;
 - d. Commercial Operation Date (Day, Month, and Year);
 - e. Name, address, telephone number, and e-mail address of Interconnection Customer's contact person;
 - f. Approximate location of the proposed Point of Interconnection (optional);
 - g. Interconnection Customer Data (set forth in Attachment A);
 - h. Primary frequency response operating range for electric storage resources;
 - i. Requested capacity (in MW) of Interconnection Service (if lower than the Generating Facility Capacity);
 - j. If applicable, (1) the requested operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) to be used by Transmission Provider that reflect the proposed charging behavior of a Generating Facility that includes at least one electric storage resource, and (2) a description of any control technologies (software and/or hardware) that will limit the operation of the Generating Facility to its intended operation.
6. Applicable deposit amount as specified in the LGIP.

7. Evidence of Site Control as specified in the LGIP (check one)

_____ Is attached to this Interconnection Request

_____ Will be provided at a later date in accordance with this LGIP

8. This Interconnection Request shall be submitted to the representative indicated below:

{To be completed by Transmission Provider}

9. Representative of Interconnection Customer to contact:

{To be completed by Interconnection Customer}

10. This Interconnection Request is submitted by:

Name of Interconnection Customer: _____

By (signature): _____

Name (type or print): _____

Title: _____

Date: _____

Attachment A to Appendix 1
Interconnection Request

LARGE GENERATING FACILITY DATA

UNIT RATINGS

kVA _____ °F _____ Voltage _____
 Power Factor _____
 Speed (RPM) _____ Connection (e.g. Wye) _____
 Short Circuit Ratio _____ Frequency, Hertz _____
 Stator Amperes at Rated kVA _____ Field Volts _____
 Max Turbine MW _____ °F _____

Primary frequency response operating range for electric storage
resources:

Minimum State of Charge: _____

Maximum State of Charge: _____

COMBINED TURBINE-GENERATOR-EXCITER INERTIA DATA

Inertia Constant, H = _____ kW sec/kVA

Moment-of-Inertia, WR^2 = _____ lb. ft.²

REACTANCE DATA (PER UNIT-RATED KVA)

	DIRECT AXIS	QUADRATURE AXIS
Synchronous – saturated	X_{dv} _____	X_{qv} _____
Synchronous – unsaturated	X_{di} _____	X_{qi} _____
Transient – saturated	X'_{dv} _____	X'_{qv} _____
Transient – unsaturated	X'_{di} _____	X'_{qi} _____
Subtransient – saturated	X''_{dv} _____	X''_{qv} _____
Subtransient – unsaturated	X''_{di} _____	X''_{qi} _____
Negative Sequence – saturated	X_{2v} _____	
Negative Sequence – unsaturated	X_{2i} _____	
Zero Sequence – saturated	X_{0v} _____	
Zero Sequence – unsaturated	X_{0i} _____	
Leakage Reactance	X_{lm} _____	

FIELD TIME CONSTANT DATA (SEC)

Open Circuit	T'_{do}	_____	T'_{qo}	_____
Three-Phase Short Circuit Transient	T'_{d3}	_____	T'_q	_____
Line to Line Short Circuit Transient	T'_{d2}	_____		
Line to Neutral Short Circuit Transient	T'_{d1}	_____		
Short Circuit Subtransient	T''_d	_____	T''_q	_____
Open Circuit Subtransient	T''_{do}	_____	T''_{qo}	_____

ARMATURE TIME CONSTANT DATA (SEC)

Three Phase Short Circuit	T_{a3}	_____
Line to Line Short Circuit	T_{a2}	_____
Line to Neutral Short Circuit	T_{a1}	_____

NOTE: If requested information is not applicable, indicate by marking "N/A."

**MW CAPABILITY AND PLANT CONFIGURATION
LARGE GENERATING FACILITY DATA**

ARMATURE WINDING RESISTANCE DATA (PER UNIT)

Positive R_1 _____

Negative R_2 _____

Zero R_0 _____

Rotor Short Time Thermal Capacity $I_2^2t =$ _____

Field Current at Rated kVA, Armature Voltage and PF = _____ amps

Field Current at Rated kVA and Armature Voltage, 0 PF = _____ amps

Three Phase Armature Winding Capacitance = _____ microfarad

Field Winding Resistance = _____ ohms _____ °C

Armature Winding Resistance (Per Phase) = _____ ohms _____ °C

CURVES

Provide Saturation, Vee, Reactive Capability, Capacity Temperature Correction curves.
Designate normal and emergency Hydrogen Pressure operating range for multiple curves.

GENERATOR STEP-UP TRANSFORMER DATA RATINGS

Capacity Self-cooled/
Maximum Nameplate
_____ / _____ kVA

Voltage Ratio(Generator Side/System side/Tertiary)
_____ / _____ / _____ kV

Winding Connections (Low V/High V/Tertiary V (Delta or Wye))
_____ / _____ / _____

Fixed Taps Available _____

Present Tap Setting _____

IMPEDANCE

Positive Z_1 (on self-cooled kVA rating) _____ % _____ X/R

Zero Z_0 (on self-cooled kVA rating) _____ % _____ X/R

EXCITATION SYSTEM DATA

Identify appropriate IEEE model block diagram of excitation system and power system stabilizer (PSS) for computer representation in power system stability simulations and the corresponding excitation system and PSS constants for use in the model.

GOVERNOR SYSTEM DATA

Identify appropriate IEEE model block diagram of governor system for computer representation in power system stability simulations and the corresponding governor system constants for use in the model.

WIND GENERATORS

Number of generators to be interconnected pursuant to this Interconnection Request:

Elevation: _____ _____ Single Phase _____ Three Phase

Inverter manufacturer, model name, number, and version:

List of adjustable setpoints for the protective equipment or software:

Note: A completed General Electric Company Power Systems Load Flow (PSLF) data sheet or other compatible formats, such as IEEE and PTI power flow models, must be supplied with the Interconnection Request. If other data sheets are more appropriate to the proposed device, then they shall be provided and discussed at Scoping Meeting.

INDUCTION GENERATORS

- (*) Field Volts: _____
- (*) Field Amperes: _____
- (*) Motoring Power (kW): _____
- (*) Neutral Grounding Resistor (If Applicable): _____
- (*) I_2^2t or K (Heating Time Constant): _____
- (*) Rotor Resistance: _____
- (*) Stator Resistance: _____
- (*) Stator Reactance: _____
- (*) Rotor Reactance: _____
- (*) Magnetizing Reactance: _____
- (*) Short Circuit Reactance: _____
- (*) Exciting Current: _____
- (*) Temperature Rise: _____
- (*) Frame Size: _____
- (*) Design Letter: _____
- (*) Reactive Power Required In Vars (No Load): _____
- (*) Reactive Power Required In Vars (Full Load): _____
- (*) Total Rotating Inertia, H: _____ Per Unit on KVA Base

Note: Please consult Transmission Provider prior to submitting the Interconnection Request to determine if the information designated by (*) is required.

MODELS FOR NON-SYNCHRONOUS GENERATORS

For a non-synchronous Large Generating Facility, Interconnection Customer shall provide (1) a validated user-defined root mean squared (RMS) positive sequence dynamics model; (2) an appropriately parameterized generic library RMS positive sequence dynamics model, including model block diagram of the inverter control and plant control systems, as defined by the selection in Table 1 or a model otherwise approved by the Western Electricity Coordinating Council, that corresponds to Interconnection Customer's Large Generating Facility; and (3) if applicable, a validated electromagnetic transient model if Transmission Provider performs an electromagnetic transient study as part of the interconnection study process. A user-defined model is a set of programming code created by equipment manufacturers or developers that captures the latest features of controllers that are mainly software based and represents the entities' control strategies but does not necessarily correspond to any generic library model. Interconnection Customer must also demonstrate that the model is validated by providing evidence that the equipment behavior is consistent with the model behavior (e.g., an attestation from Interconnection Customer that the model accurately represents the entire Large Generating Facility; attestations from each equipment manufacturer that the user defined model accurately represents the component of the Large Generating Facility; or test data).

Table 1: Acceptable Generic Library RMS Positive Sequence Dynamics Models

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
pvd1		PVD1	Distributed PV system model
der_a	DERAU1	DER_A	Distributed energy resource model
regc_a	REGCAU1, REGCA1	REGC_A	Generator/converter model
regc_b	REGCBU1	REGC_B	Generator/converter model

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
wt1g	WT1G1	WT1G and WT1G1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)
wt2g	WT2G1	WT2G and WT2G1	Generator model for generic Type-2 wind turbines
wt2e	WT2E1	WT2E and WT2E1	Rotor resistance control model for wound-rotor induction wind-turbine generator wt2g
reec_a	REECAU1, REECA1	REEC_A	Renewable energy electrical control model
reec_c	REECCU1	REEC_C	Electrical control model for battery energy storage system
reec_d	REECDU1	REEC_D	Renewable energy electrical control model
wt1t	WT12T1	WT1T and WT12T1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)
wt1p_b	wt1p_b	WT12A1U_B	Generic wind turbine pitch controller for WTGs of Types 1 and 2
wt2t	WT12T1	WT2T	Wind turbine model for Type-2 wind turbines (directly connected induction generator wind turbines with an external rotor resistance)
wtgt_a	WTDTAU1, WTDTA1	WTGT_A	Wind turbine drive train model
wtga_a	WTARAU1, WTARA1	WTGA_A	Simple aerodynamic model
wtgp_a	WTPTAU1, WTPTA1	WTGPT_A	Wind Turbine Generator Pitch controller
wtgq_a	WTTQAU1, WTTQA1	WTGTRQ_A	Wind Turbine Generator Torque controller

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
wtgwo_a	WTGWGOAU	WTGWGO_A	Supplementary control model for Weak Grids
wtgibffr_a	WTGIBFFRA	WTGIBFFR_A	Inertial-base fast frequency response control
wtgp_b	WTPTBU1	WTGPT_B	Wind Turbine Generator Pitch controller
wtgt_b	WTDTBU1	WTGT_B	Drive train model
repc_a	Type 4: REPCAU1 (v33), REPCA1 (v34) Type 3: REPCTAU1 (v33), REPCTA1 (v34)	REPC_A	Power Plant Controller

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
repc_b	PLNTBU1	REPC_B	<p>Power Plant Level Controller for controlling several plants/devices</p> <p>In regard to Siemens PSS/E*: Names of other models for interface with other devices: REA3XBU1, REAX4BU1- for interface with Type 3 and 4 renewable machines SWSAXBU1- for interface with SVC (modeled as switched shunt in powerflow) SYNTAXBU1- for interface with synchronous condenser FCTAXBUI- for interface with FACTS device</p>
repc_c	REPCCU	REPC_C	Power plant controller

APPENDIX 2 to LGIP
CLUSTER STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ___ day of _____, 20___ by and between _____, a _____ organized and existing under the laws of the State of _____, (“Interconnection Customer,”) and _____ a _____ organized and existing under the laws of the State of _____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party, ” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a Cluster Study to assess the impact of interconnecting the Large Generating Facility to the Transmission System, and of any Affected Systems; and

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be performed a Cluster Study consistent with Section 7.0 of this LGIP in accordance with the Tariff.
- 3.0 The scope of the Cluster Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Cluster Study will be based upon the technical information provided by Interconnection Customer in the Interconnection Request, subject to any modifications in accordance with Section 4.4 of this LGIP. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the Cluster Study.
- 5.0 The Cluster Study Report shall provide the following information:
 - identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection and

- description and non-binding, good faith estimated cost of facilities required to interconnect the Large Generating Facility to the Transmission System and to address the identified short circuit, instability, and power flow issues.

6.0 Transmission Provider's good faith estimate for the time of completion of the Cluster Study is {insert date}.

Upon receipt of the Cluster Study Report, Transmission Provider shall charge and Interconnection Customer shall pay its share of the actual costs of the Cluster Study, consistent with Section 13.3 of this LGIP.

Any difference between the deposit and the actual cost of the study shall be paid by or refunded to Interconnection Customer, as appropriate.

7.0 Miscellaneous. The Cluster Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP and the LGIA.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

Attachment A To Appendix 2
Cluster Study Agreement

ASSUMPTIONS USED IN CONDUCTING THE
CLUSTER STUDY

The Cluster Study will be based upon the technical information provided by Interconnection Customer in the Interconnection Request, subject to any modifications in accordance with Section 4.4 of this LGIP, and the following assumptions:

Designation of Point of Interconnection and configuration to be studied.

Designation of alternative Point(s) of Interconnection and configuration.

{Above assumptions to be completed by Interconnection Customer and other assumptions to be provided by Interconnection Customer and Transmission Provider}

APPENDIX 3 to LGIP
INTERCONNECTION FACILITIES STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ___ day of _____, 20___ by and between _____, a _____ organized and existing under the laws of the State of _____, (“Interconnection Customer,”) and _____ a _____ organized and existing under the laws of the State of _____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party,,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Transmission Provider has completed a Cluster Study (the “Cluster Study”) and provided the results of said study to Interconnection Customer; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform an Interconnection Facilities Study to specify and estimate the cost of the equipment, engineering, procurement and construction work needed to implement the

conclusions of the Cluster Study in accordance with Good Utility Practice to physically and electrically connect the Large Generating Facility to the Transmission System.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in Transmission Provider's FERC-approved LGIP.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause an Interconnection Facilities Study consistent with Section 8.0 of this LGIP to be performed in accordance with the Tariff.
- 3.0 The scope of the Interconnection Facilities Study shall be subject to the assumptions set forth in Attachment A and the data provided in Attachment B to this Agreement.
- 4.0 The Interconnection Facilities Study Report (i) shall provide a description, estimated cost of (consistent with Attachment A), schedule for required facilities to interconnect the Large Generating Facility to the Transmission System and (ii) shall address the short circuit, instability, and power flow issues identified in the Cluster Study.
- 5.0 Interconnection Customer shall provide a Commercial Readiness Deposit per Section 8.1 of this LGIP to enter the Interconnection Facilities Study. The time for completion of the Interconnection Facilities Study is specified in Attachment A.

6.0 Miscellaneous. The Interconnection Facilities Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP and the LGIA.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

Attachment A To Appendix 3
Interconnection Facilities
Study Agreement

**INTERCONNECTION CUSTOMER SCHEDULE ELECTION FOR
CONDUCTING THE INTERCONNECTION FACILITIES STUDY**

Transmission Provider shall complete the study and issue a draft Interconnection Facilities Study Report to Interconnection Customer within the following number of days after receipt of an executed copy of this Interconnection Facilities Study Agreement:

- ninety (90) Calendar Days with no more than a +/- 20 percent cost estimate contained in the report, or

- one hundred eighty (180) Calendar Days with no more than a +/- 10 percent cost estimate contained in the report.

Attachment B to Appendix 3
Interconnection Facilities
Study Agreement

DATA FORM TO BE PROVIDED BY INTERCONNECTION CUSTOMER
WITH THE
INTERCONNECTION FACILITIES STUDY AGREEMENT

Provide location plan and simplified one-line diagram of the plant and station facilities. For staged projects, please indicate future generation, transmission circuits, etc.

One set of metering is required for each generation connection to the new ring bus or existing Transmission Provider station. Number of generation connections:

On the one-line diagram indicate the generation capacity attached at each metering location. (Maximum load on CT/PT)

On the one-line diagram indicate the location of auxiliary power. (Minimum load on CT/PT) Amps

Will an alternate source of auxiliary power be available during CT/PT maintenance?

Yes No

Will a transfer bus on the generation side of the metering require that each meter set be designed for the total plant generation? ____Yes ____No (Please indicate on one line diagram).

What type of control system or PLC will be located at Interconnection Customer's Large Generating Facility?

What protocol does the control system or PLC use?

Please provide a 7.5-minute quadrangle of the site. Sketch the plant, station, transmission line, and property line.

Physical dimensions of the proposed interconnection station:

Bus length from generation to interconnection station:

Line length from interconnection station to Transmission Provider's transmission line.

Tower number observed in the field. (Painted on tower leg)* _____

Number of third party easements required for transmission lines*:

* To be completed in coordination with Transmission Provider.

Is the Large Generating Facility in Transmission Provider's service area?

Yes No Local provider: _____

Please provide proposed schedule dates:

Begin Construction Date: _____

Generator step-up transformer Date: _____
receives back feed power

Generation Testing Date: _____

Commercial Operation Date: _____

APPENDIX 4 to LGIP
OPTIONAL INTERCONNECTION STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ___ day of _____, 20___ by and between _____, a _____ organized and existing under the laws of the State of _____, (“Interconnection Customer,”) and _____ a _____ organized and existing under the laws of the State of _____ - _____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer is proposing to establish an interconnection with the Transmission System; and

WHEREAS, Interconnection Customer has submitted to Transmission Provider an Interconnection Request; and

WHEREAS, on or after the date when Interconnection Customer receives the Cluster Study results, Interconnection Customer has further requested that Transmission Provider prepare an Optional Interconnection Study;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in Transmission Provider's FERC-approved LGIP.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause an Optional Interconnection Study consistent with Section 10.0 of this LGIP to be performed in accordance with the Tariff.
- 3.0 The scope of the Optional Interconnection Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Optional Interconnection Study shall be performed solely for informational purposes.
- 5.0 The Optional Interconnection Study report shall provide a sensitivity analysis based on the assumptions specified by Interconnection Customer in Attachment A to this Agreement. The Optional Interconnection Study will identify Transmission Provider's Interconnection Facilities and the Network Upgrades, and the estimated cost thereof, that may be required to provide transmission service or interconnection service based upon the assumptions specified by Interconnection Customer in Attachment A.
- 6.0 Interconnection Customer shall provide a deposit of \$10,000 for the performance of the Optional Interconnection Study. Transmission Provider's good faith estimate for the time of completion of the Optional Interconnection Study is {insert date}.

Upon receipt of the Optional Interconnection Study, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Optional Study.

Any difference between the initial payment and the actual cost of the study shall be paid by or refunded to Interconnection Customer, as appropriate.

7.0 Miscellaneous. The Optional Interconnection Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP and the LGIA.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____

Title: _____

Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

APPENDIX 5 to LGIP
LARGE GENERATOR INTERCONNECTION AGREEMENT
(SEE LGIA)

APPENDIX 6 to LGIP
INTERCONNECTION PROCEDURES FOR A WIND GENERATING PLANT

Appendix 6 sets forth procedures specific to a wind generating plant. All other requirements of this LGIP continue to apply to wind generating plant interconnections.

A. Special Procedures Applicable to Wind Generators

The wind plant Interconnection Customer, in completing the Interconnection Request required by Section 3.3 of this LGIP, may provide to Transmission Provider a set of preliminary electrical design specifications depicting the wind plant as a single equivalent generator. Upon satisfying these and other applicable Interconnection Request conditions, the wind plant may enter the queue and receive the base case data as provided for in this LGIP.

No later than six months after submitting an Interconnection Request completed in this manner, the wind plant Interconnection Customer must submit completed detailed electrical design specifications and other data (including collector system layout data) needed to allow Transmission Provider to complete the Cluster Study.

**APPENDIX 7 to LGIP
TRANSITIONAL CLUSTER STUDY AGREEMENT**

THIS AGREEMENT is made and entered into this ____ day of _____, 20__ by and between _____, a _____ organized and existing under the laws of the State of _____ (“Interconnection Customer”), and _____, a _____ organized and existing under the laws of the State of _____ (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____;

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a “Transitional Cluster Study,” which combines the Cluster Study and Interconnection Facilities Study, in a single cluster study, followed by any needed restudies, to specify and estimate the cost of the equipment, engineering, procurement, and construction work needed to physically and electrically connect the Large Generating Facility to Transmission Provider’s Transmission System; and

WHEREAS, Interconnection Customer has a valid Queue Position as of the {Transmission Provider to insert Commission-approved effective date of compliance filing}.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Interconnection Customer elects, and Transmission Provider shall cause to be performed, a Transitional Cluster Study.
- 3.0 The Transitional Cluster Study shall be based upon the technical information provided by Interconnection Customer in the Interconnection Request. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the Transitional Cluster Study and Interconnection Customer shall provide such data as quickly as reasonable.
- 4.0 Pursuant to Section 5.1.1.2 of this LGIP, the interim Transitional Cluster Study Report shall provide the information below:
 - identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection; and

- Transmission Provider's Interconnection Facilities and Network Upgrades that are expected to be required as a result of the Interconnection Request(s) and a non-binding, good faith estimate of cost responsibility and a non-binding, good faith estimated time to construct.
- 5.0 Pursuant to Section 5.1.1.2 of this LGIP, the final Transitional Cluster Study Report shall: (1) provide all the information included in the interim Transitional Cluster Study Report; (2) provide a description of, estimated cost of, and schedule for required facilities to interconnect the Generating Facility to the Transmission System; and (3) address the short circuit, instability, and power flow issues identified in the interim Transitional Cluster Study Report.
- 6.0 Interconnection Customer has met the requirements described in Section 5.1.1.2 of this LGIP.
- 7.0 Interconnection Customer previously provided a deposit for the performance of Interconnection Studies. Upon receipt of the final Transitional Cluster Study Report, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Transitional Cluster Study. Any difference between the study deposit and the actual cost of the study shall be paid by or refunded to Interconnection Customer, in accordance with the provisions of Section 13.3 of this LGIP.
- 8.0 Miscellaneous. The Transitional Cluster Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP and the LGIA.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____

Title: _____

Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

APPENDIX 8 to LGIP
TRANSITIONAL SERIAL INTERCONNECTION FACILITIES STUDY
AGREEMENT

THIS AGREEMENT is made and entered into this ____ day of ___, 20___, by and between _____, a _____ organized and existing under the laws of the State of _____ (“Interconnection Customer”) and _____, a _____ organized and existing under the laws of the State of _____ (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Large Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to continue processing its Interconnection Facilities Study to specify and estimate the cost of the equipment, engineering, procurement, and construction work needed to implement the conclusions of the final interconnection system impact study (from the previously effective serial study process) in accordance with Good Utility Practice to physically and electrically connect the Large Generating Facility to the Transmission System; and

WHEREAS, Transmission Provider has provided an Interconnection Facilities Study Agreement to Interconnection Customer on or before {Transmission Provider to insert Commission-approved effective date of compliance filing}.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be performed an Interconnection Facilities Study consistent with Section 8 of this LGIP.
- 3.0 The scope of the Interconnection Facilities Study shall be subject to the assumptions set forth in Attachment A to this Agreement, which shall be the same assumptions as the previous Interconnection Facilities Study Agreement executed by Interconnection Customer.
- 4.0 The Interconnection Facilities Study Report shall: (1) provide a description, estimated cost of (consistent with Attachment A), and schedule for required facilities to interconnect the Large Generating Facility to the Transmission System; and (2) address the short circuit, instability, and power flow issues identified in the most recently published Cluster Study Report.
- 5.0 Interconnection Customer has met the requirements described in Section 5.1.1.1 of this LGIP. The time for completion of the Interconnection Facilities Study is specified in Attachment A, and shall be no later than one hundred fifty (150) Calendar Days after {Transmission Provider to insert Commission-approved effective date of compliance filing}.
- 6.0 Interconnection Customer previously provided a deposit of _____ dollars (\$____) for the performance of the Interconnection Facilities Study.

- 7.0 Upon receipt of the Interconnection Facilities Study results, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Interconnection Facilities Study.

- 8.0 Any difference between the study deposit and the actual cost of the study shall be paid by or refunded to Interconnection Customer, as appropriate.

- 9.0 Miscellaneous. The Interconnection Facilities Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP and this LGIA.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____

Title:

Date: _____

{Insert name of Interconnection Customer}

By:

Title:

Date:

**Attachment A to Appendix 8
Transitional Serial Interconnection Facilities Study Agreement**

**ASSUMPTIONS USED IN CONDUCTING THE TRANSITIONAL SERIAL
INTERCONNECTION FACILITIES STUDY**

{Assumptions to be completed by Interconnection Customer and Transmission Provider}

APPENDIX 9 to LGIP
TWO-PARTY AFFECTED SYSTEM STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ____ day of _____, 20____, by and between _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer) and _____, a _____ organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Affected System Interconnection Customer is proposing to develop a {description of generating facility or generating capacity addition to an existing generating facility} consistent with the interconnection request submitted by Affected System Interconnection Customer to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customer desires to interconnect the {generating facility} with {name of host transmission provider}’s transmission system;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.

- 2.0 Transmission Provider shall coordinate with Affected System Interconnection Customer to perform an Affected System Study consistent with Section 9 of this LGIP.
- 3.0 The scope of the Affected System Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Affected System Study will be based upon the technical information provided by Affected System Interconnection Customer and {name of host transmission provider}. Transmission Provider reserves the right to request additional technical information from Affected System Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the Affected System Study.
- 5.0 The Affected System Study shall provide the following information:
- identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection;
 - non-binding, good faith estimated cost and time required to construct facilities required on Transmission Provider's Transmission System

to accommodate the interconnection of the {generating facility} to the transmission system of the host transmission provider; and

- description of how such facilities will address the identified short circuit, instability, and power flow issues.

6.0 Affected System Interconnection Customer shall provide a deposit of _____ for performance of the Affected System Study. Upon receipt of the results of the Affected System Study by the Affected System Interconnection Customer, Transmission Provider shall charge, and Affected System Interconnection Customer shall pay, the actual cost of the Affected System Study. Any difference between the deposit and the actual cost of the Affected System Study shall be paid by or refunded to Affected System Interconnection Customer, as appropriate, including interest calculated in accordance with section 35.19a(a)(2) of FERC’s regulations.

7.0 This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability, and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Affected System Interconnection Customer}

By: _____

Title: _____

Date: _____

Project No. _____

**Attachment A to Appendix 9
Two-Party Affected System Study Agreement**

**ASSUMPTIONS USED IN CONDUCTING THE
AFFECTED SYSTEM STUDY**

The Affected System Study will be based upon the following assumptions:

{Assumptions to be completed by Affected System Interconnection Customer and
Transmission Provider}

APPENDIX 10 to LGIP

MULTIPARTY AFFECTED SYSTEM STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ___ day of _____, 20___, by and among _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); and _____, a _____ organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customers and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.” When it is not important to differentiate among them, Affected System Interconnection Customers each may be referred to as “Affected System Interconnection Customer” or collectively as the “Affected System Interconnection Customers.”

RECITALS

WHEREAS, Affected System Interconnection Customers are proposing to develop {description of generating facilities or generating capacity additions to an existing generating facility}, consistent with the interconnection requests submitted by Affected System Interconnection Customers to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customers desire to interconnect the {generating facilities} with {name of host transmission provider}’s transmission system;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Transmission Provider shall coordinate with Affected System Interconnection Customers to perform an Affected System Study consistent with Section 9 of this LGIP.
- 3.0 The scope of the Affected System Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Affected System Study will be based upon the technical information provided by Affected System Interconnection Customers and {name of host transmission provider}. Transmission Provider reserves the right to request additional technical information from Affected System Interconnection Customers as may reasonably become necessary consistent with Good Utility Practice during the course of the Affected System Study.
- 5.0 The Affected System Study shall provide the following information:
 - identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection;

- non-binding, good faith estimated cost and time required to construct facilities required on Transmission Provider’s Transmission System to accommodate the interconnection of the {generating facilities} to the transmission system of the host transmission provider; and
- description of how such facilities will address the identified short circuit, instability, and power flow issues.

6.0 Affected System Interconnection Customers shall each provide a deposit of _____ for performance of the Affected System Study. Upon receipt of the results of the Affected System Study by the Affected System Interconnection Customers, Transmission Provider shall charge, and Affected System Interconnection Customers shall pay, the actual cost of the Affected System Study. Any difference between the deposit and the actual cost of the Affected System Study shall be paid by or refunded to Affected System Interconnection Customers, as appropriate, including interest calculated in accordance with section 35.19a(a)(2) of FERC’s regulations.

7.0 This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability, and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Affected System Interconnection Customer}

By: _____

Title: _____

Date: _____

Project No. _____

{Insert name of Affected System Interconnection Customer}

By: _____

Title: _____

Date: _____

Project No. _____

Attachment A to Appendix 10
Multiparty Affected System Study Agreement

ASSUMPTIONS USED IN CONDUCTING THE
MULTIPARTY AFFECTED SYSTEM STUDY

The Affected System Study will be based upon the following assumptions:

{Assumptions to be completed by Affected System Interconnection Customers and
Transmission Provider}

APPENDIX 11 TO LGIP
TWO-PARTY AFFECTED SYSTEM FACILITIES CONSTRUCTION
AGREEMENT

THIS AGREEMENT is made and entered into this ____ day of _____, 20__, by and between _____, organized and existing under the laws of the State of _____ (Affected System Interconnection Customer) and _____, an entity organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customer and Transmission Provider each may be referred to as a “Party” or collectively as the “Parties.”

RECITALS

WHEREAS, Affected System Interconnection Customer is proposing to develop a {description of generating facility or generating capacity addition to an existing generating facility} consistent with the interconnection request submitted by Affected System Interconnection Customer to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customer desires to interconnect the {generating facility} to {name of host transmission provider}’s transmission system; and

WHEREAS, additions, modifications, and upgrade(s) must be made to certain existing facilities of Transmission Provider’s Transmission System to accommodate such interconnection; and

WHEREAS, Affected System Interconnection Customer has requested, and Transmission Provider has agreed, to enter into this Agreement for the purpose of facilitating the construction of necessary Affected System Network Upgrade(s);

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

ARTICLE 1
DEFINITIONS

When used in this Agreement, with initial capitalization, the terms specified and not otherwise defined in this Agreement shall have the meanings indicated in this LGIP.

ARTICLE 2
TERM OF AGREEMENT

2.1 Effective Date. This Agreement shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by FERC.

2.2 Term.

2.2.1 General. This Agreement shall become effective as provided in Article 2.1 and shall continue in full force and effect until the earlier of (1) the final repayment, where applicable, by Transmission Provider of the amount funded by Affected System Interconnection Customer for Transmission Provider's design, procurement, construction and installation of the Affected System Network Upgrade(s) provided in Appendix A; (2) the Parties agree to mutually terminate this Agreement; (3) earlier termination is permitted or provided for under Appendix A of this Agreement; or (4) Affected System Interconnection Customer terminates this Agreement after providing Transmission Provider with written notice at least sixty (60) Calendar Days prior to the proposed termination date, provided that Affected System Interconnection Customer has no outstanding contractual obligations to Transmission Provider under this Agreement. No

termination of this Agreement shall be effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination. The term of this Agreement may be adjusted upon mutual agreement of the Parties if (1) the commercial operation date for the {generating facility} is adjusted in accordance with the rules and procedures established by {name of host transmission provider} or (2) the in-service date for the Affected System Network Upgrade(s) is adjusted in accordance with the rules and procedures established by Transmission Provider.

2.2.2 Termination Upon Default. Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 5 of this Agreement where Breach and Breaching Party are defined in Article 5. Defaulting Party shall mean the Party that is in Default. In the event of a Default by a Party, the non-Defaulting Party shall have the termination rights described in Articles 5 and 6; provided, however, Transmission Provider may not terminate this Agreement if Affected System Interconnection Customer is the Defaulting Party and compensates Transmission Provider within thirty (30) Calendar Days for the amount of damages billed to Affected System Interconnection Customer by Transmission Provider for any such damages, including costs and expenses, incurred by Transmission Provider as a result of such Default.

2.2.3 Consequences of Termination. In the event of a termination by either Party, other than a termination by Affected System Interconnection Customer due to a Default by Transmission Provider, Affected System Interconnection Customer shall be responsible for the payment to Transmission Provider of all amounts then due and payable for construction and installation of the Affected System Network Upgrade(s) (including, without limitation, any equipment ordered related to such construction), plus all out-of-pocket expenses incurred by Transmission Provider in connection with the construction and installation of the Affected System Network Upgrade(s), through the date of termination, and, in the event of the termination of the entire Agreement, any actual costs which Transmission Provider reasonably incurs in (1) winding up work and construction demobilization and (2) ensuring the safety of persons and

property and the integrity and safe and reliable operation of Transmission Provider's Transmission System. Transmission Provider shall use Reasonable Efforts to minimize such costs.

- 2.2.4 Reservation of Rights.** Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Affected System Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement pursuant to section 206 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations thereunder, except to the extent that the Parties otherwise mutually agree as provided herein.
- 2.3 Filing.** Transmission Provider shall file this Agreement (and any amendment hereto) with the appropriate Governmental Authority, if required. Affected System Interconnection Customer may request that any information so provided be subject to the confidentiality provisions of Article 8. If Affected System Interconnection Customer has executed this Agreement, or any amendment thereto, Affected System Interconnection Customer shall reasonably cooperate with Transmission Provider with respect to such filing and to provide any information reasonably requested by Transmission Provider needed to comply with applicable regulatory requirements.
- 2.4 Survival.** This Agreement shall continue in effect after termination, to the extent necessary, to provide for final billings and payments and for costs incurred hereunder, including billings and payments pursuant to this Agreement; to permit the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and

to permit each Party to have access to the lands of the other Party pursuant to this Agreement or other applicable agreements, to disconnect, remove, or salvage its own facilities and equipment.

- 2.5 Termination Obligations.** Upon any termination pursuant to this Agreement, Affected System Interconnection Customer shall be responsible for the payment of all costs or other contractual obligations incurred prior to the termination date, including previously incurred capital costs, penalties for early termination, and costs of removal and site restoration.

ARTICLE 3

CONSTRUCTION OF AFFECTED SYSTEM NETWORK UPGRADE(S)

3.1 Construction.

3.1.1 Transmission Provider Obligations. Transmission Provider shall (or shall cause such action to) design, procure, construct, and install, and Affected System Interconnection Customer shall pay, consistent with Article 3.2, the costs of all Affected System Network Upgrade(s) identified in Appendix A. All Affected System Network Upgrade(s) designed, procured, constructed, and installed by Transmission Provider pursuant to this Agreement shall satisfy all requirements of applicable safety and/or engineering codes and comply with Good Utility Practice, and further, shall satisfy all Applicable Laws and Regulations. Transmission Provider shall not be required to undertake any action which is inconsistent with its standard safety practices, its material and equipment specifications, its design criteria and construction procedures, its labor agreements, or any Applicable Laws and Regulations.

3.1.2 Suspension of Work.

3.1.2.1 Right to Suspend. Affected System Interconnection Customer must provide to Transmission Provider written notice of its request for suspension. Only the milestones described in the Appendices of this Agreement are subject to suspension under this Article 3.1.2. Affected System Network Upgrade(s) will be constructed on the schedule described in the Appendices of this Agreement unless: (1) construction is prevented by the order of a Governmental Authority; (2) the Affected System Network Upgrade(s) are not needed by any other Interconnection Customer; or (3) Transmission Provider determines that a Force Majeure event prevents construction. In the event of (1), (2), or (3), any security paid to Transmission Provider under Article 4.1 of this Agreement shall be released by Transmission Provider upon the determination by Transmission Provider that the Affected System Network Upgrade(s) will no longer be constructed. If suspension occurs, Affected System Interconnection Customer shall be responsible for the costs which Transmission Provider incurs (i) in accordance with this Agreement prior to the suspension; (ii) in suspending such work, including any costs incurred to perform such work as may be necessary to ensure the safety of persons and property and the integrity of Transmission Provider's Transmission System and, if applicable, any costs incurred in connection with the cancellation of contracts and orders for material which Transmission Provider cannot reasonably avoid; and (iii) reasonably incurs in winding up work and construction demobilization; provided, however, that, prior to canceling any such contracts or orders, Transmission Provider shall obtain Affected System Interconnection Customer's authorization. Affected System Interconnection Customer shall be responsible for all costs incurred in connection with Affected System Interconnection Customer's failure to authorize cancellation of such contracts or orders.

Interest on amounts paid by Affected System Interconnection Customer to Transmission Provider for the design,

procurement, construction, and installation of the Affected System Network Upgrade(s) shall not accrue during periods in which Affected System Interconnection Customer has suspended construction under this Article 3.1.2.

Transmission Provider shall invoice Affected System Interconnection Customer pursuant to Article 4 and will use Reasonable Efforts to minimize its costs. In the event Affected System Interconnection Customer suspends work by Affected System Transmission Provider required under this Agreement pursuant to this Article 3.1.2.1, and has not requested Affected System Transmission Provider to recommence the work required under this Agreement on or before the expiration of three (3) years following commencement of such suspension, this Agreement shall be deemed terminated. The three-year period shall begin on the date the suspension is requested, or the date of the written notice to Affected System Transmission Provider, whichever is earlier, if no effective date of suspension is specified.

3.1.3 Construction Status. Transmission Provider shall keep Affected System Interconnection Customer advised periodically as to the progress of its design, procurement and construction efforts, as described in Appendix A. Affected System Interconnection Customer may, at any time and reasonably, request a progress report from Transmission Provider. If, at any time, Affected System Interconnection Customer determines that the completion of the Affected System Network Upgrade(s) will not be required until after the specified in-service date, Affected System Interconnection Customer will provide written notice to Transmission Provider of such later date upon which the completion of the Affected System Network Upgrade(s) would be required. Transmission Provider may delay the in-service date of the Affected System Network Upgrade(s) accordingly.

3.1.4 Timely Completion. Transmission Provider shall use Reasonable Efforts to design, procure, construct, install, and test the Affected System Network Upgrade(s) in accordance with the schedule set forth in Appendix A, which schedule may be revised from time to time by mutual agreement of the Parties. If any event occurs that will affect the time or ability to complete the Affected System Network Upgrade(s), Transmission Provider shall promptly notify Affected System Interconnection Customer. In such circumstances, Transmission Provider shall, within fifteen (15) Calendar Days of such notice, convene a meeting with Affected System Interconnection Customer to evaluate the alternatives available to Affected System Interconnection Customer. Transmission Provider shall also make available to Affected System Interconnection Customer all studies and work papers related to the event and corresponding delay, including all information that is in the possession of Transmission Provider that is reasonably needed by Affected System Interconnection Customer to evaluate alternatives, subject to confidentiality arrangements consistent with Article 8. Transmission Provider shall, at Affected System Interconnection Customer's request and expense, use Reasonable Efforts to accelerate its work under this Agreement to meet the schedule set forth in Appendix A, provided that (1) Affected System Interconnection Customer authorizes such actions, such authorization to be withheld, conditioned, or delayed by Affected System Interconnection Customer only if it can demonstrate that the acceleration would have a material adverse effect on it; and (2) the Affected System Interconnection Customer funds costs associated therewith in advance.

3.2 Interconnection Costs.

3.2.1 Costs. Affected System Interconnection Customer shall pay to Transmission Provider costs (including taxes and financing costs) associated with seeking and obtaining all necessary approvals and of designing, engineering, constructing, and testing the Affected System Network Upgrade(s), as identified in Appendix A, in accordance with the cost recovery method provided herein. Unless Transmission Provider elects to fund the Affected System Network Upgrade(s), they shall be initially funded by Affected System Interconnection Customer.

3.2.1.1 Lands of Other Property Owners. If any part of the Affected System Network Upgrade(s) is to be installed on property owned by persons other than Affected System Interconnection Customer or Transmission Provider, Transmission Provider shall, at Affected System Interconnection Customer's expense, use efforts similar in nature and extent to those that it typically undertakes on its own behalf or on behalf of its Affiliates, including use of its eminent domain authority to the extent permitted and consistent with Applicable Laws and Regulations and, to the extent consistent with such Applicable Laws and Regulations, to procure from such persons any rights of use, licenses, rights-of-way, and easements that are necessary to construct, operate, maintain, test, inspect, replace, or remove the Affected System Network Upgrade(s) upon such property.

3.2.2 Repayment.

3.2.2.1 Repayment. Consistent with Articles 11.4.1 and 11.4.2 of Transmission Provider's pro forma LGIA, Affected System Interconnection Customer shall be entitled to a cash repayment by Transmission Provider of the amount paid to Transmission Provider, if any, for the Affected System Network Upgrade(s), including any tax gross-up or other tax-related payments associated with the Affected System Network Upgrade(s), and not refunded to Affected System Interconnection Customer pursuant to Article 3.3.1 or otherwise. The Parties may mutually agree to a repayment schedule, to be outlined in Appendix A, not to exceed twenty (20) years from the commercial operation date, for the complete repayment for all applicable costs associated with the Affected System Network Upgrade(s). Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 CFR 35.19 a(a)(2)(iii) from the date of any payment for Affected System

Network Upgrade(s) through the date on which Affected System Interconnection Customer receives a repayment of such payment pursuant to this subparagraph. Interest shall not accrue during periods in which Affected System Interconnection Customer has suspended construction pursuant to Article 3.1.2. Affected System Interconnection Customer may assign such repayment rights to any person.

3.2.2.2 Impact of Failure to Achieve Commercial Operation. If the Affected System Interconnection Customer's generating facility fails to achieve commercial operation, but it or another generating facility is later constructed and makes use of the Affected System Network Upgrade(s), Transmission Provider shall at that time reimburse Affected System Interconnection Customer for the amounts advanced for the Affected System Network Upgrade(s). Before any such reimbursement can occur, Affected System Interconnection Customer (or the entity that ultimately constructs the generating facility, if different), is responsible for identifying the entity to which the reimbursement must be made.

3.3 Taxes.

3.3.1 Indemnification for Contributions in Aid of Construction. With regard only to payments made by Affected System Interconnection Customer to Transmission Provider for the installation of the Affected System Network Upgrade(s), Transmission Provider shall not include a gross-up for income taxes in the amounts it charges Affected System Interconnection Customer for the installation of the Affected System Network Upgrade(s) unless (1) Transmission Provider has determined, in good faith, that the payments or property transfers made by Affected System Interconnection Customer to Transmission Provider should be reported as income subject to taxation, or (2) any Governmental Authority directs Transmission Provider to report payments or property as income subject to taxation. Affected System

Interconnection Customer shall reimburse Transmission Provider for such costs on a fully grossed-up basis, in accordance with this Article, within thirty (30) Calendar Days of receiving written notification from Transmission Provider of the amount due, including detail about how the amount was calculated.

The indemnification obligation shall terminate at the earlier of (1) the expiration Of the ten (10)-year testing period and the applicable statute of limitation, as it may be extended by Transmission Provider upon request of the Internal Revenue Service, to keep these years open for audit or adjustment, or (2) the occurrence of a subsequent taxable event and the payment of any related indemnification obligations as contemplated by this Article. Notwithstanding the foregoing provisions of this Article 3.3.1, and to the extent permitted by law, to the extent that the receipt of such payments by Transmission Provider is determined by any Governmental Authority to constitute income by Transmission Provider subject to taxation, Affected System Interconnection Customer shall protect, indemnify, and hold harmless Transmission Provider and its Affiliates, from all claims by any such Governmental Authority for any tax, interest, and/or penalties associated with such determination. Upon receiving written notification of such determination from the Governmental Authority, Transmission Provider shall provide Affected System Interconnection Customer with written notification within thirty (30) Calendar Days of such determination and notification. Transmission Provider, upon the timely written request by Affected System Interconnection Customer and at Affected System Interconnection Customer's expense, shall appeal, protest, seek abatement of, or otherwise oppose such determination. Transmission Provider reserves the right to make all decisions with regard to the prosecution of such appeal, protest, abatement, or other contest, including the compromise or settlement of the claim; provided that Transmission Provider shall cooperate and consult in good faith with Affected System Interconnection Customer regarding the conduct of such contest. Affected System Interconnection Customer shall not be required to pay Transmission Provider for the tax, interest, and/or penalties prior to the seventh (7th) Calendar Day before the date on which Transmission Provider (1) is required to pay the tax, interest, and/or penalties or other amount in lieu thereof pursuant to a compromise or

settlement of the appeal, protest, abatement, or other contest; (2) is required to pay the tax, interest, and/or penalties as the result of a final, non-appealable order by a Governmental Authority; or (3) is required to pay the tax, interest, and/or penalties as a prerequisite to an appeal, protest, abatement, or other contest. In the event such appeal, protest, abatement, or other contest results in a determination that Transmission Provider is not liable for any portion of any tax, interest, and/or penalties for which Affected System Interconnection Customer has already made payment to Transmission Provider, Transmission Provider shall promptly refund to Affected System Interconnection Customer any payment attributable to the amount determined to be non-taxable, plus any interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)) or other payments Transmission Provider receives or which Transmission Provider may be entitled with respect to such payment. Affected System Interconnection Customer shall provide Transmission Provider with credit assurances sufficient to meet Affected System Interconnection Customer's estimated liability for reimbursement of Transmission Provider for taxes, interest, and/or penalties under this Article 3.3.1. Such estimated liability shall be stated in Appendix A.

To the extent that Transmission Provider is a limited liability company and not a corporation, and has elected to be taxed as a partnership, then the following shall apply: Transmission Provider represents, and the Parties acknowledge, that Transmission Provider is a limited liability company and is treated as a partnership for federal income tax purposes. Any payment made by Affected System Interconnection Customer to Transmission Provider for Affected System Network Upgrade(s) is to be treated as an upfront payment. It is anticipated by the Parties that any amounts paid by Affected System Interconnection Customer to Transmission Provider for Affected System Network Upgrade(s) will be reimbursed to Affected System Interconnection Customer in accordance with the terms of this Agreement, provided Affected System Interconnection Customer fulfills its obligations under this Agreement.

3.3.2 Private Letter Ruling. At Affected System Interconnection Customer's request and expense, Transmission Provider shall file with the Internal

Revenue Service a request for a private letter ruling as to whether any property transferred or sums paid, or to be paid, by Affected System Interconnection Customer to Transmission Provider under this Agreement are subject to federal income taxation. Affected System Interconnection Customer will prepare the initial draft of the request for a private letter ruling and will certify under penalties of perjury that all facts represented in such request are true and accurate to the best of Affected System Interconnection Customer's knowledge. Transmission Provider and Affected System Interconnection Customer shall cooperate in good faith with respect to the submission of such request.

3.3.3 Other Taxes. Upon the timely request by Affected System Interconnection Customer, and at Affected System Interconnection Customer's sole expense, Transmission Provider shall appeal, protest, seek abatement of, or otherwise contest any tax (other than federal or state income tax) asserted or assessed against Transmission Provider for which Affected System Interconnection Customer may be required to reimburse Transmission Provider under the terms of this Agreement. Affected System Interconnection Customer shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission Provider's documented reasonable costs of prosecuting such appeal, protest, abatement, or other contest. Affected System Interconnection Customer and Transmission Provider shall cooperate in good faith with respect to any such contest. Unless the payment of such taxes is a prerequisite to an appeal or abatement or cannot be deferred, no amount shall be payable by Affected System Interconnection Customer to Transmission Provider for such taxes until they are assessed by a final, non-appealable order by any court or agency of competent jurisdiction. In the event that a tax payment is withheld and ultimately due and payable after appeal, Affected System Interconnection Customer will be responsible for all taxes, interest and penalties, other than penalties attributable to any delay caused by Transmission Provider. Each Party shall cooperate with the other Party to maintain each Party's tax status. Nothing in this Agreement is intended to adversely affect any Party's tax-exempt status with respect to the issuance of bonds including, but not limited to, local furnishing bonds, as described in section 142(f) of the Internal Revenue Code.

ARTICLE 4

SECURITY, BILLING, AND PAYMENTS

- 4.1 Provision of Security.** By the earlier of (1) thirty (30) Calendar Days prior to the due date for Affected System Interconnection Customer's first payment under the payment schedule specified in Appendix A, or (2) the first date specified in Appendix A for the ordering of equipment by Transmission Provider for installing the Affected System Network Upgrade(s), Affected System Interconnection Customer shall provide Transmission Provider, at Affected System Interconnection Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to Transmission Provider. Such security for payment shall be in an amount sufficient to cover the costs for constructing, procuring, and installing the applicable portion of Affected System Network Upgrade(s) and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider for these purposes.

The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider and contain terms and conditions that guarantee payment of any amount that may be due from Affected System Interconnection Customer, up to an agreed-to maximum amount. The letter of credit must be issued by a financial institution reasonably acceptable to Transmission Provider and must specify a reasonable expiration date. The surety bond must be issued by an insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.

- 4.2 Invoice.** Each Party shall submit to the other Party, on a monthly basis, invoices of amounts due, if any, for the preceding month. Each invoice shall state the month to which the invoice applies and fully describe the services and equipment provided. The Parties may discharge mutual debts and payment obligations due and owing to each other on the same date through netting, in which case all amounts a Party owes to the other Party under this Agreement, including interest payments, shall be netted so that only the net amount remaining due shall be paid by the owing Party.

- 4.3 Payment.** Invoices shall be rendered to the paying Party at the address specified by the Parties. The Party receiving the invoice shall pay the invoice within thirty (30) Calendar Days of receipt. All payments shall be made in immediately available funds payable to the other Party, or by wire transfer to a bank named and account designated by the invoicing Party. Payment of invoices by a Party will not constitute a waiver of any rights or claims that Party may have under this Agreement.
- 4.4 Final Invoice.** Within six (6) months after completion of the construction of the Affected System Network Upgrade(s), Transmission Provider shall provide an invoice of the final cost of the construction of the Affected System Network Upgrade(s) and shall set forth such costs in sufficient detail to enable Affected System Interconnection Customer to compare the actual costs with the estimates and to ascertain deviations, if any, from the cost estimates. Transmission Provider shall refund, with interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)), to Affected System Interconnection Customer any amount by which the actual payment by Affected System Interconnection Customer for estimated costs exceeds the actual costs of construction within thirty (30) Calendar Days of the issuance of such final construction invoice.
- 4.5 Interest.** Interest on any unpaid amounts shall be calculated in accordance with 18 CFR 35.19a(a)(2)(iii).
- 4.6 Payment During Dispute.** In the event of a billing dispute among the Parties, Transmission Provider shall continue to construct the Affected System Network Upgrade(s) under this Agreement as long as Affected System Interconnection Customer: (1) continues to make all payments not in dispute; and (2) pays to Transmission Provider or into an independent escrow account the portion of the invoice in dispute, pending resolution of such dispute. If Affected System Interconnection Customer fails to meet these two requirements, then Transmission Provider may provide notice to Affected System Interconnection Customer of a Default pursuant to Article 5. Within thirty (30) Calendar Days after the resolution of the dispute, the Party that owes money to another Party shall pay the amount due with interest calculated in accordance with the methodology set forth in 18 CFR 35.19a(a)(2)(iii).

ARTICLE 5
BREACH, CURE AND DEFAULT

5.1 Events of Breach. A Breach of this Agreement shall include the:

(a) Failure to pay any amount when due;

(b) Failure to comply with any material term or condition of this Agreement, including but not limited to any material Breach of a representation, warranty, or covenant made in this Agreement;

(c) Failure of a Party to provide such access rights, or a Party's attempt to revoke access or terminate such access rights, as provided under this Agreement; or

(d) Failure of a Party to provide information or data to another Party as required under this Agreement, provided the Party entitled to the information or data under this Agreement requires such information or data to satisfy its obligations under this Agreement.

5.2 Definition. Breaching Party shall mean the Party that is in Breach.

5.3 Notice of Breach, Cure, and Default. Upon the occurrence of an event of Breach, the Party not in Breach, when it becomes aware of the Breach, shall give written notice of the Breach to the Breaching Party and to any other person representing a Party to this Agreement identified in writing to the other Party in advance. Such notice shall set forth, in reasonable detail, the nature of the Breach, and where known and applicable, the steps necessary to cure such Breach.

5.3.1 Upon receiving written notice of the Breach hereunder, the Breaching Party shall have a period to cure such Breach (hereinafter referred to as the “Cure Period”) which shall be sixty (60) Calendar Days.

5.3.2 In the event the Breaching Party fails to cure within the Cure Period, the Breaching Party will be in Default of this Agreement, and the non-Defaulting Party may terminate this Agreement in accordance with Article 6.2 of this Agreement or take whatever action at law or in equity as may appear necessary or desirable to enforce the performance or observance of any rights, remedies, obligations, agreement, or covenants under this Agreement.

5.4 Rights in the Event of Default. Notwithstanding the foregoing, upon the occurrence of a Default, the non-Defaulting Party shall be entitled to exercise all rights and remedies it may have in equity or at law.

ARTICLE 6

TERMINATION OF AGREEMENT

6.1 Expiration of Term. Except as otherwise specified in this Article 6, the Parties’ obligations under this Agreement shall terminate at the conclusion of the term of this Agreement.

6.2 Termination. In addition to the termination provisions set forth in Article 2.2, a Party may terminate this Agreement upon the Default of the other Party in accordance with Article 5.2.2 of this Agreement. Subject to the limitations set forth in Article 6.3, in the event of a Default, the termination of this Agreement by the non-Defaulting Party shall require a filing at FERC of a notice of termination, which filing must be accepted for filing by FERC.

6.3 Disposition of Facilities Upon Termination of Agreement.

6.3.1 Transmission Provider Obligations. Upon termination of this Agreement, unless otherwise agreed to by the Parties in writing, Transmission Provider:

- (a) shall, prior to the construction and installation of any portion of the Affected System Network Upgrade(s) and to the extent possible, cancel any pending orders of, or return, such equipment or material for such Affected System Network Upgrade(s);
- (b) may keep in place any portion of the Affected System Network Upgrade(s) already constructed and installed; and,
- (c) shall perform such work as may be necessary to ensure the safety of persons and property and to preserve the integrity of Transmission Provider's Transmission System (e.g., construction demobilization to return the system to its original state, wind-up work).

6.3.2 Affected System Interconnection Customer Obligations. Upon billing by Transmission Provider, Affected System Interconnection Customer shall reimburse Transmission Provider for any costs incurred by Transmission Provider in performance of the actions required or permitted by Article 6.3.1 and for the cost of any Affected System Network Upgrade(s) described in Appendix A. Transmission Provider shall use Reasonable Efforts to minimize costs and shall offset the amounts owed by any salvage value of facilities, if applicable. Affected System Interconnection Customer shall pay these costs pursuant to Article 4.3 of this Agreement.

6.3.3 Pre-construction or Installation. Upon termination of this Agreement and prior to the construction and installation of any portion of the Affected System Network Upgrade(s), Transmission Provider may, at its option, retain any portion of such Affected System Network Upgrade(s) not cancelled or returned in accordance with Article 6.3.1(a), in which case

Transmission Provider shall be responsible for all costs associated with procuring such Affected System Network Upgrade(s). To the extent that Affected System Interconnection Customer has already paid Transmission Provider for any or all of such costs, Transmission Provider shall refund Affected System Interconnection Customer for those payments. If Transmission Provider elects to not retain any portion of such facilities, Transmission Provider shall convey and make available to Affected System Interconnection Customer such facilities as soon as practicable after Affected System Interconnection Customer's payment for such facilities.

- 6.4 Survival of Rights.** Termination or expiration of this Agreement shall not relieve either Party of any of its liabilities and obligations arising hereunder prior to the date termination becomes effective, and each Party may take whatever judicial or administrative actions as appear necessary or desirable to enforce its rights hereunder. The applicable provisions of this Agreement will continue in effect after expiration, or early termination hereof to the extent necessary to provide for (1) final billings, billing adjustments, and other billing procedures set forth in this Agreement; (2) the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and (3) the confidentiality provisions set forth in Article 8.

ARTICLE 7

SUBCONTRACTORS

- 7.1 Subcontractors.** Nothing in this Agreement shall prevent a Party from utilizing the services of subcontractors, as it deems appropriate, to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services, and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

- 7.1.1 Responsibility of Principal.** The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. In accordance with the provisions of this Agreement, each Party shall be fully responsible to the other Party for the acts or omissions

of any subcontractor it hires as if no subcontract had been made. Any applicable obligation imposed by this Agreement upon a Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

7.1.2 No Third-Party Beneficiary. Except as may be specifically set forth to the contrary herein, no subcontractor or any other party is intended to be, nor will it be deemed to be, a third-party beneficiary of this Agreement.

7.1.3 No Limitation by Insurance. The obligations under this Article 7 will not be limited in any way by any limitation of any insurance policies or coverages, including any subcontractor's insurance.

ARTICLE 8

CONFIDENTIALITY

8.1 Confidentiality. Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied to the other Party prior to the execution of this Agreement.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential. The Parties shall maintain as confidential any information that is provided and identified by a Party as Critical Energy Infrastructure Information (CEII), as that term is defined in 18 CFR 388.113(c).

Such confidentiality will be maintained in accordance with this Article 8. If requested by the receiving Party, the disclosing Party shall provide in writing, the basis for asserting that the information referred to in this Article warrants confidential treatment, and the requesting Party may disclose such writing to the

appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

8.1.1 Term. During the term of this Agreement, and for a period of three (3) years after the expiration or termination of this Agreement, except as otherwise provided in this Article 8 or with regard to CEII, each Party shall hold in confidence and shall not disclose to any person Confidential Information. CEII shall be treated in accordance with FERC policies and regulations.

8.1.2 Scope. Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a non-Party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of this Agreement; or (6) is required, in accordance with Article 8.1.6 of this Agreement, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under this Agreement. Information designated as Confidential Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the receiving Party that it no longer is confidential.

8.1.3 Release of Confidential Information. No Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), subcontractors, employees, agents, consultants, or to non-Parties that may be or are considering providing financing to or equity participation with Affected System Interconnection Customer, or to potential purchasers or assignees of

Affected System Interconnection Customer, on a need-to-know basis in connection with this Agreement, unless such person has first been advised of the confidentiality provisions of this Article 8 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Article 8.

- 8.1.4 Rights.** Each Party shall retain all rights, title, and interest in the Confidential Information that it discloses to the receiving Party. The disclosure by a Party to the receiving Party of Confidential Information shall not be deemed a waiver by the disclosing Party or any other person or entity of the right to protect the Confidential Information from public disclosure.
- 8.1.5 Standard of Care.** Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication, or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under this Agreement or its regulatory requirements.
- 8.1.6 Order of Disclosure.** If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires either Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the disclosing Party with prompt notice of such request(s) or requirement(s) so that the disclosing Party may seek an appropriate protective order or waive compliance with the terms of this Agreement. Notwithstanding the absence of a protective order or waiver, the Party may disclose such Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance that confidential treatment will be accorded any Confidential Information so furnished.

8.1.7 Termination of Agreement. Upon termination of this Agreement for any reason, each Party shall, within ten (10) Business Days of receipt of a written request from the other Party, use Reasonable Efforts to destroy, erase, or delete (with such destruction, erasure, and deletion certified in writing to the requesting Party) or return to the requesting Party any and all written or electronic Confidential Information received from the requesting Party, except that each Party may keep one copy for archival purposes, provided that the obligation to treat it as Confidential Information in accordance with this Article 8 shall survive such termination.

8.1.8 Remedies. The Parties agree that monetary damages would be inadequate to compensate a Party for the other Party's Breach of its obligations under this Article 8. Each Party accordingly agrees that the disclosing Party shall be entitled to equitable relief, by way of injunction or otherwise, if the receiving Party Breaches or threatens to Breach its obligations under this Article 8, which equitable relief shall be granted without bond or proof of damages, and the breaching Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Article 8, but it shall be in addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. Neither Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Article 8.

8.1.9 Disclosure to FERC, its Staff, or a State Regulatory Body.

Notwithstanding anything in this Article 8 to the contrary, and pursuant to 18 CFR 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from a Party that is otherwise required to be maintained in confidence pursuant to this Agreement, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information. In providing the information to FERC or its staff, the Party must, consistent with 18 CFR 388.112, request that the information be treated as confidential and non-public by FERC and

its staff and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party to this Agreement prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Party to the Agreement when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

8.1.10 Subject to the exception in Article 8.1.9, any information that a disclosing Party claims is competitively sensitive, commercial, or financial information under this Agreement shall not be disclosed by the receiving Party to any person not employed or retained by the receiving Party, except to the extent disclosure is (1) required by law; (2) reasonably deemed by the disclosing Party to be required to be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (3) otherwise permitted by consent of the disclosing Party, such consent not to be unreasonably withheld; or (4) necessary to fulfill its obligations under this Agreement or as Transmission Provider or a balancing authority, including disclosing the Confidential Information to a regional or national reliability organization. The Party asserting confidentiality shall notify the receiving Party in writing of the information that Party claims is confidential. Prior to any disclosures of that Party's Confidential Information under this subparagraph, or if any non-Party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the Party that received the Confidential Information from the disclosing Party agrees to promptly notify the disclosing Party in writing and agrees to assert confidentiality and cooperate with the disclosing Party in seeking to protect the Confidential Information from public disclosure by confidentiality agreement, protective order, or other reasonable measures.

ARTICLE 9

INFORMATION ACCESS AND AUDIT RIGHTS

- 9.1 Information Access.** Each Party shall make available to the other Party information necessary to verify the costs incurred by the other Party for which the requesting Party is responsible under this Agreement and carry out obligations and responsibilities under this Agreement, provided that the Parties shall not use such information for purposes other than those set forth in this Article 9.1 and to enforce their rights under this Agreement.
- 9.2 Audit Rights.** Subject to the requirements of confidentiality under Article 8 of this Agreement, the accounts and records related to the design, engineering, procurement, and construction of the Affected System Network Upgrade(s) shall be subject to audit during the period of this Agreement and for a period of twenty-four (24) months following Transmission Provider's issuance of a final invoice in accordance with Article 4.4. Affected System Interconnection Customer at its expense shall have the right, during normal business hours, and upon prior reasonable notice to Transmission Provider, to audit such accounts and records. Any audit authorized by this Article 9.2 shall be performed at the offices where such accounts and records are maintained and shall be limited to those portions of such accounts and records that relate to obligations under this Agreement.

ARTICLE 10

NOTICES

- 10.1 General.** Any notice, demand, or request required or permitted to be given by a Party to the other Party, and any instrument required or permitted to be tendered or delivered by a Party in writing to another Party, may be so given, tendered, or delivered, as the case may be, by depositing the same with the United States Postal Service with postage prepaid, for transmission by certified or registered mail, addressed to the Parties, or personally delivered to the Parties, at the address set out below:

To Transmission Provider:

To Affected System Interconnection Customer:

10.2 Billings and Payments. Billings and payments shall be sent to the addresses shown in Article 10.1 unless otherwise agreed to by the Parties.

10.3 Alternative Forms of Notice. Any notice or request required or permitted to be given by a Party to the other Party and not required by this Agreement to be given in writing may be so given by telephone, facsimile or email to the telephone numbers and email addresses set out below:

To Transmission Provider:

To Affected System Interconnection Customer:

10.4 Execution and Filing. Affected System Interconnection Customer shall either: (i) execute two originals of this tendered Agreement and return them to Transmission Provider; or (ii) request in writing that Transmission Provider file with FERC this Agreement in unexecuted form. As soon as practicable, but not later than ten (10) Business Days after receiving either the two executed originals of this tendered Agreement (if it does not conform with a FERC-approved standard form of this Agreement) or the request to file this Agreement unexecuted, Transmission Provider shall file this Agreement with FERC, together with its explanation of any matters as to which Affected System Interconnection Customer and Transmission Provider disagree and support for the costs that Transmission Provider proposes to charge to Affected System Interconnection Customer under this Agreement. An unexecuted version of this Agreement should contain terms and conditions deemed appropriate by Transmission Provider for the Affected

System Interconnection Customer's generating facility. If the Parties agree to proceed with design, procurement, and construction of facilities and upgrades under the agreed-upon terms of the unexecuted version of this Agreement, they may proceed pending FERC action.

ARTICLE 11

MISCELLANEOUS

- 11.1** This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP.

{Signature Page to Follow}

IN WITNESS WHEREOF, the Parties have executed this Agreement in multiple originals, each of which shall constitute and be an original Agreement among the Parties.

Transmission Provider

{Transmission Provider}

By: _____

Name: _____

Title: _____

Affected System Interconnection Customer

{Affected System Interconnection Customer}

By: _____

Name: _____

Title: _____

Project No. _____

**Attachment A to Appendix 11
Two-Party Affected System Facilities Construction Agreement**

**AFFECTED SYSTEM NETWORK UPGRADE(S), COST ESTIMATES AND
RESPONSIBILITY, CONSTRUCTION SCHEDULE AND MONTHLY
PAYMENT SCHEDULE**

This Appendix A is a part of the Affected System Facilities Construction Agreement between Affected System Interconnection Customer and Transmission Provider.

1.1 Affected System Network Upgrade(s) to be installed by Transmission Provider.

{description}

1.2 First Equipment Order (including permitting).

{description}

1.2.1. Permitting and Land Rights – Transmission Provider Affected System Network Upgrade(s)

{description}

1.3 Construction Schedule. Where applicable, construction of the Affected System Network Upgrade(s) is scheduled as follows and will be periodically updated as necessary:

Table 1: Transmission Provider Construction Activities

MILESTONE NUMBER	DESCRIPTION	START DATE	END DATE

Note: Construction schedule assumes that Transmission Provider has obtained final authorizations and security from Affected System Interconnection Customer and all necessary permits from Governmental Authorities as necessary prerequisites to commence construction of any of the Affected System Network Upgrade(s).

1.4 Payment Schedule.

1.4.1 Timing of and Adjustments to Affected System Interconnection Customer’s Payments and Security.

{description}

1.4.2 Monthly Payment Schedule. Affected System Interconnection Customer’s payment schedule is as follows.

{description}

Table 2: Affected System Interconnection Customer’s Payment/Security Obligations for Affected System Network Upgrade(s).

MILESTONE NUMBER	DESCRIPTION	DATE

Note: Affected System Interconnection Customer’s payment or provision of security as provided in this Agreement operates as a condition precedent to Transmission Provider’s obligations to construct any Affected System Network Upgrade(s), and failure to meet this schedule will constitute a Breach pursuant to Article 5.1 of this Agreement.

1.5 Permits, Licenses, and Authorizations.

{description}

Attachment B to Appendix 11
Two-Party Affected System Facilities Construction Agreement

NOTIFICATION OF COMPLETED CONSTRUCTION

This Appendix B is a part of the Affected Systems Facilities Construction Agreement between Affected System Interconnection Customer and Transmission Provider. Where applicable, when Transmission Provider has completed construction of the Affected System Network Upgrade(s), Transmission Provider shall send notice to Affected System Interconnection Customer in substantially the form following:

{Date}

{Affected System Interconnection Customer Address}

Re: Completion of Affected System Network Upgrade(s)

Dear {Name or Title}:

This letter is sent pursuant to the Affected System Facilities Construction Agreement between {Transmission Provider} and {Affected System Interconnection Customer}, dated _____, 20__.

On {Date}, Transmission Provider completed to its satisfaction all work on the Affected System Network Upgrade(s) required to facilitate the safe and reliable interconnection and operation of Affected System Interconnection Customer's {description of generating facility}. Transmission Provider confirms that the Affected System Network Upgrade(s) are in place.

Thank you.

{Signature}

{Transmission Provider Representative}

**Attachment C to Appendix 11
Two-Party Affected System Facilities Construction Agreement**

EXHIBITS

This Appendix C is a part of the Affected System Facilities Construction Agreement between Affected System Interconnection Customer and Transmission Provider.

Exhibit A1

Transmission Provider Site Map

Exhibit A2

Site Plan

Exhibit A3

Affected System Network Upgrade(s) Plan & Profile

Exhibit A4

Estimated Cost of Affected System Network Upgrade(s)

	Location	Facilities to Be Constructed by Transmission Provider	Estimate in Dollars

		Total:	
--	--	---------------	--

APPENDIX 12 TO LGIP

MULTIPARTY AFFECTED SYSTEM FACILITIES CONSTRUCTION AGREEMENT

THIS AGREEMENT is made and entered into this ____ day of _____, 20__, by and among _____, organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); and _____, an entity organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customers and Transmission Provider each may be referred to as a “Party” or collectively as the “Parties.” When it is not important to differentiate among them, Affected System Interconnection Customers each may be referred to as “Affected System Interconnection Customer” or collectively as “Affected System Interconnection Customers.”

RECITALS

WHEREAS, Affected System Interconnection Customers are proposing to develop {description of generating facilities or generating capacity additions to an existing generating facility}, consistent with the interconnection requests submitted by Affected System Interconnection Customers to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customers desire to interconnect the {generating facilities} to {name of host transmission provider}’s transmission system; and

WHEREAS, additions, modifications, and upgrade(s) must be made to certain existing facilities of Transmission Provider's Transmission System to accommodate such interconnection; and

WHEREAS, Affected System Interconnection Customers have requested, and Transmission Provider has agreed, to enter into this Agreement for the purpose of facilitating the construction of necessary Affected System Network Upgrade(s);

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

ARTICLE 1

DEFINITIONS

When used in this Agreement, with initial capitalization, the terms specified and not otherwise defined in this Agreement shall have the meanings indicated in this LGIP.

ARTICLE 2

TERM OF AGREEMENT

2.1 Effective Date. This Agreement shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by FERC.

2.2 Term.

2.2.1 General. This Agreement shall become effective as provided in Article 2.1 and shall continue in full force and effect until the earlier of (1) the final repayment, where applicable, by Transmission Provider of the amount funded by Affected System Interconnection Customers for Transmission Provider's design, procurement, construction, and installation of the

Affected System Network Upgrade(s) provided in Appendix A; (2) the Parties agree to mutually terminate this Agreement; (3) earlier termination is permitted or provided for under Appendix A of this Agreement; or (4) Affected System Interconnection Customers terminate this Agreement after providing Transmission Provider with written notice at least sixty (60) Calendar Days prior to the proposed termination date, provided that Affected System Interconnection Customers have no outstanding contractual obligations to Transmission Provider under this Agreement. No termination of this Agreement shall be effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination. The term of this Agreement may be adjusted upon mutual agreement of the Parties if the commercial operation date(s) for the {generating facilities} is adjusted in accordance with the rules and procedures established by {name of host transmission provider} or the in-service date for the Affected System Network Upgrade(s) is adjusted in accordance with the rules and procedures established by Transmission Provider.

2.2.2 Termination Upon Default. Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 5 of this Agreement where Breach and Breaching Party are defined in Article 5. Defaulting Party shall mean the Party that is in Default. In the event of a Default by a Party, each non-Defaulting Party shall have the termination rights described in Articles 5 and 6; provided, however, Transmission Provider may not terminate this Agreement if an Affected System Interconnection Customer is the Defaulting Party and compensates Transmission Provider within thirty (30) Calendar Days for the amount of damages billed to Affected System Interconnection Customer(s) by Transmission Provider for any such damages, including costs and expenses incurred by Transmission Provider as a result of such Default. Notwithstanding the foregoing, Default by one or more Affected System Interconnection Customers shall not provide the other Affected System Interconnection Customer(s), either individually or in concert, with the right to terminate the entire Agreement. The non-Defaulting Party/Parties may, individually or in concert, initiate the removal of an Affected System Interconnection Customer that is a Defaulting Party from this Agreement. Transmission Provider shall not terminate this Agreement or the participation of any Affected System

Interconnection Customer without provision being made for Transmission Provider to be fully reimbursed for all of its costs incurred under this Agreement.

2.2.3 Consequences of Termination. In the event of a termination by a Party, other than a termination by Affected System Interconnection Customer(s) due to a Default by Transmission Provider, each Affected System Interconnection Customer whose participation in this Agreement is terminated shall be responsible for the payment to Transmission Provider of all amounts then due and payable for construction and installation of the Affected System Network Upgrade(s) (including, without limitation, any equipment ordered related to such construction), plus all out-of-pocket expenses incurred by Transmission Provider in connection with the construction and installation of the Affected System Network Upgrade(s), through the date of termination, and, in the event of the termination of the entire Agreement, any actual costs which Transmission Provider reasonably incurs in (1) winding up work and construction demobilization and (2) ensuring the safety of persons and property and the integrity and safe and reliable operation of Transmission Provider's Transmission System. Transmission Provider shall use Reasonable Efforts to minimize such costs. The cost responsibility of other Affected System Interconnection Customers shall be adjusted, as necessary, based on the payments by an Affected System Interconnection Customer that is terminated from the Agreement.

2.2.4 Reservation of Rights. Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Affected System Interconnection Customers shall have the right to make a unilateral filing with FERC to modify this Agreement pursuant to section 206 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be

considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations thereunder, except to the extent that the Parties otherwise mutually agree as provided herein.

- 2.3 Filing.** Transmission Provider shall file this Agreement (and any amendment hereto) with the appropriate Governmental Authority, if required. Affected System Interconnection Customers may request that any information so provided be subject to the confidentiality provisions of Article 8. Each Affected System Interconnection Customer that has executed this Agreement, or any amendment thereto, shall reasonably cooperate with Transmission Provider with respect to such filing and to provide any information reasonably requested by Transmission Provider needed to comply with applicable regulatory requirements.
- 2.4 Survival.** This Agreement shall continue in effect after termination, to the extent necessary, to provide for final billings and payments and for costs incurred hereunder, including billings and payments pursuant to this Agreement; to permit the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and to permit each Party to have access to the lands of the other Party pursuant to this Agreement or other applicable agreements, to disconnect, remove, or salvage its own facilities and equipment.
- 2.5 Termination Obligations.** Upon any termination pursuant to this Agreement or termination of the participation in this Agreement of an Affected System Interconnection Customer, each Affected System Interconnection Customer shall be responsible for the payment of its proportionate share of all costs or other contractual obligations incurred prior to the termination date, including previously incurred capital costs, penalties for early termination, and costs of removal and site restoration. The cost responsibility of the other Affected System Interconnection Customers shall be adjusted as necessary.

ARTICLE 3

CONSTRUCTION OF AFFECTED SYSTEM NETWORK UPGRADE(S)

3.1 Construction.

3.1.1 Transmission Provider Obligations. Transmission Provider shall (or shall cause such action to) design, procure, construct, and install, and Affected System Interconnection Customers shall pay, consistent with Article 3.2, the costs of all Affected System Network Upgrade(s) identified in Appendix A. All Affected System Network Upgrade(s) designed, procured, constructed, and installed by Transmission Provider pursuant to this Agreement shall satisfy all requirements of applicable safety and/or engineering codes and comply with Good Utility Practice, and further, shall satisfy all Applicable Laws and Regulations. Transmission Provider shall not be required to undertake any action which is inconsistent with its standard safety practices, its material and equipment specifications, its design criteria and construction procedures, its labor agreements, or any Applicable Laws and Regulations.

3.1.2 Suspension of Work.

3.1.2.1 Right to Suspend. Affected System Interconnection Customers must jointly provide to Transmission Provider written notice of their request for suspension. Only the milestones described in the Appendices of this Agreement are subject to suspension under this Article 3.1.2. Affected System Network Upgrade(s) will be constructed on the schedule described in the Appendices of this Agreement unless: (1) construction is prevented by the order of a Governmental Authority; (2) the Affected System Network Upgrade(s) are not needed by any other Interconnection Customer; or (3) Transmission Provider determines that a Force Majeure event prevents construction. In the event of (1), (2), or (3), any security paid to Transmission Provider under Article 4.1 of this Agreement shall be released by Transmission Provider upon the determination by Transmission Provider that the Affected System Network

Upgrade(s) will no longer be constructed. If suspension occurs, Affected System Interconnection Customers shall be responsible for the costs which Transmission Provider incurs (i) in accordance with this Agreement prior to the suspension; (ii) in suspending such work, including any costs incurred to perform such work as may be necessary to ensure the safety of persons and property and the integrity of Transmission Provider's Transmission System and, if applicable, any costs incurred in connection with the cancellation of contracts and orders for material which Transmission Provider cannot reasonably avoid; and (iii) reasonably incurs in winding up work and construction demobilization; provided, however, that, prior to canceling any such contracts or orders, Transmission Provider shall obtain Affected System Interconnection Customers' authorization. Affected System Interconnection Customers shall be responsible for all costs incurred in connection with Affected System Interconnection Customers' failure to authorize cancellation of such contracts or orders.

Interest on amounts paid by Affected System Interconnection Customers to Transmission Provider for the design, procurement, construction, and installation of the Affected System Network Upgrade(s) shall not accrue during periods in which Affected System Interconnection Customers have suspended construction under this Article 3.1.2.

Transmission Provider shall invoice Affected System Interconnection Customers pursuant to Article 4 and will use Reasonable Efforts to minimize its costs. In the event Affected System Interconnection Customers suspend work by Affected System Transmission Provider required under this Agreement pursuant to this Article 3.1.2.1, and have not requested Affected System Transmission Provider to recommence the work required under this Agreement on or before the expiration of three (3) years following

commencement of such suspension, this Agreement shall be deemed terminated. The three-year period shall begin on the date the suspension is requested, or the date of the written notice to Affected System Transmission Provider, whichever is earlier, if no effective date of suspension is specified.

3.1.3 Construction Status. Transmission Provider shall keep Affected System Interconnection Customers advised periodically as to the progress of its design, procurement, and construction efforts, as described in Appendix A. An Affected System Interconnection Customer may, at any time and reasonably, request a progress report from Transmission Provider. If, at any time, an Affected System Interconnection Customer determines that the completion of the Affected System Network Upgrade(s) will not be required until after the specified in-service date, such Affected System Interconnection Customer will provide written notice to all other Parties of such later date for which the completion of the Affected System Network Upgrade(s) would be required. Transmission Provider may delay the in-service date of the Affected System Network Upgrade(s) accordingly, but only if agreed to by all other Affected System Interconnection Customers.

3.1.4 Timely Completion. Transmission Provider shall use Reasonable Efforts to design, procure, construct, install, and test the Affected System Network Upgrade(s) in accordance with the schedule set forth in Appendix A, which schedule may be revised from time to time by mutual agreement of the Parties. If any event occurs that will affect the time or ability to complete the Affected System Network Upgrade(s), Transmission Provider shall promptly notify all other Parties. In such circumstances, Transmission Provider shall, within fifteen (15) Calendar Days of such notice, convene a meeting with Affected System Interconnection Customers to evaluate the alternatives available to Affected System Interconnection Customers. Transmission Provider shall also make available to Affected System Interconnection Customers all studies and work papers related to the event and corresponding delay, including all information that is in the possession of transmission Provider that is reasonably needed by Affected System Interconnection Customers to evaluate alternatives, subject to confidentiality arrangements consistent with Article 8. Transmission

Provider shall, at any Affected System Interconnection Customer's request and expense, use Reasonable Efforts to accelerate its work under this Agreement to meet the schedule set forth in Appendix A, provided that (1) Affected System Interconnection Customers jointly authorize such actions, such authorizations to be withheld, conditioned, or delayed by a given Affected System Interconnection Customer only if it can demonstrate that the acceleration would have a material adverse effect on it; and (2) the requesting Affected System Interconnection Customer(s) funds the costs associated therewith in advance, or all Affected System Interconnection Customers agree in advance to fund such costs based on such other allocation method as they may adopt.

3.2 Interconnection Costs.

3.2.1 Costs. Affected System Interconnection Customers shall pay to Transmission Provider costs (including taxes and financing costs) associated with seeking and obtaining all necessary approvals and of designing, engineering, constructing, and testing the Affected System Network Upgrade(s), as identified in Appendix A, in accordance with the cost recovery method provided herein. Except as expressly otherwise agreed, Affected System Interconnection Customers shall be collectively responsible for these costs, based on their proportionate share of cost responsibility, as provided in Appendix A. Unless Transmission Provider elects to fund the Affected System Network Upgrade(s), they shall be initially funded by the applicable Affected System Interconnection Customer.

3.2.1.1 Lands of Other Property Owners. If any part of the Affected System Network Upgrade(s) is to be installed on property owned by persons other than Affected System Interconnection Customers or Transmission Provider, Transmission Provider shall, at Affected System Interconnection Customers' expense, use efforts similar in nature and extent to those that it typically undertakes on its

own behalf or on behalf of its Affiliates, including use of its eminent domain authority to the extent permitted and consistent with Applicable Laws and Regulations and, to the extent consistent with such Applicable Laws and Regulations, to procure from such persons any rights of use, licenses, rights-of-way, and easements that are necessary to construct, operate, maintain, test, inspect, replace, or remove the Affected System Network Upgrade(s) upon such property.

3.2.2 Repayment.

3.2.2.1 Repayment. Consistent with articles 11.4.1 and 11.4.2 of Transmission Provider's pro forma LGIA, each Affected System Interconnection Customer shall be entitled to a cash repayment by Transmission Provider of the amount each Affected System Interconnection Customer paid to Transmission Provider, if any, for the Affected System Network Upgrade(s), including any tax gross-up or other tax-related payments associated with the Affected System Network Upgrade(s), and not refunded to Affected System Interconnection Customer pursuant to Article 3.3.1 or otherwise. The Parties may mutually agree to a repayment schedule, to be outlined in Appendix A, not to exceed twenty (20) years from the commercial operation date, for the complete repayment for all applicable costs associated with the Affected System Network Upgrade(s). Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 CFR 35.19 a(a)(2)(iii) from the date of any payment for Affected System Network Upgrade(s) through the date on which Affected System Interconnection Customers receive a repayment of such payment pursuant to this subparagraph. Interest shall not accrue during periods in which Affected System Interconnection Customers have suspended construction pursuant to Article 3.1.2.1. Affected System Interconnection Customers may assign such repayment rights to any person.

3.2.2.2 Impact of Failure to Achieve Commercial Operation. If an Affected System Interconnection Customer's generating facility fails to achieve commercial operation, but it or another generating facility is later constructed and makes use of the Affected System Network Upgrade(s), Transmission Provider shall at that time reimburse such Affected System Interconnection Customers for the portion of the Affected System Network Upgrade(s) it funded. Before any such reimbursement can occur, Affected System Interconnection Customer (or the entity that ultimately constructs the generating facility, if different), is responsible for identifying the entity to which the reimbursement must be made.

3.3 Taxes.

3.3.1 Indemnification for Contributions in Aid of Construction. With regard only to payments made by Affected System Interconnection Customers to Transmission Provider for the installation of the Affected System Network Upgrade(s), Transmission Provider shall not include a gross-up for income taxes in the amounts it charges Affected System Interconnection Customers for the installation of the Affected System Network Upgrade(s) unless (1) Transmission Provider has determined, in good faith, that the payments or property transfers made by Affected System Interconnection Customers to Transmission Provider should be reported as income subject to taxation, or (2) any Governmental Authority directs Transmission Provider to report payments or property as income subject to taxation. Affected System Interconnection Customers shall reimburse Transmission Provider for such costs on a fully grossed-up basis, in accordance with this Article, within thirty (30) Calendar Days of receiving written notification from Transmission Provider of the amount due, including detail about how the amount was calculated.

The indemnification obligation shall terminate at the earlier of (1) the expiration of the ten (10)-year testing period and the applicable statute of limitation, as it may be extended by Transmission Provider upon request of the Internal Revenue Service, to keep these years open for audit or adjustment, or (2) the occurrence of a subsequent taxable event and the payment of any related indemnification obligations as contemplated by this Article. Notwithstanding the foregoing provisions of this Article 3.3.1, and to the extent permitted by law, to the extent that the receipt of such payments by Transmission Provider is determined by any Governmental Authority to constitute income by Transmission Provider subject to taxation, Affected System Interconnection Customers shall protect, indemnify, and hold harmless Transmission Provider and its Affiliates, from all claims by any such Governmental Authority for any tax, interest, and/or penalties associated with such determination. Upon receiving written notification of such determination from the Governmental Authority, Transmission Provider shall provide Affected System Interconnection Customers with written notification within thirty (30) Calendar Days of such determination and notification. Transmission Provider, upon the timely written request by any one or more Affected System Interconnection Customer(s) and at the expense of such Affected System Interconnection Customer(s), shall appeal, protest, seek abatement of, or otherwise oppose such determination. Transmission Provider reserves the right to make all decisions with regard to the prosecution of such appeal, protest, abatement or other contest, including the compromise or settlement of the claim; provided that Transmission Provider shall cooperate and consult in good faith with the requesting Affected System Interconnection Customer(s) regarding the conduct of such contest. Affected System Interconnection Customer(s) shall not be required to pay Transmission Provider for the tax, interest, and/or penalties prior to the seventh (7th) Calendar Day before the date on which Transmission Provider (1) is required to pay the tax, interest, and/or penalties or other amount in lieu thereof pursuant to a compromise or settlement of the appeal, protest, abatement, or other contest; (2) is required to pay the tax, interest, and/or penalties as the result of a final, non-appealable order by a Governmental Authority; or (3) is required to pay the tax, interest, and/or penalties as a prerequisite to an appeal, protest, abatement, or other contest. In the event such appeal, protest, abatement, or other contest results in a determination that Transmission Provider is not liable for any portion of any tax, interest,

and/or penalties for which any Affected System Interconnection Customer(s) has already made payment to Transmission Provider, Transmission Provider shall promptly refund to such Affected System Interconnection Customer(s) any payment attributable to the amount determined to be non-taxable, plus any interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)) or other payments Transmission Provider receives or to which Transmission Provider may be entitled with respect to such payment. Each Affected System Interconnection Customer shall provide Transmission Provider with credit assurances sufficient to meet each Affected System Interconnection Customer's estimated liability for reimbursement of Transmission Provider for taxes, interest, and/or penalties under this Article 3.3.1. Such estimated liability shall be stated in Appendix A.

To the extent that Transmission Provider is a limited liability company and not a corporation, and has elected to be taxed as a partnership, then the following shall apply: Transmission Provider represents, and the Parties acknowledge, that Transmission Provider is a limited liability company and is treated as a partnership for federal income tax purposes. Any payment made by Affected System Interconnection Customers to Transmission Provider for Affected System Network Upgrade(s) is to be treated as an upfront payment. It is anticipated by the Parties that any amounts paid by each Affected System Interconnection Customer to Transmission Provider for Affected System Network Upgrade(s) will be reimbursed to such Affected System Interconnection Customer in accordance with the terms of this Agreement, provided such Affected System Interconnection Customer fulfills its obligations under this Agreement.

3.3.2 Private Letter Ruling. At the request and expense of any Affected System Interconnection Customer(s), Transmission Provider shall file with the Internal Revenue Service a request for a private letter ruling as to whether any property transferred or sums paid, or to be paid, by such Affected System Interconnection Customer(s) to Transmission Provider under this Agreement are subject to federal income taxation. Each Affected System Interconnection Customer desiring such a request will prepare the initial draft of the request for a private letter ruling and will certify under penalties

of perjury that all facts represented in such request are true and accurate to the best of such Affected System Interconnection Customer's knowledge. Transmission Provider and such Affected System Interconnection Customer(s) shall cooperate in good faith with respect to the submission of such request.

3.3.3 Other Taxes. Upon the timely request by any one or more Affected System Interconnection Customer(s), and at such Affected System Interconnection Customer(s)' sole expense, Transmission Provider shall appeal, protest, seek abatement of, or otherwise contest any tax (other than federal or state income tax) asserted or assessed against Transmission Provider for which such Affected System Interconnection Customer(s) may be required to reimburse Transmission Provider under the terms of this Agreement. Affected System Interconnection Customer(s) who requested the action shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission Provider's documented reasonable costs of prosecuting such appeal, protest, abatement, or other contest. The requesting Affected System Interconnection Customer(s) and Transmission Provider shall cooperate in good faith with respect to any such contest. Unless the payment of such taxes is a prerequisite to an appeal or abatement or cannot be deferred, no amount shall be payable by Affected System Interconnection Customer(s) to Transmission Provider for such taxes until they are assessed by a final, non-appealable order by any court or agency of competent jurisdiction. In the event that a tax payment is withheld and ultimately due and payable after appeal, Affected System Interconnection Customer(s) will be responsible for all taxes, interest, and penalties, other than penalties attributable to any delay caused by Transmission Provider. Each Party shall cooperate with the other Party to maintain each Party's tax status. Nothing in this Agreement is intended to adversely affect any Party's tax-exempt status with respect to the issuance of bonds including, but not limited to, local furnishing bonds, as described in section 142(f) of the Internal Revenue Code.

ARTICLE 4

SECURITY, BILLING, AND PAYMENTS

- 4.1 Provision of Security.** By the earlier of (1) thirty (30) Calendar Days prior to the due date for each Affected System Interconnection Customer's first payment under the payment schedule specified in Appendix A, or (2) the first date specified in Appendix A for the ordering of equipment by Transmission Provider for installing the Affected System Network Upgrade(s), each Affected System Interconnection Customer shall provide Transmission Provider, at each Affected System Interconnection Customer's option, a guarantee, a surety bond, letter of credit, or other form of security that is reasonably acceptable to Transmission Provider. Such security for payment shall be in an amount sufficient to cover the costs for constructing, procuring, and installing the applicable portion of Affected System Network Upgrade(s) and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider for these purposes.

The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider and contain terms and conditions that guarantee payment of any amount that may be due from such Affected System Interconnection Customer, up to an agreed-to maximum amount. The letter of credit must be issued by a financial institution reasonably acceptable to Transmission Provider and must specify a reasonable expiration date. The surety bond must be issued by an insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.

- 4.2 Invoice.** Each Party shall submit to the other Parties, on a monthly basis, invoices of amounts due, if any, for the preceding month. Each invoice shall state the month to which the invoice applies and fully describe the services and equipment provided. The Parties may discharge mutual debts and payment obligations due and owing to each other on the same date through netting, in which case all amounts a Party owes to another Party under this Agreement, including interest payments, shall be netted so that only the net amount remaining due shall be paid by the owing Party.
- 4.3 Payment.** Invoices shall be rendered to the paying Party at the address specified by the Parties. The Party receiving the invoice shall pay the invoice within thirty (30) Calendar Days of receipt. All payments shall be made in immediately

available funds payable to the other Party, or by wire transfer to a bank named and account designated by the invoicing Party. Payment of invoices by a Party will not constitute a waiver of any rights or claims that Party may have under this Agreement.

- 4.4 Final Invoice.** Within six (6) months after completion of the construction of the Affected System Network Upgrade(s) Transmission Provider shall provide an invoice of the final cost of the construction of the Affected System Network Upgrade(s) and shall set forth such costs in sufficient detail to enable each Affected System Interconnection Customer to compare the actual costs with the estimates and to ascertain deviations, if any, from the cost estimates. Transmission Provider shall refund, with interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)), to each Affected System Interconnection Customer any amount by which the actual payment by Affected System Interconnection Customer for estimated costs exceeds the actual costs of construction within thirty (30) Calendar Days of the issuance of such final construction invoice.
- 4.5 Interest.** Interest on any unpaid amounts shall be calculated in accordance with 18 CFR 35.19a(a)(2)(iii).
- 4.6 Payment During Dispute.** In the event of a billing dispute among the Parties, Transmission Provider shall continue to construct the Affected System Network Upgrade(s) under this Agreement as long as each Affected System Interconnection Customer: (1) continues to make all payments not in dispute; and (2) pays to Transmission Provider or into an independent escrow account the portion of the invoice in dispute, pending resolution of such dispute. If any Affected System Interconnection Customer fails to meet these two requirements, then Transmission Provider may provide notice to such Affected System Interconnection Customer of a Default pursuant to Article 5. Within thirty (30) Calendar Days after the resolution of the dispute, the Party that owes money to another Party shall pay the amount due with interest calculated in accordance with the methodology set forth in 18 CFR 35.19a(a)(2)(iii).

ARTICLE 5

BREACH, CURE, AND DEFAULT

5.1 Events of Breach. A Breach of this Agreement shall include the:

- (a) Failure to pay any amount when due;
- (b) Failure to comply with any material term or condition of this Agreement, including but not limited to any material Breach of a representation, warranty, or covenant made in this Agreement;
- (c) Failure of a Party to provide such access rights, or a Party's attempt to revoke access or terminate such access rights, as provided under this Agreement; or
- (d) Failure of a Party to provide information or data to another Party as required under this Agreement, provided the Party entitled to the information or data under this Agreement requires such information or data to satisfy its obligations under this Agreement.

5.2 Definition. Breaching Party shall mean the Party that is in Breach.

5.3 Notice of Breach, Cure, and Default. Upon the occurrence of an event of Breach, any Party aggrieved by the Breach, when it becomes aware of the Breach, shall give written notice of the Breach to the Breaching Party and to any other person representing a Party to this Agreement identified in writing to the other Party in advance. Such notice shall set forth, in reasonable detail, the nature of the Breach, and where known and applicable, the steps necessary to cure such Breach.

5.2.1 Upon receiving written notice of the Breach hereunder, the Breaching Party shall have a period to cure such Breach (hereinafter referred to as the "Cure

Period”) which shall be sixty (60) Calendar Days. If an Affected System Interconnection Customer is the Breaching Party and the Breach results from a failure to provide payments or security under Article 4.1 of this Agreement, the other Affected System Interconnection Customers, either individually or in concert, may cure the Breach by paying the amounts owed or by providing adequate security, without waiver of contribution rights against the breaching Affected System Interconnection Customer. Such cure for the Breach of an Affected System Interconnection Customer is subject to the reasonable consent of Transmission Provider. Transmission Provider may also cure such Breach by funding the proportionate share of the Affected System Network Upgrade costs related to the Breach of Affected System Interconnection Customer. Transmission Provider must notify all Parties that it will exercise this option within thirty (30) Calendar Days of notification that an Affected System Interconnection Customer has failed to provide payments or security under Article 4.1.

5.2.2 In the event the Breach is not cured within the Cure Period, the Breaching Party will be in Default of this Agreement, and the non-Defaulting Parties may (1) act in concert to amend the Agreement to remove an Affected System Interconnection Customer that is in Default from this Agreement for cause and to make other changes as necessary, or (2) either in concert or individually take whatever action at law or in equity as may appear necessary or desirable to enforce the performance or observance of any rights, remedies, obligations, agreement, or covenants under this Agreement.

5.3 Rights in the Event of Default. Notwithstanding the foregoing, upon the occurrence of Default, the non-Defaulting Parties shall be entitled to exercise all rights and remedies it may have in equity or at law.

ARTICLE 6

TERMINATION OF AGREEMENT

6.1 Expiration of Term. Except as otherwise specified in this Article 6, the Parties' obligations under this Agreement shall terminate at the conclusion of the term of this Agreement.

6.2 Termination and Removal. Subject to the limitations set forth in Article 6.3, in the event of a Default, termination of this Agreement, as to a given Affected System Interconnection Customer or in its entirety, shall require a filing at FERC of a notice of termination, which filing must be accepted for filing by FERC.

6.3 Disposition of Facilities Upon Termination of Agreement.

6.3.1 Transmission Provider Obligations. Upon termination of this Agreement, unless otherwise agreed to by the Parties in writing, Transmission Provider:

(a) shall, prior to the construction and installation of any portion of the Affected System Network Upgrade(s) and to the extent possible, cancel any pending orders of, or return, such equipment or material for such Affected System Network Upgrade(s);

(b) may keep in place any portion of the Affected System Network Upgrade(s) already constructed and installed; and,

(c) shall perform such work as may be necessary to ensure the safety of persons and property and to preserve the integrity of Transmission Provider's Transmission System (e.g., construction demobilization to return the system to its original state, wind-up work).

6.3.2 Affected System Interconnection Customer Obligations. Upon billing by Transmission Provider, each Affected System Interconnection Customer shall reimburse Transmission Provider for its share of any costs incurred by Transmission Provider in performance of the actions required or permitted by Article 6.3.1 and for its share of the cost of any Affected System Network Upgrade(s) described in Appendix A. Transmission Provider shall use Reasonable Efforts to minimize costs and shall offset the amounts owed by any salvage value of facilities, if applicable. Each Affected

System Interconnection Customer shall pay these costs pursuant to Article 4.3 of this Agreement.

- 6.3.3 Pre-construction or Installation.** Upon termination of this Agreement and prior to the construction and installation of any portion of the Affected System Network Upgrade(s), Transmission Provider may, at its option, retain any portion of such Affected System Network Upgrade(s) not cancelled or returned in accordance with Article 6.3.1(a), in which case Transmission Provider shall be responsible for all costs associated with procuring such Affected System Network Upgrade(s). To the extent that an Affected System Interconnection Customer has already paid Transmission Provider for any or all of such costs, Transmission Provider shall refund Affected System Interconnection Customer for those payments. If Transmission Provider elects to not retain any portion of such facilities, and one or more of Affected System Interconnection Customers wish to purchase such facilities, Transmission Provider shall convey and make available to the applicable Affected System Interconnection Customer(s) such facilities as soon as practicable after Affected System Interconnection Customer(s)' payment for such facilities.
- 6.4 Survival of Rights.** Termination or expiration of this Agreement shall not relieve any Party of any of its liabilities and obligations arising hereunder prior to the date termination becomes effective, and each Party may take whatever judicial or administrative actions as appear necessary or desirable to enforce its rights hereunder. The applicable provisions of this Agreement will continue in effect after expiration, or early termination hereof, to the extent necessary to provide for (1) final billings, billing adjustments, and other billing procedures set forth in this Agreement; (2) the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and (3) the confidentiality provisions set forth in Article 8.

ARTICLE 7

SUBCONTRACTORS

- 7.1 Subcontractors.** Nothing in this Agreement shall prevent a Party from utilizing the services of subcontractors, as it deems appropriate, to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this

Agreement in providing such services, and each Party shall remain primarily liable to the other Parties for the performance of such subcontractor.

7.1.1 Responsibility of Principal. The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. In accordance with the provisions of this Agreement, each Party shall be fully responsible to the other Parties for the acts or omissions of any subcontractor it hires as if no subcontract had been made. Any applicable obligation imposed by this Agreement upon a Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

7.1.2 No Third-Party Beneficiary. Except as may be specifically set forth to the contrary herein, no subcontractor or any other party is intended to be, nor will it be deemed to be, a third-party beneficiary of this Agreement.

7.1.3 No Limitation by Insurance. The obligations under this Article 7 will not be limited in any way by any limitation of any insurance policies or coverages, including any subcontractor's insurance.

ARTICLE 8

CONFIDENTIALITY

8.1 Confidentiality. Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied to the other Parties prior to the execution of this Agreement.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential.

The Parties shall maintain as confidential any information that is provided and identified by a Party as Critical Energy Infrastructure Information (CEII), as that term is defined in 18 CFR 388.113(c).

Such confidentiality will be maintained in accordance with this Article 8. If requested by the receiving Party, the disclosing Party shall provide in writing, the basis for asserting that the information referred to in this Article warrants confidential treatment, and the requesting Party may disclose such writing to the appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

8.1.1 Term. During the term of this Agreement, and for a period of three (3) years after the expiration or termination of this Agreement, except as otherwise provided in this Article 8 or with regard to CEII, each Party shall hold in confidence and shall not disclose to any person Confidential Information. CEII shall be treated in accordance with FERC policies and regulations.

8.1.2 Scope. Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a non-Party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of this Agreement; or (6) is required, in accordance with Article 8.1.6 of this Agreement, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under this Agreement. Information designated as Confidential

Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the receiving Party that it no longer is confidential.

- 8.1.3 Release of Confidential Information.** No Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), subcontractors, employees, agents, consultants, or to non-Parties that may be or are considering providing financing to or equity participation with Affected System Interconnection Customer(s), or to potential purchasers or assignees of Affected System Interconnection Customer(s), on a need-to-know basis in connection with this Agreement, unless such person has first been advised of the confidentiality provisions of this Article 8 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Article 8.
- 8.1.4 Rights.** Each Party shall retain all rights, title, and interest in the Confidential Information that it discloses to the receiving Party. The disclosure by a Party to the receiving Party of Confidential Information shall not be deemed a waiver by the disclosing Party or any other person or entity of the right to protect the Confidential Information from public disclosure.
- 8.1.5 Standard of Care.** Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication, or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under this Agreement or its regulatory requirements.

8.1.6 Order of Disclosure. If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires any Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the disclosing Party with prompt notice of such request(s) or requirement(s) so that the disclosing Party may seek an appropriate protective order or waive compliance with the terms of this Agreement. Notwithstanding the absence of a protective order or waiver, the Party may disclose such Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance that confidential treatment will be accorded any Confidential Information so furnished.

8.1.7 Termination of Agreement. Upon termination of this Agreement for any reason, each Party shall, within ten (10) Business Days of receipt of a written request from the other Party, use Reasonable Efforts to destroy, erase, or delete (with such destruction, erasure, and deletion certified in writing to the requesting Party) or return to the requesting Party any and all written or electronic Confidential Information received from the requesting Party, except that each Party may keep one copy for archival purposes, provided that the obligation to treat it as Confidential Information in accordance with this Article 8 shall survive such termination.

8.1.8 Remedies. The Parties agree that monetary damages would be inadequate to compensate a Party for another Party's Breach of its obligations under this Article 8. Each Party accordingly agrees that the disclosing Party shall be entitled to equitable relief, by way of injunction or otherwise, if the receiving Party Breaches or threatens to Breach its obligations under this Article 8, which equitable relief shall be granted without bond or proof of damages, and the Breaching Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Article 8, but it shall be in

addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. No Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Article 8.

8.1.9 Disclosure to FERC, its Staff, or a State Regulatory Body.

Notwithstanding anything in this Article 8 to the contrary, and pursuant to 18 CFR 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from a Party that is otherwise required to be maintained in confidence pursuant to this Agreement, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information. In providing the information to FERC or its staff, the Party must, consistent with 18 CFR 388.112, request that the information be treated as confidential and non-public by FERC and its staff and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Parties to this Agreement prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Parties to the Agreement when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

8.1.10 Subject to the exception in Article 8.1.9, any information that a disclosing Party claims is competitively sensitive, commercial, or financial information under this Agreement shall not be disclosed by the receiving Party to any person not employed or retained by the receiving Party, except to the extent disclosure is (1) required by law; (2) reasonably deemed by the disclosing Party to be required to

be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (3) otherwise permitted by consent of the disclosing Party, such consent not to be unreasonably withheld; or (4) necessary to fulfill its obligations under this Agreement or as Transmission Provider or a balancing authority, including disclosing the Confidential Information to a regional or national reliability organization. The Party asserting confidentiality shall notify the receiving Party in writing of the information that Party claims is confidential. Prior to any disclosures of that Party's Confidential Information under this subparagraph, or if any non-Party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the Party that received the Confidential Information from the disclosing Party agrees to promptly notify the disclosing Party in writing and agrees to assert confidentiality and cooperate with the disclosing Party in seeking to protect the Confidential Information from public disclosure by confidentiality agreement, protective order, or other reasonable measures.

ARTICLE 9

INFORMATION ACCESS AND AUDIT RIGHTS

- 9.1 Information Access.** Each Party shall make available to the other Parties information necessary to verify the costs incurred by the other Parties for which the requesting Party is responsible under this Agreement and carry out obligations and responsibilities under this Agreement, provided that the Parties shall not use such information for purposes other than those set forth in this Article 9.1 and to enforce their rights under this Agreement.
- 9.2 Audit Rights.** Subject to the requirements of confidentiality under Article 8 of this Agreement, the accounts and records related to the design, engineering, procurement, and construction of the Affected System Network Upgrade(s) shall be subject to audit during the period of this Agreement and for a period of twenty-four (24) months following Transmission Provider's issuance of a final invoice in accordance with Article 4.4. Affected System Interconnection Customers may,

jointly or individually, at the expense of the requesting Party(ies), during normal business hours, and upon prior reasonable notice to Transmission Provider, audit such accounts and records. Any audit authorized by this Article 9.2 shall be performed at the offices where such accounts and records are maintained and shall be limited to those portions of such accounts and records that relate to obligations under this Agreement.

ARTICLE 10

NOTICES

10.1 General. Any notice, demand, or request required or permitted to be given by a Party to the other Parties, and any instrument required or permitted to be tendered or delivered by a Party in writing to another Party, may be so given, tendered, or delivered, as the case may be, by depositing the same with the United States Postal Service with postage prepaid, for transmission by certified or registered mail, addressed to the Parties, or personally delivered to the Parties, at the address set out below:

To Transmission Provider:

To Affected System Interconnection Customers:

10.2 Billings and Payments. Billings and payments shall be sent to the addresses shown in Article 10.1 unless otherwise agreed to by the Parties.

10.3 Alternative Forms of Notice. Any notice or request required or permitted to be given by a Party to the other Parties and not required by this Agreement to be given in writing may be so given by telephone, facsimile, or email to the telephone numbers and email addresses set out below:

To Transmission Provider:

To Affected System Interconnection Customers:

10.4 Execution and Filing. Affected System Interconnection Customers shall either: (i) execute two originals of this tendered Agreement and return them to Transmission Provider; or (ii) request in writing that Transmission Provider file with FERC this Agreement in unexecuted form. As soon as practicable, but not later than ten (10) Business Days after receiving either the two executed originals of this tendered Agreement (if it does not conform with a FERC-approved standard form of this Agreement) or the request to file this Agreement unexecuted, Transmission Provider shall file this Agreement with FERC, together with its explanation of any matters as to which Affected System Interconnection Customers and Transmission Provider disagree and support for the costs that Transmission Provider proposes to charge to Affected System Interconnection Customers under this Agreement. An unexecuted version of this Agreement should contain terms and conditions deemed appropriate by Transmission Provider for the Affected System Interconnection Customers' generating facilities. If the Parties agree to proceed with design, procurement, and construction of facilities and upgrades under the agreed-upon terms of the unexecuted version of this Agreement, they may proceed pending FERC action.

ARTICLE 11
MISCELLANEOUS

- 11.1** This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability, and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP.

{Signature Page to Follow}

IN WITNESS WHEREOF, the Parties have executed this Agreement in multiple originals, each of which shall constitute and be an original Agreement among the Parties.

Transmission Provider

{Transmission Provider}

By: _____

Name: _____

Title: _____

Affected System Interconnection Customer

{Affected System Interconnection Customer}

By: _____

Name: _____

Title: _____

Project No. _____

Affected System Interconnection Customer

{Affected System Interconnection Customer}

By: _____

Name: _____

Title: _____

Project No. _____

Attachment A to Appendix 12

Multiparty Affected System Facilities Construction Agreement

**AFFECTED SYSTEM NETWORK UPGRADE(S), COST ESTIMATES AND
RESPONSIBILITY, CONSTRUCTION SCHEDULE, AND MONTHLY
PAYMENT SCHEDULE**

This Appendix A is a part of the Multiparty Affected System Facilities Construction Agreement among Affected System Interconnection Customers and Transmission Provider.

1.1 Affected System Network Upgrade(s) to be installed by Transmission Provider.

{description}

1.2 First Equipment Order (including permitting).

{description}

1.2.1. Permitting and Land Rights – Transmission Provider Affected System Network Upgrade(s)

{description}

1.3 Construction Schedule. Where applicable, construction of the Affected System Network Upgrade(s) is scheduled as follows and will be periodically updated as necessary:

Table 3: Transmission Provider Construction Activities

MILESTONE NUMBER	DESCRIPTION	START DATE	END DATE

Note: Construction schedule assumes that Transmission Provider has obtained final authorizations and security from Affected System Interconnection Customers and all necessary permits from Governmental Authorities as necessary prerequisites to commence construction of any of the Affected System Network Upgrade(s).

1.4 Payment Schedule.

1.4.1 Timing of and Adjustments to Affected System Interconnection Customers' Payments and Security.

{description}

1.4.2 Monthly Payment Schedule. Affected System Interconnection Customers' payment schedule is as follows.

* Affected System Interconnection Customers' proportionate responsibility for each payment is as follows:

Affected System Interconnection Customer 1 ____._%

Affected System Interconnection Customer 2 ____._%

Affected System Interconnection Customer N ____._%

Note: Affected System Interconnection Customers' payment or provision of security as provided in this Agreement operates as a condition precedent to Transmission Provider's obligations to construct any Affected System Network Upgrade(s), and failure to meet this schedule will constitute a Breach pursuant to Article 5.1 of this Agreement.

1.5 Permits, Licenses, and Authorizations.

{description}

Attachment B to Appendix 12
Multiparty Affected System Facilities Construction Agreement

NOTIFICATION OF COMPLETED CONSTRUCTION

This Appendix B is a part of the Multiparty Affected System Facilities Construction Agreement among Affected System Interconnection Customers and Transmission Provider. Where applicable, when Transmission Provider has completed construction of the Affected System Network Upgrade(s), Transmission Provider shall send notice to Affected System Interconnection Customers in substantially the form following:

{Date}

{Affected System Interconnection Customers Addresses}

Re: Completion of Affected System Network Upgrade(s)

Dear {Name or Title}:

This letter is sent pursuant to the Multiparty Affected System Facilities Construction Agreement among {Transmission Provider} and {Affected System Interconnection Customers}, dated _____, 20__.

On {Date}, Transmission Provider completed to its satisfaction all work on the Affected System Network Upgrade(s) required to facilitate the safe and reliable interconnection and operation of Affected System Interconnection Customer's generating facilities. Transmission Provider confirms that the Affected System Network Upgrade(s) are in place.

Thank you.

{Signature}

{Transmission Provider Representative}

**Attachment C to Appendix 12
 Multiparty Affected System Facilities Construction Agreement**

EXHIBITS

This Appendix C is a part of the Multiparty Affected System Facilities Construction Agreement among Affected System Interconnection Customers and Transmission Provider.

**Exhibit A1
 Transmission Provider Site Map**

**Exhibit A2
 Site Plan**

**Exhibit A3
 Affected System Network Upgrade(s) Plan & Profile**

**Exhibit A4
 Estimated Cost of Affected System Network Upgrade(s)**

	Location	Facilities to Be Constructed by Transmission Provider	Estimate in Dollars

		Total:	
--	--	---------------	--

ATTACHMENT N

STANDARD LARGE GENERATOR

INTERCONNECTION AGREEMENT (LGIA)

TABLE OF CONTENTS

	Page
Recitals	1 -
Article 1. Definitions	2 -
Article 2. Effective Date, Term, and Termination	13 -
2.1 Effective Date.	13 -
2.2 Term of Agreement.	13 -
2.3 Termination Procedures.	13 -
2.3.1 Written Notice.	13 -
2.3.2 Default.	13 -
2.4 Termination Costs.	14 -
2.5 Disconnection.	15 -
2.6 Survival.....	15 -
Article 3. Regulatory Filings	16 -
3.1 Filing.	16 -
Article 4. Scope of Service	16 -
4.1 Interconnection Product Options.	16 -
4.1.1 Energy Resource Interconnection Service.....	16 -
4.1.2 Network Resource Interconnection Service.	18 -
4.2 Provision of Service.	20 -
4.3 Performance Standards.....	20 -
4.4 No Transmission Delivery Service.	21 -
4.5 Interconnection Customer Provided Services.	21 -
Article 5. Interconnection Facilities Engineering, Procurement, and Construction	21 -
5.1 Options.	21 -
5.1.1 Standard Option.....	21 -
5.1.2 Alternate Option.	22 -
5.1.3 Option to Build.....	22 -
5.1.4 Negotiated Option.	23 -
5.2 General Conditions Applicable to Option to Build.	23 -
5.3 Liquidated Damages.....	26 -
5.4 Power System Stabilizers.	27 -
5.5 Equipment Procurement.	27 -
5.6 Construction Commencement.	28 -

5.7 Work Progress.....- 28 -

5.8 Information Exchange.....- 29 -

5.9 Other Interconnection Options.- 29 -

 5.9.1 Limited Operation.- 29 -

 5.9.2 Provisional Interconnection Service.....- 29 -

5.10 Interconnection Customer's Interconnection Facilities ('ICIF').....- 30 -

 5.10.1 Interconnection Customer's Interconnection Facility Specifications.- 31 -

 5.10.2 Transmission Provider’s Review.- 31 -

 5.10.3 ICIF Construction.....- 31 -

5.11 Transmission Provider’s Interconnection Facilities Construction.- 32 -

5.12 Access Rights.....- 32 -

5.13 Lands of Other Property Owners.- 33 -

5.14 Permits.- 33 -

5.15 Early Construction of Base Case Facilities.- 33 -

5.16 Suspension.- 34 -

5.17 Taxes.- 34 -

 5.17.1 Interconnection Customer Payments Not Taxable.....- 34 -

 5.17.2 Representations and Covenants.- 35 -

 5.17.3 Indemnification for the Cost Consequences of Current Tax Liability
 Imposed Upon Transmission Provider.- 35 -

 5.17.4 Tax Gross-Up Amount.- 37 -

 5.17.5 Private Letter Ruling or Change or Clarification of Law.....- 38 -

 5.17.6 Subsequent Taxable Events.- 38 -

 5.17.7 Contests.....- 39 -

 5.17.8 Refund.....- 40 -

 5.17.9 Taxes Other Than Income Taxes.- 41 -

 5.17.10Transmission Owners Who Are Not Transmission Providers.
 - 42 -

5.18 Tax Status.- 42 -

5.19 Modification.....- 42 -

 5.19.1 General.....- 42 -

 5.19.2 Standards.....- 43 -

 5.19.3 Modification Costs.- 43 -

Article 6. Testing and Inspection- 44 -

 6.1 Pre-Commercial Operation Date Testing and Modifications.....- 44 -

 6.2 Post-Commercial Operation Date Testing and Modifications.- 44 -

 6.3 Right to Observe Testing.....- 44 -

 6.4 Right to Inspect.....- 44 -

Article 7. Metering.....- 45 -

7.1 General. - 45 -

7.2 Check Meters. - 45 -

7.3 Standards. - 46 -

7.4 Testing of Metering Equipment. - 46 -

7.5 Metering Data. - 46 -

Article 8. Communications..... - 47 -

8.1 Interconnection Customer Obligations. - 47 -

8.2 Remote Terminal Unit. - 47 -

8.3 No Annexation. - 48 -

8.4 Provision of Data from a Variable Energy Resource. - 48 -

Article 9. Operations - 49 -

9.1 General. - 49 -

9.2 Balancing Authority Area Notification. - 49 -

9.3 Transmission Provider Obligations. - 49 -

9.4 Interconnection Customer Obligations. - 49 -

9.5 Start-Up and Synchronization. - 50 -

9.6 Reactive Power and Primary Frequency Response. - 50 -

9.6.1 Power Factor Design Criteria. - 50 -

9.6.2 Voltage Schedules. - 51 -

9.6.3 Payment for Reactive Power. - 52 -

9.6.4 Primary Frequency Response. - 52 -

9.7 Outages and Interruptions. - 56 -

9.7.1 Outages. - 57 -

9.7.2 Interruption of Service. - 58 -

9.7.3 Ride Through Capability and Performance. - 59 -

9.7.4 System Protection and Other Control Requirements. - 60 -

9.7.5 Requirements for Protection. - 62 -

9.7.6 Power Quality. - 62 -

9.8 Switching and Tagging Rules. - 62 -

9.9 Use of Interconnection Facilities by Third Parties. - 63 -

9.9.1 Purpose of Interconnection Facilities. - 63 -

9.9.2 Third Party Users. - 63 -

9.10 Disturbance Analysis Data Exchange. - 63 -

Article 10. Maintenance..... - 64 -

10.1 Transmission Provider Obligations. - 64 -

10.2 Interconnection Customer Obligations. - 64 -

10.3 Coordination. - 64 -

10.4 Secondary Systems. - 64 -

10.5 Operating and Maintenance Expenses. - 65 -

Article 11. Performance Obligation- 65 -

11.1 Interconnection Customer Interconnection Facilities.- 65 -

11.2 Transmission Provider’s Interconnection Facilities.- 65 -

11.3 Network Upgrades and Distribution Upgrades.- 65 -

11.4 Transmission Credits.....- 65 -

 11.4.1 Repayment of Amounts Advanced for Network Upgrades.....- 66 -

 11.4.2 Special Provisions for Affected Systems.- 67 -

11.5 Provision of Security.....- 67 -

11.6 Interconnection Customer Compensation.- 69 -

 11.6.1 Interconnection Customer Compensation for Actions During
 Emergency Condition.- 69 -

Article 12. Invoice- 69 -

12.1 General.- 69 -

12.2 Final Invoice.- 70 -

12.3 Payment.- 70 -

12.4 Disputes.- 70 -

Article 13. Emergencies- 71 -

13.1 Definition.....- 71 -

13.2 Obligations.....- 71 -

13.3 Notice.- 71 -

13.4 Immediate Action.....- 72 -

13.5 Transmission Provider Authority.....- 72 -

 13.5.1 General.....- 72 -

 13.5.2 Reduction and Disconnection.- 73 -

13.6 Interconnection Customer Authority.- 73 -

13.7 Limited Liability.- 74 -

Article 14. Regulatory Requirements and Governing Law.....- 74 -

14.1 Regulatory Requirements.- 74 -

14.2 Governing Law.- 74 -

Article 15. Notices.- 75 -

15.1 General.- 75 -

15.2 Billings and Payments.- 75 -

15.3 Alternative Forms of Notice.- 75 -

15.4 Operations and Maintenance Notice.- 75 -

Article 16. Force Majeure.....- 75 -

16.1 Force Majeure.- 76 -

Article 17. Default - 76 -

 17.1 Default - 76 -

 17.1.1 General..... - 76 -

 17.1.2 Right to Terminate..... - 77 -

 17.2 Violation of Operating Assumptions for Generating Facilities..... - 77 -

Article 18. Indemnity, Consequential Damages and Insurance..... - 77 -

 18.1 Indemnity..... - 78 -

 18.1.1 Indemnified Person..... - 78 -

 18.1.2 Indemnifying Party..... - 78 -

 18.1.3 Indemnity Procedures. - 78 -

 18.2 Consequential Damages. - 79 -

 18.3 Insurance..... - 80 -

Article 19. Assignment..... - 83 -

 19.1 Assignment. - 83 -

Article 20. Severability - 83 -

 20.1 Severability. - 83 -

Article 21. Comparability - 84 -

 21.1 Comparability. - 84 -

Article 22. Confidentiality - 84 -

 22.1 Confidentiality. - 84 -

 22.1.1 Term..... - 84 -

 22.1.2 Scope..... - 85 -

 22.1.3 Release of Confidential Information. - 85 -

 22.1.4 Rights..... - 86 -

 22.1.5 No Warranties. - 86 -

 22.1.6 Standard of Care..... - 86 -

 22.1.7 Order of Disclosure. - 86 -

 22.1.8 Termination of Agreement..... - 87 -

 22.1.9 Remedies..... - 87 -

 22.1.10 Disclosure to FERC, its Staff, or a State. - 87 -

Article 23. Environmental Releases - 89 -

Article 24. Information Requirements - 89 -

 24.1 Information Acquisition. - 89 -

 24.2 Information Submission by Transmission Provider. - 89 -

 24.3 Updated Information Submission by Interconnection Customer. - 90 -

 24.4 Information Supplementation. - 90 -

Article 25. Information Access and Audit Rights.....- 91 -

25.1 Information Access.- 91 -

25.2 Reporting of Non-Force Majeure Events.- 92 -

25.3 Audit Rights.- 92 -

25.4 Audit Rights Periods.- 92 -

 25.4.1 Audit Rights Period for Construction-Related Accounts and
 Records.- 92 -

 25.4.2 Audit Rights Period for All Other Accounts and Records.- 93 -

25.5 Audit Results.....- 93 -

Article 26. Subcontractors- 93 -

26.1 General.- 93 -

26.2 Responsibility of Principal.- 93 -

26.3 No Limitation by Insurance.....- 94 -

Article 27. Disputes- 94 -

27.1 Submission.....- 94 -

27.2 External Arbitration Procedures.- 94 -

27.3 Arbitration Decisions.- 95 -

27.4 Costs.- 95 -

Article 28. Representations, Warranties, and Covenants- 95 -

28.1 General.- 96 -

 28.1.1 Good Standing.....- 96 -

 28.1.2 Authority.....- 96 -

 28.1.3 No Conflict.....- 96 -

 28.1.4 Consent and Approval.- 96 -

Article 29. Joint Operating Committee.....- 97 -

29.1 Joint Operating Committee.....- 97 -

Article 30. Miscellaneous- 98 -

30.1 Binding Effect.....- 98 -

30.2 Conflicts.....- 98 -

30.3 Rules of Interpretation.....- 98 -

30.4 Entire Agreement.- 99 -

30.5 No Third Party Beneficiaries.- 99 -

30.6 Waiver.- 100 -

30.7 Headings.- 100 -

30.8 Multiple Counterparts.- 100 -

30.9 Amendment.....- 100 -

30.10 Modification by the Parties.	- 100 -
30.11 Reservation of Rights.	- 100 -
30.12 No Partnership.	- 101 -

Appendix A – Interconnection Facilities, Network Upgrades, and Distribution Upgrades

Appendix B – Milestones

Appendix C – Interconnection Details

Appendix D – Security Arrangements Details

Appendix E – Commercial Operation Date

Appendix F – Addresses for Delivery of Notices and Billings

Appendix G – Interconnection Requirements for a Wind Generating Plant

Appendix H – Operating Assumptions for Generating Facility

STANDARD LARGE GENERATOR INTERCONNECTION AGREEMENT

THIS STANDARD LARGE GENERATOR INTERCONNECTION AGREEMENT (“Agreement”) is made and entered into this ____ day of _____ 20 __, by and between _____, a _____ organized and existing under the laws of the State/Commonwealth of _____ (“Interconnection Customer” with a Large Generating Facility), and _____, a _____ organized and existing under the laws of the State/Commonwealth of _____ (“Transmission Provider and/or Transmission Owner”). Interconnection Customer and Transmission Provider each may be referred to as a “Party” or collectively as the “Parties.”

Recitals

WHEREAS, Transmission Provider operates the Transmission System; and

WHEREAS, Interconnection Customer intends to own, lease and/or control and operate the Generating Facility identified as a Large Generating Facility in Appendix C to this Agreement; and,

WHEREAS, Interconnection Customer and Transmission Provider have agreed to enter into this Agreement for the purpose of interconnecting the Large Generating Facility with the Transmission System;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, it is agreed:

When used in this Standard Large Generator Interconnection Agreement, terms with initial capitalization that are not defined in Article 1 shall have the meanings specified in the Article in which they are used or the Open Access Transmission Tariff (Tariff).

Article 1. Definitions

Adverse System Impact shall mean the negative effects due to technical or operational limits on conductors or equipment being exceeded that may compromise the safety and reliability of the electric system.

Affected System shall mean an electric system other than Transmission Provider's Transmission System that may be affected by the proposed interconnection.

Affected System Operator shall mean the entity that operates an Affected System.

Affiliate shall mean, with respect to a corporation, partnership or other entity, each such other corporation, partnership or other entity that directly or indirectly, through one or more intermediaries, controls, is controlled by, or is under common control with, such corporation, partnership or other entity.

Ancillary Services shall mean those services that are necessary to support the transmission of capacity and energy from resources to loads while maintaining reliable operation of Transmission Provider's Transmission System in accordance with Good Utility Practice.

Applicable Laws and Regulations shall mean all duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Applicable Reliability Standards shall mean the requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Balancing Authority shall mean an entity that integrates resource plans ahead of time, maintains demand and resource balance within a Balancing Authority Area, and supports interconnection frequency in real time.

Balancing Authority Area shall mean the collection of generation, transmission, and loads within the metered boundaries of the Balancing Authority. The Balancing Authority maintains load-resource balance within this area.

Base Case shall mean the base case power flow, short circuit, and stability data bases used for the Interconnection Studies by Transmission Provider or Interconnection Customer.

Breach shall mean the failure of a Party to perform or observe any material term or condition of the Standard Large Generator Interconnection Agreement.

Breaching Party shall mean a Party that is in Breach of the Standard Large Generator Interconnection Agreement.

Business Day shall mean Monday through Friday, excluding Federal Holidays.

Calendar Day shall mean any day including Saturday, Sunday or a Federal Holiday.

Cluster shall mean a group of one or more Interconnection Requests that are studied together for the purpose of conducting a Cluster Study.

Cluster Restudy shall mean a restudy of a Cluster Study conducted pursuant to Section 7.5 of the LGIP.

Cluster Study shall mean the evaluation of one or more Interconnection Requests within a Cluster as described in Section 7 of the LGIP.

Clustering shall mean the process whereby one or more Interconnection Requests are studied together, instead of serially, as described in Section 7 of the LGIP.

Commercial Operation shall mean the status of a Generating Facility that has commenced generating electricity for sale, excluding electricity generated during Trial Operation.

Commercial Operation Date of a unit shall mean the date on which the Generating Facility commences Commercial Operation as agreed to by the Parties pursuant to Appendix E to the Standard Large Generator Interconnection Agreement.

Confidential Information shall mean any confidential, proprietary or trade secret information of a plan, specification, pattern, procedure, design, device, list, concept, policy or compilation relating to the present or planned business of a Party, which is designated as confidential by the Party supplying the information, whether conveyed orally, electronically, in writing, through inspection, or otherwise.

Contingent Facilities shall mean those unbuilt Interconnection Facilities and Network Upgrades upon which the Interconnection Request's costs, timing, and study findings are dependent, and if delayed or not built, could cause a need for restudies of the Interconnection Request or a reassessment of the Interconnection Facilities and/or Network Upgrades and/or costs and timing.

Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 17 of the Standard Large Generator Interconnection Agreement.

Dispute Resolution shall mean the procedure for resolution of a dispute between the Parties in which they will first attempt to resolve the dispute on an informal basis.

Distribution System shall mean Transmission Provider's facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which distribution systems operate differ among areas.

Distribution Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Generating Facility and render the transmission service necessary to effect Interconnection Customer's wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Effective Date shall mean the date on which the Standard Large Generator Interconnection Agreement becomes effective upon execution by the Parties subject to acceptance by FERC, or if filed unexecuted, upon the date specified by FERC.

Electric Reliability Organization shall mean the North American Electric Reliability Corporation (NERC) or its successor organization.

Emergency Condition shall mean a condition or situation: (1) that in the judgment of the Party making the claim is imminently likely to endanger life or property;

or (2) that, in the case of a Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to Transmission Provider's Transmission System, Transmission Provider's Interconnection Facilities or the electric systems of others to which Transmission Provider's Transmission System is directly connected; or (3) that, in the case of Interconnection Customer, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Generating Facility or Interconnection Customer's Interconnection Facilities. System restoration and black start shall be considered Emergency Conditions; provided, that Interconnection Customer is not obligated by the Standard Large Generator Interconnection Agreement to possess black start capability.

Energy Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to connect its Generating Facility to Transmission Provider's Transmission System to be eligible to deliver the Generating Facility's electric output using the existing firm or nonfirm capacity of Transmission Provider's Transmission System on an as available basis. Energy Resource Interconnection Service in and of itself does not convey transmission service.

Engineering & Procurement (E&P) Agreement shall mean an agreement that authorizes Transmission Provider to begin engineering and procurement of long lead-time items necessary for the establishment of the interconnection in order to advance the implementation of the Interconnection Request.

Environmental Law shall mean Applicable Laws or Regulations relating to pollution or protection of the environment or natural resources.

Federal Power Act shall mean the Federal Power Act, as amended, 16 U.S.C. §§ 791a et seq.

FERC shall mean the Federal Energy Regulatory Commission (Commission) or its successor.

Force Majeure shall mean any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, breakage or accident to machinery or equipment, any order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, or any other cause beyond a Party's control. A Force Majeure event does not include acts of negligence or intentional wrongdoing by the Party claiming Force Majeure.

Generating Facility shall mean Interconnection Customer's devices for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer's Interconnection Facilities.

Generating Facility Capacity shall mean the net capacity of the Generating Facility or the aggregate net capacity of the Generating Facility where it includes more than one device for the production and/or storage for later injection of electricity.

Good Utility Practice shall mean any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Governmental Authority shall mean any federal, state, local or other governmental regulatory or administrative agency, court, commission, department, board, or other governmental subdivision, legislature, rulemaking board, tribunal, or other governmental authority having jurisdiction over the Parties, their respective facilities, or the respective services they provide, and exercising or entitled to exercise any administrative, executive, police, or taxing authority or power; provided, however, that such term does not include Interconnection Customer, Transmission Provider, or any Affiliate thereof.

Hazardous Substances shall mean any chemicals, materials or substances defined as or included in the definition of "hazardous substances," "hazardous wastes," "hazardous materials," "hazardous constituents," "restricted hazardous materials," "extremely hazardous substances," "toxic substances," "radioactive substances," "contaminants," "pollutants," "toxic pollutants" or words of similar meaning and regulatory effect under any applicable Environmental Law, or any other chemical, material or substance, exposure to which is prohibited, limited or regulated by any applicable Environmental Law.

Initial Synchronization Date shall mean the date upon which the Generating Facility is initially synchronized and upon which Trial Operation begins.

In-Service Date shall mean the date upon which Interconnection Customer reasonably expects it will be ready to begin use of Transmission Provider's Interconnection Facilities to obtain back feed power.

Interconnection Customer shall mean any entity, including Transmission Provider, Transmission Owner or any of the Affiliates or subsidiaries of either, that proposes to interconnect its Generating Facility with Transmission Provider's Transmission System.

Interconnection Customer's Interconnection Facilities shall mean all facilities and equipment, as identified in Appendix A of the Standard Large Generator Interconnection Agreement, that are located between the Generating Facility and the Point of Change of Ownership, including any modification, addition, or upgrades to such facilities and equipment necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Customer's Interconnection Facilities are sole use facilities.

Interconnection Facilities shall mean Transmission Provider's Interconnection Facilities and Interconnection Customer's Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Interconnection Facilities Study shall mean a study conducted by Transmission Provider or a third party consultant for Interconnection Customer to determine a list of facilities (including Transmission Provider's Interconnection Facilities and Network Upgrades as identified in the Cluster Study), the cost of those facilities, and the time required to interconnect the Generating Facility with Transmission Provider's Transmission System. The scope of the study is defined in Section 8 of the LGIP.

Interconnection Facilities Study Agreement shall mean the form of agreement contained in Appendix 3 of the Standard Large Generator Interconnection Procedures for conducting the Interconnection Facilities Study.

Interconnection Request shall mean an Interconnection Customer's request, in the form of Appendix 1 to the LGIP, in accordance with the Tariff, to interconnect a new Generating Facility, or to increase the capacity of, or make a Material Modification to the

operating characteristics of, an existing Generating Facility that is interconnected with Transmission Provider's Transmission System.

Interconnection Service shall mean the service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling it to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Standard Large Generator Interconnection Agreement and, if applicable, Transmission Provider's Tariff.

Interconnection Study shall mean any of the following studies: the Cluster Study, the Cluster Restudy, the Surplus Interconnection Service Study, the Interconnection Facilities Study, the Affected System Study, Optional Interconnection Study, and Material Modification assessment, described in the LGIP.

IRS shall mean the Internal Revenue Service.

Joint Operating Committee shall be a group made up of representatives from Interconnection Customers and Transmission Provider to coordinate operating and technical considerations of Interconnection Service.

Large Generating Facility shall mean a Generating Facility having a Generating Facility Capacity of more than 20 MW.

LGIA Deposit shall mean the deposit Interconnection Customer submits when returning the executed LGIA, or within ten (10) Business Days of requesting that the LGIA be filed unexecuted at the Commission, in accordance with Section 11.3 of the LGIP.

Loss shall mean any and all losses relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's performance, or non-performance of its obligations under the Standard Large Generator Interconnection Agreement on behalf of the Indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the Indemnifying Party.

Material Modification shall mean those modifications that have a material impact on the cost or timing of any Interconnection Request with an equal or later Queue Position.

Metering Equipment shall mean all metering equipment installed or to be installed at the Generating Facility pursuant to the Standard Large Generator Interconnection Agreement at the metering points, including but not limited to instrument

transformers, MWh-meters, data acquisition equipment, transducers, remote terminal unit, communications equipment, phone lines, and fiber optics.

Network Resource shall mean any designated generating resource owned, purchased, or leased by a Network Customer under the Network Integration Transmission Service Tariff. Network Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Network Customer's Network Load on a non-interruptible basis.

Network Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to integrate its Large Generating Facility with Transmission Provider's Transmission System (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an RTO or ISO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service in and of itself does not convey transmission service.

Network Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Transmission System required at or beyond the point at which the Interconnection Facilities connect to Transmission Provider's Transmission System to accommodate the interconnection of the Large Generating Facility to Transmission Provider's Transmission System.

Notice of Dispute shall mean a written notice of a dispute or claim that arises out of or in connection with the Standard Large Generator Interconnection Agreement or its performance.

Optional Interconnection Study shall mean a sensitivity analysis based on assumptions specified by Interconnection Customer in the Optional Interconnection Study Agreement.

Optional Interconnection Study Agreement shall mean the form of agreement contained in Appendix 4 of the LGIP for conducting the Optional Interconnection Study.

Party or Parties shall mean Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Point of Change of Ownership shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where Interconnection Customer's Interconnection Facilities connect to Transmission Provider's Interconnection Facilities.

Point of Interconnection shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where the Interconnection Facilities connect to Transmission Provider's Transmission System.

Proportional Impact Method shall mean a technical analysis conducted by Transmission Provider to determine the degree to which each Generating Facility in the Cluster Study contributes to the need for a specific System Network Upgrade.

Provisional Interconnection Service shall mean Interconnection Service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling that Transmission System to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Provisional Large Generator Interconnection Agreement and, if applicable, the Tariff.

Provisional Large Generator Interconnection Agreement shall mean the interconnection agreement for Provisional Interconnection Service established between Transmission Provider and/or the Transmission Owner and Interconnection Customer. This agreement shall take the form of the Standard Large Generator Interconnection Agreement, modified for provisional purposes.

Queue Position shall mean the order of a valid Interconnection Request, relative to all other pending valid Interconnection Requests, established pursuant to Section 4.1 of this LGIP.

Reasonable Efforts shall mean, with respect to an action required to be attempted or taken by a Party under the Standard Large Generator Interconnection Agreement, efforts that are timely and consistent with Good Utility Practice and are otherwise substantially equivalent to those a Party would use to protect its own interests.

Scoping Meeting shall mean the meeting between representatives of Interconnection Customer(s) and Transmission Provider conducted for the purpose of discussing the proposed Interconnection Request and any alternative interconnection options, exchanging information including any transmission data and earlier study evaluations that would be reasonably expected to impact such interconnection options, refining information and models provided by Interconnection Customer(s), discussing the Cluster Study materials posted to OASIS pursuant to Section 3.5 of the LGIP, and analyzing such information.

Site Control shall mean the exclusive land right to develop, construct, operate, and maintain the Generating Facility over the term of expected operation of the Generating Facility. Site Control may be demonstrated by documentation establishing:

(1) ownership of, a leasehold interest in, or a right to develop a site of sufficient size to construct and operate the Generating Facility; (2) an option to purchase or acquire a leasehold site of sufficient size to construct and operate the Generating Facility for such purpose; or (3) any other documentation that clearly demonstrates the right of Interconnection Customer to exclusively occupy a site of sufficient size to construct and operate the Generating Facility. Transmission Provider will maintain acreage requirements for each Generating Facility type on its OASIS or public website.

Small Generating Facility shall mean a Generating Facility that has a Generating Facility Capacity of no more than 20 MW.

Stand Alone Network Upgrades shall mean Network Upgrades that are not part of an Affected System that an Interconnection Customer may construct without affecting day-to-day operations of the Transmission System during their construction. Both Transmission Provider and Interconnection Customer must agree as to what constitutes Stand Alone Network Upgrades and identify them in Appendix A to the Standard Large Generator Interconnection Agreement. If Transmission Provider and Interconnection Customer disagree about whether a particular Network Upgrade is a Stand Alone Network Upgrade, Transmission Provider must provide Interconnection Customer a written technical explanation outlining why Transmission Provider does not consider the Network Upgrade to be a Stand Alone Network Upgrade within fifteen (15) Business Days of its determination.

Standard Large Generator Interconnection Agreement (LGIA) shall mean the form of interconnection agreement applicable to an Interconnection Request pertaining to a Large Generating Facility that is included in Transmission Provider's Tariff.

Standard Large Generator Interconnection Procedures (LGIP) shall mean the interconnection procedures applicable to an Interconnection Request pertaining to a Large Generating Facility that are included in Transmission Provider's Tariff.

Substation Network Upgrades shall mean Network Upgrades that are required at the substation located at the Point of Interconnection.

Surplus Interconnection Service shall mean any unneeded portion of Interconnection Service established in a Standard Large Generator Interconnection Agreement, such that if Surplus Interconnection Service is utilized the total amount of Interconnection Service at the Point of Interconnection would remain the same.

System Network Upgrades shall mean Network Upgrades that are required beyond the substation located at the Point of Interconnection.

System Protection Facilities shall mean the equipment, including necessary protection signal communications equipment, required to protect (1) Transmission Provider's Transmission System from faults or other electrical disturbances occurring at the Generating Facility and (2) the Generating Facility from faults or other electrical system disturbances occurring on Transmission Provider's Transmission System or on other delivery systems or other generating systems to which Transmission Provider's Transmission System is directly connected.

Tariff shall mean Transmission Provider's Tariff through which open access transmission service and Interconnection Service are offered, as filed with FERC, and as amended or supplemented from time to time, or any successor tariff.

Transmission Owner shall mean an entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Standard Large Generator Interconnection Agreement to the extent necessary.

Transmission Provider shall mean the public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission Provider's Interconnection Facilities shall mean all facilities and equipment owned, controlled, or operated by Transmission Provider from the Point of Change of Ownership to the Point of Interconnection as identified in Appendix A to the Standard Large Generator Interconnection Agreement, including any modifications, additions or upgrades to such facilities and equipment. Transmission Provider's Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Transmission System shall mean the facilities owned, controlled or operated by Transmission Provider or Transmission Owner that are used to provide transmission service under the Tariff.

Trial Operation shall mean the period during which Interconnection Customer is engaged in on-site test operations and commissioning of the Generating Facility prior to Commercial Operation.

Variable Energy Resource shall mean a device for the production of electricity that is characterized by an energy source that: (1) is renewable; (2) cannot be stored by

the facility owner or operator; and (3) has variability that is beyond the control of the facility owner or operator.

Withdrawal Penalty shall mean the penalty assessed by Transmission Provider to an Interconnection Customer that chooses to withdraw or is deemed withdrawn from Transmission Provider's interconnection queue or whose Generating Facility does not otherwise reach Commercial Operation. The calculation of the Withdrawal Penalty is set forth in Section 3.7.1 of the LGIP.

Article 2. Effective Date, Term, and Termination

2.1 **Effective Date.** This LGIA shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by FERC. Transmission Provider shall promptly file this LGIA with FERC upon execution in accordance with Article 3.1, if required.

2.2 **Term of Agreement.** Subject to the provisions of Article 2.3, this LGIA shall remain in effect for a period of ten (10) years from the Effective Date or such other longer period as Interconnection Customer may request (Term to be specified in individual agreements) and shall be automatically renewed for each successive one-year period thereafter.

2.3 Termination Procedures.

2.3.1 **Written Notice.** This LGIA may be terminated by Interconnection Customer after giving Transmission Provider ninety (90) Calendar Days advance written notice, or by Transmission Provider notifying FERC after the Generating Facility permanently ceases Commercial Operation.

2.3.2 **Default.** Either Party may terminate this LGIA in accordance with Article 17.

- 2.3.3** Notwithstanding Articles 2.3.1 and 2.3.2, no termination shall become effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination, including the filing with FERC of a notice of termination of this LGIA, which notice has been accepted for filing by FERC.
- 2.4** Termination Costs. If a Party elects to terminate this Agreement pursuant to Article 2.3 above, each Party shall pay all costs incurred (including any cancellation costs relating to orders or contracts for Interconnection Facilities and equipment) or charges assessed by the other Party, as of the date of the other Party's receipt of such notice of termination, that are the responsibility of the Terminating Party under this LGIA. In the event of termination by a Party, the Parties shall use commercially Reasonable Efforts to mitigate the costs, damages and charges arising as a consequence of termination. Upon termination of this LGIA, unless otherwise ordered or approved by FERC:
- 2.4.1** With respect to any portion of Transmission Provider's Interconnection Facilities that have not yet been constructed or installed, Transmission Provider shall to the extent possible and with Interconnection Customer's authorization cancel any pending orders of, or return, any materials or equipment for, or contracts for construction of, such facilities; provided that in the event Interconnection Customer elects not to authorize such cancellation, Interconnection Customer shall assume all payment obligations with respect to such materials, equipment, and contracts, and Transmission Provider shall deliver such material and equipment, and, if necessary, assign such contracts, to Interconnection Customer as soon as practicable, at Interconnection Customer's expense. To the extent that Interconnection Customer has already paid Transmission Provider for any or all such costs of materials or equipment not taken by Interconnection Customer, Transmission Provider shall promptly refund such amounts to Interconnection Customer, less any costs, including penalties incurred by Transmission Provider to cancel any pending orders of or return such materials, equipment, or contracts.

If an Interconnection Customer terminates this LGIA, it shall be responsible for all costs incurred in association with that Interconnection Customer's interconnection, including any cancellation costs relating to orders or contracts for Interconnection Facilities and equipment, and other expenses including any Network Upgrades for which Transmission Provider has incurred expenses and has not been reimbursed by Interconnection Customer.

- 2.4.2** Transmission Provider may, at its option, retain any portion of such materials, equipment, or facilities that Interconnection Customer chooses not to accept delivery of, in which case Transmission Provider shall be responsible for all costs associated with procuring such materials, equipment, or facilities.
- 2.4.3** With respect to any portion of the Interconnection Facilities, and any other facilities already installed or constructed pursuant to the terms of this LGIA, Interconnection Customer shall be responsible for all costs associated with the removal, relocation or other disposition or retirement of such materials, equipment, or facilities.
- 2.5** Disconnection. Upon termination of this LGIA, the Parties will take all appropriate steps to disconnect the Large Generating Facility from the Transmission System. All costs required to effectuate such disconnection shall be borne by the terminating Party, unless such termination resulted from the non-terminating Party's Default of this LGIA or such non-terminating Party otherwise is responsible for these costs under this LGIA.
- 2.6** Survival. This LGIA shall continue in effect after termination to the extent necessary to provide for final billings and payments and for costs incurred hereunder, including billings and payments pursuant to this LGIA; to permit the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this LGIA was in effect; and to permit each Party to have access to the lands of the other Party pursuant to this LGIA or

other applicable agreements, to disconnect, remove or salvage its own facilities and equipment.

Article 3. Regulatory Filings

- 3.1 **Filing.** Transmission Provider shall file this LGIA (and any amendment hereto) with the appropriate Governmental Authority, if required. Interconnection Customer may request that any information so provided be subject to the confidentiality provisions of Article 22. If Interconnection Customer has executed this LGIA, or any amendment thereto, Interconnection Customer shall reasonably cooperate with Transmission Provider with respect to such filing and to provide any information reasonably requested by Transmission Provider needed to comply with applicable regulatory requirements.

Article 4. Scope of Service

- 4.1 **Interconnection Product Options.** Interconnection Customer has selected the following (checked) type of Interconnection Service:

4.1.1 Energy Resource Interconnection Service.

- 4.1.1.1 **The Product.** Energy Resource Interconnection Service allows Interconnection Customer to connect the Large Generating Facility to the Transmission System and be eligible to deliver the Large Generating Facility's output using the existing firm or non-firm capacity of the Transmission System on an "as available" basis. To the extent Interconnection Customer wants to receive Energy Resource Interconnection Service, Transmission Provider shall construct facilities identified in Attachment A.

4.1.1.2 Transmission Delivery Service Implications.

Under Energy Resource Interconnection Service, Interconnection Customer will be eligible to inject power from the Large Generating Facility into and deliver power across the interconnecting Transmission Provider's Transmission System on an "as available" basis up to the amount of MWs identified in the applicable stability and steady state studies to the extent the upgrades initially required to qualify for Energy Resource Interconnection Service have been constructed. Where eligible to do so (e.g., PJM, ISO-NE, NYISO), Interconnection Customer may place a bid to sell into the market up to the maximum identified Large Generating Facility output, subject to any conditions specified in the interconnection service approval, and the Large Generating Facility will be dispatched to the extent Interconnection Customer's bid clears. In all other instances, no transmission delivery service from the Large Generating Facility is assured, but Interconnection Customer may obtain Point-to-Point Transmission Service, Network Integration Transmission Service, or be used for secondary network transmission service, pursuant to Transmission Provider's Tariff, up to the maximum output identified in the stability and steady state studies. In those instances, in order for Interconnection Customer to obtain the right to deliver or inject energy beyond the Large Generating Facility Point of Interconnection or to improve its ability to do so, transmission delivery service must be obtained pursuant to the provisions of Transmission Provider's Tariff. Interconnection Customer's ability to inject its Large Generating Facility output beyond the Point of Interconnection, therefore, will depend on the existing capacity of Transmission Provider's Transmission System at such time as a transmission service request is made that would accommodate such delivery. The provision of firm Point-to-Point Transmission Service or Network Integration Transmission Service may require the construction of additional Network Upgrades.

4.1.2 Network Resource Interconnection Service.

4.1.2.1 The Product. Transmission Provider must conduct the necessary studies and construct the Network Upgrades needed to integrate the Large Generating Facility (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an ISO or RTO with market based congestion management, in the same manner as all Network Resources. To the extent Interconnection Customer wants to receive Network Resource Interconnection Service, Transmission Provider shall construct the facilities identified in Attachment A to this LGIA.

4.1.2.2 Transmission Delivery Service Implications. Network Resource Interconnection Service allows Interconnection Customer's Large Generating Facility to be designated by any Network Customer under the Tariff on Transmission Provider's Transmission System as a Network Resource, up to the Large Generating Facility's full output, on the same basis as existing Network Resources interconnected to Transmission Provider's Transmission System, and to be studied as a Network Resource on the assumption that such a designation will occur. Although Network Resource Interconnection Service does not convey a reservation of transmission service, any Network Customer under the Tariff can utilize its network service under the Tariff to obtain delivery of energy from the interconnected Interconnection Customer's Large Generating Facility in the same manner as it accesses Network Resources. A Large Generating Facility receiving Network Resource Interconnection Service may also be used to provide Ancillary Services after technical studies and/or periodic analyses are performed with respect to the Large Generating Facility's ability to provide any applicable Ancillary Services, provided that such studies and

analyses have been or would be required in connection with the provision of such Ancillary Services by any existing Network Resource. However, if an Interconnection Customer's Large Generating Facility has not been designated as a Network Resource by any load, it cannot be required to provide Ancillary Services except to the extent such requirements extend to all generating facilities that are similarly situated. The provision of Network Integration Transmission Service or firm Point-to-Point Transmission Service may require additional studies and the construction of additional upgrades. Because such studies and upgrades would be associated with a request for delivery service under the Tariff, cost responsibility for the studies and upgrades would be in accordance with FERC's policy for pricing transmission delivery services.

Network Resource Interconnection Service does not necessarily provide Interconnection Customer with the capability to physically deliver the output of its Large Generating Facility to any particular load on Transmission Provider's Transmission System without incurring congestion costs. In the event of transmission constraints on Transmission Provider's Transmission System, Interconnection Customer's Large Generating Facility shall be subject to the applicable congestion management procedures in Transmission Provider's Transmission System in the same manner as Network Resources.

There is no requirement either at the time of study or interconnection, or at any point in the future, that Interconnection Customer's Large Generating Facility be designated as a Network Resource by a Network Service Customer under the Tariff or that Interconnection Customer identify a specific buyer (or sink). To the extent a Network Customer does designate the Large Generating Facility as a

Network Resource, it must do so pursuant to Transmission Provider's Tariff.

Once an Interconnection Customer satisfies the requirements for obtaining Network Resource Interconnection Service, any future transmission service request for delivery from the Large Generating Facility within Transmission Provider's Transmission System of any amount of capacity and/or energy, up to the amount initially studied, will not require that any additional studies be performed or that any further upgrades associated with such Large Generating Facility be undertaken, regardless of whether or not such Large Generating Facility is ever designated by a Network Customer as a Network Resource and regardless of changes in ownership of the Large Generating Facility. However, the reduction or elimination of congestion or redispatch costs may require additional studies and the construction of additional upgrades.

To the extent Interconnection Customer enters into an arrangement for long term transmission service for deliveries from the Large Generating Facility outside Transmission Provider's Transmission System, such request may require additional studies and upgrades in order for Transmission Provider to grant such request.

- 4.2 Provision of Service. Transmission Provider shall provide Interconnection Service for the Large Generating Facility at the Point of Interconnection.
- 4.3 Performance Standards. Each Party shall perform all of its obligations under this LGIA in accordance with Applicable Laws and Regulations, Applicable Reliability Standards, and Good Utility Practice, and to the extent a Party is required or prevented or limited in taking any action by such regulations and standards, such Party shall not be deemed to be in Breach of this LGIA for its

compliance therewith. If such Party is a Transmission Provider or Transmission Owner, then that Party shall amend the LGIA and submit the amendment to FERC for approval.

- 4.4 No Transmission Delivery Service. The execution of this LGIA does not constitute a request for, nor the provision of, any transmission delivery service under Transmission Provider's Tariff, and does not convey any right to deliver electricity to any specific customer or Point of Delivery.
- 4.5 Interconnection Customer Provided Services. The services provided by Interconnection Customer under this LGIA are set forth in Article 9.6 and Article 13.5.1. Interconnection Customer shall be paid for such services in accordance with Article 11.6.

Article 5. Interconnection Facilities Engineering, Procurement, and Construction

- 5.1 Options. Unless otherwise mutually agreed to between the Parties, Interconnection Customer shall select the In-Service Date, Initial Synchronization Date, and Commercial Operation Date; and either the Standard Option or Alternate Option set forth below, and such dates and selected option shall be set forth in Appendix B, Milestones. At the same time, Interconnection Customer shall indicate whether it elects to exercise the Option to Build set forth in Article 5.1.3 below. If the dates designated by Interconnection Customer are not acceptable to Transmission Provider, Transmission Provider shall so notify Interconnection Customer within thirty (30) Calendar Days. Upon receipt of the notification that Interconnection Customer's designated dates are not acceptable to Transmission Provider, Interconnection Customer shall notify Transmission Provider within thirty (30) Calendar Days whether it elects to exercise the Option to Build if it has not already elected to exercise the Option to Build.

- 5.1.1 Standard Option. Transmission Provider shall design, procure, and construct Transmission Provider's Interconnection Facilities and Network

Upgrades, using Reasonable Efforts to complete Transmission Provider's Interconnection Facilities and Network Upgrades by the dates set forth in Appendix B, Milestones. Transmission Provider shall not be required to undertake any action which is inconsistent with its standard safety practices, its material and equipment specifications, its design criteria and construction procedures, its labor agreements, and Applicable Laws and Regulations. In the event Transmission Provider reasonably expects that it will not be able to complete Transmission Provider's Interconnection Facilities and Network Upgrades by the specified dates, Transmission Provider shall promptly provide written notice to Interconnection Customer and shall undertake Reasonable Efforts to meet the earliest dates thereafter.

- 5.1.2 Alternate Option. If the dates designated by Interconnection Customer are acceptable to Transmission Provider, Transmission Provider shall so notify Interconnection Customer within thirty (30) Calendar Days, and shall assume responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities by the designated dates.

If Transmission Provider subsequently fails to complete Transmission Provider's Interconnection Facilities by the In-Service Date, to the extent necessary to provide back feed power; or fails to complete Network Upgrades by the Initial Synchronization Date to the extent necessary to allow for Trial Operation at full power output, unless other arrangements are made by the Parties for such Trial Operation; or fails to complete the Network Upgrades by the Commercial Operation Date, as such dates are reflected in Appendix B, Milestones; Transmission Provider shall pay Interconnection Customer liquidated damages in accordance with Article 5.3, Liquidated Damages, provided, however, the dates designated by Interconnection Customer shall be extended day for day for each day that the applicable RTO or ISO refuses to grant clearances to install equipment.

- 5.1.3 Option to Build. Individual or Multiple Interconnection Customer shall have the option to assume responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades on the dates specified in Article 5.1.2, if

the requirements of this Article 5.1.3 are met. When multiple Interconnection Customers exercise this option, multiple Interconnection Customers may agree to exercise this option provided (1) all Transmission Provider's Interconnection Facilities and Stand Alone Network upgrades constructed under this option are only required for Interconnection Customers in a single Cluster and (2) all impacted Interconnection Customers execute and provide to Transmission Provider an agreement regarding responsibilities and payment for the construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades planned to be built under this option. Transmission Provider and the individual Interconnection Customer or each of the multiple Interconnection Customers must agree as to what constitutes Stand Alone Network Upgrades and identify such Stand Alone Network Upgrades in Appendix A. Except for Stand Alone Network Upgrades, Interconnection Customer shall have no right to construct Network Upgrades under this option.

5.1.4 Negotiated Option. If the dates designated by Interconnection Customer are not acceptable to Transmission Provider, the Parties shall in good faith attempt to negotiate terms and conditions (including revision of the specified dates and liquidated damages, the provision of incentives, or the procurement and construction of all facilities other than Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades if Interconnection Customer elects to exercise the Option to Build under Article 5.1.3). If the Parties are unable to reach agreement on such terms and conditions, then pursuant to Article 5.1.1 (Standard Option), Transmission Provider shall assume responsibility for the design, procurement and construction of all facilities other than Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades if Interconnection Customer elects to exercise the Option to Build.

5.2 General Conditions Applicable to Option to Build. If Interconnection Customer assumes responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades,

(1) Interconnection Customer shall engineer, procure equipment, and construct Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades (or portions thereof) using Good Utility Practice and using standards and specifications provided in advance by Transmission Provider;

(2) Interconnection Customer's engineering, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades shall comply with all requirements of law to which Transmission Provider would be subject in the engineering, procurement or construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades;

(3) Transmission Provider shall review and approve the engineering design, equipment acceptance tests, and the construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades;

(4) prior to commencement of construction, Interconnection Customer shall provide to Transmission Provider a schedule for construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades, and shall promptly respond to requests for information from Transmission Provider;

(5) at any time during construction, Transmission Provider shall have the right to gain unrestricted access to Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades and to conduct inspections of the same;

(6) at any time during construction, should any phase of the engineering, equipment procurement, or construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades not meet the standards and specifications provided by Transmission Provider, Interconnection Customer shall be obligated to remedy deficiencies in that

portion of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades;

(7) Interconnection Customer shall indemnify Transmission Provider for claims arising from Interconnection Customer's construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades under the terms and procedures applicable to Article 18.1 Indemnity;

(8) Interconnection Customer shall transfer control of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades to Transmission Provider;

(9) Unless Parties otherwise agree, Interconnection Customer shall transfer ownership of Transmission Provider's Interconnection Facilities and Stand-Alone Network Upgrades to Transmission Provider;

(10) Transmission Provider shall approve and accept for operation and maintenance Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades to the extent engineered, procured, and constructed in accordance with this Article 5.2; and

(11) Interconnection Customer shall deliver to Transmission Provider "as-built" drawings, information, and any other documents that are reasonably required by Transmission Provider to assure that the Interconnection Facilities and Stand-Alone Network Upgrades are built to the standards and specifications required by Transmission Provider.

(12) If Interconnection Customer exercises the Option to Build pursuant to Article 5.1.3, Interconnection Customer shall pay Transmission Provider the agreed upon amount of {\$ PLACEHOLDER} for Transmission Provider to execute the responsibilities enumerated to Transmission

Provider under Article 5.2. Transmission Provider shall invoice Interconnection Customer for this total amount to be divided on a monthly basis pursuant to Article 12.

- 5.3 Liquidated Damages. The actual damages to Interconnection Customer, in the event Transmission Provider's Interconnection Facilities or Network Upgrades are not completed by the dates designated by Interconnection Customer and accepted by Transmission Provider pursuant to subparagraphs 5.1.2 or 5.1.4, above, may include Interconnection Customer's fixed operation and maintenance costs and lost opportunity costs. Such actual damages are uncertain and impossible to determine at this time. Because of such uncertainty, any liquidated damages paid by Transmission Provider to Interconnection Customer in the event that Transmission Provider does not complete any portion of Transmission Provider's Interconnection Facilities or Network Upgrades by the applicable dates, shall be an amount equal to $\frac{1}{2}$ of 1 percent per day of the actual cost of Transmission Provider's Interconnection Facilities and Network Upgrades, in the aggregate, for which Transmission Provider has assumed responsibility to design, procure and construct.

However, in no event shall the total liquidated damages exceed 20 percent of the actual cost of Transmission Provider's Interconnection Facilities and Network Upgrades for which Transmission Provider has assumed responsibility to design, procure, and construct. The foregoing payments will be made by Transmission Provider to Interconnection Customer as just compensation for the damages caused to Interconnection Customer, which actual damages are uncertain and impossible to determine at this time, and as reasonable liquidated damages, but not as a penalty or a method to secure performance of this LGIA. Liquidated damages, when the Parties agree to them, are the exclusive remedy for Transmission Provider's failure to meet its schedule.

No liquidated damages shall be paid to Interconnection Customer if: (1) Interconnection Customer is not ready to commence use of Transmission Provider's Interconnection Facilities or Network Upgrades to take the delivery of power for the Large Generating Facility's Trial Operation or to export power from the Large Generating Facility on the specified dates, unless Interconnection

Customer would have been able to commence use of Transmission Provider's Interconnection Facilities or Network Upgrades to take the delivery of power for Large Generating Facility's Trial Operation or to export power from the Large Generating Facility, but for Transmission Provider's delay; (2) Transmission Provider's failure to meet the specified dates is the result of the action or inaction of Interconnection Customer or any other Interconnection Customer who has entered into an LGIA with Transmission Provider or any cause beyond Transmission Provider's reasonable control or reasonable ability to cure; (3) Interconnection Customer has assumed responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades; or (4) the Parties have otherwise agreed.

5.4 Power System Stabilizers. Interconnection Customer shall procure, install, maintain and operate Power System Stabilizers in accordance with the guidelines and procedures established by the Electric Reliability Organization. Transmission Provider reserves the right to reasonably establish minimum acceptable settings for any installed Power System Stabilizers, subject to the design and operating limitations of the Large Generating Facility. If the Large Generating Facility's Power System Stabilizers are removed from service or not capable of automatic operation, Interconnection Customer shall immediately notify Transmission Provider's system operator, or its designated representative. The requirements of this paragraph shall not apply to wind generators.

5.5 Equipment Procurement. If responsibility for construction of Transmission Provider's Interconnection Facilities or Network Upgrades is to be borne by Transmission Provider, then Transmission Provider shall commence design of Transmission Provider's Interconnection Facilities or Network Upgrades and procure necessary equipment as soon as practicable after all of the following conditions are satisfied, unless the Parties otherwise agree in writing:

5.5.1 Transmission Provider has completed the Interconnection Facilities Study pursuant to the Interconnection Facilities Study Agreement;

- 5.5.2** Transmission Provider has received written authorization to proceed with design and procurement from Interconnection Customer by the date specified in Appendix B, Milestones; and
- 5.5.3** Interconnection Customer has provided security to Transmission Provider in accordance with Article 11.5 by the dates specified in Appendix B, Milestones.
- 5.6** Construction Commencement. Transmission Provider shall commence construction of Transmission Provider's Interconnection Facilities and Network Upgrades for which it is responsible as soon as practicable after the following additional conditions are satisfied:
- 5.6.1** Approval of the appropriate Governmental Authority has been obtained for any facilities requiring regulatory approval;
- 5.6.2** Necessary real property rights and rights-of-way have been obtained, to the extent required for the construction of a discrete aspect of Transmission Provider's Interconnection Facilities and Network Upgrades;
- 5.6.3** Transmission Provider has received written authorization to proceed with construction from Interconnection Customer by the date specified in Appendix B, Milestones; and
- 5.6.4** Interconnection Customer has provided security to Transmission Provider in accordance with Article 11.5 by the dates specified in Appendix B, Milestones.
- 5.7** Work Progress. The Parties will keep each other advised periodically as to the progress of their respective design, procurement and construction efforts. Either Party may, at any time, request a progress report from the other Party. If, at any

time, Interconnection Customer determines that the completion of Transmission Provider's Interconnection Facilities will not be required until after the specified In-Service Date, Interconnection Customer will provide written notice to Transmission Provider of such later date upon which the completion of Transmission Provider's Interconnection Facilities will be required.

- 5.8 Information Exchange. As soon as reasonably practicable after the Effective Date, the Parties shall exchange information regarding the design and compatibility of the Parties' Interconnection Facilities and compatibility of the Interconnection Facilities with Transmission Provider's Transmission System, and shall work diligently and in good faith to make any necessary design changes.

5.9 Other Interconnection Options.

5.9.1 Limited Operation. If any of Transmission Provider's Interconnection Facilities or Network Upgrades are not reasonably expected to be completed prior to the Commercial Operation Date of the Large Generating Facility, Transmission Provider shall, upon the request and at the expense of Interconnection Customer, perform operating studies on a timely basis to determine the extent to which the Large Generating Facility and Interconnection Customer's Interconnection Facilities may operate prior to the completion of Transmission Provider's Interconnection Facilities or Network Upgrades consistent with Applicable Laws and Regulations, Applicable Reliability Standards, Good Utility Practice, and this LGIA. Transmission Provider shall permit Interconnection Customer to operate the Large Generating Facility and Interconnection Customer's Interconnection Facilities in accordance with the results of such studies.

5.9.2 **Provisional Interconnection Service.** Upon the request of Interconnection Customer, and prior to completion of requisite Interconnection Facilities, Network Upgrades, Distribution Upgrades, or System Protection Facilities Transmission Provider may execute a Provisional Large Generator Interconnection Agreement or Interconnection Customer may request the filing of an unexecuted Provisional Large Generator Interconnection

Agreement with Interconnection Customer for limited Interconnection Service at the discretion of Transmission Provider based upon an evaluation that will consider the results of available studies. Transmission Provider shall determine, through available studies or additional studies as necessary, whether stability, short circuit, thermal, and/or voltage issues would arise if Interconnection Customer interconnects without modifications to the Generating Facility or Transmission System. Transmission Provider shall determine whether any Interconnection Facilities, Network Upgrades, Distribution Upgrades, or System Protection Facilities that are necessary to meet the requirements of the Electric Reliability Organization, or any applicable Regional Entity for the interconnection of a new, modified and/or expanded Generating Facility are in place prior to the commencement of Interconnection Service from the Generating Facility. Where available studies indicate that such, Interconnection Facilities, Network Upgrades, Distribution Upgrades, and/or System Protection Facilities that are required for the interconnection of a new, modified and/or expanded Generating Facility are not currently in place, Transmission Provider will perform a study, at Interconnection Customer's expense, to confirm the facilities that are required for Provisional Interconnection Service. The maximum permissible output of the Generating Facility in the Provisional Large Generator Interconnection Agreement shall be studied and updated {on a frequency determined by Transmission Provider and at Interconnection Customer's expense}. Interconnection Customer assumes all risk and liabilities with respect to changes between the Provisional Large Generator Interconnection Agreement and the Large Generator Interconnection Agreement, including changes in output limits and Interconnection Facilities, Network Upgrades, Distribution Upgrades, and/or System Protection Facilities cost responsibilities.

- 5.10 Interconnection Customer's Interconnection Facilities ('ICIF'). Interconnection Customer shall, at its expense, design, procure, construct, own and install the ICIF, as set forth in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades.

- 5.10.1 Interconnection Customer's Interconnection Facility Specifications. Interconnection Customer shall submit initial specifications for the ICIF, including System Protection Facilities, to Transmission Provider at least one hundred eighty (180) Calendar Days prior to the Initial Synchronization Date; and final specifications for review and comment at least ninety (90) Calendar Days prior to the Initial Synchronization Date. Transmission Provider shall review such specifications to ensure that the ICIF are compatible with the technical specifications, operational control, and safety requirements of Transmission Provider and comment on such specifications within thirty (30) Calendar Days of Interconnection Customer's submission. All specifications provided hereunder shall be deemed confidential.
- 5.10.2 **Transmission Provider's Review.** Transmission Provider's review of Interconnection Customer's final specifications shall not be construed as confirming, endorsing, or providing a warranty as to the design, fitness, safety, durability or reliability of the Large Generating Facility, or the ICIF. Interconnection Customer shall make such changes to the ICIF as may reasonably be required by Transmission Provider, in accordance with Good Utility Practice, to ensure that the ICIF are compatible with the technical specifications, operational control, and safety requirements of Transmission Provider.
- 5.10.3 **ICIF Construction.** The ICIF shall be designed and constructed in accordance with Good Utility Practice. Within one hundred twenty (120) Calendar Days after the Commercial Operation Date, unless the Parties agree on another mutually acceptable deadline, Interconnection Customer shall deliver to Transmission Provider "as-built" drawings, information and documents for the ICIF, such as: a one-line diagram, a site plan showing the Large Generating Facility and the ICIF, plan and elevation drawings showing the layout of the ICIF, a relay functional diagram, relaying AC and DC schematic wiring diagrams and relay settings for all facilities associated with Interconnection Customer's step-up transformers, the

facilities connecting the Large Generating Facility to the step-up transformers and the ICIF, and the impedances (determined by factory tests) for the associated step-up transformers and the Large Generating Facility. Interconnection Customer shall provide Transmission Provider specifications for the excitation system, automatic voltage regulator, Large Generating Facility control and protection settings, transformer tap settings, and communications, if applicable.

- 5.11 **Transmission Provider's Interconnection Facilities Construction.** Transmission Provider's Interconnection Facilities shall be designed and constructed in accordance with Good Utility Practice. Upon request, within one hundred twenty (120) Calendar Days after the Commercial Operation Date, unless the Parties agree on another mutually acceptable deadline, Transmission Provider shall deliver to Interconnection Customer the following "as-built" drawings, information and documents for Transmission Provider's Interconnection Facilities {include appropriate drawings and relay diagrams}.

Transmission Provider will obtain control of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades upon completion of such facilities.

- 5.12 **Access Rights.** Upon reasonable notice and supervision by a Party, and subject to any required or necessary regulatory approvals, a Party ("Granting Party") shall furnish at no cost to the other Party ("Access Party") any rights of use, licenses, rights of way and easements with respect to lands owned or controlled by the Granting Party, its agents (if allowed under the applicable agency agreement), or any Affiliate, that are necessary to enable the Access Party to obtain ingress and egress to construct, operate, maintain, repair, test (or witness testing), inspect, replace or remove facilities and equipment to: (i) interconnect the Large Generating Facility with the Transmission System; (ii) operate and maintain the Large Generating Facility, the Interconnection Facilities and the Transmission System; and (iii) disconnect or remove the Access Party's facilities and equipment upon termination of this LGIA. In exercising such licenses, rights of way and easements, the Access Party shall not unreasonably disrupt or interfere with

normal operation of the Granting Party's business and shall adhere to the safety rules and procedures established in advance, as may be changed from time to time, by the Granting Party and provided to the Access Party.

- 5.13 Lands of Other Property Owners. If any part of Transmission Provider or Transmission Owner's Interconnection Facilities and/or Network Upgrades is to be installed on property owned by persons other than Interconnection Customer or Transmission Provider or Transmission Owner, Transmission Provider or Transmission Owner shall at Interconnection Customer's expense use efforts, similar in nature and extent to those that it typically undertakes on its own behalf or on behalf of its Affiliates, including use of its eminent domain authority, and to the extent consistent with state law, to procure from such persons any rights of use, licenses, rights of way and easements that are necessary to construct, operate, maintain, test, inspect, replace or remove Transmission Provider or Transmission Owner's Interconnection Facilities and/or Network Upgrades upon such property.
- 5.14 Permits. Transmission Provider or Transmission Owner and Interconnection Customer shall cooperate with each other in good faith in obtaining all permits, licenses, and authorizations that are necessary to accomplish the interconnection in compliance with Applicable Laws and Regulations. With respect to this paragraph, Transmission Provider or Transmission Owner shall provide permitting assistance to Interconnection Customer comparable to that provided to Transmission Provider's own, or an Affiliate's generation.
- 5.15 Early Construction of Base Case Facilities. Interconnection Customer may request Transmission Provider to construct, and Transmission Provider shall construct, using Reasonable Efforts to accommodate Interconnection Customer's In-Service Date, all or any portion of any Network Upgrades required for Interconnection Customer to be interconnected to the Transmission System which are included in the Base Case of the Interconnection Facilities Study for Interconnection Customer, and which also are required to be constructed for another Interconnection Customer, but where such construction is not scheduled to be completed in time to achieve Interconnection Customer's In-Service Date.

5.16 Suspension. Interconnection Customer reserves the right, upon written notice to Transmission Provider, to suspend at any time all work by Transmission Provider associated with the construction and installation of Transmission Provider's Interconnection Facilities and/or Network Upgrades required under this LGIA with the condition that Transmission System shall be left in a safe and reliable condition in accordance with Good Utility Practice and Transmission Provider's safety and reliability criteria. In such event, Interconnection Customer shall be responsible for all reasonable and necessary costs which Transmission Provider (i) has incurred pursuant to this LGIA prior to the suspension and (ii) incurs in suspending such work, including any costs incurred to perform such work as may be necessary to ensure the safety of persons and property and the integrity of the Transmission System during such suspension and, if applicable, any costs incurred in connection with the cancellation or suspension of material, equipment and labor contracts which Transmission Provider cannot reasonably avoid; provided, however, that prior to canceling or suspending any such material, equipment or labor contract, Transmission Provider shall obtain Interconnection Customer's authorization to do so.

Transmission Provider shall invoice Interconnection Customer for such costs pursuant to Article 12 and shall use due diligence to minimize its costs. In the event Interconnection Customer suspends work by Transmission Provider required under this LGIA pursuant to this Article 5.16, and has not requested Transmission Provider to recommence the work required under this LGIA on or before the expiration of three (3) years following commencement of such suspension, this LGIA shall be deemed terminated. The three-year period shall begin on the date the suspension is requested, or the date of the written notice to Transmission Provider, if no effective date is specified.

5.17 Taxes.

5.17.1 Interconnection Customer Payments Not Taxable. The Parties intend that all payments or property transfers made by Interconnection Customer to Transmission Provider for the installation of Transmission Provider's Interconnection Facilities and the Network Upgrades shall be non-taxable, either as

contributions to capital, or as an advance, in accordance with the Internal Revenue Code and any applicable state income tax laws and shall not be taxable as contributions in aid of construction or otherwise under the Internal Revenue Code and any applicable state income tax laws.

- 5.17.2 Representations and Covenants. In accordance with IRS Notice 2001-82 and IRS Notice 88-129, Interconnection Customer represents and covenants that (i) ownership of the electricity generated at the Large Generating Facility will pass to another party prior to the transmission of the electricity on the Transmission System, (ii) for income tax purposes, the amount of any payments and the cost of any property transferred to Transmission Provider for Transmission Provider's Interconnection Facilities will be capitalized by Interconnection Customer as an intangible asset and recovered using the straight-line method over a useful life of twenty (20) years, and (iii) any portion of Transmission Provider's Interconnection Facilities that is a "dual-use intertie," within the meaning of IRS Notice 88-129, is reasonably expected to carry only a de minimis amount of electricity in the direction of the Large Generating Facility. For this purpose, "de minimis amount" means no more than 5 percent of the total power flows in both directions, calculated in accordance with the "5 percent test" set forth in IRS Notice 88-129. This is not intended to be an exclusive list of the relevant conditions that must be met to conform to IRS requirements for non-taxable treatment.

At Transmission Provider's request, Interconnection Customer shall provide Transmission Provider with a report from an independent engineer confirming its representation in clause (iii), above. Transmission Provider represents and covenants that the cost of Transmission Provider's Interconnection Facilities paid for by Interconnection Customer will have no net effect on the base upon which rates are determined.

- 5.17.3 Indemnification for the Cost Consequences of Current Tax Liability Imposed Upon Transmission Provider. Notwithstanding Article

5.17.1, Interconnection Customer shall protect, indemnify and hold harmless Transmission Provider from the cost consequences of any current tax liability imposed against Transmission Provider as the result of payments or property transfers made by Interconnection Customer to Transmission Provider under this LGIA for Interconnection Facilities, as well as any interest and penalties, other than interest and penalties attributable to any delay caused by Transmission Provider.

Transmission Provider shall not include a gross-up for the cost consequences of any current tax liability in the amounts it charges Interconnection Customer under this LGIA unless (i) Transmission Provider has determined, in good faith, that the payments or property transfers made by Interconnection Customer to Transmission Provider should be reported as income subject to taxation or (ii) any Governmental Authority directs Transmission Provider to report payments or property as income subject to taxation; provided, however, that Transmission Provider may require Interconnection Customer to provide security for Interconnection Facilities, in a form reasonably acceptable to Transmission Provider (such as a parental guarantee or a letter of credit), in an amount equal to the cost consequences of any current tax liability under this Article 5.17. Interconnection Customer shall reimburse Transmission Provider for such costs on a fully grossed-up basis, in accordance with Article 5.17.4, within thirty (30) Calendar Days of receiving written notification from Transmission Provider of the amount due, including detail about how the amount was calculated.

The indemnification obligation shall terminate at the earlier of (1) the expiration of the ten year testing period and the applicable statute of limitation, as it may be extended by Transmission Provider upon request of the IRS, to keep these years open for audit or adjustment, or (2) the occurrence of a subsequent taxable event and the payment of any related indemnification obligations as contemplated by this Article 5.17.

5.17.4 Tax Gross-Up Amount. Interconnection Customer's liability for the cost consequences of any current tax liability under this Article 5.17 shall be calculated on a fully grossed-up basis. Except as may otherwise be agreed to by the parties, this means that Interconnection Customer will pay Transmission Provider, in addition to the amount paid for the Interconnection Facilities and Network Upgrades, an amount equal to (1) the current taxes imposed on Transmission Provider ("Current Taxes") on the excess of (a) the gross income realized by Transmission Provider as a result of payments or property transfers made by Interconnection Customer to Transmission Provider under this LGIA (without regard to any payments under this Article 5.17) (the "Gross Income Amount") over (b) the present value of future tax deductions for depreciation that will be available as a result of such payments or property transfers (the "Present Value Depreciation Amount"), plus (2) an additional amount sufficient to permit Transmission Provider to receive and retain, after the payment of all Current Taxes, an amount equal to the net amount described in clause (1).

For this purpose, (i) Current Taxes shall be computed based on Transmission Provider's composite federal and state tax rates at the time the payments or property transfers are received and Transmission Provider will be treated as being subject to tax at the highest marginal rates in effect at that time (the "Current Tax Rate"), and (ii) the Present Value Depreciation Amount shall be computed by discounting Transmission Provider's anticipated tax depreciation deductions as a result of such payments or property transfers by Transmission Provider's current weighted average cost of capital. Thus, the formula for calculating Interconnection Customer's liability to Transmission Owner pursuant to this Article 5.17.4 can be expressed as follows: $(\text{Current Tax Rate} \times (\text{Gross Income Amount} - \text{Present Value of Tax Depreciation})) / (1 - \text{Current Tax Rate})$. Interconnection Customer's estimated tax liability in the event taxes are imposed shall be stated in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades.

5.17.5 Private Letter Ruling or Change or Clarification of Law. At Interconnection Customer's request and expense, Transmission Provider shall file with the IRS a request for a private letter ruling as to whether any property transferred or sums paid, or to be paid, by Interconnection Customer to Transmission Provider under this LGIA are subject to federal income taxation. Interconnection Customer will prepare the initial draft of the request for a private letter ruling, and will certify under penalties of perjury that all facts represented in such request are true and accurate to the best of Interconnection Customer's knowledge. Transmission Provider and Interconnection Customer shall cooperate in good faith with respect to the submission of such request.

Transmission Provider shall keep Interconnection Customer fully informed of the status of such request for a private letter ruling and shall execute either a privacy act waiver or a limited power of attorney, in a form acceptable to the IRS, that authorizes Interconnection Customer to participate in all discussions with the IRS regarding such request for a private letter ruling. Transmission Provider shall allow Interconnection Customer to attend all meetings with IRS officials about the request and shall permit Interconnection Customer to prepare the initial drafts of any follow-up letters in connection with the request.

5.17.6 Subsequent Taxable Events. If, within 10 years from the date on which the relevant Transmission Provider's Interconnection Facilities are placed in service, (i) Interconnection Customer Breaches the covenants contained in Article 5.17.2, (ii) a "disqualification event" occurs within the meaning of IRS Notice 88-129, or (iii) this LGIA terminates and Transmission Provider retains ownership of the Interconnection Facilities and Network Upgrades, Interconnection Customer shall pay a tax gross-up for the cost consequences of any current tax liability imposed on Transmission Provider, calculated using the methodology described in Article 5.17.4 and in accordance with IRS Notice 90-60.

5.17.7 Contests. In the event any Governmental Authority determines that Transmission Provider's receipt of payments or property constitutes income that is subject to taxation, Transmission Provider shall notify Interconnection Customer, in writing, within thirty (30) Calendar Days of receiving notification of such determination by a Governmental Authority. Upon the timely written request by Interconnection Customer and at Interconnection Customer's sole expense, Transmission Provider may appeal, protest, seek abatement of, or otherwise oppose such determination. Upon Interconnection Customer's written request and sole expense, Transmission Provider may file a claim for refund with respect to any taxes paid under this Article 5.17, whether or not it has received such a determination. Transmission Provider reserves the right to make all decisions with regard to the prosecution of such appeal, protest, abatement or other contest, including the selection of counsel and compromise or settlement of the claim, but Transmission Provider shall keep Interconnection Customer informed, shall consider in good faith suggestions from Interconnection Customer about the conduct of the contest, and shall reasonably permit Interconnection Customer or an Interconnection Customer representative to attend contest proceedings.

Interconnection Customer shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission Provider's documented reasonable costs of prosecuting such appeal, protest, abatement or other contest. At any time during the contest, Transmission Provider may agree to a settlement either with Interconnection Customer's consent or after obtaining written advice from nationally-recognized tax counsel, selected by Transmission Provider, but reasonably acceptable to Interconnection Customer, that the proposed settlement represents a reasonable settlement given the hazards of litigation. Interconnection Customer's obligation shall be based on the amount of the settlement agreed to by Interconnection Customer, or if a higher amount, so much of the settlement that is supported by the written advice from nationally-recognized tax counsel selected under the terms of the preceding

sentence. The settlement amount shall be calculated on a fully grossed-up basis to cover any related cost consequences of the current tax liability. Any settlement without Interconnection Customer's consent or such written advice will relieve Interconnection Customer from any obligation to indemnify Transmission Provider for the tax at issue in the contest.

5.17.8 Refund. In the event that (a) a private letter ruling is issued to Transmission Provider which holds that any amount paid or the value of any property transferred by Interconnection Customer to Transmission Provider under the terms of this LGIA is not subject to federal income taxation, (b) any legislative change or administrative announcement, notice, ruling or other determination makes it reasonably clear to Transmission Provider in good faith that any amount paid or the value of any property transferred by Interconnection Customer to Transmission Provider under the terms of this LGIA is not taxable to Transmission Provider, (c) any abatement, appeal, protest, or other contest results in a determination that any payments or transfers made by Interconnection Customer to Transmission Provider are not subject to federal income tax, or (d) if Transmission Provider receives a refund from any taxing authority for any overpayment of tax attributable to any payment or property transfer made by Interconnection Customer to Transmission Provider pursuant to this LGIA, Transmission Provider shall promptly refund to Interconnection Customer the following:

(i) any payment made by Interconnection Customer under this Article 5.17 for taxes that is attributable to the amount determined to be non-taxable, together with interest thereon,

(ii) interest on any amounts paid by Interconnection Customer to Transmission Provider for such taxes which Transmission Provider did not submit to the taxing authority, calculated in accordance with the methodology set forth in FERC's regulations at 18 CFR §35.19a(a)(2)(iii) from the date

payment was made by Interconnection Customer to the date Transmission Provider refunds such payment to Interconnection Customer, and

(iii) with respect to any such taxes paid by Transmission Provider, any refund or credit Transmission Provider receives or to which it may be entitled from any Governmental Authority, interest (or that portion thereof attributable to the payment described in clause (i), above) owed to Transmission Provider for such overpayment of taxes (including any reduction in interest otherwise payable by Transmission Provider to any Governmental Authority resulting from an offset or credit); provided, however, that Transmission Provider will remit such amount promptly to Interconnection Customer only after and to the extent that Transmission Provider has received a tax refund, credit or offset from any Governmental Authority for any applicable overpayment of income tax related to Transmission Provider's Interconnection Facilities.

The intent of this provision is to leave the Parties, to the extent practicable, in the event that no taxes are due with respect to any payment for Interconnection Facilities and Network Upgrades hereunder, in the same position they would have been in had no such tax payments been made.

5.17.9 Taxes Other Than Income Taxes. Upon the timely request by Interconnection Customer, and at Interconnection Customer's sole expense, Transmission Provider may appeal, protest, seek abatement of, or otherwise contest any tax (other than federal or state income tax) asserted or assessed against Transmission Provider for which Interconnection Customer may be required to reimburse Transmission Provider under the terms of this LGIA. Interconnection Customer shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission

Provider's documented reasonable costs of prosecuting such appeal, protest, abatement, or other contest. Interconnection Customer and Transmission Provider shall cooperate in good faith with respect to any such contest. Unless the payment of such taxes is a prerequisite to an appeal or abatement or cannot be deferred, no amount shall be payable by Interconnection Customer to Transmission Provider for such taxes until they are assessed by a final, non-appealable order by any court or agency of competent jurisdiction. In the event that a tax payment is withheld and ultimately due and payable after appeal, Interconnection Customer will be responsible for all taxes, interest and penalties, other than penalties attributable to any delay caused by Transmission Provider.

5.17.10 Transmission Owners Who Are Not Transmission Providers. If Transmission Provider is not the same entity as the Transmission Owner, then (i) all references in this Article 5.17 to Transmission Provider shall be deemed also to refer to and to include the Transmission Owner, as appropriate, and (ii) this LGIA shall not become effective until such Transmission Owner shall have agreed in writing to assume all of the duties and obligations of Transmission Provider under this Article 5.17 of this LGIA.

5.18 Tax Status. Each Party shall cooperate with the other to maintain the other Party's tax status. Nothing in this LGIA is intended to adversely affect any Transmission Provider's tax exempt status with respect to the issuance of bonds including, but not limited to, Local Furnishing Bonds.

5.19 Modification.

5.19.1 General. Either Party may undertake modifications to its facilities. If a Party plans to undertake a modification that reasonably may be expected to affect the other Party's facilities, that Party shall provide to the other Party sufficient information regarding such modification so that the other Party may evaluate the potential impact of such

modification prior to commencement of the work. Such information shall be deemed to be confidential hereunder and shall include information concerning the timing of such modifications and whether such modifications are expected to interrupt the flow of electricity from the Large Generating Facility. The Party desiring to perform such work shall provide the relevant drawings, plans, and specifications to the other Party at least ninety (90) Calendar Days in advance of the commencement of the work or such shorter period upon which the Parties may agree, which agreement shall not unreasonably be withheld, conditioned or delayed.

In the case of Large Generating Facility modifications that do not require Interconnection Customer to submit an Interconnection Request, Transmission Provider shall provide, within thirty (30) Calendar Days (or such other time as the Parties may agree), an estimate of any additional modifications to the Transmission System, Transmission Provider's Interconnection Facilities or Network Upgrades necessitated by such Interconnection Customer modification and a good faith estimate of the costs thereof.

5.19.2 Standards. Any additions, modifications, or replacements made to a Party's facilities shall be designed, constructed and operated in accordance with this LGIA and Good Utility Practice.

5.19.3 Modification Costs. Interconnection Customer shall not be directly assigned for the costs of any additions, modifications, or replacements that Transmission Provider makes to Transmission Provider's Interconnection Facilities or the Transmission System to facilitate the interconnection of a third party to Transmission Provider's Interconnection Facilities or the Transmission System, or to provide transmission service to a third party under Transmission Provider's Tariff. Interconnection Customer shall be responsible for the costs of any additions, modifications, or replacements to Interconnection Customer's Interconnection Facilities that may be necessary to maintain or upgrade such Interconnection Customer's

Interconnection Facilities consistent with Applicable Laws and Regulations, Applicable Reliability Standards or Good Utility Practice.

Article 6. Testing and Inspection

- 6.1 Pre-Commercial Operation Date Testing and Modifications.** Prior to the Commercial Operation Date, Transmission Provider shall test Transmission Provider's Interconnection Facilities and Network Upgrades and Interconnection Customer shall test the Large Generating Facility and Interconnection Customer's Interconnection Facilities to ensure their safe and reliable operation. Similar testing may be required after initial operation. Each Party shall make any modifications to its facilities that are found to be necessary as a result of such testing. Interconnection Customer shall bear the cost of all such testing and modifications. Interconnection Customer shall generate test energy at the Large Generating Facility only if it has arranged for the delivery of such test energy.
- 6.2 Post-Commercial Operation Date Testing and Modifications.** Each Party shall at its own expense perform routine inspection and testing of its facilities and equipment in accordance with Good Utility Practice as may be necessary to ensure the continued interconnection of the Large Generating Facility with the Transmission System in a safe and reliable manner. Each Party shall have the right, upon advance written notice, to require reasonable additional testing of the other Party's facilities, at the requesting Party's expense, as may be in accordance with Good Utility Practice.
- 6.3 Right to Observe Testing.** Each Party shall notify the other Party in advance of its performance of tests of its Interconnection Facilities. The other Party has the right, at its own expense, to observe such testing.
- 6.4 Right to Inspect.** Each Party shall have the right, but shall have no obligation to:
- (i) observe the other Party's tests and/or inspection of any of its System Protection Facilities and other protective equipment, including Power System Stabilizers;
 - (ii) review the settings of the other Party's System Protection Facilities and other

protective equipment; and (iii) review the other Party's maintenance records relative to the Interconnection Facilities, the System Protection Facilities and other protective equipment. A Party may exercise these rights from time to time as it deems necessary upon reasonable notice to the other Party. The exercise or non-exercise by a Party of any such rights shall not be construed as an endorsement or confirmation of any element or condition of the Interconnection Facilities or the System Protection Facilities or other protective equipment or the operation thereof, or as a warranty as to the fitness, safety, desirability, or reliability of same. Any information that a Party obtains through the exercise of any of its rights under this Article 6.4 shall be deemed to be Confidential Information and treated pursuant to Article 22 of this LGIA.

Article 7. Metering

- 7.1 General. Each Party shall comply with the Electric Reliability Organization requirements. Unless otherwise agreed by the Parties, Transmission Provider shall install Metering Equipment at the Point of Interconnection prior to any operation of the Large Generating Facility and shall own, operate, test and maintain such Metering Equipment. Power flows to and from the Large Generating Facility shall be measured at or, at Transmission Provider's option, compensated to, the Point of Interconnection. Transmission Provider shall provide metering quantities, in analog and/or digital form, to Interconnection Customer upon request. Interconnection Customer shall bear all reasonable documented costs associated with the purchase, installation, operation, testing and maintenance of the Metering Equipment.
- 7.2 Check Meters. Interconnection Customer, at its option and expense, may install and operate, on its premises and on its side of the Point of Interconnection, one or more check meters to check Transmission Provider's meters. Such check meters shall be for check purposes only and shall not be used for the measurement of power flows for purposes of this LGIA, except as provided in Article 7.4 below. The check meters shall be subject at all reasonable times to inspection and examination by Transmission Provider or its designee. The installation, operation

and maintenance thereof shall be performed entirely by Interconnection Customer in accordance with Good Utility Practice.

- 7.3 Standards. Transmission Provider shall install, calibrate, and test revenue quality Metering Equipment in accordance with applicable ANSI standards.
- 7.4 Testing of Metering Equipment. Transmission Provider shall inspect and test all Transmission Provider-owned Metering Equipment upon installation and at least once every two (2) years thereafter. If requested to do so by Interconnection Customer, Transmission Provider shall, at Interconnection Customer's expense, inspect or test Metering Equipment more frequently than every two (2) years. Transmission Provider shall give reasonable notice of the time when any inspection or test shall take place, and Interconnection Customer may have representatives present at the test or inspection. If at any time Metering Equipment is found to be inaccurate or defective, it shall be adjusted, repaired or replaced at Interconnection Customer's expense, in order to provide accurate metering, unless the inaccuracy or defect is due to Transmission Provider's failure to maintain, then Transmission Provider shall pay. If Metering Equipment fails to register, or if the measurement made by Metering Equipment during a test varies by more than two percent from the measurement made by the standard meter used in the test, Transmission Provider shall adjust the measurements by correcting all measurements for the period during which Metering Equipment was in error by using Interconnection Customer's check meters, if installed. If no such check meters are installed or if the period cannot be reasonably ascertained, the adjustment shall be for the period immediately preceding the test of the Metering Equipment equal to one-half the time from the date of the last previous test of the Metering Equipment.
- 7.5 Metering Data. At Interconnection Customer's expense, the metered data shall be telemetered to one or more locations designated by Transmission Provider and one or more locations designated by Interconnection Customer. Such telemetered data shall be used, under normal operating conditions, as the official measurement of the amount of energy delivered from the Large Generating Facility to the Point of Interconnection.

Article 8. Communications

8.1 Interconnection Customer Obligations. Interconnection Customer shall maintain satisfactory operating communications with Transmission Provider's Transmission System dispatcher or representative designated by Transmission Provider. Interconnection Customer shall provide standard voice line, dedicated voice line and facsimile communications at its Large Generating Facility control room or central dispatch facility through use of either the public telephone system, or a voice communications system that does not rely on the public telephone system. Interconnection Customer shall also provide the dedicated data circuit(s) necessary to provide Interconnection Customer data to Transmission Provider as set forth in Appendix D, Security Arrangements Details. The data circuit(s) shall extend from the Large Generating Facility to the location(s) specified by Transmission Provider. Any required maintenance of such communications equipment shall be performed by Interconnection Customer. Operational communications shall be activated and maintained under, but not be limited to, the following events: system paralleling or separation, scheduled and unscheduled shutdowns, equipment clearances, and hourly and daily load data.

8.2 Remote Terminal Unit. Prior to the Initial Synchronization Date of the Large Generating Facility, a Remote Terminal Unit, or equivalent data collection and transfer equipment acceptable to the Parties, shall be installed by Interconnection Customer, or by Transmission Provider at Interconnection Customer's expense, to gather accumulated and instantaneous data to be telemetered to the location(s) designated by Transmission Provider through use of a dedicated point-to-point data circuit(s) as indicated in Article 8.1. The communication protocol for the data circuit(s) shall be specified by Transmission Provider. Instantaneous bi-directional analog real power and reactive power flow information must be telemetered directly to the location(s) specified by Transmission Provider.

Each Party will promptly advise the other Party if it detects or otherwise learns of any metering, telemetry or communications equipment errors or malfunctions that require the attention and/or correction by the other Party. The Party owning such equipment shall correct such error or malfunction as soon as reasonably feasible.

- 8.3 No Annexation. Any and all equipment placed on the premises of a Party shall be and remain the property of the Party providing such equipment regardless of the mode and manner of annexation or attachment to real property, unless otherwise mutually agreed by the Parties.
- 8.4 Provision of Data from a Variable Energy Resource. Interconnection Customer whose Generating Facility contains at least one Variable Energy Resource shall provide meteorological and forced outage data to Transmission Provider to the extent necessary for Transmission Provider's development and deployment of power production forecasts for that class of Variable Energy Resources. Interconnection Customer with a Variable Energy Resource having wind as the energy source, at a minimum, will be required to provide Transmission Provider with site-specific meteorological data including: temperature, wind speed, wind direction, and atmospheric pressure. Interconnection Customer with a Variable Energy Resource having solar as the energy source, at a minimum, will be required to provide Transmission Provider with site-specific meteorological data including: temperature, atmospheric pressure, and irradiance. Transmission Provider and Interconnection Customer whose Generating Facility contains a Variable Energy Resource shall mutually agree to any additional meteorological data that are required for the development and deployment of a power production forecast. Interconnection Customer whose Generating Facility contains a Variable Energy Resource also shall submit data to Transmission Provider regarding all forced outages to the extent necessary for Transmission Provider's development and deployment of power production forecasts for that class of Variable Energy Resources. The exact specifications of the meteorological and forced outage data to be provided by Interconnection Customer to Transmission Provider, including the frequency and timing of data submittals, shall be made taking into account the size and configuration of the Variable Energy Resource, its characteristics, location, and its importance in maintaining generation resource adequacy and transmission system reliability in its area. All requirements for meteorological and forced outage data must be commensurate with the power production forecasting employed by Transmission Provider. Such requirements for meteorological and forced outage data are set forth in Appendix C, Interconnection Details, of this LGIA, as they may change from time to time.

Article 9. Operations

- 9.1 General. Each Party shall comply with the Electric Reliability Organization requirements. Each Party shall provide to the other Party all information that may reasonably be required by the other Party to comply with Applicable Laws and Regulations and Applicable Reliability Standards.
- 9.2 **Balancing Authority** Area Notification. At least three months before Initial Synchronization Date, Interconnection Customer shall notify Transmission Provider in writing of the Balancing Authority Area in which the Large Generating Facility will be located. If Interconnection Customer elects to locate the Large Generating Facility in a Balancing Authority Area other than the Balancing Authority Area in which the Large Generating Facility is physically located, and if permitted to do so by the relevant transmission tariffs, all necessary arrangements, including but not limited to those set forth in Article 7 and Article 8 of this LGIA, and remote Balancing Authority Area generator interchange agreements, if applicable, and the appropriate measures under such agreements, shall be executed and implemented prior to the placement of the Large Generating Facility in the other Balancing Authority Area.
- 9.3 Transmission Provider Obligations. Transmission Provider shall cause the Transmission System and Transmission Provider's Interconnection Facilities to be operated, maintained and controlled in a safe and reliable manner and in accordance with this LGIA. Transmission Provider may provide operating instructions to Interconnection Customer consistent with this LGIA and Transmission Provider's operating protocols and procedures as they may change from time to time. Transmission Provider will consider changes to its operating protocols and procedures proposed by Interconnection Customer.
- 9.4 Interconnection Customer Obligations. Interconnection Customer shall at its own expense operate, maintain and control the Large Generating Facility and Interconnection Customer's Interconnection Facilities in a safe and reliable manner and in accordance with this LGIA. Interconnection Customer shall operate the Large Generating Facility and Interconnection Customer's Interconnection Facilities in accordance with all applicable requirements of the

Balancing Authority Area of which it is part, as such requirements are set forth in Appendix C, Interconnection Details, of this LGIA. Appendix C, Interconnection Details, will be modified to reflect changes to the requirements as they may change from time to time. Either Party may request that the other Party provide copies of the requirements set forth in Appendix C, Interconnection Details, of this LGIA.

9.5 Start-Up and Synchronization. Consistent with the Parties' mutually acceptable procedures, Interconnection Customer is responsible for the proper synchronization of the Large Generating Facility to Transmission Provider's Transmission System.

9.6 Reactive Power and Primary Frequency Response.

9.6.1 Power Factor Design Criteria.

9.6.1.1 Synchronous Generation. Interconnection Customer shall design the Large Generating Facility to maintain a composite power delivery at continuous rated power output at the Point of Interconnection at a power factor within the range of 0.95 leading to 0.95 lagging, unless Transmission Provider has established different requirements that apply to all synchronous generators in the Balancing Authority Area on a comparable basis.

9.6.1.2 Non-Synchronous Generation. Interconnection Customer shall design the Large Generating Facility to maintain a composite power delivery at continuous rated power output at the high-side of the generator substation at a power factor within the range of 0.95 leading to 0.95 lagging, unless Transmission Provider has established a different power factor range that applies to all non-synchronous generators in the Balancing Authority Area on a comparable basis. This

power factor range standard shall be dynamic and can be met using, for example, power electronics designed to supply this level of reactive capability (taking into account any limitations due to voltage level, real power output, etc.) or fixed and switched capacitors, or a combination of the two. This requirement shall only apply to newly interconnecting non-synchronous generators that have not yet executed a Facilities Study Agreement as of the effective date of the Final Rule establishing this requirement (Order No. 827).

9.6.2 Voltage Schedules. Once Interconnection Customer has synchronized the Large Generating Facility with the Transmission System, Transmission Provider shall require Interconnection Customer to operate the Large Generating Facility to produce or absorb reactive power within the design limitations of the Large Generating Facility set forth in Article 9.6.1 (Power Factor Design Criteria). Transmission Provider's voltage schedules shall treat all sources of reactive power in the Balancing Authority Area in an equitable and not unduly discriminatory manner. Transmission Provider shall exercise Reasonable Efforts to provide Interconnection Customer with such schedules at least one (1) day in advance, and may make changes to such schedules as necessary to maintain the reliability of the Transmission System. Interconnection Customer shall operate the Large Generating Facility to maintain the specified output voltage or power factor at the Point of Interconnection within the design limitations of the Large Generating Facility set forth in Article 9.6.1 (Power Factor Design Criteria). If Interconnection Customer is unable to maintain the specified voltage or power factor, it shall promptly notify the System Operator.

9.6.2.1 Voltage Regulators. Whenever the Large Generating Facility is operated in parallel with the Transmission System and voltage regulators are capable of operation, Interconnection Customer shall operate the Large Generating Facility with its voltage regulators in automatic operation. If the Large Generating Facility's voltage regulators are not capable of such automatic operation, Interconnection Customer shall immediately notify Transmission Provider's system operator,

or its designated representative, and ensure that such Large Generating Facility's reactive power production or absorption (measured in MVARs) are within the design capability of the Large Generating Facility's generating unit(s) and steady state stability limits. Interconnection Customer shall not cause its Large Generating Facility to disconnect automatically or instantaneously from the Transmission System or trip any generating unit comprising the Large Generating Facility for an under or over frequency condition unless the abnormal frequency condition persists for a time period beyond the limits set forth in ANSI/IEEE Standard C37.106, or such other standard as applied to other generators in the Balancing Authority Area on a comparable basis.

9.6.3 Payment for Reactive Power. Transmission Provider is required to pay Interconnection Customer for reactive power that Interconnection Customer provides or absorbs from the Large Generating Facility when Transmission Provider requests Interconnection Customer to operate its Large Generating Facility outside the range specified in Article 9.6.1, provided that if Transmission Provider pays its own or affiliated generators for reactive power service within the specified range, it must also pay Interconnection Customer. Payments shall be pursuant to Article 11.6 or such other agreement to which the Parties have otherwise agreed.

9.6.4 Primary Frequency Response. Interconnection Customer shall ensure the primary frequency response capability of its Large Generating Facility by installing, maintaining, and operating a functioning governor or equivalent controls. The term "functioning governor or equivalent controls" as used herein shall mean the required hardware and/or software that provides frequency responsive real power control with the ability to sense changes in system frequency and autonomously adjust the Large Generating Facility's real power output in accordance with the droop and deadband parameters and in the direction needed to correct frequency deviations. Interconnection Customer is required to install a governor or equivalent controls with the capability of operating: (1) with a maximum 5 percent droop and ± 0.036 Hz deadband; or (2) in accordance with the relevant

droop, deadband, and timely and sustained response settings from an approved Electric Reliability Organization reliability standard providing for equivalent or more stringent parameters. The droop characteristic shall be: (1) based on the nameplate capacity of the Large Generating Facility, and shall be linear in the range of frequencies between 59 to 61 Hz that are outside of the deadband parameter; or (2) based on an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter. The deadband parameter shall be: the range of frequencies above and below nominal (60 Hz) in which the governor or equivalent controls is not expected to adjust the Large Generating Facility's real power output in response to frequency deviations. The deadband shall be implemented: (1) without a step to the droop curve, that is, once the frequency deviation exceeds the deadband parameter, the expected change in the Large Generating Facility's real power output in response to frequency deviations shall start from zero and then increase (for under-frequency deviations) or decrease (for over-frequency deviations) linearly in proportion to the magnitude of the frequency deviation; or (2) in accordance with an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter. Interconnection Customer shall notify Transmission Provider that the primary frequency response capability of the Large Generating Facility has been tested and confirmed during commissioning. Once Interconnection Customer has synchronized the Large Generating Facility with the Transmission system, Interconnection Customer shall operate the Large Generating Facility consistent with the provisions specified in articles 9.6.4.1 and 9.6.4.2 of this Agreement. The primary frequency response requirements contained herein shall apply to both synchronous and non-synchronous Large Generating Facilities.

9.6.4.1 Governor or Equivalent Controls. Whenever the Large Generating Facility is operated in parallel with the Transmission System, Interconnection Customer shall operate the Large Generating Facility with its governor or equivalent controls in service and responsive to frequency. Interconnection Customer shall: (1) in coordination with Transmission Provider and/or the relevant balancing authority, set the deadband parameter to: (1) a maximum of

± 0.036 Hz and set the droop parameter to a maximum of 5 percent; or (2) implement the relevant droop and deadband settings from an approved Electric Reliability Organization reliability standard that provides for equivalent or more stringent parameters. Interconnection Customer shall be required to provide the status and settings of the governor or equivalent controls to Transmission Provider and/or the relevant balancing authority upon request. If Interconnection Customer needs to operate the Large Generating Facility with its governor or equivalent controls not in service, Interconnection Customer shall immediately notify Transmission Provider and the relevant balancing authority, and provide both with the following information: (1) the operating status of the governor or equivalent controls (i.e., whether it is currently out of service or when it will be taken out of service); (2) the reasons for removing the governor or equivalent controls from service; and (3) a reasonable estimate of when the governor or equivalent controls will be returned to service. Interconnection Customer shall make Reasonable Efforts to return its governor or equivalent controls into service as soon as practicable. Interconnection Customer shall make Reasonable Efforts to keep outages of the Large Generating Facility's governor or equivalent controls to a minimum whenever the Large Generating Facility is operated in parallel with the Transmission System.

9.6.4.2 Timely and Sustained Response. Interconnection Customer shall ensure that the Large Generating Facility's real power response to sustained frequency deviations outside of the deadband setting is automatically provided and shall begin immediately after frequency deviates outside of the deadband, and to the extent the Large Generating Facility has operating capability in the direction needed to correct the frequency deviation. Interconnection Customer shall not block or otherwise inhibit the ability of the governor or equivalent controls to respond and shall ensure that the response is not inhibited, except under certain operational constraints

including, but not limited to, ambient temperature limitations, physical energy limitations, outages of mechanical equipment, or regulatory requirements. The Large Generating Facility shall sustain the real power response at least until system frequency returns to a value within the deadband setting of the governor or equivalent controls. A Commission-approved reliability standard with equivalent or more stringent requirements shall supersede the above requirements.

- 9.6.4.3 Exemptions. Large Generating Facilities that are regulated by the United States Nuclear Regulatory Commission shall be exempt from articles 9.6.4, 9.6.4.1, and 9.6.4.2 of this Agreement. Large Generating Facilities that are behind the meter generation that is sized-to-load (i.e., the thermal load and the generation are near-balanced in real-time operation and the generation is primarily controlled to maintain the unique thermal, chemical, or mechanical output necessary for the operating requirements of its host facility) shall be required to install primary frequency response capability in accordance with the droop and deadband capability requirements specified in article 9.6.4, but shall be otherwise exempt from the operating requirements in articles 9.6.4, 9.6.4.1, 9.6.4.2, and 9.6.4.4 of this Agreement.
- 9.6.4.4 Electric Storage Resources. Interconnection Customer interconnecting a Generating Facility that contains an electric storage resource shall establish an operating range in Appendix C of its LGIA that specifies a minimum state of charge and a maximum state of charge between which the electric storage resource will be required to provide primary frequency response consistent with the conditions set forth in articles 9.6.4, 9.6.4.1, 9.6.4.2 and 9.6.4.3 of this Agreement. Appendix C shall specify whether the operating range is static or dynamic, and shall consider (1) the expected magnitude of frequency deviations in the interconnection; (2) the expected

duration that system frequency will remain outside of the deadband parameter in the interconnection; (3) the expected incidence of frequency deviations outside of the deadband parameter in the interconnection; (4) the physical capabilities of the electric storage resource; (5) operational limitations of the electric storage resource due to manufacturer specifications; and (6) any other relevant factors agreed to by Transmission Provider and Interconnection Customer, and in consultation with the relevant transmission owner or balancing authority as appropriate. If the operating range is dynamic, then Appendix C must establish how frequently the operating range will be reevaluated and the factors that may be considered during its reevaluation.

Interconnection Customer's electric storage resource is required to provide timely and sustained primary frequency response consistent with article 9.6.4.2 of this Agreement when it is online and dispatched to inject electricity to the Transmission System and/or receive electricity from the Transmission System. This excludes circumstances when the electric storage resource is not dispatched to inject electricity to the Transmission System and/or dispatched to receive electricity from the Transmission System. If Interconnection

Customer's electric storage resource is charging at the time of a frequency deviation outside of its deadband parameter, it is to increase (for over-frequency deviations) or decrease (for under-frequency deviations) the rate at which it is charging in accordance with its droop parameter. Interconnection Customer's electric storage resource is not required to change from charging to discharging, or vice versa, unless the response necessitated by the droop and deadband settings requires it to do so and it is technically capable of making such a transition.

9.7 Outages and Interruptions.

9.7.1 Outages.

9.7.1.1 Outage Authority and Coordination. Each Party may in accordance with Good Utility Practice in coordination with the other Party remove from service any of its respective Interconnection Facilities or Network Upgrades that may impact the other Party's facilities as necessary to perform maintenance or testing or to install or replace equipment. Absent an Emergency Condition, the Party scheduling a removal of such facility(ies) from service will use Reasonable Efforts to schedule such removal on a date and time mutually acceptable to the Parties. In all circumstances, any Party planning to remove such facility(ies) from service shall use Reasonable Efforts to minimize the effect on the other Party of such removal.

9.7.1.2 Outage Schedules. Transmission Provider shall post scheduled outages of its transmission facilities on the OASIS. Interconnection Customer shall submit its planned maintenance schedules for the Large Generating Facility to Transmission Provider for a minimum of a rolling twenty-four month period. Interconnection Customer shall update its planned maintenance schedules as necessary. Transmission Provider may request Interconnection Customer to reschedule its maintenance as necessary to maintain the reliability of the Transmission System; provided, however, adequacy of generation supply shall not be a criterion in determining Transmission System reliability. Transmission Provider shall compensate Interconnection Customer for any additional direct costs that Interconnection Customer incurs as a result of having to reschedule maintenance, including any additional overtime, breaking of maintenance contracts or other costs above and beyond the cost Interconnection Customer would have incurred absent Transmission Provider's request to reschedule maintenance. Interconnection Customer will not

be eligible to receive compensation, if during the twelve (12) months prior to the date of the scheduled maintenance, Interconnection Customer had modified its schedule of maintenance activities.

9.7.1.3 **Outage Restoration.** If an outage on a Party's Interconnection Facilities or Network Upgrades adversely affects the other Party's operations or facilities, the Party that owns or controls the facility that is out of service shall use Reasonable Efforts to promptly restore such facility(ies) to a normal operating condition consistent with the nature of the outage. The Party that owns or controls the facility that is out of service shall provide the other Party, to the extent such information is known, information on the nature of the Emergency Condition, an estimated time of restoration, and any corrective actions required. Initial verbal notice shall be followed up as soon as practicable with written notice explaining the nature of the outage.

9.7.2 Interruption of Service. If required by Good Utility Practice to do so, Transmission Provider may require Interconnection Customer to interrupt or reduce deliveries of electricity if such delivery of electricity could adversely affect Transmission Provider's ability to perform such activities as are necessary to safely and reliably operate and maintain the Transmission System. The following provisions shall apply to any interruption or reduction permitted under this Article 9.7.2:

9.7.2.1 The interruption or reduction shall continue only for so long as reasonably necessary under Good Utility Practice;

9.7.2.2 Any such interruption or reduction shall be made on an equitable, non-discriminatory basis with respect to all generating facilities directly connected to the Transmission System;

9.7.2.3 When the interruption or reduction must be made under circumstances which do not allow for advance notice, Transmission Provider shall notify Interconnection Customer by telephone as soon as practicable of the reasons for the curtailment, interruption, or reduction, and, if known, its expected duration. Telephone notification shall be followed by written notification as soon as practicable;

9.7.2.4 Except during the existence of an Emergency Condition, when the interruption or reduction can be scheduled without advance notice, Transmission Provider shall notify Interconnection Customer in advance regarding the timing of such scheduling and further notify Interconnection Customer of the expected duration. Transmission Provider shall coordinate with Interconnection Customer using Good Utility Practice to schedule the interruption or reduction during periods of least impact to Interconnection Customer and Transmission Provider;

9.7.2.5 The Parties shall cooperate and coordinate with each other to the extent necessary in order to restore the Large Generating Facility, Interconnection Facilities, and the Transmission System to their normal operating state, consistent with system conditions and Good Utility Practice.

9.7.3 Ride Through Capability and Performance. The Transmission System is designed to automatically activate a load-shed program as required by the Electric Reliability Organization in the event of an under-frequency system disturbance. Interconnection Customer shall implement under-frequency and over-frequency relay set points for the Large Generating Facility as required by the Electric Reliability Organization to ensure frequency “ride through” capability of the Transmission System. Large Generating Facility response to frequency deviations of pre-determined magnitudes, both under-frequency and over-frequency deviations, shall be studied and

coordinated with Transmission Provider in accordance with Good Utility Practice. Interconnection Customer shall also implement under-voltage and over-voltage relay set points, or equivalent electronic controls, as required by the Electric Reliability Organization to ensure voltage “ride through” capability of the Transmission System. The term “ride through” as used herein shall mean the ability of a Generating Facility to stay connected to and synchronized with the Transmission System during system disturbances within a range of under-frequency, over-frequency, under-voltage, and over-voltage conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other Generating Facilities in the Balancing Authority Area on a comparable basis. For abnormal frequency conditions and voltage conditions within the “no trip zone” defined by Reliability Standard PRC-024-3 or successor mandatory ride through reliability standards, the non-synchronous Large Generating Facility must ensure that, within any physical limitations of the Large Generating Facility, its control and protection settings are configured or set to (1) continue active power production during disturbance and post disturbance periods at pre-disturbance levels, unless reactive power priority mode is enabled or unless providing primary frequency response or fast frequency response; (2) minimize reductions in active power and remain within dynamic voltage and current limits, if reactive power priority mode is enabled, unless providing primary frequency response or fast frequency response; (3) not artificially limit dynamic reactive power capability during disturbances; and (4) return to pre-disturbance active power levels without artificial ramp rate limits if active power is reduced, unless providing primary frequency response or fast frequency response.

9.7.4 System Protection and Other Control Requirements.

9.7.4.1 System Protection Facilities. Interconnection Customer shall, at its expense, install, operate and maintain System Protection Facilities as a part of the Large Generating Facility or Interconnection Customer’s Interconnection Facilities. Transmission Provider shall install at Interconnection Customer’s expense any System Protection Facilities that

may be required on Transmission Provider's Interconnection Facilities or the Transmission System as a result of the interconnection of the Large Generating Facility and Interconnection Customer's Interconnection Facilities.

- 9.7.4.2** Each Party's protection facilities shall be designed and coordinated with other systems in accordance with Good Utility Practice.
- 9.7.4.3** Each Party shall be responsible for protection of its facilities consistent with Good Utility Practice.
- 9.7.4.4** Each Party's protective relay design shall incorporate the necessary test switches to perform the tests required in Article 6. The required test switches will be placed such that they allow operation of lockout relays while preventing breaker failure schemes from operating and causing unnecessary breaker operations and/or the tripping of Interconnection Customer's units.
- 9.7.4.5** Each Party will test, operate and maintain System Protection Facilities in accordance with Good Utility Practice.
- 9.7.4.6** Prior to the In-Service Date, and again prior to the Commercial Operation Date, each Party or its agent shall perform a complete calibration test and functional trip test of the System Protection Facilities. At intervals suggested by Good Utility Practice and following any apparent malfunction of the System Protection Facilities, each Party shall perform both calibration and functional trip tests of its System Protection Facilities. These tests do not require the tripping of any in-service generation unit. These tests do, however,

require that all protective relays and lockout contacts be activated.

- 9.7.5 Requirements for Protection. In compliance with Good Utility Practice, Interconnection Customer shall provide, install, own, and maintain relays, circuit breakers and all other devices necessary to remove any fault contribution of the Large Generating Facility to any short circuit occurring on the Transmission System not otherwise isolated by Transmission Provider's equipment, such that the removal of the fault contribution shall be coordinated with the protective requirements of the Transmission System. Such protective equipment shall include, without limitation, a disconnecting device or switch with load-interrupting capability located between the Large Generating Facility and the Transmission System at a site selected upon mutual agreement (not to be unreasonably withheld, conditioned or delayed) of the Parties. Interconnection Customer shall be responsible for protection of the Large Generating Facility and Interconnection Customer's other equipment from such conditions as negative sequence currents, over- or under-frequency, sudden load rejection, over- or under-voltage, and generator loss-of-field. Interconnection Customer shall be solely responsible to disconnect the Large Generating Facility and Interconnection Customer's other equipment if conditions on the Transmission System could adversely affect the Large Generating Facility.
- 9.7.6 Power Quality. Neither Party's facilities shall cause excessive voltage flicker nor introduce excessive distortion to the sinusoidal voltage or current waves as defined by ANSI Standard C84.1-1989, in accordance with IEEE Standard 519, or any applicable superseding electric industry standard. In the event of a conflict between ANSI Standard C84.1-1989, or any applicable superseding electric industry standard, ANSI Standard C84.1-1989, or the applicable superseding electric industry standard, shall control.
- 9.8 Switching and Tagging Rules. Each Party shall provide the other Party a copy of its switching and tagging rules that are applicable to the other Party's activities.

Such switching and tagging rules shall be developed on a non-discriminatory basis. The Parties shall comply with applicable switching and tagging rules, as amended from time to time, in obtaining clearances for work or for switching operations on equipment.

9.9 Use of Interconnection Facilities by Third Parties.

9.9.1 Purpose of Interconnection Facilities. Except as may be required by Applicable Laws and Regulations, or as otherwise agreed to among the Parties, the Interconnection Facilities shall be constructed for the sole purpose of interconnecting the Large Generating Facility to the Transmission System and shall be used for no other purpose.

9.9.2 Third Party Users. If required by Applicable Laws and Regulations or if the Parties mutually agree, such agreement not to be unreasonably withheld, to allow one or more third parties to use Transmission Provider's Interconnection Facilities, or any part thereof, Interconnection Customer will be entitled to compensation for the capital expenses it incurred in connection with the Interconnection Facilities based upon the pro rata use of the Interconnection Facilities by Transmission Provider, all third party users, and Interconnection Customer, in accordance with Applicable Laws and Regulations or upon some other mutually-agreed upon methodology. In addition, cost responsibility for ongoing costs, including operation and maintenance costs associated with the Interconnection Facilities, will be allocated between Interconnection Customer and any third party users based upon the pro rata use of the Interconnection Facilities by Transmission Provider, all third party users, and Interconnection Customer, in accordance with Applicable Laws and Regulations or upon some other mutually agreed upon methodology. If the issue of such compensation or allocation cannot be resolved through such negotiations, it shall be submitted to FERC for resolution.

9.10 Disturbance Analysis Data Exchange. The Parties will cooperate with one another in the analysis of disturbances to either the Large Generating Facility or

Transmission Provider's Transmission System by gathering and providing access to any information relating to any disturbance, including information from oscillography, protective relay targets, breaker operations and sequence of events records, and any disturbance information required by Good Utility Practice.

Article 10. Maintenance

10.1 Transmission Provider Obligations. Transmission Provider shall maintain the Transmission System and Transmission Provider's Interconnection Facilities in a safe and reliable manner and in accordance with this LGIA.

10.2 Interconnection Customer Obligations. Interconnection Customer shall maintain the Large Generating Facility and Interconnection Customer's Interconnection Facilities in a safe and reliable manner and in accordance with this LGIA.

10.3 Coordination. The Parties shall confer regularly to coordinate the planning, scheduling and performance of preventive and corrective maintenance on the Large Generating Facility and the Interconnection Facilities.

10.4 Secondary Systems. Each Party shall cooperate with the other in the inspection, maintenance, and testing of control or power circuits that operate below 600 volts, AC or DC, including, but not limited to, any hardware, control or protective devices, cables, conductors, electric raceways, secondary equipment panels, transducers, batteries, chargers, and voltage and current transformers that directly affect the operation of a Party's facilities and equipment which may reasonably be expected to impact the other Party. Each Party shall provide advance notice to the other Party before undertaking any work on such circuits, especially on electrical circuits involving circuit breaker trip and close contacts, current transformers, or potential transformers.

- 10.5 **Operating and Maintenance Expenses.** Subject to the provisions herein addressing the use of facilities by others, and except for operations and maintenance expenses associated with modifications made for providing interconnection or transmission service to a third party and such third party pays for such expenses, Interconnection Customer shall be responsible for all reasonable expenses including overheads, associated with: (1) owning, operating, maintaining, repairing, and replacing Interconnection Customer's Interconnection Facilities; and (2) operation, maintenance, repair and replacement of Transmission Provider's Interconnection Facilities.

Article 11. Performance Obligation

- 11.1 **Interconnection Customer Interconnection Facilities.** Interconnection Customer shall design, procure, construct, install, own and/or control Interconnection Customer Interconnection Facilities described in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades, at its sole expense.
- 11.2 **Transmission Provider's Interconnection Facilities.** Transmission Provider or Transmission Owner shall design, procure, construct, install, own and/or control Transmission Provider's Interconnection Facilities described in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades, at the sole expense of Interconnection Customer.
- 11.3 **Network Upgrades and Distribution Upgrades.** Transmission Provider or Transmission Owner shall design, procure, construct, install, and own the Network Upgrades and Distribution Upgrades described in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades. Interconnection Customer shall be responsible for all costs related to Distribution Upgrades. Unless Transmission Provider or Transmission Owner elects to fund the capital for the Network Upgrades, they shall be solely funded by Interconnection Customer.
- 11.4 **Transmission Credits.**

11.4.1 Repayment of Amounts Advanced for Network Upgrades. Interconnection Customer shall be entitled to a cash repayment, equal to the total amount paid to Transmission Provider and Affected System Operator, if any, for the Network Upgrades, including any tax gross-up or other tax-related payments associated with Network Upgrades, and not refunded to Interconnection Customer pursuant to Article 5.17.8 or otherwise, to be paid to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, as payments are made under Transmission Provider's Tariff and Affected System's Tariff for transmission services with respect to the Large Generating Facility. Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 C.F.R. § 35.19a(a)(2)(iii) from the date of any payment for Network Upgrades through the date on which Interconnection Customer receives a repayment of such payment pursuant to this subparagraph. Interconnection Customer may assign such repayment rights to any person.

Notwithstanding the foregoing, Interconnection Customer, Transmission Provider, and Affected System Operator may adopt any alternative payment schedule that is mutually agreeable so long as Transmission Provider and Affected System Operator take one of the following actions no later than five years from the Commercial Operation Date: (1) return to Interconnection Customer any amounts advanced for Network Upgrades not previously repaid, or (2) declare in writing that Transmission Provider or Affected System Operator will continue to provide payments to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, or develop an alternative schedule that is mutually agreeable and provides for the return of all amounts advanced for Network Upgrades not previously repaid; however, full reimbursement shall not extend beyond twenty (20) years from the Commercial Operation Date.

If the Large Generating Facility fails to achieve commercial operation, but it or another Generating Facility is later constructed and makes use of the Network Upgrades, Transmission Provider and Affected System Operator shall at that time reimburse Interconnection Customer for the amounts advanced for the Network Upgrades. Before any such reimbursement can occur, Interconnection Customer, or the entity that ultimately constructs the Generating Facility, if different, is responsible for identifying the entity to which reimbursement must be made.

11.4.2 Special Provisions for Affected Systems. Unless Transmission Provider provides, under the LGIA, for the repayment of amounts advanced to Affected System Operator for Network Upgrades, Interconnection Customer and Affected System Operator shall enter into an agreement that provides for such repayment. The agreement shall specify the terms governing payments to be made by Interconnection Customer to the Affected System Operator as well as the repayment by the Affected System Operator.

11.4.3 Notwithstanding any other provision of this LGIA, nothing herein shall be construed as relinquishing or foreclosing any rights, including but not limited to firm transmission rights, capacity rights, transmission congestion rights, or transmission credits, that Interconnection Customer, shall be entitled to, now or in the future under any other agreement or tariff as a result of, or otherwise associated with, the transmission capacity, if any, created by the Network Upgrades, including the right to obtain cash reimbursements or transmission credits for transmission service that is not associated with the Large Generating Facility.

11.5 Provision of Security. At least thirty (30) Calendar Days prior to the commencement of the procurement, installation, or construction of a discrete portion of a Transmission Provider's Interconnection Facilities, Network Upgrades, or Distribution Upgrades, Interconnection Customer shall provide

Transmission Provider, at Interconnection Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to Transmission Provider and is consistent with the Uniform Commercial Code of the jurisdiction identified in Article 14.2.1. Such security for payment, as specified in Appendix B of this LGIA, shall be in an amount sufficient to cover the costs for constructing, procuring and installing the applicable portion of Transmission Provider's Interconnection Facilities, Network Upgrades, or Distribution Upgrades and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider for these purposes. Transmission Provider must use the LGIA Deposit required in Section 11.3 of the LGIP before requiring Interconnection Customer to submit security in addition to that LGIA Deposit. Transmission Provider must specify, in Appendix B of this LGIA, the dates for which Interconnection Customer must provide additional security for construction of each discrete portion of Transmission Provider's Interconnection Facilities, Network Upgrades, or Distribution Upgrades and Interconnection Customer must provide such additional security.

In addition:

- 11.5.1** The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider, and contain terms and conditions that guarantee payment of any amount that may be due from Interconnection Customer, up to an agreed-to maximum amount.
- 11.5.2** The letter of credit must be issued by a financial institution reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.
- 11.5.3** The surety bond must be issued by an insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.

11.6 Interconnection Customer Compensation. If Transmission Provider requests or directs Interconnection Customer to provide a service pursuant to Articles 9.6.3 (Payment for Reactive Power), or 13.5.1 of this LGIA, Transmission Provider shall compensate Interconnection Customer in accordance with Interconnection Customer's applicable rate schedule then in effect unless the provision of such service(s) is subject to an RTO or ISO FERC-approved rate schedule. Interconnection Customer shall serve Transmission Provider or RTO or ISO with any filing of a proposed rate schedule at the time of such filing with FERC. To the extent that no rate schedule is in effect at the time Interconnection Customer is required to provide or absorb any Reactive Power under this LGIA, Transmission Provider agrees to compensate Interconnection Customer in such amount as would have been due Interconnection Customer had the rate schedule been in effect at the time service commenced; provided, however, that such rate schedule must be filed at FERC or other appropriate Governmental Authority within sixty (60) Calendar Days of the commencement of service.

11.6.1 Interconnection Customer Compensation for Actions During Emergency Condition. Transmission Provider or RTO or ISO shall compensate Interconnection Customer for its provision of real and reactive power and other Emergency Condition services that Interconnection Customer provides to support the Transmission System during an Emergency Condition in accordance with Article 11.6.

Article 12. Invoice

12.1 General. Each Party shall submit to the other Party, on a monthly basis, invoices of amounts due for the preceding month. Each invoice shall state the month to which the invoice applies and fully describe the services and equipment provided. The Parties may discharge mutual debts and payment obligations due and owing to each other on the same date through netting, in which case all amounts a Party owes to the other Party under this LGIA, including interest payments or credits, shall be netted so that only the net amount remaining due shall be paid by the owing Party.

- 12.2 Final Invoice. Within six months after completion of the construction of Transmission Provider's Interconnection Facilities and the Network Upgrades, Transmission Provider shall provide an invoice of the final cost of the construction of Transmission Provider's Interconnection Facilities and the Network Upgrades and shall set forth such costs in sufficient detail to enable Interconnection Customer to compare the actual costs with the estimates and to ascertain deviations, if any, from the cost estimates. Transmission Provider shall refund to Interconnection Customer any amount by which the actual payment by Interconnection Customer for estimated costs exceeds the actual costs of construction within thirty (30) Calendar Days of the issuance of such final construction invoice.
- 12.3 Payment. Invoices shall be rendered to the paying Party at the address specified in Appendix F. The Party receiving the invoice shall pay the invoice within thirty (30) Calendar Days of receipt. All payments shall be made in immediately available funds payable to the other Party, or by wire transfer to a bank named and account designated by the invoicing Party. Payment of invoices by either Party will not constitute a waiver of any rights or claims either Party may have under this LGIA.
- 12.4 Disputes. In the event of a billing dispute between Transmission Provider and Interconnection Customer, Transmission Provider shall continue to provide Interconnection Service under this LGIA as long as Interconnection Customer: (i) continues to make all payments not in dispute; and (ii) pays to Transmission Provider or into an independent escrow account the portion of the invoice in dispute, pending resolution of such dispute. If Interconnection Customer fails to meet these two requirements for continuation of service, then Transmission Provider may provide notice to Interconnection Customer of a Default pursuant to Article 17. Within thirty (30) Calendar Days after the resolution of the dispute, the Party that owes money to the other Party shall pay the amount due with interest calculated in accord with the methodology set forth in FERC's regulations at 18 CFR § 35.19a(a)(2)(iii).

Article 13. Emergencies

13.1 Definition. “Emergency Condition” shall mean a condition or situation: (i) that in

the judgment of the Party making the claim is imminently likely to endanger life or property; or (ii) that, in the case of Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to the Transmission System, Transmission Provider’s Interconnection Facilities or the Transmission Systems of others to which the Transmission System is directly connected; or (iii) that, in the case of Interconnection Customer, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Large Generating Facility or Interconnection Customer’s Interconnection Facilities’ System restoration and black start shall be considered Emergency Conditions; provided, that Interconnection Customer is not obligated by this LGIA to possess black start capability.

13.2 Obligations. Each Party shall comply with the Emergency Condition procedures of the applicable ISO/RTO, the Electric Reliability Organization, Applicable Laws and Regulations, and any emergency procedures agreed to by the Joint Operating Committee.

13.3 Notice. Transmission Provider shall notify Interconnection Customer promptly when it becomes aware of an Emergency Condition that affects Transmission Provider’s Interconnection Facilities or the Transmission System that may reasonably be expected to affect Interconnection Customer’s operation of the Large Generating Facility or Interconnection Customer’s Interconnection Facilities. Interconnection Customer shall notify Transmission Provider promptly when it becomes aware of an Emergency Condition that affects the Large Generating Facility or Interconnection Customer’s Interconnection Facilities that may reasonably be expected to affect the Transmission System or Transmission Provider’s Interconnection Facilities. To the extent information is known, the notification shall describe the Emergency Condition, the extent of the damage or deficiency, the expected effect on the operation of Interconnection Customer’s or Transmission Provider’s facilities and operations, its anticipated duration and the corrective action taken and/or to be taken. The initial notice shall be followed as soon as practicable with written notice.

13.4 Immediate Action. Unless, in Interconnection Customer's reasonable judgment, immediate action is required, Interconnection Customer shall obtain the consent of Transmission Provider, such consent to not be unreasonably withheld, prior to performing any manual switching operations at the Large Generating Facility or Interconnection Customer's Interconnection Facilities in response to an Emergency Condition either declared by Transmission Provider or otherwise regarding the Transmission System.

13.5 Transmission Provider Authority.

13.5.1 General. Transmission Provider may take whatever actions or inactions with regard to the Transmission System or Transmission Provider's Interconnection Facilities it deems necessary during an Emergency Condition in order to (i) preserve public health and safety, (ii) preserve the reliability of the Transmission System or Transmission Provider's Interconnection Facilities, (iii) limit or prevent damage, and (iv) expedite restoration of service.

Transmission Provider shall use Reasonable Efforts to minimize the effect of such actions or inactions on the Large Generating Facility or Interconnection Customer's Interconnection Facilities.

Transmission Provider may, on the basis of technical considerations, require the Large Generating Facility to mitigate an Emergency Condition by taking actions necessary and limited in scope to remedy the Emergency Condition, including, but not limited to, directing Interconnection Customer to shut-down, start-up, increase or decrease the real or reactive power output of the Large Generating Facility; implementing a reduction or disconnection pursuant to Article 13.5.2; directing Interconnection Customer to assist with blackstart (if available) or restoration efforts; or altering the outage schedules of the Large Generating Facility and Interconnection Customer's Interconnection Facilities. Interconnection Customer shall comply with all of Transmission Provider's operating instructions concerning Large Generating Facility real power and

reactive power output within the manufacturer's design limitations of the Large Generating Facility's equipment that is in service and physically available for operation at the time, in compliance with Applicable Laws and Regulations.

13.5.2 Reduction and Disconnection. Transmission Provider may reduce Interconnection Service or disconnect the Large Generating Facility or Interconnection Customer's Interconnection Facilities, when such, reduction or disconnection is necessary under Good Utility Practice due to Emergency Conditions. These rights are separate and distinct from any right of curtailment of Transmission Provider pursuant to Transmission Provider's Tariff. When Transmission Provider can schedule the reduction or disconnection in advance, Transmission Provider shall notify Interconnection Customer of the reasons, timing and expected duration of the reduction or disconnection. Transmission Provider shall coordinate with Interconnection Customer using Good Utility Practice to schedule the reduction or disconnection during periods of least impact to Interconnection Customer and Transmission Provider. Any reduction or disconnection shall continue only for so long as reasonably necessary under Good Utility Practice. The Parties shall cooperate with each other to restore the Large Generating Facility, the Interconnection Facilities, and the Transmission System to their normal operating state as soon as practicable consistent with Good Utility Practice.

13.6 Interconnection Customer Authority. Consistent with Good Utility Practice and the LGIA and the LGIP, Interconnection Customer may take actions or inactions with regard to the Large Generating Facility or Interconnection Customer's Interconnection Facilities during an Emergency Condition in order to (i) preserve public health and safety, (ii) preserve the reliability of the Large Generating Facility or Interconnection Customer's Interconnection Facilities, (iii) limit or prevent damage, and (iv) expedite restoration of service. Interconnection Customer shall use Reasonable Efforts to minimize the effect of such actions or inactions on the Transmission System and Transmission Provider's

Interconnection Facilities. Transmission Provider shall use Reasonable Efforts to assist Interconnection Customer in such actions.

- 13.7 Limited Liability. Except as otherwise provided in Article 11.6.1 of this LGIA, neither Party shall be liable to the other for any action it takes in responding to an Emergency Condition so long as such action is made in good faith and is consistent with Good Utility Practice.

Article 14. Regulatory Requirements and Governing Law

- 14.1 Regulatory Requirements. Each Party's obligations under this LGIA shall be subject to its receipt of any required approval or certificate from one or more Governmental Authorities in the form and substance satisfactory to the applying Party, or the Party making any required filings with, or providing notice to, such Governmental Authorities, and the expiration of any time period associated therewith. Each Party shall in good faith seek and use its Reasonable Efforts to obtain such other approvals. Nothing in this LGIA shall require Interconnection Customer to take any action that could result in its inability to obtain, or its loss of, status or exemption under the Federal Power Act, the Public Utility Holding Company Act of 1935, as amended, or the Public Utility Regulatory Policies Act of 1978.

14.2 Governing Law.

- 14.2.1** The validity, interpretation and performance of this LGIA and each of its provisions shall be governed by the laws of the state where the Point of Interconnection is located, without regard to its conflicts of law principles.

- 14.2.2** This LGIA is subject to all Applicable Laws and Regulations.

14.2.3 Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, rules, or regulations of a Governmental Authority.

Article 15. Notices.

15.1 General. Unless otherwise provided in this LGIA, any notice, demand or request required or permitted to be given by either Party to the other and any instrument required or permitted to be tendered or delivered by either Party in writing to the other shall be effective when delivered and may be so given, tendered or delivered, by recognized national courier, or by depositing the same with the United States Postal Service with postage prepaid, for delivery by certified or registered mail, addressed to the Party, or personally delivered to the Party, at the address set out in Appendix F, Addresses for Delivery of Notices and Billings.

Either Party may change the notice information in this LGIA by giving five (5) Business Days written notice prior to the effective date of the change.

15.2 Billings and Payments. Billings and payments shall be sent to the addresses set out in Appendix F.

15.3 Alternative Forms of Notice. Any notice or request required or permitted to be given by a Party to the other and not required by this Agreement to be given in writing may be so given by telephone, facsimile or email to the telephone numbers and email addresses set out in Appendix F.

15.4 Operations and Maintenance Notice. Each Party shall notify the other Party in writing of the identity of the person(s) that it designates as the point(s) of contact with respect to the implementation of Articles 9 and 10.

Article 16. Force Majeure

16.1 Force Majeure.

16.1.1 Economic hardship is not considered a Force Majeure event.

16.1.2 Neither Party shall be considered to be in Default with respect to any obligation hereunder, (including obligations under Article 4), other than the obligation to pay money when due, if prevented from fulfilling such obligation by Force Majeure. A Party unable to fulfill any obligation hereunder (other than an obligation to pay money when due) by reason of Force Majeure shall give notice and the full particulars of such Force Majeure to the other Party in writing or by telephone as soon as reasonably possible after the occurrence of the cause relied upon. Telephone notices given pursuant to this article shall be confirmed in writing as soon as reasonably possible and shall specifically state full particulars of the Force Majeure, the time and date when the Force Majeure occurred and when the Force Majeure is reasonably expected to cease. The Party affected shall exercise due diligence to remove such disability with reasonable dispatch, but shall not be required to accede or agree to any provision not satisfactory to it in order to settle and terminate a strike or other labor disturbance.

Article 17. Default

17.1 Default

17.1.1 General. No Default shall exist where such failure to discharge an obligation (other than the payment of money) is the result of Force Majeure as defined in this LGIA or the result of an act of omission of the other Party. Upon a Breach, the non-breaching Party shall give written notice of such Breach to the breaching Party. Except as provided in Article 17.1.2, the breaching Party shall have thirty (30)

Calendar Days from receipt of the Default notice within which to cure such Breach; provided however, if such Breach is not capable of cure within thirty (30) Calendar Days, the breaching Party shall commence such cure within thirty (30) Calendar Days after notice and continuously and diligently complete such cure within ninety (90) Calendar Days from receipt of the Default notice; and, if cured within such time, the Breach specified in such notice shall cease to exist.

17.1.2 Right to Terminate. If a Breach is not cured as provided in this article, or if a Breach is not capable of being cured within the period provided for herein, the non-breaching Party shall have the right to declare a Default and terminate this LGIA by written notice at any time until cure occurs, and be relieved of any further obligation hereunder and, whether or not that Party terminates this LGIA, to recover from the breaching Party all amounts due hereunder, plus all other damages and remedies to which it is entitled at law or in equity. The provisions of this article will survive termination of this LGIA.

17.2 Violation of Operating Assumptions for Generating Facilities. If Transmission Provider requires Interconnection Customer to memorialize the operating assumptions for the charging behavior of a Generating Facility that includes at least one electric storage resource in Appendix H of this LGIA, Transmission Provider may consider Interconnection Customer to be in Breach of the LGIA if Interconnection Customer fails to operate the Generating Facility in accordance with those operating assumptions for charging behavior. However, if Interconnection Customer operates contrary to the operating assumptions for charging behavior specified in Appendix H of this LGIA at the direction of Transmission Provider, Transmission Provider shall not consider Interconnection Customer in Breach of this LGIA.

Article 18. Indemnity, Consequential Damages and Insurance

18.1 Indemnity. The Parties shall at all times indemnify, defend, and hold the other Party harmless from, any and all damages, losses, claims, including claims and actions relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's action or inactions of its obligations under this LGIA on behalf of the Indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the indemnified Party.

18.1.1 Indemnified Person. If an Indemnified Person is entitled to indemnification under this Article 18 as a result of a claim by a third party, and the Indemnifying Party fails, after notice and reasonable opportunity to proceed under Article 18.1, to assume the defense of such claim, such Indemnified Person may at the expense of the Indemnifying Party contest, settle or consent to the entry of any judgment with respect to, or pay in full, such claim.

18.1.2 Indemnifying Party. If an Indemnifying Party is obligated to indemnify and hold any Indemnified Person harmless under this Article 18, the amount owing to the Indemnified Person shall be the amount of such Indemnified Person's actual Loss, net of any insurance or other recovery.

18.1.3 Indemnity Procedures. Promptly after receipt by an Indemnified Person of any claim or notice of the commencement of any action or administrative or legal proceeding or investigation as to which the indemnity provided for in Article 18.1 may apply, the Indemnified Person shall notify the Indemnifying Party of such fact. Any failure of or delay in such notification shall not affect a Party's indemnification obligation unless such failure or delay is materially prejudicial to the Indemnifying Party.

The Indemnifying Party shall have the right to assume the defense thereof with counsel designated by such Indemnifying Party and

reasonably satisfactory to the Indemnified Person. If the defendants in any such action include one or more Indemnified Persons and the Indemnifying Party and if the Indemnified Person reasonably concludes that there may be legal defenses available to it and/or other Indemnified Persons which are different from or additional to those available to the Indemnifying Party, the Indemnified Person shall have the right to select separate counsel to assert such legal defenses and to otherwise participate in the defense of such action on its own behalf. In such instances, the Indemnifying Party shall only be required to pay the fees and expenses of one additional attorney to represent an Indemnified Person or Indemnified Persons having such differing or additional legal defenses.

The Indemnified Person shall be entitled, at its expense, to participate in any such action, suit or proceeding, the defense of which has been assumed by the Indemnifying Party.

Notwithstanding the foregoing, the Indemnifying Party (i) shall not be entitled to assume and control the defense of any such action, suit or proceedings if and to the extent that, in the opinion of the Indemnified Person and its counsel, such action, suit or proceeding involves the potential imposition of criminal liability on the Indemnified Person, or there exists a conflict or adversity of interest between the Indemnified Person and the Indemnifying Party, in such event the Indemnifying Party shall pay the reasonable expenses of the Indemnified Person, and (ii) shall not settle or consent to the entry of any judgment in any action, suit or proceeding without the consent of the Indemnified Person, which shall not be reasonably withheld, conditioned or delayed.

- 18.2 Consequential Damages. Other than the Liquidated Damages heretofore described, in no event shall either Party be liable under any provision of this LGIA for any losses, damages, costs or expenses for any special, indirect, incidental, consequential, or punitive damages, including but not limited to loss of profit or revenue, loss of the use of equipment, cost of capital, cost of temporary equipment or services, whether based in whole or in part in contract, in tort, including negligence, strict liability, or any other theory of liability; provided, however, that

damages for which a Party may be liable to the other Party under another agreement will not be considered to be special, indirect, incidental, or consequential damages hereunder.

18.3 Insurance. Each party shall, at its own expense, maintain in force throughout the period of this LGIA, and until released by the other Party, the following minimum insurance coverages, with insurers authorized to do business in the state where the Point of Interconnection is located:

18.3.1 Employers' Liability and Workers' Compensation Insurance providing statutory benefits in accordance with the laws and regulations of the state in which the Point of Interconnection is located.

18.3.2 Commercial General Liability Insurance including premises and operations, personal injury, broad form property damage, broad form blanket contractual liability coverage (including coverage for the contractual indemnification) products and completed operations coverage, coverage for explosion, collapse and underground hazards, independent contractors coverage, coverage for pollution to the extent normally available and punitive damages to the extent normally available and a cross liability endorsement, with minimum limits of One Million Dollars (\$1,000,000) per occurrence/One Million Dollars (\$1,000,000) aggregate combined single limit for personal injury, bodily injury, including death and property damage.

18.3.3 Comprehensive Automobile Liability Insurance for coverage of owned and non-owned and hired vehicles, trailers or semi-trailers designed for travel on public roads, with a minimum, combined single limit of One Million Dollars (\$1,000,000) per occurrence for bodily injury, including death, and property damage.

- 18.3.4** Excess Public Liability Insurance over and above the Employers' Liability Commercial General Liability and Comprehensive Automobile Liability Insurance coverage, with a minimum combined single limit of Twenty Million Dollars (\$20,000,000) per occurrence/Twenty Million Dollars (\$20,000,000) aggregate.
- 18.3.5** The Commercial General Liability Insurance, Comprehensive Automobile Insurance and Excess Public Liability Insurance policies shall name the other Party, its parent, associated and Affiliate companies and their respective directors, officers, agents, servants and employees ("Other Party Group") as additional insured. All policies shall contain provisions whereby the insurers waive all rights of subrogation in accordance with the provisions of this LGIA against the Other Party Group and provide thirty (30) Calendar Days advance written notice to the Other Party Group prior to anniversary date of cancellation or any material change in coverage or condition.
- 18.3.6** The Commercial General Liability Insurance, Comprehensive Automobile Liability Insurance and Excess Public Liability Insurance policies shall contain provisions that specify that the policies are primary and shall apply to such extent without consideration for other policies separately carried and shall state that each insured is provided coverage as though a separate policy had been issued to each, except the insurer's liability shall not be increased beyond the amount for which the insurer would have been liable had only one insured been covered. Each Party shall be responsible for its respective deductibles or retentions.
- 18.3.7** The Commercial General Liability Insurance, Comprehensive Automobile Liability Insurance and Excess Public Liability Insurance policies, if written on a Claims First Made Basis, shall be maintained in full force and effect for two (2) years after termination of this LGIA, which coverage may be in the form of tail coverage or extended reporting period coverage if agreed by the Parties.

- 18.3.8** The requirements contained herein as to the types and limits of all insurance to be maintained by the Parties are not intended to and shall not in any manner, limit or qualify the liabilities and obligations assumed by the Parties under this LGIA.
- 18.3.9** Within ten (10) Business Days following execution of this LGIA, and as soon as practicable after the end of each fiscal year or at the renewal of the insurance policy and in any event within ninety (90) Calendar Days thereafter, each Party shall provide certification of all insurance required in this LGIA, executed by each insurer or by an authorized representative of each insurer.
- 18.3.10** Notwithstanding the foregoing, each Party may self-insure to meet the minimum insurance requirements of Articles 18.3.2 through 18.3.8 to the extent it maintains a self-insurance program; provided that, such Party's senior secured debt is rated at investment grade or better by Standard & Poor's and that its self-insurance program meets the minimum insurance requirements of Articles 18.3.2 through 18.3.8. For any period of time that a Party's senior secured debt is unrated by Standard & Poor's or is rated at less than investment grade by Standard & Poor's, such Party shall comply with the insurance requirements applicable to it under Articles 18.3.2 through 18.3.9. In the event that a Party is permitted to self-insure pursuant to this article, it shall notify the other Party that it meets the requirements to self-insure and that its self-insurance program meets the minimum insurance requirements in a manner consistent with that specified in Article 18.3.9.
- 18.3.11** The Parties agree to report to each other in writing as soon as practical all accidents or occurrences resulting in injuries to any person, including death, and any property damage arising out of this LGIA.

Article 19. Assignment

19.1 Assignment. This LGIA may be assigned by either Party only with the written consent of the other; provided that either Party may assign this LGIA without the consent of the other Party to any Affiliate of the assigning Party with an equal or greater credit rating and with the legal authority and operational ability to satisfy the obligations of the assigning Party under this LGIA; and provided further that Interconnection Customer shall have the right to assign this LGIA, without the consent of Transmission Provider, for collateral security purposes to aid in providing financing for the Large Generating Facility, provided that Interconnection Customer will promptly notify Transmission Provider of any such assignment. Any financing arrangement entered into by Interconnection Customer pursuant to this article will provide that prior to or upon the exercise of the secured party's, trustee's or mortgagee's assignment rights pursuant to said arrangement, the secured creditor, the trustee or mortgagee will notify Transmission Provider of the date and particulars of any such exercise of assignment right(s), including providing Transmission Provider with proof that it meets the requirements of Articles 11.5 and 18.3. Any attempted assignment that violates this article is void and ineffective. Any assignment under this LGIA shall not relieve a Party of its obligations, nor shall a Party's obligations be enlarged, in whole or in part, by reason thereof. Where required, consent to assignment will not be unreasonably withheld, conditioned or delayed.

Article 20. Severability

20.1 Severability. If any provision in this LGIA is finally determined to be invalid, void or unenforceable by any court or other Governmental Authority having jurisdiction, such determination shall not invalidate, void or make unenforceable any other provision, agreement or covenant of this LGIA; provided that if Interconnection Customer (or any third party, but only if such third party is not acting at the direction of Transmission Provider) seeks and obtains such a final determination with respect to any provision of the Alternate Option (Article 5.1.2), or the Negotiated Option (Article 5.1.4), then none of these provisions shall thereafter have any force or effect and the Parties' rights and obligations shall be governed solely by the Standard Option (Article 5.1.1).

Article 21. Comparability

21.1 Comparability. The Parties will comply with all applicable comparability and code of conduct laws, rules and regulations, as amended from time to time.

Article 22. Confidentiality

22.1 Confidentiality. Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied by either of the Parties to the other prior to the execution of this LGIA.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential.

If requested by either Party, the other Party shall provide in writing, the basis for asserting that the information referred to in this Article 22 warrants confidential treatment, and the requesting Party may disclose such writing to the appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

22.1.1 Term. During the term of this LGIA, and for a period of three (3) years after the expiration or termination of this LGIA, except as otherwise provided in this Article 22, each Party shall hold in confidence and shall not disclose to any person Confidential Information.

- 22.1.2 Scope. Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a third party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of this LGIA; or (6) is required, in accordance with Article 22.1.7 of the LGIA, Order of Disclosure, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under this LGIA. Information designated as Confidential Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the other Party that it no longer is confidential.
- 22.1.3 Release of Confidential Information. Neither Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), subcontractors, employees, consultants, or to parties who may be or considering providing financing to or equity participation with Interconnection Customer, or to potential purchasers or assignees of Interconnection Customer, on a need-to-know basis in connection with this LGIA, unless such person has first been advised of the confidentiality provisions of this Article 22 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Article 22.

- 22.1.4 Rights. Each Party retains all rights, title, and interest in the Confidential Information that each Party discloses to the other Party. The disclosure by each Party to the other Party of Confidential Information shall not be deemed a waiver by either Party or any other person or entity of the right to protect the Confidential Information from public disclosure.
- 22.1.5 No Warranties. By providing Confidential Information, neither Party makes any warranties or representations as to its accuracy or completeness. In addition, by supplying Confidential Information, neither Party obligates itself to provide any particular information or Confidential Information to the other Party nor to enter into any further agreements or proceed with any other relationship or joint venture.
- 22.1.6 Standard of Care. Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under this LGIA or its regulatory requirements.
- 22.1.7 Order of Disclosure. If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires either Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the other Party with prompt notice of such request(s) or requirement(s) so that the other Party may seek an appropriate protective order or waive compliance with the terms of this LGIA. Notwithstanding the absence of a protective order or waiver, the Party may disclose such Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance

that confidential treatment will be accorded any Confidential Information so furnished.

- 22.1.8 Termination of Agreement. Upon termination of this LGIA for any reason, each Party shall, within ten (10) Calendar Days of receipt of a written request from the other Party, use Reasonable Efforts to destroy, erase, or delete (with such destruction, erasure, and deletion certified in writing to the other Party) or return to the other Party, without retaining copies thereof, any and all written or electronic Confidential Information received from the other Party.
- 22.1.9 Remedies. The Parties agree that monetary damages would be inadequate to compensate a Party for the other Party's Breach of its obligations under this Article 22. Each Party accordingly agrees that the other Party shall be entitled to equitable relief, by way of injunction or otherwise, if the first Party Breaches or threatens to Breach its obligations under this Article 22, which equitable relief shall be granted without bond or proof of damages, and the receiving Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Article 22, but shall be in addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. No Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Article 22.
- 22.1.10 Disclosure to FERC, its Staff, or a State. Notwithstanding anything in this Article 22 to the contrary, and pursuant to 18 CFR section 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to this LGIA, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information.

In providing the information to FERC or its staff, the Party must, consistent with 18 CFR section 388.112, request that the information be treated as confidential and non-public by FERC and its staff and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party to this LGIA prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Party to the LGIA when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR section 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

22.1.11 Subject to the exception in Article 22.1.10, any information that a Party claims is competitively sensitive, commercial or financial information under this LGIA (“Confidential Information”) shall not be disclosed by the other Party to any person not employed or retained by the other Party, except to the extent disclosure is (i) required by law; (ii) reasonably deemed by the disclosing Party to be required to be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (iii) otherwise permitted by consent of the other Party, such consent not to be unreasonably withheld; or (iv) necessary to fulfill its obligations under this LGIA or as a transmission service provider or a Balancing Authority Area operator including disclosing the Confidential Information to an RTO or ISO or to a regional or national reliability organization. The Party asserting confidentiality shall notify the other Party in writing of the information it claims is confidential. Prior to any disclosures of the other Party’s Confidential Information under this subparagraph, or if any third party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the disclosing Party agrees to promptly notify the other Party in writing and agrees to assert confidentiality and cooperate with the other Party in seeking to protect the Confidential Information from public

disclosure by confidentiality agreement, protective order or other reasonable measures.

Article 23. Environmental Releases

23.1 Each Party shall notify the other Party, first orally and then in writing, of the release of any Hazardous Substances, any asbestos or lead abatement activities, or any type of remediation activities related to the Large Generating Facility or the Interconnection Facilities, each of which may reasonably be expected to affect the other Party. The notifying Party shall: (i) provide the notice as soon as practicable, provided such Party makes a good faith effort to provide the notice no later than twenty-four hours after such Party becomes aware of the occurrence; and (ii) promptly furnish to the other Party copies of any publicly available reports filed with any Governmental Authorities addressing such events.

Article 24. Information Requirements

24.1 Information Acquisition. Transmission Provider and Interconnection Customer shall submit specific information regarding the electrical characteristics of their respective facilities to each other as described below and in accordance with Applicable Reliability Standards.

24.2 Information Submission by Transmission Provider. The initial information submission by Transmission Provider shall occur no later than one hundred eighty (180) Calendar Days prior to Trial Operation and shall include Transmission System information necessary to allow Interconnection Customer to select equipment and meet any system protection and stability requirements, unless otherwise agreed to by the Parties. On a monthly basis Transmission Provider shall provide Interconnection Customer a status report on the construction and installation of Transmission Provider's Interconnection Facilities and Network Upgrades, including, but not limited to, the following information: (1) progress to

date; (2) a description of the activities since the last report (3) a description of the action items for the next period; and (4) the delivery status of equipment ordered.

- 24.3 Updated Information Submission by Interconnection Customer. The updated information submission by Interconnection Customer, including manufacturer information, shall occur no later than one hundred eighty (180) Calendar Days prior to the Trial Operation. Interconnection Customer shall submit a completed copy of the Large Generating Facility data requirements contained in Appendix 1 to the LGIP. It shall also include any additional information provided to Transmission Provider for the Cluster Study and Facilities Study. Information in this submission shall be the most current Large Generating Facility design or expected performance data. Information submitted for stability models shall be compatible with Transmission Provider standard models. If there is no compatible model, Interconnection Customer will work with a consultant mutually agreed to by the Parties to develop and supply a standard model and associated information.

If Interconnection Customer's data is materially different from what was originally provided to Transmission Provider pursuant to the Interconnection Study Agreement between Transmission Provider and Interconnection Customer, then Transmission Provider will conduct appropriate studies to determine the impact on Transmission Provider Transmission System based on the actual data submitted pursuant to this Article 24.3. Interconnection Customer shall not begin Trial Operation until such studies are completed.

- 24.4 Information Supplementation. Prior to the Operation Date, the Parties shall supplement their information submissions described above in this Article 24 with any and all "as-built" Large Generating Facility information or "as-tested" performance information that differs from the initial submissions or, alternatively, written confirmation that no such differences exist. Interconnection Customer shall conduct tests on the Large Generating Facility as required by Good Utility Practice such as an open circuit "step voltage" test on the Large Generating Facility to verify proper operation of the Large Generating Facility's automatic voltage regulator.

Unless otherwise agreed, the test conditions shall include: (1) Large Generating Facility at synchronous speed; (2) automatic voltage regulator on and in voltage control mode; and (3) a five percent change in Large Generating Facility terminal voltage initiated by a change in the voltage regulators reference voltage. Interconnection Customer shall provide validated test recordings showing the responses of Large Generating Facility terminal and field voltages. In the event that direct recordings of these voltages is impractical, recordings of other voltages or currents that mirror the response of the Large Generating Facility's terminal or field voltage are acceptable if information necessary to translate these alternate quantities to actual Large Generating Facility terminal or field voltages is provided. Large Generating Facility testing shall be conducted and results provided to Transmission Provider for each individual generating unit in a station.

Subsequent to the Operation Date, Interconnection Customer shall provide Transmission Provider any information changes due to equipment replacement, repair, or adjustment. Transmission Provider shall provide Interconnection Customer any information changes due to equipment replacement, repair or adjustment in the directly connected substation or any adjacent Transmission Provider-owned substation that may affect Interconnection Customer's Interconnection Facilities equipment ratings, protection or operating requirements. The Parties shall provide such information no later than thirty (30) Calendar Days after the date of the equipment replacement, repair or adjustment.

Article 25. Information Access and Audit Rights

- 25.1 Information Access. Each Party (the "disclosing Party") shall make available to the other Party information that is in the possession of the disclosing Party and is necessary in order for the other Party to: (i) verify the costs incurred by the disclosing Party for which the other Party is responsible under this LGIA; and (ii) carry out its obligations and responsibilities under this LGIA. The Parties shall not use such information for purposes other than those set forth in this Article 25.1 and to enforce their rights under this LGIA.

- 25.2 Reporting of Non-Force Majeure Events. Each Party (the “notifying Party”) shall notify the other Party when the notifying Party becomes aware of its inability to comply with the provisions of this LGIA for a reason other than a Force Majeure event. The Parties agree to cooperate with each other and provide necessary information regarding such inability to comply, including the date, duration, reason for the inability to comply, and corrective actions taken or planned to be taken with respect to such inability to comply. Notwithstanding the foregoing, notification, cooperation or information provided under this article shall not entitle the Party receiving such notification to allege a cause for anticipatory breach of this LGIA.
- 25.3 Audit Rights. Subject to the requirements of confidentiality under Article 22 of this LGIA, each Party shall have the right, during normal business hours, and upon prior reasonable notice to the other Party, to audit at its own expense the other Party’s accounts and records pertaining to either Party’s performance or either Party’s satisfaction of obligations under this LGIA. Such audit rights shall include audits of the other Party’s costs, calculation of invoiced amounts, Transmission Provider’s efforts to allocate responsibility for the provision of reactive support to the Transmission System, Transmission Provider’s efforts to allocate responsibility for interruption or reduction of generation on the Transmission System, and each Party’s actions in an Emergency Condition. Any audit authorized by this article shall be performed at the offices where such accounts and records are maintained and shall be limited to those portions of such accounts and records that relate to each Party’s performance and satisfaction of obligations under this LGIA. Each Party shall keep such accounts and records for a period equivalent to the audit rights periods described in Article 25.4.

25.4 Audit Rights Periods.

- 25.4.1 Audit Rights Period for Construction-Related Accounts and Records. Accounts and records related to the design, engineering, procurement, and construction of Transmission Provider’s Interconnection Facilities and Network Upgrades shall be subject to audit for a period of twenty-four months following Transmission

Provider's issuance of a final invoice in accordance with Article 12.2.

25.4.2 Audit Rights Period for All Other Accounts and Records. Accounts and records related to either Party's performance or satisfaction of all obligations under this LGIA other than those described in Article 25.4.1 shall be subject to audit as follows: (i) for an audit relating to cost obligations, the applicable audit rights period shall be twenty-four months after the auditing Party's receipt of an invoice giving rise to such cost obligations; and (ii) for an audit relating to all other obligations, the applicable audit rights period shall be twenty-four months after the event for which the audit is sought.

25.5 Audit Results. If an audit by a Party determines that an overpayment or an underpayment has occurred, a notice of such overpayment or underpayment shall be given to the other Party together with those records from the audit which support such determination.

Article 26. Subcontractors

26.1 General. Nothing in this LGIA shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this LGIA; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this LGIA in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

26.2 Responsibility of Principal. The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this LGIA. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or

inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under Article 5 of this LGIA. Any applicable obligation imposed by this LGIA upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

- 26.3 **No Limitation by Insurance.** The obligations under this Article 26 will not be limited in any way by any limitation of subcontractor's insurance.

Article 27. Disputes

- 27.1 Submission.** In the event either Party has a dispute, or asserts a claim, that arises out of or in connection with this LGIA or its performance, such Party (the "disputing Party") shall provide the other Party with written notice of the dispute or claim ("Notice of Dispute"). Such dispute or claim shall be referred to a designated senior representative of each Party for resolution on an informal basis as promptly as practicable after receipt of the Notice of Dispute by the other Party. In the event the designated representatives are unable to resolve the claim or dispute through unassisted or assisted negotiations within thirty (30) Calendar Days of the other Party's receipt of the Notice of Dispute, such claim or dispute may, upon mutual agreement of the Parties, be submitted to arbitration and resolved in accordance with the arbitration procedures set forth below. In the event the Parties do not agree to submit such claim or dispute to arbitration, each Party may exercise whatever rights and remedies it may have in equity or at law consistent with the terms of this LGIA.
- 27.2 **External Arbitration Procedures.** Any arbitration initiated under this LGIA shall be conducted before a single neutral arbitrator appointed by the Parties. If the Parties fail to agree upon a single arbitrator within ten (10) Calendar Days of the submission of the dispute to arbitration, each Party shall choose one arbitrator who shall sit on a three-member arbitration panel. The two arbitrators so chosen shall within twenty (20) Calendar Days select a third arbitrator to chair the arbitration panel. In either case, the arbitrators shall be knowledgeable in electric utility

matters, including electric transmission and bulk power issues, and shall not have any current or past substantial business or financial relationships with any party to the arbitration (except prior arbitration). The arbitrator(s) shall provide each of the Parties an opportunity to be heard and, except as otherwise provided herein, shall conduct the arbitration in accordance with the Commercial Arbitration Rules of the American Arbitration Association ("Arbitration Rules") and any applicable FERC regulations or RTO rules; provided, however, in the event of a conflict between the Arbitration Rules and the terms of this Article 27, the terms of this Article 27 shall prevail.

- 27.3 Arbitration Decisions. Unless otherwise agreed by the Parties, the arbitrator(s) shall render a decision within ninety (90) Calendar Days of appointment and shall notify the Parties in writing of such decision and the reasons therefor. The arbitrator(s) shall be authorized only to interpret and apply the provisions of this LGIA and shall have no power to modify or change any provision of this Agreement in any manner. The decision of the arbitrator(s) shall be final and binding upon the Parties, and judgment on the award may be entered in any court having jurisdiction. The decision of the arbitrator(s) may be appealed solely on the grounds that the conduct of the arbitrator(s), or the decision itself, violated the standards set forth in the Federal Arbitration Act or the Administrative Dispute Resolution Act. The final decision of the arbitrator must also be filed with FERC if it affects jurisdictional rates, terms and conditions of service, Interconnection Facilities, or Network Upgrades.
- 27.4 Costs. Each Party shall be responsible for its own costs incurred during the arbitration process and for the following costs, if applicable: (1) the cost of the arbitrator chosen by the Party to sit on the three member panel and one half of the cost of the third arbitrator chosen; or (2) one half the cost of the single arbitrator jointly chosen by the Parties.

Article 28. Representations, Warranties, and Covenants

28.1 General. Each Party makes the following representations, warranties and covenants:

28.1.1 Good Standing. Such Party is duly organized, validly existing and in good standing under the laws of the state in which it is organized, formed, or incorporated, as applicable; that it is qualified to do business in the state or states in which the Large Generating Facility, Interconnection Facilities and Network Upgrades owned by such Party, as applicable, are located; and that it has the corporate power and authority to own its properties, to carry on its business as now being conducted and to enter into this LGIA and carry out the transactions contemplated hereby and perform and carry out all covenants and obligations on its part to be performed under and pursuant to this LGIA.

28.1.2 Authority. Such Party has the right, power and authority to enter into this LGIA, to become a Party hereto and to perform its obligations hereunder. This LGIA is a legal, valid and binding obligation of such Party, enforceable against such Party in accordance with its terms, except as the enforceability thereof may be limited by applicable bankruptcy, insolvency, reorganization or other similar laws affecting creditors' rights generally and by general equitable principles (regardless of whether enforceability is sought in a proceeding in equity or at law).

28.1.3 No Conflict. The execution, delivery and performance of this LGIA does not violate or conflict with the organizational or formation documents, or bylaws or operating agreement, of such Party, or any judgment, license, permit, order, material agreement or instrument applicable to or binding upon such Party or any of its assets.

28.1.4 Consent and Approval. Such Party has sought or obtained, or, in accordance with this LGIA will seek or obtain, each consent,

approval, authorization, order, or acceptance by any Governmental Authority in connection with the execution, delivery and performance of this LGIA, and it will provide to any Governmental Authority notice of any actions under this LGIA that are required by Applicable Laws and Regulations.

Article 29. Joint Operating Committee

29.1 Joint Operating Committee. Except in the case of ISOs and RTOs, Transmission Provider shall constitute a Joint Operating Committee to coordinate operating and technical considerations of Interconnection Service. At least six (6) months prior to the expected Initial Synchronization Date, Interconnection Customer and Transmission Provider shall each appoint one representative and one alternate to the Joint Operating Committee. Each Interconnection Customer shall notify Transmission Provider of its appointment in writing. Such appointments may be changed at any time by similar notice. The Joint Operating Committee shall meet as necessary, but not less than once each calendar year, to carry out the duties set forth herein. The Joint Operating Committee shall hold a meeting at the request of either Party, at a time and place agreed upon by the representatives. The Joint Operating Committee shall perform all of its duties consistent with the provisions of this LGIA. Each Party shall cooperate in providing to the Joint Operating Committee all information required in the performance of the Joint Operating Committee's duties. All decisions and agreements, if any, made by the Joint Operating Committee, shall be evidenced in writing. The duties of the Joint Operating Committee shall include the following:

29.1.1 Establish data requirements and operating record requirements.

29.1.2 Review the requirements, standards, and procedures for data acquisition equipment, protective equipment, and any other equipment or software.

- 29.1.3** Annually review the one (1) year forecast of maintenance and planned outage schedules of Transmission Provider's and Interconnection Customer's facilities at the Point of Interconnection.
- 29.1.4** Coordinate the scheduling of maintenance and planned outages on the Interconnection Facilities, the Large Generating Facility and other facilities that impact the normal operation of the interconnection of the Large Generating Facility to the Transmission System.
- 29.1.5** Ensure that information is being provided by each Party regarding equipment availability.
- 29.1.6** Perform such other duties as may be conferred upon it by mutual agreement of the Parties.

Article 30. Miscellaneous

- 30.1 **Binding Effect.** This LGIA and the rights and obligations hereof, shall be binding upon and shall inure to the benefit of the successors and assigns of the Parties hereto.
- 30.2 **Conflicts.** In the event of a conflict between the body of this LGIA and any attachment, appendices or exhibits hereto, the terms and provisions of the body of this LGIA shall prevail and be deemed the final intent of the Parties.
- 30.3 **Rules of Interpretation.** This LGIA, unless a clear contrary intention appears, shall be construed and interpreted as follows: (1) the singular number includes the plural number and vice versa; (2) reference to any person includes such person's successors and assigns but, in the case of a Party, only if such successors and

assigns are permitted by this LGIA, and reference to a person in a particular capacity excludes such person in any other capacity or individually; (3) reference to any agreement (including this LGIA), document, instrument or tariff means such agreement, document, instrument, or tariff as amended or modified and in effect from time to time in accordance with the terms thereof and, if applicable, the terms hereof; (4) reference to any Applicable Laws and Regulations means such Applicable Laws and Regulations as amended, modified, codified, or reenacted, in whole or in part, and in effect from time to time, including, if applicable, rules and regulations promulgated thereunder; (5) unless expressly stated otherwise, reference to any Article, Section or Appendix means such Article of this LGIA or such Appendix to this LGIA, or such Section to the LGIP or such Appendix to the LGIP, as the case may be; (6) “hereunder”, “hereof”, “herein”, “hereto” and words of similar import shall be deemed references to this LGIA as a whole and not to any particular Article or other provision hereof or thereof; (7) “including” (and with correlative meaning “include”) means including without limiting the generality of any description preceding such term; and (8) relative to the determination of any period of time, “from” means “from and including,” “to” means “to but excluding” and “through” means “through and including.”

30.4 Entire Agreement. This LGIA, including all Appendices and Schedules attached hereto, constitutes the entire agreement between the Parties with reference to the subject matter hereof, and supersedes all prior and contemporaneous understandings or agreements, oral or written, between the Parties with respect to the subject matter of this LGIA. There are no other agreements, representations, warranties, or covenants which constitute any part of the consideration for, or any condition to, either Party’s compliance with its obligations under this LGIA.

30.5 No Third Party Beneficiaries. This LGIA is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and, where permitted, their assigns.

- 30.6 Waiver. The failure of a Party to this LGIA to insist, on any occasion, upon strict performance of any provision of this LGIA will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

Any waiver at any time by either Party of its rights with respect to this LGIA shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this LGIA. Termination or Default of this LGIA for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this LGIA shall, if requested, be provided in writing.

- 30.7 Headings. The descriptive headings of the various Articles of this LGIA have been inserted for convenience of reference only and are of no significance in the interpretation or construction of this LGIA.
- 30.8 Multiple Counterparts. This LGIA may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.
- 30.9 Amendment. The Parties may by mutual agreement amend this LGIA by a written instrument duly executed by the Parties.
- 30.10 Modification by the Parties. The Parties may by mutual agreement amend the Appendices to this LGIA by a written instrument duly executed by the Parties. Such amendment shall become effective and a part of this LGIA upon satisfaction of all Applicable Laws and Regulations.
- 30.11 Reservation of Rights. Transmission Provider shall have the right to make a unilateral filing with FERC to modify this LGIA with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules

and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this LGIA pursuant to section 206 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this LGIA shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations thereunder, except to the extent that the Parties otherwise mutually agree as provided herein.

30.12 No Partnership. This LGIA shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power, or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

IN WITNESS WHEREOF, the Parties have executed this LGIA in duplicate originals, each of which shall constitute and be an original effective Agreement between the Parties.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

Appendix A to LGIA
Interconnection Facilities, Network Upgrades and Distribution Upgrades

1. Interconnection Facilities:

(a) {insert Interconnection Customer's Interconnection Facilities}:

(b) {insert Transmission Provider's Interconnection Facilities}:

2. Network Upgrades:

(a) {insert Stand Alone Network Upgrades}:

(b) {insert Substation Network Upgrades}:

(c) {insert System Network Upgrades}:

3. Distribution Upgrades:

Appendix B to LGIA Milestones

Site Control

Check box if applicable { }

Interconnection Customer with qualifying regulatory limitations must demonstrate 100% Site Control by {Transmission Provider to insert date one hundred eighty (180) Calendar Days from the effective date of this LGIA} or the LGIA may be terminated per Article 17 (Default) of this LGIA and Interconnection Customer may be subject to Withdrawal Penalties per Section 3.7.1.1 of Transmission Provider's LGIP (Calculation of the Withdrawal Penalty).

Appendix C to LGIA
Interconnection Details

Appendix D to LGIA

Security Arrangements Details

Infrastructure security of Transmission System equipment and operations and control hardware and software is essential to ensure day-to-day Transmission System reliability and operational security. FERC will expect all Transmission Providers, market participants, and Interconnection Customers interconnected to the Transmission System to comply with the recommendations offered by the President's Critical Infrastructure Protection Board and, eventually, best practice recommendations from the electric reliability authority. All public utilities will be expected to meet basic standards for system infrastructure and operational security, including physical, operational, and cyber-security practices.

**Appendix E to LGIA
Commercial Operation Date**

This Appendix E is a part of the LGIA between Transmission Provider and Interconnection Customer.

{Date}

{Transmission Provider Address}

Re: _____ Large Generating Facility

Dear _____:

On **{Date}** **{Interconnection Customer}** has completed Trial Operation of Unit No. _____. This letter confirms that **{Interconnection Customer}** commenced Commercial Operation of Unit No. _____ at the Large Generating Facility, effective as of **{Date plus one day}**.

Thank you.

{Signature}

{Interconnection Customer Representative}

Appendix F to LGIA
Addresses for Delivery of Notices and Billings

Notices:

Transmission Provider:

{To be supplied.}

Interconnection Customer:

{To be supplied.}

Billings and Payments:

Transmission Provider:

{To be supplied.}

Interconnection Customer:

{To be supplied.}

Alternative Forms of Delivery of Notices (telephone, facsimile or email):

Transmission Provider:

{To be supplied.}

Interconnection Customer:

{To be supplied.}

APPENDIX G

INTERCONNECTION REQUIREMENTS FOR A WIND GENERATING PLANT

Appendix G sets forth requirements and provisions specific to a wind generating plant or a Generating Facility that contains a wind generating plant. All other requirements of this LGIA continue to apply to wind generating plant interconnections.

A. Technical Standards Applicable to a Wind Generating Plant

i. Low Voltage Ride-Through (LVRT) Capability

A wind generating plant shall be able to remain online during voltage disturbances up to the time periods and associated voltage levels set forth in the standard below. The LVRT standard provides for a transition period standard and a post-transition period standard.

Transition Period LVRT Standard

The transition period standard applies to wind generating plants subject to FERC Order 661 that have either: (i) interconnection agreements signed and filed with the Commission, filed with the Commission in unexecuted form, or filed with the Commission as non-conforming agreements between January 1, 2006 and December 31, 2006, with a scheduled in-service date no later than December 31, 2007, or (ii) wind

generating turbines subject to a wind turbine procurement contract executed prior to December 31, 2005, for delivery through 2007.

1. Wind generating plants are required to remain in-service during three-phase faults with normal clearing (which is a time period of approximately 4 – 9 cycles) and single line to ground faults with delayed clearing, and subsequent post-fault voltage recovery to prefault voltage unless clearing the fault effectively disconnects the generator from the system. The clearing time requirement for a three-phase fault will be specific to the wind generating plant substation location, as determined by and documented by transmission provider. The maximum clearing time the wind generating plant shall be required to withstand for a three-phase fault shall be 9 cycles at a voltage as low as 0.15 p.u., as measured at the high side of the wind generating plant step-up transformer (i.e. the transformer that steps the voltage up to the transmission interconnection voltage or “GSU”), after which, if the fault remains following the location-specific normal clearing time for three-phase faults, the wind generating plant may disconnect from the transmission system.
2. This requirement does not apply to faults that would occur between the wind generator terminals and the high side of the GSU or to faults that would result in a voltage lower than 0.15 per unit on the high side of the GSU serving the facility.
3. Wind generating plants may be tripped after the fault period if this action is intended as part of a special protection system.
4. Wind generating plants may meet the LVRT requirements of this standard by the

performance of the generators or by installing additional equipment (e.g., Static VAR Compensator, etc.) within the wind generating plant or by a combination of generator performance and additional equipment.

5. Existing individual generator units that are, or have been, interconnected to the network at the same location at the effective date of the Appendix G LVRT Standard are exempt from meeting the Appendix G LVRT Standard for the remaining life of the existing generation equipment. Existing individual generator units that are replaced are required to meet the Appendix G LVRT Standard.

Post-transition Period LVRT Standard

All wind generating plants subject to FERC Order No. 661 and not covered by the transition period described above must meet the following requirements:

1. Wind generating plants are required to remain in-service during three-phase faults with normal clearing (which is a time period of approximately 4 – 9 cycles) and single line to ground faults with delayed clearing, and subsequent post-fault voltage recovery to pre-fault voltage unless clearing the fault effectively disconnects the generator from the system. The clearing time requirement for a three-phase fault will be specific to the wind generating plant substation location, as determined by and documented by transmission provider. The maximum clearing time the wind generating plant shall be required to withstand for a three-phase fault shall be 9 cycles after which, if the fault remains following the

location-specific normal clearing time for three-phase faults, the wind generating plant may disconnect from the transmission system. A wind generating plant shall remain interconnected during such a fault on the transmission system for a voltage level as low as zero volts, as measured at the high voltage side of the wind GSU.

2. This requirement does not apply to faults that would occur between the wind generator terminals and the high side of the GSU.
3. Wind generating plants may be tripped after the fault period if this action is intended as part of a special protection system.
4. Wind generating plants may meet the LVRT requirements of this standard by the performance of the generators or by installing additional equipment (e.g., Static VAR Compensator) within the wind generating plant or by a combination of generator performance and additional equipment.

Existing individual generator units that are, or have been, interconnected to the network at the same location at the effective date of the Appendix G LVRT Standard are exempt from meeting the Appendix G LVRT Standard for the remaining life of the existing generation equipment. Existing individual generator units that are replaced are required to meet the Appendix G LVRT Standard.

ii. Power Factor Design Criteria (Reactive Power)

The following reactive power requirements apply only to a newly interconnecting wind generating plant that has executed a Facilities Study Agreement as of the effective

date of the Final Rule establishing the reactive power requirements for non-synchronous generators in article 9.6.1 of this LGIA (Order No. 827). A wind generating plant to which this provision applies shall maintain a power factor within the range of 0.95 leading to 0.95 lagging, measured at the Point of Interconnection as defined in this LGIA, if Transmission Provider's Cluster Study shows that such a requirement is necessary to ensure safety or reliability. The power factor range standard can be met by using, for example, power electronics designed to supply this level of reactive capability (taking into account any limitations due to voltage level, real power output, etc.) or fixed and switched capacitors if agreed to by Transmission Provider, or a combination of the two. Interconnection Customer shall not disable power factor equipment while the wind plant is in operation. Wind plants shall also be able to provide sufficient dynamic voltage support in lieu of the power system stabilizer and automatic voltage regulation at the generator excitation system if the Cluster Study shows this to be required for system safety or reliability.

iii. Supervisory Control and Data Acquisition (SCADA) Capability

The wind plant shall provide SCADA capability to transmit data and receive instructions from Transmission Provider to protect system reliability. Transmission Provider and the wind plant Interconnection Customer shall determine what SCADA information is essential for the proposed wind plant, taking into account the size of the plant and its characteristics, location, and importance in maintaining generation resource

adequacy and transmission system reliability in its area.

Appendix H to LGIA

Operating Assumptions for Generating Facility

Check box if applicable { }

Operating Assumptions:

{insert operating assumptions that reflect the charging behavior of the Generating Facility that includes at least one electric storage resource}

ATTACHMENT O

Small Generator Interconnection Procedures (SGIP)

**SMALL GENERATOR
INTERCONNECTION PROCEDURES (SGIP)**

(For Generating Facilities No Larger Than 20 MW)

TABLE OF CONTENTS

	Page No.
Section 1. Application	1
1.1 Applicability.....	1
1.2 Pre-Application	2
1.3 Interconnection Request	5
1.4 Modification of the Interconnection Request	6
1.5 Site Control	6
1.6 Queue Position	6
1.7 Interconnection Requests Submitted Prior to the Effective Date of the SGIP	7
Section 2. Fast Track Process	7
2.1 Applicability.....	7
2.2 Initial Review	8
2.3 Customer Options Meeting.....	12
2.4 Supplemental Review	12
Section 3. Study Process	17
3.1 Applicability.....	17
3.2 Scoping Meeting	17
3.3 Feasibility Study.....	18
3.4 System Impact Study	19
3.5 Facilities Study.....	21
Section 4. Provisions that Apply to All Interconnection Requests	22
4.1 Reasonable Efforts	22
4.2 Disputes	22
4.3 Interconnection Metering.....	23
4.4 Commissioning.....	23
4.5 Confidentiality.....	23
4.6 Comparability.....	24
4.7 Record Retention.....	25

4.8 Interconnection Agreement..... 25
4.9 Coordination with Affected Systems 25
4.10 Capacity of the Small Generating Facility 25

Attachment 1 – Glossary of Terms

Attachment 2 – Small Generator Interconnection Request

Attachment 3 – Certification Codes and Standards

Attachment 4 – Certification of Small Generator Equipment Packages

Attachment 5 – Application, Procedures, and Terms and Conditions for Interconnecting a Certified Inverter-Based Small Generating Facility No Larger than 10 kW (“10 kW Inverter Process”).

Attachment 6 – Feasibility Study Agreement

Attachment 7 – System Impact Study Agreement

Attachment 8 – Facilities Study Agreement

Section 1. Application

1.1 Applicability

- 1.1.1 A request to interconnect a certified Small Generating Facility (See Attachments 3 and 4 for description of certification criteria) to Transmission Provider's Distribution System shall be evaluated under the section 2 Fast Track Process if the eligibility requirements of section 2.1 are met. A request to interconnect a certified inverter-based Small Generating Facility no larger than 10 kilowatts (kW) shall be evaluated under the Attachment 5 10 kW Inverter Process. A request to interconnect a Small Generating Facility no larger than 20 megawatts (MW) that does not meet the eligibility requirements of section 2.1, or does not pass the Fast Track Process or the 10 kW Inverter Process, shall be evaluated under the section 3 Study Process. If Interconnection Customer wishes to interconnect its Small Generating Facility using Network Resource Interconnection Service, it must do so under the Standard Large Generator Interconnection Procedures and execute the Standard Large Generator Interconnection Agreement.
- 1.1.2 Capitalized terms used herein shall have the meanings specified in the Glossary of Terms in Attachment 1 or the body of these procedures.
- 1.1.3 Neither these procedures nor the requirements included hereunder apply to Small Generating Facilities interconnected or approved for interconnection prior to sixty (60) Business Days after the effective date of these procedures.
- 1.1.4 Prior to submitting its Interconnection Request (Attachment 2), Interconnection Customer may ask Transmission Provider's interconnection contact employee or office whether the proposed interconnection is subject to these procedures. Transmission Provider shall respond within fifteen (15) Business Days.
- 1.1.5 Infrastructure security of electric system equipment and operations and control hardware and software is essential to ensure day-to-day reliability and operational security. The Federal Energy Regulatory Commission expects all Transmission Providers, market participants, and Interconnection Customers interconnected with electric systems to comply

with the recommendations offered by the President's Critical Infrastructure Protection Board and best practice recommendations from the electric reliability authority. All public utilities are expected to meet basic standards for electric system infrastructure and operational security, including physical, operational, and cyber-security practices.

- 1.1.6 References in these procedures to interconnection agreement are to the Small Generator Interconnection Agreement (SGIA).

1.2 Pre-Application

- 1.2.1 Transmission Provider shall designate an employee or office from which information on the application process and on an Affected System can be obtained through informal requests from Interconnection Customer presenting a proposed project for a specific site. The name, telephone number, and e-mail address of such contact employee or office shall be made available on Transmission Provider's Internet web site. Electric system information provided to Interconnection Customer should include relevant system studies, interconnection studies, and other materials useful to an understanding of an interconnection at a particular point on Transmission Provider's Transmission System, to the extent such provision does not violate confidentiality provisions of prior agreements or critical infrastructure requirements. Transmission Provider shall comply with reasonable requests for such information.
- 1.2.2 In addition to the information described in section 1.2.1, which may be provided in response to an informal request, an Interconnection Customer may submit a formal written request form along with a non-refundable fee of \$300 for a pre-application report on a proposed project at a specific site. Transmission Provider shall provide the pre-application data described in section 1.2.3 to Interconnection Customer within twenty (20) Business Days of receipt of the completed request form and payment of the \$300 fee. The pre-application report produced by Transmission Provider is non-binding, does not confer any rights, and Interconnection Customer must still successfully apply to interconnect to Transmission Provider's system. The written pre-application report request form shall include the

information in sections 1.2.2.1 through 1.2.2.8 below to clearly and sufficiently identify the location of the proposed Point of Interconnection.

- 1.2.2.1 Project contact information, including name, address, phone number, and email address.
- 1.2.2.2 Project location (street address with nearby cross streets and town)
- 1.2.2.3 Meter number, pole number, or other equivalent information identifying proposed Point of Interconnection, if available.
- 1.2.2.4 Generator Type (e.g., solar, wind, combined heat and power, etc.)
- 1.2.2.5 Size (alternating current kW)
- 1.2.2.6 Single or three phase generator configuration
- 1.2.2.7 Stand-alone generator (no onsite load, not including station service – Yes or No?)
- 1.2.2.8 Is new service requested? Yes or No? If there is existing service, include the customer account number, site minimum and maximum current or proposed electric loads in kW (if available) and specify if the load is expected to change.

1.2.3. Using the information provided in the pre-application report request form in section 1.2.2, Transmission Provider will identify the substation/area bus, bank or circuit likely to serve the proposed Point of Interconnection. This selection by Transmission Provider does not necessarily indicate, after application of the screens and/or study, that this would be the circuit the project ultimately connects to. Interconnection Customer must request additional pre-application reports if information about multiple Points of Interconnection is requested. Subject to section 1.2.4, the pre-application report will include the following information:

- 1.2.3.1 Total capacity (in MW) of substation/area bus, bank or circuit based on normal or operating ratings likely to serve the proposed Point of Interconnection.

- 1.2.3.2 Existing aggregate generation capacity (in MW) interconnected to a substation/area bus, bank or circuit (i.e., amount of generation online) likely to serve the proposed Point of Interconnection.
- 1.2.3.3 Aggregate queued generation capacity (in MW) for a substation/area bus, bank or circuit (i.e., amount of generation in the queue) likely to serve the proposed Point of Interconnection.
- 1.2.3.4 Available capacity (in MW) of substation/area bus or bank and circuit likely to serve the proposed Point of Interconnection (i.e., total capacity less the sum of existing aggregate generation capacity and aggregate queued generation capacity).
- 1.2.3.5 Substation nominal distribution voltage and/or transmission nominal voltage if applicable.
- 1.2.3.6 Nominal distribution circuit voltage at the proposed Point of Interconnection.
- 1.2.3.7 Approximate circuit distance between the proposed Point of Interconnection and the substation.
- 1.2.3.8 Relevant line section(s) actual or estimated peak load and minimum load data, including daytime minimum load as described in section 2.4.4.1.1 below and absolute minimum load, when available.
- 1.2.3.9 Number and rating of protective devices and number and type (standard, bi-directional) of voltage regulating devices between the proposed Point of Interconnection and the substation/area. Identify whether the substation has a load tap changer.
- 1.2.3.10 Number of phases available at the proposed Point of Interconnection. If a single phase, distance from the three-phase circuit.
- 1.2.3.11 Limiting conductor ratings from the proposed Point of Interconnection to the distribution substation.

- 1.2.3.12 Whether the Point of Interconnection is located on a spot network, grid network, or radial supply.
- 1.2.3.13 Based on the proposed Point of Interconnection, existing or known constraints such as, but not limited to, electrical dependencies at that location, short circuit interrupting capacity issues, power quality or stability issues on the circuit, capacity constraints, or secondary networks.
- 1.2.4 The pre-application report need only include existing data. A pre-application report request does not obligate Transmission Provider to conduct a study or other analysis of the proposed generator in the event that data is not readily available. If Transmission Provider cannot complete all or some of a pre-application report due to lack of available data, the Transmission Provider shall provide Interconnection Customer with a pre-application report that includes the data that is available. The provision Of information on “available capacity” pursuant to section 1.2.3.4 does not imply that an interconnection up to this level may be completed without impacts since there are many variables studied as part of the interconnection review process, and data provided in the pre-application report may become outdated at the time of the submission of the complete Interconnection Request. Notwithstanding any of the provisions of this section, Transmission Provider shall, in good faith, include data in the pre-application report that represents the best available information at the time of reporting.

1.3 Interconnection Request

Interconnection Customer shall submit its Interconnection Request to Transmission Provider, together with the processing fee or deposit specified in the Interconnection Request. The Interconnection Request shall be date- and time-stamped upon receipt. The original date- and time-stamp applied to the Interconnection Request at the time of its original submission shall be accepted as the qualifying date- and time-stamp for the purposes of any timetable in these procedures. Interconnection Customer shall be notified of receipt by Transmission Provider within three (3) Business Days of receiving the Interconnection Request. Transmission Provider shall notify Interconnection Customer within ten (10) Business Days of the receipt of the Interconnection Request as to whether the Interconnection Request is

complete or incomplete. If the Interconnection Request is incomplete, Transmission Provider shall provide along with the notice that the Interconnection Request is incomplete, a written list detailing all information that must be provided to complete the Interconnection Request. Interconnection Customer will have ten (10) Business Days after receipt of the notice to submit the listed information or to request an extension of time to provide such information. If Interconnection Customer does not provide the listed information or a request for an extension of time within the deadline, the Interconnection Request will be deemed withdrawn. An Interconnection Request will be deemed complete upon submission of the listed information to Transmission Provider.

1.4 Modification of the Interconnection Request

Any modification to machine data or equipment configuration or to the interconnection site of the Small Generating Facility not agreed to in writing by Transmission Provider and Interconnection Customer may be deemed a withdrawal of the Interconnection Request and may require submission of a new Interconnection Request, unless proper notification of each Party by the other and a reasonable time to cure the problems created by the changes are undertaken. Any such modification of the Interconnection Request must be accompanied by any resulting updates to the models described in Attachment 2 of this SGIP.

1.5 Site Control

Documentation of site control must be submitted with the Interconnection Request. Site control may be demonstrated through:

- 1.5.1 Ownership of, a leasehold interest in, or a right to develop a site for the purpose of constructing the Small Generating Facility;
- 1.5.2 An option to purchase or acquire a leasehold site for such purpose; or
- 1.5.3 An exclusivity or other business relationship between Interconnection Customer and the entity having the right to sell, lease, or grant Interconnection Customer the right to possess or occupy a site for such purpose.

1.6 Queue Position

Transmission Provider shall assign a Queue Position based upon the date- and time-stamp of the Interconnection Request. The Queue Position of each Interconnection Request will be used to determine the cost responsibility for the Upgrades necessary to accommodate the interconnection. Transmission Provider shall maintain a single queue per geographic region. At Transmission Provider's option, Interconnection Requests may be studied serially or in clusters for the purpose of the system impact study.

1.7 Interconnection Requests Submitted Prior to the Effective Date of the SGIP

Nothing in this SGIP affects an Interconnection Customer's Queue Position assigned before the effective date of this SGIP. The Parties agree to complete work on any interconnection study agreement executed prior the effective date of this SGIP in accordance with the terms and conditions of that interconnection study agreement. Any new studies or other additional work will be completed pursuant to this SGIP.

Section 2. Fast Track Process

2.1 Applicability

The Fast Track Process is available to an Interconnection Customer proposing to interconnect its Small Generating Facility with Transmission Provider's Distribution System if the Small Generating Facility's capacity does not exceed the size limits identified in the table below. Small Generating Facilities below these limits are eligible for Fast Track review. However, Fast Track eligibility is distinct from the Fast Track Process itself, and eligibility does not imply or indicate that a Small Generating Facility will pass the Fast Track screens in section 2.2.1 below or the Supplemental Review screens in section 2.4.4 below.

Fast Track eligibility is determined based upon the generator type, the size of the generator, voltage of the line and the location of and the type of line at the Point of Interconnection. All Small Generating Facilities connecting to lines greater than 69 kilovolt (kV) are ineligible for the Fast Track Process regardless of size. All synchronous and induction machines must be no larger than 2 MW to be eligible for the Fast Track Process, regardless of location. For certified inverter-based systems, the size limit varies according to the voltage of the line at the proposed Point of Interconnection. Certified inverter-based Small Generating Facilities

located within 2.5 electrical circuit miles of a substation and on a mainline (as defined in the table below) are eligible for the Fast Track Process under the higher thresholds according to the table below. In addition to the size threshold, Interconnection Customer’s proposed Small Generating Facility must meet the codes, standards, and certification requirements of Attachments 3 and 4 of these procedures, or Transmission Provider has to have reviewed the design or tested the proposed Small Generating Facility and is satisfied that it is safe to operate.

Fast Track Eligibility for Inverter-Based Systems		
Line Voltage	Fast Track Eligibility Regardless of Location	Fast Track Eligibility on a Mainline ¹ and ≤ 2.5 Electrical Circuit Miles from Substation ²
< 5 kV	≤ 500 kW	≤ 500 kW
≥ 5 kV and < 15 kV	≤ 2 MW	≤ 3 MW
≥ 15 kV and < 30 kV	≤ 3 MW	≤ 4 MW
≥ 30 kV and ≤ 69 kV	≤ 4 MW	≤ 5 MW

2.2 Initial Review

¹ For purposes of this table, a mainline is the three-phase backbone of a circuit. It will typically constitute lines with wire sizes of 4/0 American wire gauge, 336.4 kcmil, 397.5 kcmil, 477 kcmil and 795 kcmil.

² An Interconnection Customer can determine this information about its proposed interconnection location in advance by requesting a pre-application report pursuant to section 1.2.

Within fifteen (15) Business Days after Transmission Provider notifies Interconnection Customer it has received a complete Interconnection Request, Transmission Provider shall perform an initial review using the screens set forth below, shall notify Interconnection Customer of the results, and include with the notification copies of the analysis and data underlying Transmission Provider's determinations under the screens.

2.2.1 Screens

- 2.2.1.1 The proposed Small Generating Facility's Point of Interconnection must be on a portion of Transmission Provider's Distribution System that is subject to the Tariff.
- 2.2.1.2 For interconnection of a proposed Small Generating Facility to a radial distribution circuit, the aggregated generation, including the proposed Small Generating Facility, on the circuit shall not exceed 15 % of the line section annual peak load as most recently measured at the substation. A line section is that portion of a Transmission Provider's electric system connected to a customer bounded by automatic sectionalizing devices or the end of the distribution line.
- 2.2.1.3 For interconnection of a proposed Small Generating Facility to the load side of spot network protectors, the proposed Small Generating Facility must utilize an inverter-based equipment package and, together with the aggregated other inverter-based generation, shall not exceed the smaller of 5 % of a spot network's maximum load or 50 kW.³
- 2.2.1.4 The proposed Small Generating Facility, in aggregation with other generation on the distribution circuit, shall not contribute more than 10 % to the distribution circuit's maximum fault current at the point on the high voltage

³ A spot network is a type of distribution system found within modern commercial buildings to provide high reliability of service to a single customer. (Standard Handbook for Electrical Engineers, 11th edition, Donald Fink, McGraw Hill Book Company)

(primary) level nearest the proposed point of change of ownership.

2.2.1.5 The proposed Small Generating Facility, in aggregate with other generation on the distribution circuit, shall not cause any distribution protective devices and equipment (including, but not limited to, substation breakers, fuse cutouts, and line reclosers), or Interconnection Customer equipment on the system to exceed 87.5 % of the short circuit interrupting capability; nor shall the interconnection be proposed for a circuit that already exceeds 87.5 % of the short circuit interrupting capability.

2.2.1.6 Using the table below, determine the type of interconnection to a primary distribution line. This screen includes a review of the type of electrical service provided to the Interconnecting Customer, including line configuration and the transformer connection to limit the potential for creating over-voltages on Transmission Provider’s electric power system due to a loss of ground during the operating time of any anti-islanding function.

Primary Distribution Line Type	Type of Interconnection to Primary Distribution Line	Result/Criteria
Three-phase, three wire	3-phase or single phase, phase-to-phase	Pass screen
Three-phase, four wire	Effectively-grounded 3 phase or Single-phase, line-to-neutral	Pass screen

2.2.1.7 If the proposed Small Generating Facility is to be interconnected on single-phase shared secondary, the aggregate generation capacity on the shared secondary, including the proposed Small Generating Facility, shall not exceed 20 kW.

- 2.2.1.8 If the proposed Small Generating Facility is single-phase and is to be interconnected on a center tap neutral of a 240 volt service, its addition shall not create an imbalance between the two sides of the 240 volt service of more than 20 % of the nameplate rating of the service transformer.
- 2.2.1.9 The Small Generating Facility, in aggregate with other generation interconnected to the transmission side of a substation transformer feeding the circuit where the Small Generating Facility proposes to interconnect shall not exceed 10 MW in an area where there are known, or posted, transient stability limitations to generating units located in the general electrical vicinity (e.g., three or four transmission busses from the point of interconnection).
- 2.2.1.10 No construction of facilities by Transmission Provider on its own system shall be required to accommodate the Small Generating Facility.
- 2.2.2 If the proposed interconnection passes the screens, the Interconnection Request shall be approved and Transmission Provider will provide Interconnection Customer an executable interconnection agreement within five (5) Business Days after the determination.
- 2.2.3 If the proposed interconnection fails the screens, but Transmission Provider determines that the Small Generating Facility may nevertheless be interconnected consistent with safety, reliability, and power quality standards, Transmission Provider shall provide Interconnection Customer an executable interconnection agreement within five (5) Business Days after the determination.
- 2.2.4 If the proposed interconnection fails the screens, and Transmission Provider does not or cannot determine from the initial review that the Small Generating Facility may nevertheless be interconnected consistent with safety, reliability, and power quality standards unless Interconnection Customer is willing to consider minor modifications or further study, Transmission Provider shall provide

Interconnection Customer with the opportunity to attend a customer options meeting.

2.3 Customer Options Meeting

If Transmission Provider determines the Interconnection Request cannot be approved without (1) minor modifications at minimal cost, (2) a supplemental study or other additional studies or actions, or (3) incurring significant cost to address safety, reliability, or power quality problems, Transmission Provider shall notify Interconnection Customer of that determination within five (5) Business Days after the determination and provide copies of all data and analyses underlying its conclusion. Within ten (10) Business Days of Transmission Provider's determination, Transmission Provider shall offer to convene a customer options meeting with Transmission Provider to review possible Interconnection Customer facility modifications or the screen analysis and related results, to determine what further steps are needed to permit the Small Generating Facility to be connected safely and reliably. At the time of notification of Transmission Provider's determination, or at the customer options meeting, Transmission Provider shall:

- 2.3.1 Offer to perform facility modifications or minor modifications to Transmission Provider's electric system (e.g., changing meters, fuses, relay settings) and provide a non-binding good faith estimate of the limited cost to make such modifications to Transmission Provider's electric system. If Interconnection Customer agrees to pay for the modifications to the Transmission Provider's electric system, the Transmission Provider will provide the Interconnection Customer with an executable interconnection agreement within ten (10) Business Days of the customer options meeting; or
- 2.3.2 Offer to perform a supplemental review in accordance with section 2.4 and provide a non-binding good faith estimate of the costs of such review; or
- 2.3.3 Obtain Interconnection Customer's agreement to continue evaluating the Interconnection Request under the section 3 Study Process.

2.4 Supplemental Review

- 2.4.1 To accept the offer of a supplemental review, Interconnection Customer shall agree in writing and submit a deposit for the

estimated costs of the supplemental review in the amount of Transmission Provider's good faith estimate of the costs of such review, both within fifteen (15) Business Days of the offer. If the written agreement and deposit have not been received by Transmission Provider within that timeframe, the Interconnection Request shall continue to be evaluated under the section 3 Study Process unless it is withdrawn by Interconnection Customer.

- 2.4.2 Interconnection Customer may specify the order in which Transmission Provider will complete the screens in section 2.4.4.
- 2.4.3 Interconnection Customer shall be responsible for Transmission Provider's actual costs for conducting the supplemental review. Interconnection Customer must pay any review costs that exceed the deposit within twenty (20) Business Days of receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced costs, Transmission Provider will return such excess within twenty (20) Business Days of the invoice without interest.
- 2.4.4 Within thirty (30) Business Days following receipt of the deposit for a supplemental review, Transmission Provider shall (1) perform a supplemental review using the screens set forth below; (2) notify in writing Interconnection Customer of the results; and (3) include with the notification copies of the analysis and data underlying Transmission Provider's determinations under the screens. Unless Interconnection Customer provided instructions for how to respond to the failure of any of the supplemental review screens below at the time Interconnection Customer accepted the offer of supplemental review, Transmission Provider shall notify Interconnection Customer following the failure of any of the screens, or if it is unable to perform the screen in section 2.4.4.1, within two (2) Business Days of making such determination to obtain Interconnection Customer's permission to: (1) continue evaluating the proposed interconnection under this section 2.4.4; (2) terminate the supplemental review and continue evaluating the Small Generating Facility under section 3; or (3) terminate the supplemental review upon withdrawal of the Interconnection Request by Interconnection Customer.

- 2.4.4.1 Minimum Load Screen: Where 12 months of line section minimum load data (including onsite load but not station service load served by the proposed Small Generating Facility) are available, can be calculated, can be estimated from existing data, or determined from a power flow model, the aggregate Generating Facility capacity on the line section is less than 100% of the minimum load for all line sections bounded by automatic sectionalizing devices upstream of the proposed Small Generating Facility. If minimum load data is not available, or cannot be calculated, estimated or determined, Transmission Provider shall include the reason(s) that it is unable to calculate, estimate or determine minimum load in its supplemental review results notification under section 2.4.4.
- 2.4.4.1.1 The type of generation used by the proposed Small Generating Facility will be taken into account when calculating, estimating, or determining circuit or line section minimum load relevant for the application of screen 2.4.4.1. Solar photovoltaic (PV) generation systems with no battery storage use daytime minimum load (i.e. 10 a.m. to 4 p.m. for fixed panel systems and 8 a.m. to 6 p.m. for PV systems utilizing tracking systems), while all other generation uses absolute minimum load.
- 2.4. 4.1.2 When this screen is being applied to a Small Generating Facility that serves some station service load, only the net injection into Transmission Provider's electric system will be considered as part of the aggregate generation.
- 2.4. 4.1.3 Transmission Provider will not consider as part of the aggregate generation for purposes of this

screen generating facility capacity known to be already reflected in the minimum load data.

- 2.4.4.2 Voltage and Power Quality Screen: In aggregate with existing generation on the line section: (1) the voltage regulation on the line section can be maintained in compliance with relevant requirements under all system conditions; (2) the voltage fluctuation is within acceptable limits as defined by Institute of Electrical and Electronics Engineers (IEEE) Standard 1453, or utility practice similar to IEEE Standard 1453; and (3) the harmonic levels meet IEEE Standard 519 limits.
- 2.4.4.3 Safety and Reliability Screen: The location of the proposed Small Generating Facility and the aggregate generation capacity on the line section do not create impacts to safety or reliability that cannot be adequately addressed without application of the Study Process. Transmission Provider shall give due consideration to the following and other factors in determining potential impacts to safety and reliability in applying this screen.
- 2.4.4.3.1 Whether the line section has significant minimum loading levels dominated by a small number of customers (e.g., several large commercial customers).
- 2.4.4.3.2 Whether the loading along the line section is uniform or even.
- 2.4.4.3.3 Whether the proposed Small Generating Facility is located in close proximity to the substation (i.e., less than 2.5 electrical circuit miles), and whether the line section from the substation to the Point of Interconnection is a Mainline rated for normal and emergency ampacity.
- 2.4.4.3.4 Whether the proposed Small Generating Facility incorporates a time delay function to prevent reconnection of the generator to the

system until system voltage and frequency are within normal limits for a prescribed time.

2.4.4.3.5 Whether operational flexibility is reduced by the proposed Small Generating Facility, such that transfer of the line section(s) of the Small Generating Facility to a neighboring distribution circuit/substation may trigger overloads or voltage issues.

2.4.4.3.6 Whether the proposed Small Generating Facility employs equipment or systems certified by a recognized standards organization to address technical issues such as, but not limited to, islanding, reverse power flow, or voltage quality.

2.4.5 If the proposed interconnection passes the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above, the Interconnection Request shall be approved and Transmission Provider will provide Interconnection Customer with an executable interconnection agreement within the timeframes established in sections 2.4.5.1 and 2.4.5.2 below. If the proposed interconnection fails any of the supplemental review screens and Interconnection Customer does not withdraw its Interconnection Request, it shall continue to be evaluated under the section 3 Study Process consistent with section 2.4.5.3 below.

2.4.5.1 If the proposed interconnection passes the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above and does not require construction of facilities by Transmission Provider on its own system, the interconnection agreement shall be provided within ten (10) Business Days after the notification of the supplemental review results.

2.4.5.2 If interconnection facilities or minor modifications to Transmission Provider's system are required for the proposed interconnection to pass the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above, and Interconnection Customer agrees to pay for the modifications to Transmission Provider's electric system, the interconnection agreement,

along with a non-binding good faith estimate for the interconnection facilities and/or minor modifications, shall be provided to Interconnection Customer within fifteen (15) Business Days after receiving written notification of the supplemental review results.

- 2.4.5.3 If the proposed interconnection would require more than interconnection facilities or minor modifications to Transmission Provider's system to pass the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above, Transmission Provider shall notify Interconnection Customer, at the same time it notifies Interconnection Customer with the supplemental review results, that the Interconnection Request shall be evaluated under the section 3 Study Process unless Interconnection Customer withdraws its Small Generating Facility.

Section 3. Study Process

3.1 Applicability

The Study Process shall be used by an Interconnection Customer proposing to interconnect its Small Generating Facility with Transmission Provider's Transmission System or Distribution System if the Small Generating Facility (1) is larger than 2 MW but no larger than 20 MW, (2) is not certified, or (3) is certified but did not pass the Fast Track Process or the 10 kW Inverter Process.

3.2 Scoping Meeting

3.2.1 A scoping meeting will be held within ten (10) Business Days after the Interconnection Request is deemed complete, or as otherwise mutually agreed to by the Parties. Transmission Provider and Interconnection Customer will bring to the meeting personnel, including system engineers and other resources as may be reasonably required to accomplish the purpose of the meeting.

3.2.2 The purpose of the scoping meeting is to discuss the Interconnection Request and review existing studies relevant to the Interconnection Request. The Parties shall further discuss whether Transmission Provider

should perform a feasibility study or proceed directly to a system impact study, or a facilities study, or an interconnection agreement. If the Parties agree that a feasibility study should be performed, Transmission Provider shall provide Interconnection Customer, as soon as possible, but not later than five (5) Business Days after the scoping meeting, a feasibility study agreement (Attachment 6) including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study.

- 3.2.3 The scoping meeting may be omitted by mutual agreement. In order to remain in consideration for interconnection, an Interconnection Customer who has requested a feasibility study must return the executed feasibility study agreement within fifteen (15) Business Days. If the Parties agree not to perform a feasibility study, Transmission Provider shall provide Interconnection Customer, no later than five (5) Business Days after the scoping meeting, a system impact study agreement (Attachment 7) including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study.

3.3 Feasibility Study

- 3.3.1 The feasibility study shall identify any potential adverse system impacts that would result from the interconnection of the Small Generating Facility.
- 3.3.2 A deposit of the lesser of 50 percent of the good faith estimated feasibility study costs or earnest money of \$1,000 may be required from Interconnection Customer.
- 3.3.3 The scope of and cost responsibilities for the feasibility study are described in the attached feasibility study agreement (Attachment 6).
- 3.3.4 If the feasibility study shows no potential for adverse system impacts, Transmission Provider shall send Interconnection Customer a facilities study agreement, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study. If no additional facilities are required, Transmission Provider shall send Interconnection Customer an executable interconnection agreement within five (5) Business Days.
- 3.3.5 If the feasibility study shows the potential for adverse system impacts, the review process shall proceed to the appropriate system impact study(s).

3.3.6 The feasibility study shall evaluate static synchronous compensators, static VAR compensators, advanced power flow control devices, transmission switching, synchronous condensers, voltage source converters, advanced conductors, and tower lifting. Transmission Provider shall evaluate each identified alternative transmission technology and determine whether it should be used, consistent with Good Utility Practice, Applicable Reliability Standards, and Applicable Laws and Regulations. Transmission Provider shall include an explanation of the results of Transmission Provider's evaluation for each technology in the feasibility study report.

3.4 System Impact Study

3.4.1 A system impact study shall identify and detail the electric system impacts that would result if the proposed Small Generating Facility were interconnected without project modifications or electric system modifications, focusing on the adverse system impacts identified in the feasibility study, or to study potential impacts, including but not limited to those identified in the scoping meeting. A system impact study shall evaluate the impact of the proposed interconnection on the reliability of the electric system.

3.4.2 If no transmission system impact study is required, but potential electric power Distribution System adverse system impacts are identified in the scoping meeting or shown in the feasibility study, a distribution system impact study must be performed. Transmission Provider shall send Interconnection Customer a distribution system impact study agreement within fifteen (15) Business Days of transmittal of the feasibility study report, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study, or following the scoping meeting if no feasibility study is to be performed.

3.4.3 In instances where the feasibility study or the distribution system impact study shows potential for transmission system adverse system impacts, within five (5) Business Days following transmittal of the feasibility study report, Transmission Provider shall send Interconnection Customer a transmission system impact study agreement, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study, if such a study is required.

- 3.4.4 If a transmission system impact study is not required, but electric power Distribution System adverse system impacts are shown by the feasibility study to be possible and no distribution system impact study has been conducted, Transmission Provider shall send Interconnection Customer a distribution system impact study agreement.
- 3.4.5 If the feasibility study shows no potential for transmission system or Distribution System adverse system impacts, Transmission Provider shall send Interconnection Customer either a facilities study agreement (Attachment 8), including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study, or an executable interconnection agreement, as applicable.
- 3.4.6 In order to remain under consideration for interconnection, Interconnection Customer must return executed system impact study agreements, if applicable, within thirty (30) Business Days.
- 3.4.7 A deposit of the good faith estimated costs for each system impact study may be required from Interconnection Customer.
- 3.4.8 The scope of and cost responsibilities for a system impact study are described in the attached system impact study agreement.
- 3.4.9 Where transmission systems and Distribution Systems have separate owners, such as is the case with transmission-dependent utilities (“TDUs”) – whether investor-owned or not – Interconnection Customer may apply to the nearest Transmission Provider (Transmission Owner, Regional Transmission Operator, or Independent Transmission Provider) providing transmission service to the TDU to request project coordination. Affected Systems shall participate in the study and provide all information necessary to prepare the study.
- 3.4.10 The system impact study shall evaluate static synchronous compensators, static VAR compensators, advanced power flow control devices, transmission switching, synchronous condensers, voltage source converters, advanced conductors, and tower lifting. Transmission Provider shall evaluate each identified alternative transmission technology and determine whether it should be used, consistent with Good Utility Practice, Applicable Reliability Standards, and Applicable Laws and Regulations. Transmission Provider shall include an explanation of the results of Transmission

Provider's evaluation for each technology in the system impact study report.

3.5 Facilities Study

- 3.5.1 Once the required system impact study(s) is completed, a system impact study report shall be prepared and transmitted to Interconnection Customer along with a facilities study agreement within five (5) Business Days, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the facilities study. In the case where one or both impact studies are determined to be unnecessary, a notice of the fact shall be transmitted to Interconnection Customer within the same timeframe.
- 3.5.2 In order to remain under consideration for interconnection, or, as appropriate, in Transmission Provider's interconnection queue, Interconnection Customer must return the executed facilities study agreement or a request for an extension of time within thirty (30) Business Days.
- 3.5.3 The facilities study shall specify and estimate the cost of the equipment, engineering, procurement and construction work (including overheads) needed to implement the conclusions of the system impact study(s).
- 3.5.4 Design for any required Interconnection Facilities and/or Upgrades shall be performed under the facilities study agreement. Transmission Provider may contract with consultants to perform activities required under the facilities study agreement. Interconnection Customer and Transmission Provider may agree to allow Interconnection Customer to separately arrange for the design of some of the Interconnection Facilities. In such cases, facilities design will be reviewed and/or modified prior to acceptance by Transmission Provider, under the provisions of the facilities study agreement. If the Parties agree to separately arrange for design and construction, and provided security and confidentiality requirements can be met, Transmission Provider shall make sufficient information available to Interconnection Customer in accordance with confidentiality and critical infrastructure requirements to permit Interconnection Customer to obtain an independent design and cost estimate for any necessary facilities.

- 3.5.5 A deposit of the good faith estimated costs for the facilities study may be required from Interconnection Customer.
- 3.5.6 The scope of and cost responsibilities for the facilities study are described in the attached facilities study agreement.
- 3.5.7 Upon completion of the facilities study, and with the agreement of Interconnection Customer to pay for Interconnection Facilities and Upgrades identified in the facilities study, Transmission Provider shall provide Interconnection Customer an executable interconnection agreement within five (5) Business Days.

Section 4. Provisions that Apply to All Interconnection Requests

1.1 Reasonable Efforts

Transmission Provider shall make reasonable efforts to meet all time frames provided in these procedures unless Transmission Provider and Interconnection Customer agree to a different schedule. If Transmission Provider cannot meet a deadline provided herein, it shall notify Interconnection Customer, explain the reason for the failure to meet the deadline, and provide an estimated time by which it will complete the applicable interconnection procedure in the process.

4.2 Disputes

- 4.2.1 The Parties agree to attempt to resolve all disputes arising out of the interconnection process according to the provisions of this article.
- 4.2.2 In the event of a dispute, either Party shall provide the other Party with a written Notice of Dispute. Such Notice shall describe in detail the nature of the dispute.
- 4.2.3 If the dispute has not been resolved within two (2) Business Days after receipt of the Notice, either Party may contact FERC's Dispute Resolution Service (DRS) for assistance in resolving the dispute.
- 4.2.4 The DRS will assist the Parties in either resolving their dispute or in selecting an appropriate dispute resolution venue (e.g., mediation, settlement judge, early neutral evaluation, or technical expert) to assist the

Parties in resolving their dispute. DRS can be reached at 1-877-337-2237 or via the internet at <http://www.ferc.gov/legal/adr.asp>.

- 4.2.5 Each Party agrees to conduct all negotiations in good faith and will be responsible for one-half of any costs paid to neutral third-parties.
- 4.2.6 If neither Party elects to seek assistance from the DRS, or if the attempted dispute resolution fails, then either Party may exercise whatever rights and remedies it may have in equity or law consistent with the terms of these procedures.

4.3 Interconnection Metering

Any metering necessitated by the use of the Small Generating Facility shall be installed at Interconnection Customer's expense in accordance with Federal Energy Regulatory Commission, state, or local regulatory requirements or Transmission Provider's specifications.

4.4 Commissioning

Commissioning tests of Interconnection Customer's installed equipment shall be performed pursuant to applicable codes and standards. Transmission Provider must be given at least five (5) Business Days written notice, or as otherwise mutually agreed to by the Parties, of the tests and may be present to witness the commissioning tests.

4.5. Confidentiality

4.5.1 Confidential information shall mean any confidential and/or proprietary information provided by one Party to the other Party that is clearly marked or otherwise designated "Confidential." For purposes of these procedures all design, operating specifications, and metering data provided by Interconnection Customer shall be deemed confidential information regardless of whether it is clearly marked or otherwise designated as such.

4.5.2 Confidential Information does not include information previously in the public domain, required to be publicly submitted or divulged by Governmental Authorities (after notice to the other Party and after exhausting any opportunity to oppose such publication or release), or necessary to be divulged in an action to enforce these procedures. Each Party receiving Confidential Information shall hold such information in

confidence and shall not disclose it to any third party nor to the public without the prior written authorization from the Party providing that information, except to fulfill obligations under these procedures, or to fulfill legal or regulatory requirements.

4.5.2.1 Each Party shall employ at least the same standard of care to protect Confidential Information obtained from the other Party as it employs to protect its own Confidential Information.

4.5.2.2 Each Party is entitled to equitable relief, by injunction or otherwise, to enforce its rights under this provision to prevent the release of Confidential Information without bond or proof of damages, and may seek other remedies available at law or in equity for breach of this provision.

4.5.3 Notwithstanding anything in this article to the contrary, and pursuant to 18 CFR § 1b.20, if FERC, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to these procedures, the Party shall provide the requested information to FERC, within the time provided for in the request for information. In providing the information to FERC, the Party may, consistent with 18 CFR § 388.112, request that the information be treated as confidential and non-public by FERC and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party prior to the release of the Confidential Information to FERC. The Party shall notify the other Party when it is notified by FERC that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR § 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

4.6 Comparability

Transmission Provider shall receive, process and analyze all Interconnection Requests in a timely manner as set forth in this document. Transmission Provider shall use the same reasonable efforts in processing and analyzing Interconnection

Requests from all Interconnection Customers, whether the Small Generating Facility is owned or operated by Transmission Provider, its subsidiaries or affiliates, or others.

4.7 Record Retention

Transmission Provider shall maintain for three years records, subject to audit, of all Interconnection Requests received under these procedures, the times required to complete Interconnection Request approvals and disapprovals, and justification for the actions taken on the Interconnection Requests.

4.8 Interconnection Agreement

After receiving an interconnection agreement from Transmission Provider, Interconnection Customer shall have thirty (30) Business Days or another mutually agreeable timeframe to sign and return the interconnection agreement or request that Transmission Provider file an unexecuted interconnection agreement with the Federal Energy Regulatory Commission. If Interconnection Customer does not sign the interconnection agreement, or ask that it be filed unexecuted by Transmission Provider within thirty (30) Business Days, the Interconnection Request shall be deemed withdrawn. After the interconnection agreement is signed by the Parties, the interconnection of the Small Generating Facility shall proceed under the provisions of the interconnection agreement.

4.9 Coordination with Affected Systems

Transmission Provider shall coordinate the conduct of any studies required to determine the impact of the Interconnection Request on Affected Systems with Affected System operators and, if possible, include those results (if available) in its applicable interconnection study within the time frame specified in these procedures. Transmission Provider will include such Affected System operators in all meetings held with Interconnection Customer as required by these procedures. Interconnection Customer will cooperate with Transmission Provider in all matters related to the conduct of studies and the determination of modifications to Affected Systems. A Transmission Provider which may be an Affected System shall cooperate with Transmission Provider with whom interconnection has been requested in all matters related to the conduct of studies and the determination of modifications to Affected Systems.

4.10 Capacity of the Small Generating Facility

- 4.10.1 If the Interconnection Request is for an increase in capacity for an existing Small Generating Facility, the Interconnection Request shall be evaluated on the basis of the new total capacity of the Small Generating Facility.
- 4.10.2 If the Interconnection Request is for a Small Generating Facility that includes multiple energy production devices at a site for which Interconnection Customer seeks a single Point of Interconnection, the Interconnection Request shall be evaluated on the basis of the aggregate capacity of the multiple devices.
- 4.10.3 The Interconnection Request shall be evaluated using the maximum capacity that the Small Generating Facility is capable of injecting into Transmission Provider's electric system. However, if the maximum capacity that the Small Generating Facility is capable of injecting into Transmission Provider's electric system is limited (e.g., through use of a control system, power relay(s), or other similar device settings or adjustments), then Interconnection Customer must obtain Transmission Provider's agreement, with such agreement not to be unreasonably withheld, that the manner in which Interconnection Customer proposes to implement such a limit will not adversely affect the safety and reliability of Transmission Provider's system. If Transmission Provider does not so agree, then the Interconnection Request must be withdrawn or revised to specify the maximum capacity that the Small Generating Facility is capable of injecting into Transmission Provider's electric system without such limitations. Furthermore, nothing in this section shall prevent a Transmission Provider from considering an output higher than the limited output, if appropriate, when evaluating system protection impacts.

Attachment 1

Glossary of Terms

10 kW Inverter Process – The procedure for evaluating an Interconnection Request for a certified inverter-based Small Generating Facility no larger than 10 kW that uses the section 2 screens. The application process uses an all-in-one document that includes a simplified Interconnection Request, simplified procedures, and a brief set of terms and conditions. See SGIP Attachment 5.

Affected System – An electric system other than Transmission Provider’s Transmission System that may be affected by the proposed interconnection.

Applicable Reliability Standards – The requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Applicable Laws and Regulations – All duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Business Day – Monday through Friday, excluding Federal Holidays.

Distribution System – Transmission Provider’s facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which Distribution Systems operate differ among areas.

Distribution Upgrades – The additions, modifications, and upgrades to Transmission Provider’s Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Small Generating Facility and render the transmission service necessary to effect Interconnection Customer’s wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Fast Track Process – The procedure for evaluating an Interconnection Request for a certified Small Generating Facility that meets the eligibility requirements of section 2.1 and includes the section 2 screens, customer options meeting, and optional supplemental review.

Good Utility Practice – Any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and act which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Interconnection Customer – Any entity, including Transmission Provider, the Transmission Owner or any of the affiliates or subsidiaries of either, that proposes to interconnect its Small Generating Facility with Transmission Provider’s Transmission System.

Interconnection Facilities – Transmission Provider’s Interconnection Facilities and Interconnection Customer’s Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Small Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Small Generating Facility to Transmission Provider’s Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades or Network Upgrades.

Interconnection Request – Interconnection Customer’s request, in accordance with the Tariff, to interconnect a new Small Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Small Generating Facility that is interconnected with Transmission Provider’s Transmission System.

Material Modification – A modification that has a material impact on the cost or timing of any Interconnection Request with a later queue priority date.

Network Resource – Any designated generating resource owned, purchased, or leased by a Network Customer under the Network Integration Transmission Service Tariff. Network Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Network Customer’s Network Load on a non-interruptible basis.

Network Resource Interconnection Service – An Interconnection Service that allows Interconnection Customer to integrate its Generating Facility with Transmission Provider’s System (1) in a manner comparable to that in which Transmission Provider

integrates its generating facilities to serve native load customers; or (2) in an RTO or ISO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service in and of itself does not convey transmission service.

Network Upgrades – Additions, modifications, and upgrades to Transmission Provider’s Transmission System required at or beyond the point at which the Small Generating Facility interconnects with Transmission Provider’s Transmission System to accommodate the interconnection with the Small Generating Facility to Transmission Provider’s Transmission System. Network Upgrades do not include Distribution Upgrades.

Party or Parties – Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Point of Interconnection – The point where the Interconnection Facilities connect with Transmission Provider’s Transmission System.

Queue Position – The order of a valid Interconnection Request, relative to all other pending valid Interconnection Requests, that is established based upon the date and time of receipt of the valid Interconnection Request by Transmission Provider.

Small Generating Facility – Interconnection Customer’s device for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer’s Interconnection Facilities.

Study Process – The procedure for evaluating an Interconnection Request that includes the section 3 scoping meeting, feasibility study, system impact study, and facilities study.

Transmission Owner – The entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Small Generator Interconnection Agreement to the extent necessary.

Transmission Provider – The public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission System – The facilities owned, controlled or operated by Transmission Provider or the Transmission Owner that are used to provide transmission service under the Tariff.

Upgrades – The required additions and modifications to Transmission Provider’s Transmission System at or beyond the Point of Interconnection. Upgrades may be Network Upgrades or Distribution Upgrades. Upgrades do not include Interconnection Facilities.

Attachment 2
SMALL GENERATOR INTERCONNECTION REQUEST
(Application Form)

Transmission Provider: _____

Designated Contact Person: _____

Address: _____

Telephone Number: _____

Fax: _____

E-Mail Address: _____

An Interconnection Request is considered complete when it provides all applicable and correct information required below. Per SGIP section 1.5, documentation of site control must be submitted with the Interconnection Request.

Preamble and Instructions

An Interconnection Customer who requests a Federal Energy Regulatory Commission jurisdictional interconnection must submit this Interconnection Request by hand delivery, mail, e-mail, or fax to Transmission Provider.

Processing Fee or Deposit:

If the Interconnection Request is submitted under the Fast Track Process, the non-refundable processing fee is \$500.

If the Interconnection Request is submitted under the Study Process, whether a new submission or an Interconnection Request that did not pass the Fast Track Process, Interconnection Customer shall submit to Transmission Provider a deposit not to exceed \$1,000 towards the cost of the feasibility study.

Interconnection Customer Information

Legal Name of Interconnection Customer (or, if an individual, individual's name)

Name: _____

Contact Person: _____

Mailing Address:

City: _____ State: _____ Zip: _____

Facility Location (if different from above):

Telephone (Day): _____ Telephone (Evening): _____

Fax: _____ E-Mail Address: _____

Alternative Contact Information (if different from Interconnection Customer)

Contact Name: _____

Title: _____

Address: _____

Telephone (Day): _____ Telephone (Evening): _____

Fax: _____ E-Mail Address: _____

Application is for: _____ New Small Generating Facility

_____ Capacity addition to Existing Small Generating Facility

If capacity addition to existing facility, please describe: _____

Will the Small Generating Facility be used for any of the following?

Net Metering? Yes ___ No ___

To Supply Power to Interconnection Customer? Yes ___ No ___

To Supply Power to Others? Yes ___ No ___

For installations at locations with existing electric service to which the proposed Small Generating Facility will interconnect, provide:

(Local Electric Service Provider*)

(Existing Account Number*)

{*To be provided by Interconnection Customer if the local electric service provider is different from Transmission Provider}

Contact Name:

Title:

Address:

Telephone (Day): _____ Telephone (Evening): _____

Fax: _____ E-Mail Address: _____

Requested Point of Interconnection:

Interconnection Customer's Requested In-Service Date:

Small Generating Facility Information

Data apply only to the Small Generating Facility, not the Interconnection Facilities.

Energy Source: ___ Solar ___ Wind ___ Hydro ___ Hydro Type (e.g. Run-of-River): _____
___ Diesel ___ Natural Gas ___ Fuel Oil Other (state type)

Prime Mover: ___ Fuel Cell ___ Recip Engine ___ Gas Turb ___ Steam Turb

Microturbine PV Other

Type of Generator: Synchronous Induction Inverter

Generator Nameplate Rating: _____ kW (Typical) Generator Nameplate kVAR:

Interconnection Customer or Customer-Site Load: _____ kW (if none, so state)

Typical Reactive Load (if known): _____

Maximum Physical Export Capability Requested: _____ kW

List components of the Small Generating Facility equipment package that are currently certified:

	Equipment Type	Certifying Entity
1.	_____	_____
2.	_____	_____
3.	_____	_____
4.	_____	_____
5.	_____	_____

Is the prime mover compatible with the certified protective relay package? Yes
 No

Generator (or solar collector) Manufacturer, Model Name & Number:

Version Number: _____

Nameplate Output Power Rating in kW: (Summer) _____ (Winter)

Nameplate Output Power Rating in kVA: (Summer) _____ (Winter)

Individual Generator Power Factor

Rated Power Factor: Leading: _____ Lagging: _____

Total Number of Generators in wind farm to be interconnected pursuant to this

Interconnection Request: _____ Elevation: _____ Single phase _____ Three phase

Inverter Manufacturer, Model Name & Number (if used): _____

List of adjustable set points for the protective equipment or software:

Note: A completed Power Systems Load Flow data sheet must be supplied with the Interconnection Request.

Small Generating Facility Characteristic Data (for inverter-based machines)

Max design fault contribution current: _____ Instantaneous or RMS _____?

Harmonics Characteristics:

Start-up requirements:

Small Generating Facility Characteristic Data (for rotating machines)

RPM Frequency: _____

(*) Neutral Grounding Resistor (If Applicable): _____

Synchronous Generators:

Direct Axis Synchronous Reactance, X_d : _____ P.U.

Direct Axis Transient Reactance, X'_d : _____ P.U.

Direct Axis Subtransient Reactance, X''_d : _____ P.U.

Negative Sequence Reactance, X_2 : _____ P.U.

Zero Sequence Reactance, X_0 : _____ P.U.

KVA Base: _____

Field Volts: _____

Field Amperes: _____

Induction Generators:

Motoring Power (kW): _____

I22t or K (Heating Time Constant): _____

Rotor Resistance, R_r : _____

Stator Resistance, R_s : _____

Stator Reactance, X_s : _____

Rotor Reactance, X_r : _____

Magnetizing Reactance, X_m : _____

Short Circuit Reactance, X_d'' : _____

Exciting Current: _____

Temperature Rise: _____

Frame Size: _____

Design Letter: _____

Reactive Power Required In Vars (No Load): _____

Reactive Power Required In Vars (Full Load): _____

Total Rotating Inertia, H: _____ Per Unit on kVA Base

Note: Please contact Transmission Provider prior to submitting the Interconnection Request to determine if the specified information above is required.

Excitation and Governor System Data for Synchronous Generators Only

Provide appropriate IEEE model block diagram of excitation system, governor system and power system stabilizer (PSS) in accordance with the regional reliability council criteria. A PSS may be determined to be required by applicable studies. A copy of the manufacturer’s block diagram may not be substituted.

Models for Non-synchronous Small Generating Facilities

For a non-synchronous Small Generating Facility, Interconnection Customer shall provide (1) a validated user-defined root mean squared (RMS) positive sequence dynamics model; (2) an appropriately parameterized generic library RMS positive sequence dynamics model, including model block diagram of the inverter control and plant control systems, as defined by the selection in Table 1 or a model otherwise approved by the Western Electricity Coordinating Council, that corresponds to Interconnection Customer’s Small Generating Facility; and (3) if applicable, a validated electromagnetic transient model if Transmission Provider performs an electromagnetic transient study as part of the interconnection study process. A user-defined model is a set of programming code created by equipment manufacturers or developers that captures the latest features of controllers that are mainly software based and represents the entities’ control strategies but does not necessarily correspond to any generic library model. Interconnection Customer must also demonstrate that the model is validated by providing evidence that the equipment behavior is consistent with the model behavior (e.g., an attestation from Interconnection Customer that the model accurately represents the entire Small Generating Facility; attestations from each equipment manufacturer that the user defined model accurately represents the component of the Small Generating Facility; or test data).

Table 1: Acceptable Generic Library RMS Positive Sequence Dynamics Models

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
pvd1		PVD1	Distributed PV system model
der_a	DERAU1	DER_A	Distributed energy resource model
regc_a	REGCAU1, REGCA1	REGC_A	Generator/converter model
regc_b	REGCBU1	REGC_B	Generator/converter model
wtlg	WT1G1	WT1G and WT1G1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
wt2g	WT2G1	WT2G and WT2G1	Generator model for generic Type-2 wind turbines
wt2e	WT2E1	WT2E and WT2E1	Rotor resistance control model for wound-rotor induction wind-turbine generator wt2g
reec_a	REECAU1, REECA1	REEC_A	Renewable energy electrical control model
reec_c	REECCU1	REEC_C	Electrical control model for battery energy storage system
reec_d	REECDU1	REEC_D	Renewable energy electrical control model
wt1t	WT12T1	WT1T and WT12T1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)
wt1p_b	wt1p_b	WT12A1U_B	Generic wind turbine pitch controller for WTGs of Types 1 and 2
wt2t	WT12T1	WT2T	Wind turbine model for Type-2 wind turbines (directly connected induction generator wind turbines with an external rotor resistance)
wtgt_a	WTDTAU1, WTDTA1	WTGT_A	Wind turbine drive train model
wtga_a	WTARAU1, WTARA1	WTGA_A	Simple aerodynamic model
wtgp_a	WTPTAU1, WTPTA1	WTGPT_A	Wind Turbine Generator Pitch controller
wtgq_a	WTTQAU1, WTTQA1	WTGTRQ_A	Wind Turbine Generator Torque controller
wtgwgo_a	WTGWGOAU	WTGWGO_A	Supplementary control model for Weak Grids
wtgibffr_a	WTGIBFFRA	WTGIBFFR_A	Inertial-base fast frequency response control
wtgp_b	WTPTBU1	WTGPT_B	Wind Turbine Generator Pitch controller
wtgt_b	WTDTBU1	WTGT_B	Drive train model

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
repc_a	Type 4: REPCAU1 (v33), REPCA1 (v34) Type 3: REPCTAU1 (v33), REPCTA1 (v34)	REPC_A	Power Plant Controller
repc_b	PLNTBU1	REPC_B	Power Plant Level Controller for controlling several plants/devices In regard to Siemens PSS/E*: Names of other models for interface with other devices: REA3XBU1, REAX4BU1- for interface with Type 3 and 4 renewable machines SWSAXBU1- for interface with SVC (modeled as switched shunt in powerflow) SYNAXBU1- for interface with synchronous condenser FCTAXBUI- for interface with FACTS device
repc_c	REPCCU	REPC_C	Power plant controller

Interconnection Facilities Information

Will a transformer be used between the generator and the point of common coupling?

Yes No

Will the transformer be provided by Interconnection Customer? Yes No

Transformer Data (If Applicable, for Interconnection Customer-Owned Transformer):

Is the transformer: single phase three phase? Size: _____ kVA

Transformer Impedance: _____% on _____kVA Base

If Three Phase:

Transformer Primary: _____ Volts _____ Delta _____ Wye _____ Wye Grounded

Transformer Secondary: _____ Volts _____ Delta _____ Wye _____ Wye Grounded

Transformer Tertiary: _____ Volts _____ Delta _____ Wye _____ Wye Grounded

Transformer Fuse Data (If Applicable, for Interconnection Customer-Owned Fuse):

(Attach copy of fuse manufacturer’s Minimum Melt and Total Clearing Time-Current Curves)

Manufacturer: _____ Type: _____ Size: _____ Speed: _____

Interconnecting Circuit Breaker (if applicable):

Manufacturer: _____ Type: _____

Load Rating (Amps): _____ Interrupting Rating (Amps): _____ Trip Speed (Cycles): _____

Interconnection Protective Relays (If Applicable):

If Microprocessor-Controlled:

List of Functions and Adjustable Setpoints for the protective equipment or software:

	Setpoint Function	Minimum	Maximum
1.	_____	_____	_____
2.	_____	_____	_____
3.	_____	_____	_____
4.	_____	_____	_____
5.	_____	_____	_____
6.	_____	_____	_____

If Discrete Components:

(Enclose Copy of any Proposed Time-Overcurrent Coordination Curves)

Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____

Current Transformer Data (If Applicable):

(Enclose Copy of Manufacturer's Excitation and Ratio Correction Curves)

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection: _____

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection: _____

Potential Transformer Data (If Applicable):

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection:

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection:

General Information

Enclose copy of site electrical one-line diagram showing the configuration of all Small Generating Facility equipment, current and potential circuits, and protection and control schemes. This one-line diagram must be signed and stamped by a licensed Professional Engineer if the Small Generating Facility is larger than 50 kW. Is One-Line Diagram Enclosed? ___ Yes ___ No

Enclose copy of any site documentation that indicates the precise physical location of the proposed Small Generating Facility (e.g., USGS topographic map or other diagram or documentation).

Proposed location of protective interface equipment on property (include address if different from Interconnection Customer’s address) _____

Enclose copy of any site documentation that describes and details the operation of the protection and control schemes. Is Available Documentation Enclosed? ___ Yes ___ No

Enclose copies of schematic drawings for all protection and control circuits, relay current circuits, relay potential circuits, and alarm/monitoring circuits (if applicable).

Are Schematic Drawings Enclosed? ___ Yes ___ No

Applicant Signature

I hereby certify that, to the best of my knowledge, all the information provided in this Interconnection Request is true and correct.

For Interconnection Customer: _____ Date:

Attachment 3

Certification Codes and Standards

IEEE1547 Standard for Interconnecting Distributed Resources with Electric Power Systems (including use of IEEE 1547.1 testing protocols to establish conformity)

UL 1741 Inverters, Converters, and Controllers for Use in Independent Power Systems

IEEE Std 929-2000 IEEE Recommended Practice for Utility Interface of Photovoltaic (PV) Systems

NFPA 70 (2002), National Electrical Code

IEEE Std C37.90.1-1989 (R1994), IEEE Standard Surge Withstand Capability (SWC) Tests for Protective Relays and Relay Systems

IEEE Std C37.90.2 (1995), IEEE Standard Withstand Capability of Relay Systems to Radiated Electromagnetic Interference from Transceivers

IEEE Std C37.108-1989 (R2002), IEEE Guide for the Protection of Network Transformers

IEEE Std C57.12.44-2000, IEEE Standard Requirements for Secondary Network Protectors

IEEE Std C62.41.2-2002, IEEE Recommended Practice on Characterization of Surges in Low Voltage (1000V and Less) AC Power Circuits

IEEE Std C62.45-1992 (R2002), IEEE Recommended Practice on Surge Testing for Equipment Connected to Low-Voltage (1000V and Less) AC Power Circuits

ANSI C84.1-1995 Electric Power Systems and Equipment – Voltage Ratings (60 Hertz)

IEEE Std 100-2000, IEEE Standard Dictionary of Electrical and Electronic Terms

NEMA MG 1-1998, Motors and Small Resources, Revision 3

IEEE Std 519-1992, IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems

NEMA MG 1-2003 (Rev 2004), Motors and Generators, Revision 1

Attachment 4

Certification of Small Generator Equipment Packages

- 1.0 Small Generating Facility equipment proposed for use separately or packaged with other equipment in an interconnection system shall be considered certified for interconnected operation if (1) it has been tested in accordance with industry standards for continuous utility interactive operation in compliance with the appropriate codes and standards referenced below by any Nationally Recognized Testing Laboratory (NRTL) recognized by the United States Occupational Safety and Health Administration to test and certify interconnection equipment pursuant to the relevant codes and standards listed in SGIP Attachment 3, (2) it has been labeled and is publicly listed by such NRTL at the time of the interconnection application, and (3) such NRTL makes readily available for verification all test standards and procedures it utilized in performing such equipment certification, and, with consumer approval, the test data itself. The NRTL may make such information available on its website and by encouraging such information to be included in the manufacturer's literature accompanying the equipment.
- 2.0 Interconnection Customer must verify that the intended use of the equipment falls within the use or uses for which the equipment was tested, labeled, and listed by the NRTL.
- 3.0 Certified equipment shall not require further type-test review, testing, or additional equipment to meet the requirements of this interconnection procedure; however, nothing herein shall preclude the need for an on-site commissioning test by the parties to the interconnection nor follow-up production testing by the NRTL.
- 4.0 If the certified equipment package includes only interface components (switchgear, inverters, or other interface devices), then an Interconnection Customer must show that the generator or other electric source being utilized with the equipment package is compatible with the equipment package and is consistent with the testing and listing specified for this type of interconnection equipment.
- 5.0 Provided the generator or electric source, when combined with the equipment package, is within the range of capabilities for which it was tested by the NRTL, and does not violate the interface components' labeling and listing performed by the NRTL, no further design review, testing or additional equipment on the

customer side of the point of common coupling shall be required to meet the requirements of this interconnection procedure.

6.0 An equipment package does not include equipment provided by the utility.

7.0 Any equipment package approved and listed in a state by that state's regulatory body for interconnected operation in that state prior to the effective date of these small generator interconnection procedures shall be considered certified under these procedures for use in that state.

Attachment 5

Application, Procedures, and Terms and Conditions for Interconnecting a Certified Inverter-Based Small Generating Facility No Larger than 10 kW (“10 kW Inverter Process”)

- 1.0 Interconnection Customer (“Customer”) completes the Interconnection Request (“Application”) and submits it to Transmission Provider (“Company”).
- 2.0 The Company acknowledges to the Customer receipt of the Application within three (3) Business Days of receipt.
- 3.0 The Company evaluates the Application for completeness and notifies the Customer within ten (10) Business Days of receipt that the Application is or is not complete and, if not, advises what material is missing.
- 4.0 The Company verifies that the Small Generating Facility can be interconnected safely and reliably using the screens contained in the Fast Track Process in the Small Generator Interconnection Procedures (SGIP). The Company has fifteen (15) Business Days to complete this process. Unless the Company determines and demonstrates that the Small Generating Facility cannot be interconnected safely and reliably, the Company approves the Application and returns it to the Customer. Note to Customer: Please check with the Company before submitting the Application if disconnection equipment is required.
- 5.0 After installation, the Customer returns the Certificate of Completion to the Company. Prior to parallel operation, the Company may inspect the Small Generating Facility for compliance with standards which may include a witness test, and may schedule appropriate metering replacement, if necessary.
- 6.0 The Company notifies the Customer in writing that interconnection of the Small Generating Facility is authorized. If the witness test is not satisfactory, the Company has the right to disconnect the Small Generating Facility. The Customer has no right to operate in parallel until a witness test has been performed, or previously waived on the Application. The Company is obligated to complete this witness test within ten (10) Business Days of the receipt of the Certificate of Completion. If the Company does not inspect within ten (10) Business Days or by mutual agreement of the Parties, the witness test is deemed waived.

- 7.0 Contact Information – The Customer must provide the contact information for the legal applicant (i.e., Interconnection Customer). If another entity is responsible for interfacing with the Company, that contact information must be provided on the Application.
- 8.0 Ownership Information – Enter the legal names of the owner(s) of the Small Generating Facility. Include the percentage ownership (if any) by any utility or public utility holding company, or by any entity owned by either.
- 9.0 UL1741 Listed – This standard (“Inverters, Converters, and Controllers for Use in Independent Power Systems”) addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL1741. This “listing” is then marked on the equipment and supporting documentation.

Application for Interconnecting a Certified Inverter-Based Small Generating Facility No Larger than 10kW

This Application is considered complete when it provides all applicable and correct information required below. Per SGIP section 1.5, documentation of site control must be submitted with the Interconnection Request. Additional information to evaluate the Application may be required.

Processing Fee

A non-refundable processing fee of \$100 must accompany this Application.

Interconnection Customer

Name:

Contact Person:

Address:

City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

Contact (if different from Interconnection Customer)

Name:

Contact Person:

Address:

City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

Owner of the facility (include % ownership by any electric utility):

____ Small Generating Facility Information

Location (if different from above):

Electric Service Company:

Account Number:

Inverter Manufacturer: _____ Model: _____
Nameplate Rating: _____ (kW) _____ (kVA) _____ (AC Volts)

Single Phase ____ Three Phase ____

System Design Capacity: _____ (kW) _____ (kVA)

Prime Mover: ____ Photovoltaic ____ Reciprocating Engine ____ Fuel Cell
____ Turbine ____ Other (describe) _____

Energy Source: ____ Solar ____ Wind ____ Hydro ____ Diesel ____ Natural Gas
____ Fuel Oil ____ Other (describe) _____

Is the equipment UL1741 Listed? ____ Yes ____ No

If Yes, attach manufacturer's cut-sheet showing UL1741 listing

Estimated Installation Date: _____ Estimated In-Service Date:

The 10 kW Inverter Process is available only for inverter-based Small Generating Facilities no larger than 10 kW that meet the codes, standards, and certification requirements of Attachments 3 and 4 of the Small Generator Interconnection Procedures (SGIP), or Transmission Provider has reviewed the design or tested the proposed Small Generating Facility and is satisfied that it is safe to operate.

List components of the Small Generating Facility equipment package that are currently certified:

	Equipment Type	Certifying Entity
1.	_____	_____
2.	_____	_____
3.	_____	_____
4.	_____	_____
5.	_____	_____

Interconnection Customer Signature

I hereby certify that, to the best of my knowledge, the information provided in this Application is true. I agree to abide by the Terms and Conditions for Interconnecting an Inverter-Based Small Generating Facility No Larger than 10kW and return the Certificate of Completion when the Small Generating Facility has been installed.

Signed:

Title: _____

Date:

.....
.....

Contingent Approval to Interconnect the Small Generating Facility

(For Company use only)

Interconnection of the Small Generating Facility is approved contingent upon the Terms and Conditions for Interconnecting an Inverter-Based Small Generating Facility No Larger than 10kW and return of the Certificate of Completion.

Company Signature:

Title: _____

Date:

Application ID number: _____

Company waives inspection/witness test? Yes ___ No ___

Small Generating Facility Certificate of Completion

Is the Small Generating Facility owner-installed? Yes _____ No _____

Interconnection Customer:

Contact Person:

Address:

Location of the Small Generating Facility (if different from above):

_____ City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

Electrician:

Name:

Address:

Location of the Small Generating Facility (if different from above):

_____ City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

License number: _____

Date Approval to Install Facility granted by the Company: _____

Application ID number: _____

Inspection:

The Small Generating Facility has been installed and inspected in compliance with the local

building/electrical code of:

Signed (Local electrical wiring inspector, or attach signed electrical inspection):

Print Name: _____

Date: _____

As a condition of interconnection, you are required to send/fax a copy of this form along with a copy of the signed electrical permit to (insert Company information below):

Name: _____

Company: _____

Address: _____

City, State ZIP: _____

Fax: _____

.....
.....

Approval to Energize the Small Generating Facility (For Company use only)

Energizing the Small Generating Facility is approved contingent upon the Terms and Conditions for Interconnecting an Inverter-Based Small Generating Facility No Larger than 10kW

Company Signature: _____

Title: _____ Date: _____

**Terms and Conditions for Interconnecting an Inverter-Based
Small Generating Facility No Larger than 10kW**

1.0 Construction of the Facility

Interconnection Customer (the “Customer”) may proceed to construct (including operational testing not to exceed two hours) the Small Generating Facility when Transmission Provider (the “Company”) approves the Interconnection Request (the “Application”) and returns it to the Customer.

2.0 Interconnection and Operation

The Customer may operate Small Generating Facility and interconnect with the Company’s electric system once all of the following have occurred:

- 2.1 Upon completing construction, the Customer will cause the Small Generating Facility to be inspected or otherwise certified by the appropriate local electrical wiring inspector with jurisdiction, and
- 2.2 The Customer returns the Certificate of Completion to the Company, and
- 2.3 The Company has either:
 - 2.3.1 Completed its inspection of the Small Generating Facility to ensure that all equipment has been appropriately installed and that all electrical connections have been made in accordance with applicable codes. All inspections must be conducted by the Company, at its own expense, within ten (10) Business Days after receipt of the Certificate of Completion and shall take place at a time agreeable to the Parties. The Company shall provide a written statement that the Small Generating Facility has passed inspection or shall notify the Customer of what steps it must take to pass inspection as soon as practicable after the inspection takes place; or
 - 2.3.2 If the Company does not schedule an inspection of the Small Generating Facility within ten (10) Business Days after receiving the Certificate of Completion, the witness test is deemed waived (unless the Parties agree otherwise); or
 - 2.3.3 The Company waives the right to inspect the Small Generating Facility.

- 2.4 The Company has the right to disconnect the Small Generating Facility in the event of improper installation or failure to return the Certificate of Completion.
- 2.5 Revenue quality metering equipment must be installed and tested in accordance with applicable ANSI standards.

3.0 Safe Operations and Maintenance

The Customer shall be fully responsible to operate, maintain, and repair the Small Generating Facility as required to ensure that it complies at all times with the interconnection standards to which it has been certified.

4.0 Access

The Company shall have access to the disconnect switch (if the disconnect switch is required) and metering equipment of the Small Generating Facility at all times. The Company shall provide reasonable notice to the Customer when possible prior to using its right of access.

5.0 Disconnection

The Company may temporarily disconnect the Small Generating Facility upon the following conditions:

- 5.1 For scheduled outages upon reasonable notice.
- 5.2 For unscheduled outages or emergency conditions.
- 5.3 If the Small Generating Facility does not operate in the manner consistent with these Terms and Conditions.
- 5.4 The Company shall inform the Customer in advance of any scheduled disconnection, or as is reasonable after an unscheduled disconnection.

6.0 Indemnification

The Parties shall at all times indemnify, defend, and save the other Party harmless from, any and all damages, losses, claims, including claims and actions relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's action or inactions of its obligations under this agreement on behalf of the indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the indemnified Party.

7.0 Insurance

The Parties agree to follow all applicable insurance requirements imposed by the state in which the Point of Interconnection is located. All insurance policies must be maintained with insurers authorized to do business in that state.

8.0 Limitation of Liability

Each party's liability to the other party for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall either party be liable to the other party for any indirect, incidental, special, consequential, or punitive damages of any kind whatsoever, except as allowed under paragraph 6.0.

9.0 Termination

The agreement to operate in parallel may be terminated under the following conditions:

9.1 By the Customer

By providing written notice to the Company.

9.2 By the Company

If the Small Generating Facility fails to operate for any consecutive 12 month period or the Customer fails to remedy a violation of these Terms and Conditions.

9.3 Permanent Disconnection

In the event this Agreement is terminated, the Company shall have the right to disconnect its facilities or direct the Customer to disconnect its Small Generating Facility.

9.4 Survival Rights

This Agreement shall continue in effect after termination to the extent necessary to allow or require either Party to fulfill rights or obligations that arose under the Agreement.

10.0 Assignment/Transfer of Ownership of the Facility

This Agreement shall survive the transfer of ownership of the Small Generating Facility to a new owner when the new owner agrees in writing to comply with the terms of this Agreement and so notifies the Company.

Attachment 6
Feasibility Study Agreement

THIS AGREEMENT is made and entered into this ____ day of _____
20__ by and between _____,
a _____ organized and existing under the laws of the State of _____,
_____, (“Interconnection Customer,”) and _____,
a _____ organized and existing under the laws of the State of _____,
_____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party, ” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Small Generating Facility or generating capacity addition to an existing Small Generating Facility consistent with the Interconnection Request completed by Interconnection Customer on _____; and

WHEREAS, Interconnection Customer desires to interconnect the Small Generating Facility with Transmission Provider’s Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a feasibility study to assess the feasibility of interconnecting the proposed Small Generating Facility with Transmission Provider’s Transmission System, and of any Affected Systems;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated or the meanings specified in the standard Small Generator Interconnection Procedures.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be performed an interconnection feasibility study consistent the standard Small

Generator Interconnection Procedures in accordance with the Open Access Transmission Tariff.

- 3.0 The scope of the feasibility study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The feasibility study shall be based on the technical information provided by Interconnection Customer in the Interconnection Request, as may be modified as the result of the scoping meeting. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the feasibility study and as designated in accordance with the standard Small Generator Interconnection Procedures. If Interconnection Customer modifies its Interconnection Request, the time to complete the feasibility study may be extended by agreement of the Parties.
- 5.0 In performing the study, Transmission Provider shall rely, to the extent reasonably practicable, on existing studies of recent vintage. Interconnection Customer shall not be charged for such existing studies; however, Interconnection Customer shall be responsible for charges associated with any new study or modifications to existing studies that are reasonably necessary to perform the feasibility study.
- 6.0 The feasibility study report shall provide the following analyses for the purpose of identifying any potential adverse system impacts that would result from the interconnection of the Small Generating Facility as proposed:
 - 6.1 Initial identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - 6.2 Initial identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - 6.3 Initial review of grounding requirements and electric system protection;and
 - 6.4 Description and non-binding estimated cost of facilities required to interconnect the proposed Small Generating Facility and to address the identified short circuit and power flow issues.

- 7.0 The feasibility study shall model the impact of the Small Generating Facility regardless of purpose in order to avoid the further expense and interruption of operation for reexamination of feasibility and impacts if Interconnection Customer later changes the purpose for which the Small Generating Facility is being installed.
- 8.0 The study shall include the feasibility of any interconnection at a proposed project site where there could be multiple potential Points of Interconnection, as requested by Interconnection Customer and at Interconnection Customer's cost.
- 9.0 A deposit of the lesser of 50 percent of good faith estimated feasibility study costs or earnest money of \$1,000 may be required from Interconnection Customer.
- 10.0 Once the feasibility study is completed, a feasibility study report shall be prepared and transmitted to Interconnection Customer. Barring unusual circumstances, the feasibility study must be completed and the feasibility study report transmitted within thirty (30) Business Days of Interconnection Customer's agreement to conduct a feasibility study.
- 11.0 Any study fees shall be based on Transmission Provider's actual costs and will be invoiced to Interconnection Customer after the study is completed and delivered and will include a summary of professional time.
- 12.0 Interconnection Customer must pay any study costs that exceed the deposit without interest within thirty (30) Calendar Days on receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced fees, Transmission Provider shall refund such excess within thirty (30) Calendar Days of the invoice without interest.
- 13.0 Governing Law, Regulatory Authority, and Rules
- The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____ (where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.
- 14.0 Amendment

The Parties may amend this Agreement by a written instrument duly executed by both Parties.

15.0 No Third-Party Beneficiaries

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

16.0 Waiver

16.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

16.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

17.0 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

18.0 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

19.0 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

20.0 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

20.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

20.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

21.0 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral

filing with FERC to modify this Agreement under any applicable provision of the Federal Power Act and FERC's rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider} {Insert name of Interconnection Customer}

Signed: _____

Signed: _____

Name (Printed):

Name (Printed):

Title: _____

Title: _____

**Attachment A to
Feasibility Study Agreement
Assumptions Used in Conducting the Feasibility Study**

The feasibility study will be based upon the information set forth in the Interconnection Request and agreed upon in the scoping meeting held on _____:

- 1) Designation of Point of Interconnection and configuration to be studied.

- 2) Designation of alternative Points of Interconnection and configuration.

1) and 2) are to be completed by the Interconnection Customer. Other assumptions (listed below) are to be provided by Interconnection Customer and Transmission Provider.

Attachment 7

System Impact Study Agreement

THIS AGREEMENT is made and entered into this ____ day of _____
 20__ by and between _____,
 a _____ organized and existing under the laws of the State of
 _____, (“Interconnection Customer,”) and
 _____, a _____
 organized and existing under the laws of the State
 of _____,
 (“Transmission Provider”). Interconnection Customer and Transmission Provider each
 may be referred to as a “Party, ” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Small Generating Facility or generating capacity addition to an existing Small Generating Facility consistent with the Interconnection Request completed by Interconnection Customer on _____; and

WHEREAS, Interconnection Customer desires to interconnect the Small Generating Facility with Transmission Provider’s Transmission System;

WHEREAS, Transmission Provider has completed a feasibility study and provided the results of said study to Interconnection Customer (This recital to be omitted if the Parties have agreed to forego the feasibility study.); and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a system impact study(s) to assess the impact of interconnecting the Small Generating Facility with Transmission Provider’s Transmission System, and of any Affected Systems;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated or the meanings specified in the standard Small Generator Interconnection Procedures.

- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be performed a system impact study(s) consistent with the standard Small Generator Interconnection Procedures in accordance with the Open Access Transmission Tariff.
- 3.0 The scope of a system impact study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 A system impact study will be based upon the results of the feasibility study and the technical information provided by Interconnection Customer in the Interconnection Request. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the system impact study. If Interconnection Customer modifies its designated Point of Interconnection, Interconnection Request, or the technical information provided therein is modified, the time to complete the system impact study may be extended.
- 5.0 A system impact study shall consist of a short circuit analysis, a stability analysis, a power flow analysis, voltage drop and flicker studies, protection and set point coordination studies, and grounding reviews, as necessary. A system impact study shall state the assumptions upon which it is based, state the results of the analyses, and provide the requirement or potential impediments to providing the requested interconnection service, including a preliminary indication of the cost and length of time that would be necessary to correct any problems identified in those analyses and implement the interconnection. A system impact study shall provide a list of facilities that are required as a result of the Interconnection Request and non-binding good faith estimates of cost responsibility and time to construct.
- 6.0 A distribution system impact study shall incorporate a distribution load flow study, an analysis of equipment interrupting ratings, protection coordination study, voltage drop and flicker studies, protection and set point coordination studies, grounding reviews, and the impact on electric system operation, as necessary.
- 7.0 Affected Systems may participate in the preparation of a system impact study, with a division of costs among such entities as they may agree. All Affected Systems shall be afforded an opportunity to review and comment upon a system impact study that covers potential adverse system impacts on their electric

systems, and Transmission Provider has twenty (20) additional Business Days to complete a system impact study requiring review by Affected Systems.

- 8.0 If Transmission Provider uses a queuing procedure for sorting or prioritizing projects and their associated cost responsibilities for any required Network Upgrades, the system impact study shall consider all generating facilities (and with respect to paragraph 8.3 below, any identified Upgrades associated with such higher queued interconnection) that, on the date the system impact study is commenced –
- 8.1 Are directly interconnected with Transmission Provider’s electric system;
- or
- 8.2 Are interconnected with Affected Systems and may have an impact on the proposed interconnection; and
- 8.3 Have a pending higher queued Interconnection Request to interconnect with Transmission Provider’s electric system.
- 9.0 A distribution system impact study, if required, shall be completed and the results transmitted to Interconnection Customer within thirty (30) Business Days after this Agreement is signed by the Parties. A transmission system impact study, if required, shall be completed and the results transmitted to Interconnection Customer within forty-five (45) Business Days after this Agreement is signed by the Parties, or in accordance with Transmission Provider’s queuing procedures.
- 10.0 A deposit of the equivalent of the good faith estimated cost of a distribution system impact study and the one half the good faith estimated cost of a transmission system impact study may be required from Interconnection Customer.
- 11.0 Any study fees shall be based on Transmission Provider’s actual costs and will be invoiced to Interconnection Customer after the study is completed and delivered and will include a summary of professional time.
- 12.0 Interconnection Customer must pay any study costs that exceed the deposit without interest within thirty (30) Calendar Days on receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced fees, Transmission Provider shall refund such excess within thirty (30) Calendar Days of the invoice without interest.
- 13.0 Governing Law, Regulatory Authority, and Rules

The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____ (where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.

14.0 Amendment

The Parties may amend this Agreement by a written instrument duly executed by both Parties.

15.0 No Third-Party Beneficiaries

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

16.0 Waiver

16.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

16.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

17.0 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

18.0 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

19.0 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

20.0 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

20.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

20.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

21.0 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement under any applicable provision of the

Federal Power Act and FERC’s rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC’s rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider} {Insert name of Interconnection Customer}

Signed: _____

Signed: _____

Name (Printed):

Name (Printed):

Title: _____

Title: _____

**Attachment A to System
Impact Study Agreement
Assumptions Used in Conducting the System Impact Study**

The system impact study shall be based upon the results of the feasibility study, subject to any modifications in accordance with the standard Small Generator Interconnection Procedures, and the following assumptions:

- 1) Designation of Point of Interconnection and configuration to be studied.

- 2) Designation of alternative Points of Interconnection and configuration.

1) and 2) are to be completed by Interconnection Customer. Other assumptions (listed below) are to be provided by Interconnection Customer and Transmission Provider.

Attachment 8
Facilities Study Agreement

THIS AGREEMENT is made and entered into this ____ day of _____
20__ by and between _____,
a _____ organized and existing under the laws of the State of
_____, (“Interconnection Customer,”) and
_____, a _____
organized and existing under the laws of the State
of _____,
 (“Transmission Provider”). Interconnection Customer and Transmission Provider each
may be referred to as a “Party, ” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Small Generating Facility or generating capacity addition to an existing Small Generating Facility consistent with the Interconnection Request completed by Interconnection Customer on _____; and

WHEREAS, Interconnection Customer desires to interconnect the Small Generating Facility with Transmission Provider’s Transmission System;

WHEREAS, Transmission Provider has completed a system impact study and provided the results of said study to Interconnection Customer; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a facilities study to specify and estimate the cost of the equipment, engineering, procurement and construction work needed to implement the conclusions of the system impact study in accordance with Good Utility Practice to physically and electrically connect the Small Generating Facility with Transmission Provider’s Transmission System.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated or the meanings specified in the standard Small Generator Interconnection Procedures.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause a facilities study consistent with the standard Small Generator Interconnection Procedures to be performed in accordance with the Open Access Transmission Tariff.
- 3.0 The scope of the facilities study shall be subject to data provided in Attachment A to this Agreement.
- 4.0 The facilities study shall specify and estimate the cost of the equipment, engineering, procurement and construction work (including overheads) needed to implement the conclusions of the system impact study(s). The facilities study shall also identify (1) the electrical switching configuration of the equipment, including, without limitation, transformer, switchgear, meters, and other station equipment, (2) the nature and estimated cost of Transmission Provider's Interconnection Facilities and Upgrades necessary to accomplish the interconnection, and (3) an estimate of the time required to complete the construction and installation of such facilities.
- 5.0 Transmission Provider may propose to group facilities required for more than one Interconnection Customer in order to minimize facilities costs through economies of scale, but any Interconnection Customer may require the installation of facilities required for its own Small Generating Facility if it is willing to pay the costs of those facilities.
- 6.0 A deposit of the good faith estimated facilities study costs may be required from Interconnection Customer.
- 7.0 In cases where Upgrades are required, the facilities study must be completed within forty-five (45) Business Days of the receipt of this Agreement. In cases where no Upgrades are necessary, and the required facilities are limited to Interconnection Facilities, the facilities study must be completed within thirty (30) Business Days.
- 8.0 Once the facilities study is completed, a "draft" facilities study report shall be prepared and transmitted to Interconnection Customer. Barring unusual circumstances, the facilities study must be completed and the "draft" facilities

study report transmitted within thirty (30) Business Days of Interconnection Customer's agreement to conduct a facilities study.

- 9.0 Interconnection Customer may, within thirty (30) Calendar Days after receipt of the draft report, provide written comments to Transmission Provider, which Transmission Provider shall include in the final report. Transmission Provider shall issue the final Interconnection Facilities Study report within fifteen (15) Business Days of receiving Interconnection Customer's comments or promptly upon receiving Interconnection Customer's statement that it will not provide comments. Transmission Provider may reasonably extend such fifteen-day period upon notice to Interconnection Customer if Interconnection Customer's comments require Transmission Provider to perform additional analyses or make other significant modifications prior to the issuance of the final Interconnection Facilities Report. Upon request, Transmission Provider shall provide Interconnection Customer supporting documentation, workpapers, and databases or data developed in the preparation of the Interconnection Facilities Study, subject to confidentiality arrangements consistent with Section 4.5 of the standard Small Generator Interconnection Procedures.
- 10.0 Within ten (10) Business Days of providing a draft Interconnection Facilities Study report to Interconnection Customer, Transmission Provider and Interconnection Customer shall meet to discuss the results of the Interconnection Facilities Study.
- 11.0 Any study fees shall be based on Transmission Provider's actual costs and will be invoiced to Interconnection Customer after the study is completed and delivered and will include a summary of professional time.
- 12.0 Interconnection Customer must pay any study costs that exceed the deposit without interest within thirty (30) Calendar Days on receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced fees, Transmission Provider shall refund such excess within thirty (30) Calendar Days of the invoice without interest.
- 13.0 Governing Law, Regulatory Authority, and Rules
- The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____

(where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.

14.0 Amendment

The Parties may amend this Agreement by a written instrument duly executed by both Parties.

15.0 No Third-Party Beneficiaries

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

16.0 Waiver

16.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

16.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

17.0 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

18.0 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

19.0 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

20.0 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

20.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

20.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

21.0 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement under any applicable provision of the Federal Power Act and FERC's rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider} {Insert name of Interconnection Customer}

Signed _____

Signed _____

Name (Printed):

Name (Printed):

Title _____

Title _____

**Attachment A to
Facilities Study Agreement
Data to Be Provided by Interconnection Customer
with the Facilities Study Agreement**

Provide location plan and simplified one-line diagram of the plant and station facilities. For staged projects, please indicate future generation, transmission circuits, etc.

On the one-line diagram, indicate the generation capacity attached at each metering location. (Maximum load on CT/PT)

On the one-line diagram, indicate the location of auxiliary power. (Minimum load on CT/PT) Amps

One set of metering is required for each generation connection to the new ring bus or existing Transmission Provider station. Number of generation connections:

Will an alternate source of auxiliary power be available during CT/PT maintenance?

Yes ____ No ____

Will a transfer bus on the generation side of the metering require that each meter set be designed for the total plant generation? Yes ____ No ____

(Please indicate on the one-line diagram).

What type of control system or PLC will be located at the Small Generating Facility?

What protocol does the control system or PLC use?

Please provide a 7.5-minute quadrangle map of the site. Indicate the plant, station, transmission line, and property lines.

Physical dimensions of the proposed interconnection station:

_____ Bus length from generation to interconnection station:

_____ Line length from interconnection station to Transmission Provider's Transmission System.

_____ Tower number observed in the field. (Painted on tower leg)*:

_____ Number of third party easements required for transmission lines*:

_____ * To be completed in coordination with Transmission Provider.

Is the Small Generating Facility located in Transmission Provider's service area?

Yes _____ No _____ If No, please provide name of local provider:

Please provide the following proposed schedule dates:

Begin Construction Date: _____

Generator step-up transformers Date: _____

receive back feed power

Generation Testing

Date: _____

Commercial Operation

Date: _____

ATTACHMENT P

Small Generator Interconnection Agreement

**SMALL GENERATOR
INTERCONNECTION AGREEMENT (SGIA)**

(For Generating Facilities No Larger Than 20 MW)

TABLE OF CONTENTS

Page No.

Article 1. Scope and Limitations of Agreement.....- 2 -

 1.5 Responsibilities of the Parties.....- 2 -

 1.6 Parallel Operation Obligations- 5 -

 1.7 Metering- 5 -

 1.8 Reactive Power and Primary Frequency Response- 5 -

 1.8.1 Power Factor Design Criteria.....- 5 -

 1.8.4 Primary Frequency Response.- 7 -

Article 2. Inspection, Testing, Authorization, and Right of Access- 10 -

 2.1 Equipment Testing and Inspection- 10 -

 2.2 Authorization Required Prior to Parallel Operation- 11 -

 2.3 Right of Access- 11 -

Article 3. Effective Date, Term, Termination, and Disconnection- 12 -

 3.1 Effective Date- 12 -

 3.2 Term of Agreement- 12 -

 3.3 Termination.....- 13 -

 3.4 Temporary Disconnection- 13 -

 3.4.1 Emergency Conditions- 13 -

 3.4.2 Routine Maintenance, Construction, and Repair- 14 -

 3.4.3 Forced Outages.....- 14 -

 3.4.4 Adverse Operating Effects.....- 15 -

 3.4.5 Modification of the Small Generating Facility- 15 -

 3.4.6 Reconnection.....- 15 -

Article 4. Cost Responsibility for Interconnection Facilities and Distribution Upgrades- 15 -

 4.1 Interconnection Facilities- 16 -

 4.2 Distribution Upgrades- 16 -

Article 5. Cost Responsibility for Network Upgrades.....- 16 -

 5.1 Applicability- 16 -

 5.2 Network Upgrades- 16 -

 5.2.1 Repayment of Amounts Advanced for Network Upgrades.....- 17 -

 5.3 Special Provisions for Affected Systems- 18 -

 5.4 Rights Under Other Agreements.....- 18 -

Article 6. Billing, Payment, Milestones, and Financial Security.....- 18 -

6.1 Billing and Payment Procedures and Final Accounting - 18 -

6.2 Milestones..... - 19 -

6.3 Financial Security Arrangements..... - 20 -

Article 7. Assignment, Liability, Indemnity, Force Majeure, Consequential Damages, and Default - 20 -

7.1 Assignment - 20 -

7.2 Limitation of Liability - 21 -

7.3 Indemnity - 21 -

7.4 Consequential Damages - 22 -

7.5 Force Majeure - 23 -

7.6 Default - 23 -

Article 8. Insurance - 24 -

Article 9. Confidentiality - 25 -

Article 10. Disputes - 26 -

Article 11. Taxes - 27 -

Article 12. Miscellaneous - 27 -

12.1 Governing Law, Regulatory Authority, and Rules - 27 -

12.2 Amendment..... - 27 -

12.3 No Third-Party Beneficiaries..... - 27 -

12.4 Waiver - 28 -

12.5 Entire Agreement - 28 -

12.6 Multiple Counterparts - 28 -

12.7 No Partnership - 29 -

12.8 Severability - 29 -

12.9 Security Arrangements..... - 29 -

12.10 Environmental Releases - 29 -

12.11 Subcontractors - 30 -

12.12 Reservation of Rights - 30 -

Article 13. Notices - 31 -

13.1 General - 31 -

13.2 Billing and Payment - 32 -

13.3 Alternative Forms of Notice - 32 -

13.4 Designated Operating Representative - 33 -

13.5 Changes to the Notice Information - 34 -

Article 14. Signatures - 34 -

[Attachment 1](#) – Glossary of Terms

[Attachment 2](#) – Description and Costs of the Small Generating Facility, Interconnection Facilities, and Metering Equipment

[Attachment 3](#) – One-line Diagram Depicting the Small Generating Facility, Interconnection Facilities, Metering Equipment, and Upgrades

[Attachment 4](#) – Milestones

[Attachment 5](#) – Additional Operating Requirements for Transmission Provider’s Transmission System and Affected Systems Needed to Support Interconnection Customer’s Needs

[Attachment 6](#) – Transmission Provider’s Description of its Upgrades and Best Estimate of Upgrade Costs

This Interconnection Agreement (“Agreement”) is made and entered into this _____ day of _____, 20__ , by

 (“Transmission Provider”), and

 (“Interconnection Customer”) each hereinafter sometimes referred to individually as “Party” or both referred to collectively as the “Parties.”

Transmission Provider Information

Transmission Provider: _____

Attention: _____

Address: _____

City: _____ State: _____ Zip: _____

Phone: _____ Fax: _____

Interconnection Customer Information

Interconnection Customer: _____

Attention: _____

Address: _____

City: _____ State: _____ Zip: _____

Phone: _____ Fax: _____

Interconnection Customer Application No: _____

In consideration of the mutual covenants set forth herein, the Parties agree as follows:

Article 1. Scope and Limitations of Agreement

1.1 Applicability

This Agreement shall be used for all Interconnection Requests submitted under the Small Generator Interconnection Procedures (SGIP) except for those submitted under the 10 kW Inverter Process contained in SGIP Attachment 5.

1.2 Purpose

This Agreement governs the terms and conditions under which Interconnection Customer's Small Generating Facility will interconnect with, and operate in parallel with, Transmission Provider's Transmission System.

1.3 No Agreement to Purchase or Deliver Power

This Agreement does not constitute an agreement to purchase or deliver Interconnection Customer's power. The purchase or delivery of power and other services that Interconnection Customer may require will be covered under separate agreements, if any. Interconnection Customer will be responsible for separately making all necessary arrangements (including scheduling) for delivery of electricity with the applicable Transmission Provider.

1.4 Limitations

Nothing in this Agreement is intended to affect any other agreement between Transmission Provider and Interconnection Customer.

1.5 Responsibilities of the Parties

1.5.1 The Parties shall perform all obligations of this Agreement in accordance with all Applicable Laws and Regulations, Operating Requirements, and Good Utility Practice.

1.5.2 Interconnection Customer shall construct, interconnect, operate and maintain its Small Generating Facility and construct, operate, and maintain its Interconnection Facilities in accordance with the applicable

manufacturer's recommended maintenance schedule, and in accordance with this Agreement, and with Good Utility Practice.

- 1.5.3 Transmission Provider shall construct, operate, and maintain its Transmission System and Interconnection Facilities in accordance with this Agreement, and with Good Utility Practice.
- 1.5.4 Interconnection Customer agrees to construct its facilities or systems in accordance with applicable specifications that meet or exceed those provided by the National Electrical Safety Code, the American National Standards Institute, IEEE, Underwriter's Laboratory, and Operating Requirements in effect at the time of construction and other applicable national and state codes and standards. Interconnection Customer agrees to design, install, maintain, and operate its Small Generating Facility so as to reasonably minimize the likelihood of a disturbance adversely affecting or impairing the system or equipment of Transmission Provider and any Affected Systems.
- 1.5.5 Each Party shall operate, maintain, repair, and inspect, and shall be fully responsible for the facilities that it now or subsequently may own unless otherwise specified in the Attachments to this Agreement. Each Party shall be responsible for the safe installation, maintenance, repair and condition of their respective lines and appurtenances on their respective sides of the point of change of ownership. Transmission Provider and Interconnection Customer, as appropriate, shall provide Interconnection Facilities that adequately protect Transmission Provider's Transmission System, personnel, and other persons from damage and injury. The allocation of responsibility for the design, installation, operation, maintenance and ownership of Interconnection Facilities shall be delineated in the Attachments to this Agreement.
- 1.5.6 Transmission Provider shall coordinate with all Affected Systems to support the interconnection.

1.5.7 Interconnection Customer shall ensure “frequency ride through” capability and “voltage ride through” capability of its Small Generating Facility. Interconnection Customer shall enable these capabilities such that its Small Generating Facility shall not disconnect automatically or instantaneously from the system or equipment of Transmission Provider and any Affected Systems for a defined under-frequency or over-frequency condition, or an under-voltage or over-voltage condition, as tested pursuant to Section 2.1 of this agreement. The defined conditions shall be in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. The Small Generating Facility’s protective equipment settings shall comply with Transmission Provider’s automatic load-shed program. Transmission Provider shall review the protective equipment settings to confirm compliance with the automatic load-shed program. The term “ride through” as used herein shall mean the ability of a Small Generating Facility to stay connected to and synchronized with the system or equipment of Transmission Provider and any Affected Systems during system disturbances within a range of conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. The term “frequency ride through” as used herein shall mean the ability of a Small Generating Facility to stay connected to and synchronized with the system or equipment of Transmission Provider and any Affected Systems during system disturbances within a range of under-frequency and over-frequency conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. The term “voltage ride through” as used herein shall mean the ability of a Small Generating Facility to stay connected to and synchronized with the system or equipment of Transmission Provider and any Affected Systems during system disturbances within a range of under-voltage and over-voltage conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. For abnormal frequency conditions and voltage conditions within the “no trip zone” defined by Reliability Standard PRC-024-3 or successor mandatory ride through Applicable Reliability Standards, the non-synchronous Small Generating Facility must ensure that, within any physical limitations of the Small Generating Facility, its control and protection settings are configured or set to (1) continue active power

production during disturbance and post disturbance periods at pre-disturbance levels unless reactive power priority mode is enabled or unless providing primary frequency response or fast frequency response; (2) minimize reductions in active power and remain within dynamic voltage and current limits, if reactive power priority mode is enabled, unless providing primary frequency response or fast frequency response; (3) not artificially limit dynamic reactive power capability during disturbances; and (4) return to pre-disturbance active power levels without artificial ramp rate limits if active power is reduced, unless providing primary frequency response or fast frequency response.

1.6 Parallel Operation Obligations

Once the Small Generating Facility has been authorized to commence parallel operation, Interconnection Customer shall abide by all rules and procedures pertaining to the parallel operation of the Small Generating Facility in the applicable Balancing Authority Area, including, but not limited to; 1) the rules and procedures concerning the operation of generation set forth in the Tariff or by the applicable system operator(s) for Transmission Provider's Transmission System and; 2) the Operating Requirements set forth in Attachment 5 of this Agreement.

1.7 Metering

Interconnection Customer shall be responsible for Transmission Provider's reasonable and necessary cost for the purchase, installation, operation, maintenance, testing, repair, and replacement of metering and data acquisition equipment specified in Attachments 2 and 3 of this Agreement. Interconnection Customer's metering (and data acquisition, as required) equipment shall conform to applicable industry rules and Operating Requirements.

1.8 Reactive Power and Primary Frequency Response

1.8.1 Power Factor Design Criteria

1.8.1.1 Synchronous Generation. Interconnection Customer shall design its Small Generating Facility to maintain a composite power delivery at continuous rated power output at the Point of Interconnection at a power factor within the range of 0.95 leading to 0.95 lagging, unless

Transmission Provider has established different requirements that apply to all similarly situated synchronous generators in the Balancing Authority Area on a comparable basis.

1.8.1.2 Non-Synchronous Generation. Interconnection Customer shall design its Small Generating Facility to maintain a composite power delivery at continuous rated power output at the high-side of the generator substation at a power factor within the range of 0.95 leading to 0.95 lagging, unless Transmission Provider has established a different power factor range that applies to all similarly situated non-synchronous generators in the Balancing Authority Area on a comparable basis. This power factor range standard shall be dynamic and can be met using, for example, power electronics designed to supply this level of reactive capability (taking into account any limitations due to voltage level, real power output, etc.) or fixed and switched capacitors, or a combination of the two. This requirement shall only apply to newly interconnecting non-synchronous generators that have not yet executed a Facilities Study Agreement as of the effective date of the Final Rule establishing this requirement (Order No. 827).

1.8.2 Transmission Provider is required to pay Interconnection Customer for reactive power that Interconnection Customer provides or absorbs from the Small Generating Facility when Transmission Provider requests Interconnection Customer to operate its Small Generating Facility outside the range specified in Article 1.8.1. In addition, if Transmission Provider pays its own or affiliated generators for reactive power service within the specified range, it must also pay Interconnection Customer.

1.8.3 Payments shall be in accordance with Interconnection Customer's applicable rate schedule then in effect unless the provision of such service(s) is subject to a regional transmission organization or independent system operator FERC-approved rate schedule. To the extent that no rate schedule is in effect at the time Interconnection Customer is required to provide or absorb reactive power under this Agreement, the Parties agree to expeditiously file such rate schedule and agree to support any request for

waiver of the Commission's prior notice requirement in order to compensate Interconnection Customer from the time service commenced.

- 1.8.4 Primary Frequency Response. Interconnection Customer shall ensure the primary frequency response capability of its Small Generating Facility by installing, maintaining, and operating a functioning governor or equivalent controls. The term "functioning governor or equivalent controls" as used herein shall mean the required hardware and/or software that provides frequency responsive real power control with the ability to sense changes in system frequency and autonomously adjust the Small Generating Facility's real power output in accordance with the droop and deadband parameters and in the direction needed to correct frequency deviations. Interconnection Customer is required to install a governor or equivalent controls with the capability of operating: (1) with a maximum 5 percent droop and ± 0.036 Hz deadband; or (2) in accordance with the relevant droop, deadband, and timely and sustained response settings from an approved Electric Reliability Organization reliability standard providing for equivalent or more stringent parameters. The droop characteristic shall be: (1) based on the nameplate capacity of the Small Generating Facility, and shall be linear in the range of frequencies between 59 to 61 Hz that are outside of the deadband parameter; or (2) based on an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter. The deadband parameter shall be: the range of frequencies above and below nominal (60 Hz) in which the governor or equivalent controls is not expected to adjust the Small Generating Facility's real power output in response to frequency deviations. The deadband shall be implemented: (1) without a step to the droop curve, that is, once the frequency deviation exceeds the deadband parameter, the expected change in the Small Generating Facility's real power output in response to frequency deviations shall start from zero and then increase (for under-frequency deviations) or decrease (for over-frequency deviations) linearly in proportion to the magnitude of the frequency deviation; or (2) in accordance with an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter. Interconnection Customer shall notify Transmission Provider that the primary frequency response capability of the Small Generating Facility has been tested and confirmed during commissioning. Once Interconnection Customer has synchronized the Small Generating Facility with the Transmission System, Interconnection Customer shall operate the Small

Generating Facility consistent with the provisions specified in Sections 1.8.4.1 and 1.8.4.2 of this Agreement. The primary frequency response requirements contained herein shall apply to both synchronous and non-synchronous Small Generating Facilities.

1.8.4.1 Governor or Equivalent Controls. Whenever the Small Generating Facility is operated in parallel with the Transmission System, Interconnection Customer shall operate the Small Generating Facility with its governor or equivalent controls in service and responsive to frequency. Interconnection Customer shall: (1) in coordination with Transmission Provider and/or the relevant Balancing Authority, set the deadband parameter to: (1) a maximum of ± 0.036 Hz and set the droop parameter to a maximum of 5 percent; or (2) implement the relevant droop and deadband settings from an approved Electric Reliability Organization reliability standard that provides for equivalent or more stringent parameters. Interconnection Customer shall be required to provide the status and settings of the governor or equivalent controls to Transmission Provider and/or the relevant Balancing Authority upon request. If Interconnection Customer needs to operate the Small Generating Facility with its governor or equivalent controls not in service, Interconnection Customer shall immediately notify Transmission Provider and the relevant Balancing Authority, and provide both with the following information: (1) the operating status of the governor or equivalent controls (i.e., whether it is currently out of service or when it will be taken out of service); (2) the reasons for removing the governor or equivalent controls from service; and (3) a reasonable estimate of when the governor or equivalent controls will be returned to service. Interconnection Customer shall make Reasonable Efforts to return its governor or equivalent controls into service as soon as practicable. Interconnection Customer shall make Reasonable Efforts to keep outages of the Small Generating Facility's governor or equivalent controls to a minimum whenever the Small Generating Facility is operated in parallel with the Transmission System.

1.8.4.2 Timely and Sustained Response. Interconnection Customer shall ensure that the Small Generating Facility's real power response to sustained frequency deviations outside of the deadband setting is automatically provided and shall begin immediately after frequency deviates outside of the deadband, and to the extent the Small

Generating Facility has operating capability in the direction needed to correct the frequency deviation. Interconnection Customer shall not block or otherwise inhibit the ability of the governor or equivalent controls to respond and shall ensure that the response is not inhibited, except under certain operational constraints including, but not limited to, ambient temperature limitations, physical energy limitations, outages of mechanical equipment, or regulatory requirements. The Small Generating Facility shall sustain the real power response at least until system frequency returns to a value within the deadband setting of the governor or equivalent controls. A Commission-approved Reliability Standard with equivalent or more stringent requirements shall supersede the above requirements.

1.8.4.3 Exemptions. Small Generating Facilities that are regulated by the United States Nuclear Regulatory Commission shall be exempt from Sections 1.8.4, 1.8.4.1, and 1.8.4.2 of this Agreement. Small Generating Facilities that are behind the meter generation that is sized-to-load (i.e., the thermal load and the generation are near-balanced in real-time operation and the generation is primarily controlled to maintain the unique thermal, chemical, or mechanical output necessary for the operating requirements of its host facility) shall be required to install primary frequency response capability in accordance with the droop and deadband capability requirements specified in Section 1.8.4, but shall be otherwise exempt from the operating requirements in Sections 1.8.4, 1.8.4.1, 1.8.4.2, and 1.8.4.4 of this Agreement.

1.8.4.4 Electric Storage Resources. Interconnection Customer interconnecting an electric storage resource shall establish an operating range in Attachment 5 of its SGIA that specifies a minimum state of charge and a maximum state of charge between which the electric storage resource will be required to provide primary frequency response consistent with the conditions set forth in Sections 1.8.4, 1.8.4.1, 1.8.4.2 and 1.8.4.3 of this Agreement. Attachment 5 shall specify whether the operating range is static or dynamic, and shall consider: (1) the expected magnitude of frequency deviations in the interconnection; (2) the expected duration that system frequency will remain outside of the deadband parameter in the interconnection; (3) the expected incidence of frequency deviations outside of the deadband parameter in the interconnection; (4) the physical capabilities of the electric storage resource; (5) operational limitations of the electric storage resource due to manufacturer specifications; and (6) any other relevant factors

agreed to by Transmission Provider and Interconnection Customer, and in consultation with the relevant transmission owner or Balancing Authority as appropriate. If the operating range is dynamic, then Attachment 5 must establish how frequently the operating range will be reevaluated and the factors that may be considered during its reevaluation.

Interconnection Customer's electric storage resource is required to provide timely and sustained primary frequency response consistent with Section 1.8.4.2 of this Agreement when it is online and dispatched to inject electricity to the Transmission System and/or receive electricity from the Transmission System. This excludes circumstances when the electric storage resource is not dispatched to inject electricity to the Transmission System and/or dispatched to receive electricity from the Transmission System. If Interconnection Customer's electric storage resource is charging at the time of a frequency deviation outside of its deadband parameter, it is to increase (for over-frequency deviations) or decrease (for under-frequency deviations) the rate at which it is charging in accordance with its droop parameter. Interconnection Customer's electric storage resource is not required to change from charging to discharging, or vice versa, unless the response necessitated by the droop and deadband settings requires it to do so and it is technically capable of making such a transition.

- 1.9 Capitalized terms used herein shall have the meanings specified in the Glossary of Terms in Attachment 1 or the body of this Agreement.

Article 2. Inspection, Testing, Authorization, and Right of Access

2.1 Equipment Testing and Inspection

- 2.1.1 Interconnection Customer shall test and inspect its Small Generating Facility and Interconnection Facilities prior to interconnection. Interconnection Customer shall notify Transmission Provider of such activities no fewer than five (5) Business Days (or as may be agreed to by the Parties) prior to such testing and inspection. Testing and inspection shall occur on a Business Day. Transmission Provider may, at its own expense, send qualified personnel to the Small Generating Facility site to

inspect the interconnection and observe the testing. Interconnection Customer shall provide Transmission Provider a written test report when such testing and inspection is completed.

2.1.2 Transmission Provider shall provide Interconnection Customer written acknowledgment that it has received Interconnection Customer's written test report. Such written acknowledgment shall not be deemed to be or construed as any representation, assurance, guarantee, or warranty by Transmission Provider of the safety, durability, suitability, or reliability of the Small Generating Facility or any associated control, protective, and safety devices owned or controlled by Interconnection Customer or the quality of power produced by the Small Generating Facility.

2.2 Authorization Required Prior to Parallel Operation

2.2.1 Transmission Provider shall use Reasonable Efforts to list applicable parallel operation requirements in Attachment 5 of this Agreement. Additionally, Transmission Provider shall notify Interconnection Customer of any changes to these requirements as soon as they are known. Transmission Provider shall make Reasonable Efforts to cooperate with Interconnection Customer in meeting requirements necessary for Interconnection Customer to commence parallel operations by the in-service date.

2.2.2 Interconnection Customer shall not operate its Small Generating Facility in parallel with Transmission Provider's Transmission System without prior written authorization of Transmission Provider. Transmission Provider will provide such authorization once Transmission Provider receives notification that Interconnection Customer has complied with all applicable parallel operation requirements. Such authorization shall not be unreasonably withheld, conditioned, or delayed.

2.3 Right of Access

- 2.3.1 Upon reasonable notice, Transmission Provider may send a qualified person to the premises of Interconnection Customer at or immediately before the time the Small Generating Facility first produces energy to inspect the interconnection, and observe the commissioning of the Small Generating Facility (including any required testing), startup, and operation for a period of up to three (3) Business Days after initial start-up of the unit. In addition, Interconnection Customer shall notify Transmission Provider at least five (5) Business Days prior to conducting any on-site verification testing of the Small Generating Facility.
- 2.3.2 Following the initial inspection process described above, at reasonable hours, and upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition, Transmission Provider shall have access to Interconnection Customer's premises for any reasonable purpose in connection with the performance of the obligations imposed on it by this Agreement or if necessary to meet its legal obligation to provide service to its customers.
- 2.3.3 Each Party shall be responsible for its own costs associated with following this article.

Article 3. Effective Date, Term, Termination, and Disconnection

3.1 Effective Date

This Agreement shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by the FERC. Transmission Provider shall promptly file this Agreement with the FERC upon execution, if required.

3.2 Term of Agreement

This Agreement shall become effective on the Effective Date and shall remain in effect for a period of ten years from the Effective Date or such other longer period as Interconnection Customer may request and shall be automatically renewed for each successive one-year period thereafter, unless terminated earlier in accordance with article 3.3 of this Agreement.

3.3 Termination

No termination shall become effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination, including the filing with FERC of a notice of termination of this Agreement (if required), which notice has been accepted for filing by FERC.

3.3.1 Interconnection Customer may terminate this Agreement at any time by giving Transmission Provider twenty (20) Business Days written notice.

3.3.2 Either Party may terminate this Agreement after Default pursuant to article 7.6.

3.3.3 Upon termination of this Agreement, the Small Generating Facility will be disconnected from Transmission Provider's Transmission System. All costs required to effectuate such disconnection shall be borne by the terminating Party, unless such termination resulted from the non-terminating Party's Default of this SGIA or such non-terminating Party otherwise is responsible for these costs under this SGIA.

3.3.4 The termination of this Agreement shall not relieve either Party of its liabilities and obligations, owed or continuing at the time of the termination.

3.3.5 The provisions of this article shall survive termination or expiration of this Agreement.

3.4 Temporary Disconnection

Temporary disconnection shall continue only for so long as reasonably necessary under Good Utility Practice.

3.4.1 Emergency Conditions – "Emergency Condition" shall mean a condition or situation: (1) that in the judgment of the Party making the claim is imminently likely to endanger life or property; or (2) that, in the case of

Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to the Transmission System, Transmission Provider's Interconnection Facilities or the Transmission Systems of others to which the Transmission System is directly connected; or (3) that, in the case of Interconnection Customer, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Small Generating Facility or Interconnection Customer's Interconnection Facilities. Under Emergency Conditions, Transmission Provider may immediately suspend interconnection service and temporarily disconnect the Small Generating Facility. Transmission Provider shall notify Interconnection Customer promptly when it becomes aware of an Emergency Condition that may reasonably be expected to affect Interconnection Customer's operation of the Small Generating Facility. Interconnection Customer shall notify Transmission Provider promptly when it becomes aware of an Emergency Condition that may reasonably be expected to affect Transmission Provider's Transmission System or any Affected Systems. To the extent information is known, the notification shall describe the Emergency Condition, the extent of the damage or deficiency, the expected effect on the operation of both Parties' facilities and operations, its anticipated duration, and the necessary corrective action.

3.4.2 Routine Maintenance, Construction, and Repair

Transmission Provider may interrupt interconnection service or curtail the output of the Small Generating Facility and temporarily disconnect the Small Generating Facility from Transmission Provider's Transmission System when necessary for routine maintenance, construction, and repairs on Transmission Provider's Transmission System. Transmission Provider shall provide Interconnection Customer with five (5) Business Days notice prior to such interruption. Transmission Provider shall use Reasonable Efforts to coordinate such reduction or temporary disconnection with Interconnection Customer.

3.4.3 Forced Outages

During any forced outage, Transmission Provider may suspend interconnection service to effect immediate repairs on Transmission Provider's Transmission System. Transmission Provider shall use Reasonable Efforts to provide Interconnection Customer with prior notice.

If prior notice is not given, Transmission Provider shall, upon request, provide Interconnection Customer written documentation after the fact explaining the circumstances of the disconnection.

3.4.4 Adverse Operating Effects

Transmission Provider shall notify Interconnection Customer as soon as practicable if, based on Good Utility Practice, operation of the Small Generating Facility may cause disruption or deterioration of service to other customers served from the same electric system, or if operating the Small Generating Facility could cause damage to Transmission Provider's Transmission System or Affected Systems. Supporting documentation used to reach the decision to disconnect shall be provided to Interconnection Customer upon request. If, after notice, Interconnection Customer fails to remedy the adverse operating effect within a reasonable time, Transmission Provider may disconnect the Small Generating Facility. Transmission Provider shall provide Interconnection Customer with five Business Day notice of such disconnection, unless the provisions of article 3.4.1 apply.

3.4.5 Modification of the Small Generating Facility

Interconnection Customer must receive written authorization from Transmission Provider before making any change to the Small Generating Facility that may have a material impact on the safety or reliability of the Transmission System. Such authorization shall not be unreasonably withheld. Modifications shall be done in accordance with Good Utility Practice. If Interconnection Customer makes such modification without Transmission Provider's prior written authorization, the latter shall have the right to temporarily disconnect the Small Generating Facility.

3.4.6 Reconnection

The Parties shall cooperate with each other to restore the Small Generating Facility, Interconnection Facilities, and Transmission Provider's Transmission System to their normal operating state as soon as reasonably practicable following a temporary disconnection.

Article 4. Cost Responsibility for Interconnection Facilities and Distribution

Upgrades

4.1 Interconnection Facilities

4.1.1 Interconnection Customer shall pay for the cost of the Interconnection Facilities itemized in Attachment 2 of this Agreement. Transmission Provider shall provide a best estimate cost, including overheads, for the purchase and construction of its Interconnection Facilities and provide a detailed itemization of such costs. Costs associated with Interconnection Facilities may be shared with other entities that may benefit from such facilities by agreement of Interconnection Customer, such other entities, and Transmission Provider.

4.1.2 Interconnection Customer shall be responsible for its share of all reasonable expenses, including overheads, associated with (1) owning, operating, maintaining, repairing, and replacing its own Interconnection Facilities, and (2) operating, maintaining, repairing, and replacing Transmission Provider's Interconnection Facilities.

4.2 Distribution Upgrades

Transmission Provider shall design, procure, construct, install, and own the Distribution Upgrades described in Attachment 6 of this Agreement. If Transmission Provider and Interconnection Customer agree, Interconnection Customer may construct Distribution Upgrades that are located on land owned by Interconnection Customer. The actual cost of the Distribution Upgrades, including overheads, shall be directly assigned to Interconnection Customer.

Article 5. Cost Responsibility for Network Upgrades

5.1 Applicability

No portion of this article 5 shall apply unless the interconnection of the Small Generating Facility requires Network Upgrades.

5.2 Network Upgrades

Transmission Provider or the Transmission Owner shall design, procure, construct, install, and own the Network Upgrades described in Attachment 6 of this Agreement. If Transmission Provider and Interconnection Customer agree, Interconnection Customer may construct Network Upgrades that are located on land owned by Interconnection Customer. Unless Transmission Provider elects to pay for Network Upgrades, the actual cost of the Network Upgrades, including overheads, shall be borne initially by Interconnection Customer.

5.2.1 Repayment of Amounts Advanced for Network Upgrades
Interconnection Customer shall be entitled to a cash repayment, equal to the total amount paid to Transmission Provider and Affected System operator, if any, for Network Upgrades, including any tax gross-up or other tax-related payments associated with the Network Upgrades, and not otherwise refunded to Interconnection Customer, to be paid to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, as payments are made under Transmission Provider's Tariff and Affected System's Tariff for transmission services with respect to the Small Generating Facility. Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 C.F.R. § 35.19a(a)(2)(iii) from the date of any payment for Network Upgrades through the date on which Interconnection Customer receives a repayment of such payment pursuant to this subparagraph. Interconnection Customer may assign such repayment rights to any person.

5.2.1.1 Notwithstanding the foregoing, Interconnection Customer, Transmission Provider, and any applicable Affected System operators may adopt any alternative payment schedule that is mutually agreeable so long as Transmission Provider and said Affected System operators take one of the following actions no later than five years from the Commercial Operation Date: (1) return to Interconnection Customer any amounts advanced for Network Upgrades not previously repaid, or (2) declare in writing that Transmission Provider or any applicable Affected System operators will continue to provide payments to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, or develop an alternative schedule that is mutually agreeable and provides for the return of all amounts advanced for Network Upgrades not previously repaid; however, full

reimbursement shall not extend beyond twenty (20) years from the commercial operation date.

5.2.1.2 If the Small Generating Facility fails to achieve commercial operation, but it or another generating facility is later constructed and requires use of the Network Upgrades, Transmission Provider and Affected System operator shall at that time reimburse Interconnection Customer for the amounts advanced for the Network Upgrades. Before any such reimbursement can occur, Interconnection Customer, or the entity that ultimately constructs the generating facility, if different, is responsible for identifying the entity to which reimbursement must be made.

5.3 Special Provisions for Affected Systems

Unless Transmission Provider provides, under this Agreement, for the repayment of amounts advanced to any applicable Affected System operators for Network Upgrades, Interconnection Customer and Affected System operator shall enter into an agreement that provides for such repayment. The agreement shall specify the terms governing payments to be made by Interconnection Customer to Affected System operator as well as the repayment by Affected System operator.

5.4 Rights Under Other Agreements

Notwithstanding any other provision of this Agreement, nothing herein shall be construed as relinquishing or foreclosing any rights, including but not limited to firm transmission rights, capacity rights, transmission congestion rights, or transmission credits, that Interconnection Customer shall be entitled to, now or in the future, under any other agreement or tariff as a result of, or otherwise associated with, the transmission capacity, if any, created by the Network Upgrades, including the right to obtain cash reimbursements or transmission credits for transmission service that is not associated with the Small Generating Facility.

Article 6. Billing, Payment, Milestones, and Financial Security

6.1 Billing and Payment Procedures and Final Accounting

6.1.1 Transmission Provider shall bill Interconnection Customer for the design, engineering, construction, and procurement costs of Interconnection Facilities and Upgrades contemplated by this Agreement on a monthly basis, or as otherwise agreed by the Parties. Interconnection Customer shall pay each bill within thirty (30) Calendar Days of receipt, or as otherwise agreed to by the Parties.

6.1.2 Within three months of completing the construction and installation of Transmission Provider's Interconnection Facilities and/or Upgrades described in the Attachments to this Agreement, Transmission Provider shall provide Interconnection Customer with a final accounting report of any difference between (1) Interconnection Customer's cost responsibility for the actual cost of such facilities or Upgrades, and (2) Interconnection Customer's previous aggregate payments to Transmission Provider for such facilities or Upgrades. If Interconnection Customer's cost responsibility exceeds its previous aggregate payments, Transmission Provider shall invoice Interconnection Customer for the amount due and Interconnection Customer shall make payment to Transmission Provider within thirty (30) Calendar Days. If Interconnection Customer's previous aggregate payments exceed its cost responsibility under this Agreement, Transmission Provider shall refund to Interconnection Customer an amount equal to the difference within thirty (30) Calendar Days of the final accounting report.

6.2 Milestones

The Parties shall agree on milestones for which each Party is responsible and list them in Attachment 4 of this Agreement. A Party's obligations under this provision may be extended by agreement. If a Party anticipates that it will be unable to meet a milestone for any reason other than a Force Majeure Event, it shall immediately notify the other Party of the reason(s) for not meeting the milestone and (1) propose the earliest reasonable alternate date by which it can attain this and future milestones, and (2) requesting appropriate amendments to Attachment 4. The Party affected by the failure to meet a milestone shall not unreasonably withhold agreement to such an amendment unless it will suffer significant uncompensated economic or operational harm from the delay, (2) attainment of the same milestone has previously been delayed, or (3) it has reason to believe that the delay in meeting the milestone is intentional or unwarranted notwithstanding the circumstances explained by the Party proposing the amendment.

6.3 Financial Security Arrangements

At least twenty (20) Business Days prior to the commencement of the design, procurement, installation, or construction of a discrete portion of Transmission Provider's Interconnection Facilities and Upgrades, Interconnection Customer shall provide Transmission Provider, at Interconnection Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to Transmission Provider and is consistent with the Uniform Commercial Code of the jurisdiction where the Point of Interconnection is located. Such security for payment shall be in an amount sufficient to cover the costs for constructing, designing, procuring, and installing the applicable portion of Transmission Provider's Interconnection Facilities and Upgrades and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider under this Agreement during its term. In addition:

6.3.1 The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider, and contain terms and conditions that guarantee payment of any amount that may be due from Interconnection Customer, up to an agreed-to maximum amount.

6.3.2 The letter of credit or surety bond must be issued by a financial institution or insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.

Article 7. Assignment, Liability, Indemnity, Force Majeure, Consequential Damages, and Default

7.1 Assignment

This Agreement may be assigned by either Party upon fifteen (15) Business Days prior written notice and opportunity to object by the other Party; provided that:

7.1.1 Either Party may assign this Agreement without the consent of the other Party to any affiliate of the assigning Party with an equal or greater credit rating and with the legal authority and operational ability to satisfy the obligations of the assigning Party under this Agreement, provided that

Interconnection Customer promptly notifies Transmission Provider of any such assignment;

7.1.2 Interconnection Customer shall have the right to assign this Agreement, without the consent of Transmission Provider, for collateral security purposes to aid in providing financing for the Small Generating Facility, provided that Interconnection Customer will promptly notify Transmission Provider of any such assignment.

7.1.3 Any attempted assignment that violates this article is void and ineffective. Assignment shall not relieve a Party of its obligations, nor shall a Party's obligations be enlarged, in whole or in part, by reason thereof. An assignee is responsible for meeting the same financial, credit, and insurance obligations as Interconnection Customer. Where required, consent to assignment will not be unreasonably withheld, conditioned or delayed.

7.2 Limitation of Liability

Each Party's liability to the other Party for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall either Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized by this Agreement.

7.3 Indemnity

7.3.1 This provision protects each Party from liability incurred to third parties as a result of carrying out the provisions of this Agreement. Liability under this provision is exempt from the general limitations on liability found in article 7.2.

7.3.2 The Parties shall at all times indemnify, defend, and hold the other Party harmless from, any and all damages, losses, claims, including claims and actions relating to injury to or death of any person or damage to property,

demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's action or failure to meet its obligations under this Agreement on behalf of the indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the indemnified Party.

7.3.3 If an indemnified person is entitled to indemnification under this article as a result of a claim by a third party, and the indemnifying Party fails, after notice and reasonable opportunity to proceed under this article, to assume the defense of such claim, such indemnified person may at the expense of the indemnifying Party contest, settle or consent to the entry of any judgment with respect to, or pay in full, such claim.

7.3.4 If an indemnifying party is obligated to indemnify and hold any indemnified person harmless under this article, the amount owing to the indemnified person shall be the amount of such indemnified person's actual loss, net of any insurance or other recovery.

7.3.5 Promptly after receipt by an indemnified person of any claim or notice of the commencement of any action or administrative or legal proceeding or investigation as to which the indemnity provided for in this article may apply, the indemnified person shall notify the indemnifying party of such fact. Any failure of or delay in such notification shall not affect a Party's indemnification obligation unless such failure or delay is materially prejudicial to the indemnifying party.

7.4 Consequential Damages

Other than as expressly provided for in this Agreement, neither Party shall be liable under any provision of this Agreement for any losses, damages, costs or expenses for any special, indirect, incidental, consequential, or punitive damages, including but not limited to loss of profit or revenue, loss of the use of equipment, cost of capital, cost of temporary equipment or services, whether based in whole or in part in contract, in tort, including negligence, strict liability, or any other theory of liability; provided, however, that damages for which a Party may be liable to the other Party under another agreement will not be considered to be special, indirect, incidental, or consequential damages hereunder.

7.5 Force Majeure

- 7.5.1 As used in this article, a Force Majeure Event shall mean "any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, breakage or accident to machinery or equipment, any order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, or any other cause beyond a Party's control. A Force Majeure Event does not include an act of negligence or intentional wrongdoing."
- 7.5.2 If a Force Majeure Event prevents a Party from fulfilling any obligations under this Agreement, the Party affected by the Force Majeure Event (Affected Party) shall promptly notify the other Party, either in writing or via the telephone, of the existence of the Force Majeure Event. The notification must specify in reasonable detail the circumstances of the Force Majeure Event, its expected duration, and the steps that the Affected Party is taking to mitigate the effects of the event on its performance. The Affected Party shall keep the other Party informed on a continuing basis of developments relating to the Force Majeure Event until the event ends. The Affected Party will be entitled to suspend or modify its performance of obligations under this Agreement (other than the obligation to make payments) only to the extent that the effect of the Force Majeure Event cannot be mitigated by the use of Reasonable Efforts. The Affected Party will use Reasonable Efforts to resume its performance as soon as possible.

7.6 Default

- 7.6.1 No Default shall exist where such failure to discharge an obligation (other than the payment of money) is the result of a Force Majeure Event as defined in this Agreement or the result of an act or omission of the other Party. Upon a Default, the non-defaulting Party shall give written notice of such Default to the defaulting Party. Except as provided in article 7.6.2, the defaulting Party shall have sixty (60) Calendar Days from receipt of the Default notice within which to cure such Default; provided however, if such Default is not capable of cure within sixty (60) Calendar Days, the

defaulting Party shall commence such cure within twenty (20) Calendar Days after notice and continuously and diligently complete such cure within six months from receipt of the Default notice; and, if cured within such time, the Default specified in such notice shall cease to exist.

7.6.2 If a Default is not cured as provided in this article, or if a Default is not capable of being cured within the period provided for herein, the non-defaulting Party shall have the right to terminate this Agreement by written notice at any time until cure occurs, and be relieved of any further obligation hereunder and, whether or not that Party terminates this Agreement, to recover from the defaulting Party all amounts due hereunder, plus all other damages and remedies to which it is entitled at law or in equity. The provisions of this article will survive termination of this Agreement.

Article 8. Insurance

8.1 Interconnection Customer shall, at its own expense, maintain in force general liability insurance without any exclusion for liabilities related to the interconnection undertaken pursuant to this Agreement. The amount of such insurance shall be sufficient to insure against all reasonably foreseeable direct liabilities given the size and nature of the generating equipment being interconnected, the interconnection itself, and the characteristics of the system to which the interconnection is made. Interconnection Customer shall obtain additional insurance only if necessary as a function of owning and operating a generating facility. Such insurance shall be obtained from an insurance provider authorized to do business in the State where the interconnection is located. Certification that such insurance is in effect shall be provided upon request of Transmission Provider, except that Interconnection Customer shall show proof of insurance to Transmission Provider no later than ten (10) Business Days prior to the anticipated commercial operation date. An Interconnection Customer of sufficient credit-worthiness may propose to self-insure for such liabilities, and such a proposal shall not be unreasonably rejected.

8.2 Transmission Provider agrees to maintain general liability insurance or self-insurance consistent with Transmission Provider's commercial practice. Such

insurance or self-insurance shall not exclude coverage for Transmission Provider's liabilities undertaken pursuant to this Agreement.

- 8.3 The Parties further agree to notify each other whenever an accident or incident occurs resulting in any injuries or damages that are included within the scope of coverage of such insurance, whether or not such coverage is sought.

Article 9. Confidentiality

- 9.1 Confidential Information shall mean any confidential and/or proprietary information provided by one Party to the other Party that is clearly marked or otherwise designated "Confidential." For purposes of this Agreement all design, operating specifications, and metering data provided by Interconnection Customer shall be deemed Confidential Information regardless of whether it is clearly marked or otherwise designated as such.
- 9.2 Confidential Information does not include information previously in the public domain, required to be publicly submitted or divulged by Governmental Authorities (after notice to the other Party and after exhausting any opportunity to oppose such publication or release), or necessary to be divulged in an action to enforce this Agreement. Each Party receiving Confidential Information shall hold such information in confidence and shall not disclose it to any third party nor to the public without the prior written authorization from the Party providing that information, except to fulfill obligations under this Agreement, or to fulfill legal or regulatory requirements.
- 9.2.1 Each Party shall employ at least the same standard of care to protect Confidential Information obtained from the other Party as it employs to protect its own Confidential Information.
- 9.2.2 Each Party is entitled to equitable relief, by injunction or otherwise, to enforce its rights under this provision to prevent the release of Confidential Information without bond or proof of damages, and may seek other remedies available at law or in equity for breach of this provision.

- 9.3 Notwithstanding anything in this article to the contrary, and pursuant to 18 CFR § 1b.20, if FERC, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to this Agreement, the Party shall provide the requested information to FERC, within the time provided for in the request for information. In providing the information to FERC, the Party may, consistent with 18 CFR § 388.112, request that the information be treated as confidential and non-public by FERC and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party to this Agreement prior to the release of the Confidential Information to FERC. The Party shall notify the other Party to this Agreement when it is notified by FERC that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR § 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

Article 10. Disputes

- 10.1 The Parties agree to attempt to resolve all disputes arising out of the interconnection process according to the provisions of this article.
- 10.2 In the event of a dispute, either Party shall provide the other Party with a written Notice of Dispute. Such Notice shall describe in detail the nature of the dispute.
- 10.3 If the dispute has not been resolved within two (2) Business Days after receipt of the Notice, either Party may contact FERC's Dispute Resolution Service (DRS) for assistance in resolving the dispute.
- 10.4 The DRS will assist the Parties in either resolving their dispute or in selecting an appropriate dispute resolution venue (e.g., mediation, settlement judge, early neutral evaluation, or technical expert) to assist the Parties in resolving their dispute. DRS can be reached at 1-877-337-2237 or via the internet at <http://www.ferc.gov/legal/adr.asp>.

- 10.5 Each Party agrees to conduct all negotiations in good faith and will be responsible for one-half of any costs paid to neutral third-parties.
- 10.6 If neither Party elects to seek assistance from the DRS, or if the attempted dispute resolution fails, then either Party may exercise whatever rights and remedies it may have in equity or law consistent with the terms of this Agreement.

Article 11. Taxes

- 11.1 The Parties agree to follow all applicable tax laws and regulations, consistent with FERC policy and Internal Revenue Service requirements.
- 11.2 Each Party shall cooperate with the other to maintain the other Party's tax status. Nothing in this Agreement is intended to adversely affect Transmission Provider's tax exempt status with respect to the issuance of bonds including, but not limited to, local furnishing bonds.

Article 12. Miscellaneous

- 12.1 **Governing Law, Regulatory Authority, and Rules**
The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____ (where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.
- 12.2 **Amendment**
The Parties may amend this Agreement by a written instrument duly executed by both Parties, or under article 12.12 of this Agreement.
- 12.3 **No Third-Party Beneficiaries**

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

12.4 Waiver

12.4.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

12.4.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

12.5 Entire Agreement

This Agreement, including all Attachments, constitutes the entire agreement between the Parties with reference to the subject matter hereof, and supersedes all prior and contemporaneous understandings or agreements, oral or written, between the Parties with respect to the subject matter of this Agreement. There are no other agreements, representations, warranties, or covenants which constitute any part of the consideration for, or any condition to, either Party's compliance with its obligations under this Agreement.

12.6 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

12.7 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

12.8 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

12.9 Security Arrangements

Infrastructure security of electric system equipment and operations and control hardware and software is essential to ensure day-to-day reliability and operational security. FERC expects all Transmission Providers, market participants, and Interconnection Customers interconnected to electric systems to comply with the recommendations offered by the President's Critical Infrastructure Protection Board and, eventually, best practice recommendations from the electric reliability authority. All public utilities are expected to meet basic standards for system infrastructure and operational security, including physical, operational, and cyber-security practices.

12.10 Environmental Releases

Each Party shall notify the other Party, first orally and then in writing, of the release of any hazardous substances, any asbestos or lead abatement activities, or any type of remediation activities related to the Small Generating Facility or the Interconnection Facilities, each of which may reasonably be expected to affect the other Party. The notifying Party shall (1) provide the notice as soon as practicable, provided such Party makes a good faith effort to provide the notice no later than 24 hours after such Party becomes aware of the occurrence, and (2) promptly

furnish to the other Party copies of any publicly available reports filed with any governmental authorities addressing such events.

12.11 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

12.11.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

12.11.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

12.12 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement under any applicable provision of the Federal Power Act and FERC's rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be

considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

Article 13. Notices

13.1 General

Unless otherwise provided in this Agreement, any written notice, demand, or request required or authorized in connection with this Agreement ("Notice") shall be deemed properly given if delivered in person, delivered by recognized national courier service, or sent by first class mail, postage prepaid, to the person specified below:

If to Interconnection Customer:

Interconnection Customer:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

If to Transmission Provider:

Transmission Provider:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

13.2 Billing and Payment

Billings and payments shall be sent to the addresses set out below:

Interconnection Customer: _____

Attention: _____

Address: _____

City: _____ State: _____

Zip: _____

Transmission Provider: _____

Attention: _____

Address: _____

City: _____ State: _____

Zip: _____

13.3 Alternative Forms of Notice

Any notice or request required or permitted to be given by either Party to the other and not required by this Agreement to be given in writing may be so given by telephone, facsimile or e-mail to the telephone numbers and e-mail addresses set out below:

If to Interconnection Customer:

Interconnection Customer: _____

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

If to Transmission Provider:

Transmission Provider:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

13.4 Designated Operating Representative

The Parties may also designate operating representatives to conduct the communications which may be necessary or convenient for the administration of this Agreement. This person will also serve as the point of contact with respect to operations and maintenance of the Party’s facilities.

Interconnection Customer’s Operating Representative:

Interconnection Customer:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

Transmission Provider's Operating Representative:

Transmission Provider:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

13.5 Changes to the Notice Information

Either Party may change this information by giving five (5) Business Days written notice prior to the effective date of the change.

Article 14. Signatures

IN WITNESS WHEREOF, the Parties have caused this Agreement to be executed by their respective duly authorized representatives.

For Transmission Provider

Name: _____

Title: _____

Date: _____

For Interconnection Customer

Name: _____

Title: _____

Date: _____

Attachment 1**Glossary of Terms**

Affected System – An electric system other than Transmission Provider’s Transmission System that may be affected by the proposed interconnection.

Applicable Laws and Regulations – All duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Applicable Reliability Standards - The requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Balancing Authority – An entity that integrates resource plans ahead of time, maintains demand and resource balance within a Balancing Authority Area, and supports interconnection frequency in real time.

Balancing Authority Area – The collection of generation, transmission, and loads within the metered boundaries of the Balancing Authority. The Balancing Authority maintains load-resource balance within this area.

Business Day – Monday through Friday, excluding Federal Holidays.

Default – The failure of a breaching Party to cure its breach under the Small Generator Interconnection Agreement.

Distribution System – Transmission Provider’s facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which Distribution Systems operate differ among areas.

Distribution Upgrades – The additions, modifications, and upgrades to Transmission Provider’s Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Small Generating Facility and render the transmission service necessary to effect Interconnection Customer’s wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Good Utility Practice – Any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Governmental Authority – Any federal, state, local or other governmental regulatory or administrative agency, court, commission, department, board, or other governmental subdivision, legislature, rulemaking board, tribunal, or other governmental authority having jurisdiction over the Parties, their respective facilities, or the respective services they provide, and exercising or entitled to exercise any administrative, executive, police, or taxing authority or power; provided, however, that such term does not include Interconnection Customer, the Interconnection Provider, or any Affiliate thereof.

Interconnection Customer – Any entity, including Transmission Provider, the Transmission Owner or any of the affiliates or subsidiaries of either, that proposes to interconnect its Small Generating Facility with Transmission Provider's Transmission System.

Interconnection Facilities – Transmission Provider's Interconnection Facilities and Interconnection Customer's Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Small Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Small Generating Facility to Transmission Provider's Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades or Network Upgrades.

Interconnection Request – Interconnection Customer's request, in accordance with the Tariff, to interconnect a new Small Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Small Generating Facility that is interconnected with Transmission Provider's Transmission System.

Material Modification – A modification that has a material impact on the cost or timing of any Interconnection Request with a later queue priority date.

Network Upgrades – Additions, modifications, and upgrades to Transmission Provider's Transmission System required at or beyond the point at which the Small Generating Facility interconnects with Transmission Provider's Transmission System to accommodate the interconnection of the Small Generating Facility with Transmission

Provider's Transmission System. Network Upgrades do not include Distribution Upgrades.

Operating Requirements – Any operating and technical requirements that may be applicable due to Regional Transmission Organization, Independent System Operator, Balancing Authority Area, or Transmission Provider's requirements, including those set forth in the Small Generator Interconnection Agreement.

Party or Parties – Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Point of Interconnection – The point where the Interconnection Facilities connect with Transmission Provider's Transmission System.

Reasonable Efforts – With respect to an action required to be attempted or taken by a Party under the Small Generator Interconnection Agreement, efforts that are timely and consistent with Good Utility Practice and are otherwise substantially equivalent to those a Party would use to protect its own interests.

Small Generating Facility – Interconnection Customer's device for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer's Interconnection Facilities.

Tariff – Transmission Provider or Affected System's Tariff through which open access transmission service and Interconnection Service are offered, as filed with the FERC, and as amended or supplemented from time to time, or any successor tariff.

Transmission Owner – The entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Small Generator Interconnection Agreement to the extent necessary.

Transmission Provider – The public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission System – The facilities owned, controlled or operated by Transmission Provider or the Transmission Owner that are used to provide transmission service under the Tariff.

Upgrades – The required additions and modifications to Transmission Provider's Transmission System at or beyond the Point of Interconnection. Upgrades may be Network Upgrades or Distribution Upgrades. Upgrades do not include Interconnection Facilities.

Attachment 2**Description and Costs of the Small Generating Facility,
Interconnection Facilities, and Metering Equipment**

Equipment, including the Small Generating Facility, Interconnection Facilities, and metering equipment shall be itemized and identified as being owned by Interconnection Customer, Transmission Provider, or the Transmission Owner. Transmission Provider will provide a best estimate itemized cost, including overheads, of its Interconnection Facilities and metering equipment, and a best estimate itemized cost of the annual operation and maintenance expenses associated with its Interconnection Facilities and metering equipment.

Docket No. RM22-14-001

- 2 -

Attachment 3

**One-line Diagram Depicting the Small Generating Facility, Interconnection
Facilities, Metering Equipment, and Upgrades**

Docket No. RM22-14-001

- 3 -

Attachment 4

Milestones

In-Service Date: _____

Critical milestones and responsibility as agreed to by the Parties:

	Milestone/Date	Responsible Party
(1)	_____	_____
(2)	_____	_____
(3)	_____	_____
(4)	_____	_____
(5)	_____	_____
(6)	_____	_____
(7)	_____	_____

Docket No. RM22-14-001

- 4 -

(8) _____

(9) _____

(10) _____

Agreed to by:

For Transmission Provider _____ Date _____

For Transmission Owner (If Applicable) _____
Date _____

For Interconnection Customer _____ Date _____

Docket No. RM22-14-001

- 5 -

Attachment 5

**Additional Operating Requirements for Transmission Provider's
Transmission System and Affected Systems Needed to Support
Interconnection Customer's Needs**

Transmission Provider shall also provide requirements that must be met by Interconnection Customer prior to initiating parallel operation with Transmission Provider's Transmission System.

Docket No. RM22-14-001

- 6 -

Attachment 6**Transmission Provider's Description of its Upgrades
and Best Estimate of Upgrade Costs**

Transmission Provider shall describe Upgrades and provide an itemized best estimate of the cost, including overheads, of the Upgrades and annual operation and maintenance expenses associated with such Upgrades. Transmission Provider shall functionalize Upgrade costs and annual expenses as either transmission or distribution related.

FERC rendition of the electronically filed tariff records in Docket No. ER24-02027-000

Filing Data:

CID: C001298

Filing Title: OATT Order No. 2023 Compliance

Company Filing Identifier: 20240516

Type of Filing Code: 80

Associated Filing Identifier:

Tariff Title: Open Access Transmission Tariff

Tariff ID: 4

Payment Confirmation:

Suspension Motion:

Tariff Record Data:

Record Content Description, Tariff Record Title, Record Version Number, Option Code:

OATT Attachment M, ATTACHMENT M Standard Large Generator Int. Procedures, 4.0.0, A

Record Narrative Name:

Tariff Record ID: 61

Tariff Record Collation Value: 61005 Tariff Record Parent Identifier: 0

Proposed Date: 2024-05-17

Priority Order: 501

Record Change Type: CHANGE

Record Content Type: 1

Associated Filing Identifier:

ATTACHMENT M

STANDARD LARGE GENERATOR

INTERCONNECTION PROCEDURES (LGIP)

Standard Large Generator

Interconnection Procedures (LGIP)

(Applicable to Generating Facilities that exceed 20 MW)

TABLE OF CONTENTS

		Page No.
<u>Section 1.</u>	<u>Definitions</u>	- 1 -
<u>Section 2.</u>	<u>Scope and Application</u>	- 13 -
<u>2.1</u>	<u>Application of Standard Large Generator Interconnection Procedures.</u>	- 13 -
<u>2.2</u>	<u>Comparability.</u>	- 14 -
<u>2.3</u>	<u>Base Case Data.</u>	- 14 -
<u>2.4</u>	<u>No Applicability to Transmission Service.</u>	- 14 -
<u>Section 3.</u>	<u>Interconnection Requests</u>	- 15 -
<u>3.1</u>	<u>Interconnection Requests.</u>	- 15 -
<u>3.2</u>	<u>Identification of Types of Interconnection Services.</u>	- 17 -
<u>3.3</u>	<u>Utilization of Surplus Interconnection Service.</u>	- 20 -
<u>3.4</u>	<u>Valid Interconnection Request.</u>	- 22 -
<u>3.5.</u>	<u>OASIS Posting.</u>	- 28 -

- 3.6 [Coordination with Affected Systems](#)..... - 36 -
- 3.7 [Withdrawal](#)..... - 37 -
- 3.8 [Identification of Contingent Facilities](#)..... - 50 -
- 3.9 [Penalties for Failure to Meet Study Deadlines](#)..... - 52 -
- Section 4. [Interconnection Request Evaluation Process](#)..... - 54 -
 - 4.1 [Queue Position](#)..... - 55 -
 - 4.2. [General Study Process](#)..... - 55 -
 - 4.3 [Transferability of Queue Position](#)..... - 57 -
 - 4.4 [Modifications](#)..... - 57 -
- Section 5. [Procedures for Interconnection Requests Submitted Prior to Effective Date of the Cluster Study Revisions](#)..... - 61 -
 - 5.1 [Procedures for Transitioning to the Cluster Study Process](#)..... - 61 -
 - 5.2 [New Transmission Provider](#)..... - 67 -
- Section 6. [Interconnection Information Access](#)..... - 68 -
 - 6.1 [Publicly Posted Interconnection Information](#)..... - 68 -
- Section 7. [Cluster Study](#)..... - 69 -
 - 7.1 [Cluster Study Agreement](#)..... - 69 -
 - 7.2 [Execution of Cluster Study Agreement](#)..... - 69 -
 - 7.3 [Scope of Cluster Study](#)..... - 69 -
 - 7.4 [Cluster Study Procedures](#)..... - 71 -
 - 7.5 [Cluster Study Restudies](#)..... - 72 -
- Section 8. [Interconnection Facilities Study](#)..... - 75 -
 - 8.1 [Interconnection Facilities Study Agreement](#)..... - 75 -
 - 8.2 [Scope of Interconnection Facilities Study](#)..... - 76 -
 - 8.3 [Interconnection Facilities Study Procedures](#)..... - 76 -
 - 8.4 [Meeting with Transmission Provider](#)..... - 78 -
 - 8.5 [Restudy](#)..... - 78 -
- Section 9. [Affected System Study](#)..... - 78 -
 - 9.1 [Applicability](#)..... - 78 -
 - 9.2 [Response to Notifications](#)..... - 78 -
 - 9.3 [Affected System Queue Position](#)..... - 79 -
 - 9.4 [Affected System Study Agreement/Multiparty Affected System Study Agreement](#)..... - 80 -
 - 9.5 [Execution of Affected System Study Agreement/Multiparty Affected System Study Agreement](#)..... - 80 -
 - 9.6 [Scope of Affected System Study](#)..... - 81 -
 - 9.7 [Affected System Study Procedures](#)..... - 82 -
 - 9.8 [Meeting with Transmission Provider](#)..... - 83 -
 - 9.9 [Affected System Cost Allocation](#)..... - 83 -

- [9.10 Tender of Affected Systems Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement.](#) - 84 -
- [9.11 Restudy.](#) - 84 -
- [Section 10. Optional Interconnection Study](#)..... - 84 -
- [10.1 Optional Interconnection Study Agreement.](#) - 84 -
- [10.2 Scope of Optional Interconnection Study.](#) - 85 -
- [10.3 Optional Interconnection Study Procedures.](#) - 86 -
- [Section 11. Standard Large Generator Interconnection Agreement \(LGIA\) ..](#) - 86 -
- [11.1 Tender.](#) - 86 -
- [11.2 Negotiation.](#) - 87 -
- [11.3 Execution and Filing.](#)..... - 88 -
- [11.4 Commencement of Interconnection Activities.](#)..... - 89 -
- [Section 12. Construction of Transmission Provider’s Interconnection Facilities and Network Upgrades](#) - 90 -
- [12.1 Schedule.](#)..... - 90 -
- [12.2 Construction Sequencing.](#)..... - 90 -
- [Section 13. Miscellaneous](#)..... - 92 -
- [13.1 Confidentiality.](#) - 92 -
- [13.2 Delegation of Responsibility.](#) - 97 -
- [13.3 Obligation for Study Costs.](#) - 97 -
- [13.4 Third Parties Conducting Studies.](#) - 98 -
- [13.5 Disputes.](#) - 99 -
- [13.6 Local Furnishing Bonds.](#) - 102 -
- [13.7 Engineering & Procurement \(‘E&P’\) Agreement.](#) - 103 -

Appendix 1 – Interconnection Request for a Large Generating Facility

Appendix 2 – Cluster Study Agreement

Appendix 3 – Interconnection Facilities Study Agreement

Appendix 4 – Optional Interconnection Study Agreement

Appendix 5 – Standard Large Generator Interconnection Agreement

Appendix 6 – Interconnection Procedures for a Wind Generating Plant

Appendix 7 – Transitional Cluster Study Agreement

Appendix 8 – Transitional Serial Interconnection Facilities Study Agreement

Appendix 9 – Two-Party Affected System Study Agreement

Appendix 10 – Multiparty Affected System Study Agreement

Appendix 11 – Two-Party Affected System Facilities Construction Agreement

Appendix 12 – Multiparty Affected System Facilities Construction Agreement

Section 1. Definitions

Adverse System Impact shall mean the negative effects due to technical or operational limits on conductors or equipment being exceeded that may compromise the safety and reliability of the electric system.

Affected System shall mean an electric system other than Transmission Provider's Transmission System that may be affected by the proposed interconnection.

Affected System Facilities Construction Agreement shall mean the agreement contained in Appendix 11 to this LGIP that is made between Transmission Provider and Affected System Interconnection Customer to facilitate the construction of and to set forth cost responsibility for necessary Affected System Network Upgrades on Transmission Provider's Transmission System.

Affected System Interconnection Customer shall mean any entity that submits an interconnection request for a generating facility to a transmission system other than Transmission Provider's Transmission System that may cause the need for Affected System Network Upgrades on Transmission Provider's Transmission System.

Affected System Network Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Transmission System required to accommodate Affected System Interconnection Customer's proposed interconnection to a transmission system other than Transmission Provider's Transmission System.

Affected System Operator shall mean the entity that operates an Affected System.

Affected System Queue Position shall mean the queue position of an Affected System Interconnection Customer in Transmission Provider's interconnection queue relative to Transmission Provider's Interconnection Customers' Queue Positions.

Affected System Study shall mean the evaluation of Affected System Interconnection Customers' proposed interconnection(s) to a transmission system other than Transmission Provider's Transmission System that have an impact on Transmission Provider's Transmission System, as described in Section 9 of this LGIP.

Affected System Study Agreement shall mean the agreement contained in Appendix 9 to this LGIP that is made between Transmission Provider and Affected System Interconnection Customer to conduct an Affected System Study pursuant to Section 9 of this LGIP.

Affected System Study Report shall mean the report issued following completion of an Affected System Study pursuant to Section 9. 7 of this LGIP.

Affiliate shall mean, with respect to a corporation, partnership or other entity, each such other corporation, partnership or other entity that directly or indirectly, through one or more intermediaries, controls, is controlled by, or is under common control with, such corporation, partnership or other entity.

Ancillary Services shall mean those services that are necessary to support the transmission of capacity and energy from resources to loads while maintaining reliable operation of Transmission Provider's Transmission System in accordance with Good Utility Practice.

Applicable Laws and Regulations shall mean all duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Applicable Reliability Standards shall mean the requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Balancing Authority shall mean an entity that integrates resource plans ahead of time, maintains demand and resource balance within a Balancing Authority Area, and supports interconnection frequency in real time.

Balancing Authority Area shall mean the collection of generation, transmission, and loads within the metered boundaries of the Balancing Authority. The Balancing Authority maintains load-resource balance within this area.

Base Case shall mean the base case power flow, short circuit, and stability data bases used for the Interconnection Studies by Transmission Provider or Interconnection Customer.

Breach shall mean the failure of a Party to perform or observe any material term or condition of the Standard Large Generator Interconnection Agreement.

Breaching Party shall mean a Party that is in Breach of the Standard Large Generator Interconnection Agreement.

Business Day shall mean Monday through Friday, excluding Federal Holidays.

Calendar Day shall mean any day including Saturday, Sunday or a Federal Holiday.

Cluster shall mean a group of one or more Interconnection Requests that are studied together for the purpose of conducting a Cluster Study.

Cluster Request Window shall mean the time period set forth in Section 3.4.1 of this LGIP.

Cluster Restudy shall mean a restudy of a Cluster Study conducted pursuant to Section 7.5 of this LGIP.

Cluster Restudy Report shall mean the report issued following completion of a Cluster Restudy pursuant to Section 7.5 of this LGIP.

Cluster Restudy Report Meeting shall mean the meeting held to discuss the results of a Cluster Restudy pursuant to Section 7.5 of this LGIP.

Cluster Study shall mean the evaluation of one or more Interconnection Requests within a Cluster as described in Section 7 of this LGIP.

Cluster Study Agreement shall mean the agreement contained in Appendix 2 to this LGIP for conducting the Cluster Study.

Cluster Study Process shall mean the following processes, conducted in sequence: the Cluster Request Window; the Customer Engagement Window and Scoping Meetings therein; the Cluster Study; any needed Cluster Restudies; and the Interconnection Facilities Study.

Cluster Study Report shall mean the report issued following completion of a Cluster Study pursuant to Section 7 of this LGIP.

Cluster Study Report Meeting shall mean the meeting held to discuss the results of a Cluster Study pursuant to Section 7 of this LGIP.

Clustering shall mean the process whereby one or more Interconnection Requests are studied together, instead of serially, as described in Section 7 of this LGIP.

Commercial Operation shall mean the status of a Generating Facility that has commenced generating electricity for sale, excluding electricity generated during Trial Operation.

Commercial Operation Date of a unit shall mean the date on which the Generating Facility commences Commercial Operation as agreed to by the Parties pursuant to Appendix E to the Standard Large Generator Interconnection Agreement.

Commercial Readiness Deposit shall mean a deposit paid as set forth in Sections 3.4.2, 7.5, and 8.1 of this LGIP.

Confidential Information shall mean any confidential, proprietary or trade secret information of a plan, specification, pattern, procedure, design, device, list, concept, policy or compilation relating to the present or planned business of a Party, which is designated as confidential by the Party supplying the information, whether conveyed orally, electronically, in writing, through inspection, or otherwise.

Contingent Facilities shall mean those unbuilt Interconnection Facilities and Network Upgrades upon which the Interconnection Request's costs, timing, and study findings are dependent, and if delayed or not built, could cause a need for restudies of the Interconnection Request or a reassessment of the Interconnection Facilities and/or Network Upgrades and/or costs and timing.

Customer Engagement Window shall mean the time period set forth in Section 3.4.5 of this LGIP.

Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 17 of the Standard Large Generator Interconnection Agreement.

Dispute Resolution shall mean the procedure for resolution of a dispute between the Parties in which they will first attempt to resolve the dispute on an informal basis.

Distribution System shall mean Transmission Provider's facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which distribution systems operate differ among areas.

Distribution Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Generating Facility and render the transmission service necessary to effect Interconnection Customer's wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Effective Date shall mean the date on which the Standard Large Generator Interconnection Agreement becomes effective upon execution by the Parties subject to acceptance by FERC, or if filed unexecuted, upon the date specified by FERC.

Electric Reliability Organization shall mean the North American Electric Reliability Corporation (NERC) or its successor organization.

Emergency Condition shall mean a condition or situation: (1) that in the judgment of the Party making the claim is imminently likely to endanger life or property; or (2) that, in the case of a Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to Transmission Provider's Transmission System, Transmission Provider's Interconnection Facilities or the electric systems of others to which Transmission Provider's Transmission System is directly connected; or (3) that, in the case of Interconnection Customer, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Generating Facility or Interconnection Customer's Interconnection Facilities. System restoration and black start shall be considered Emergency Conditions; provided that Interconnection Customer is not obligated by the Standard Large Generator Interconnection Agreement to possess black start capability.

Energy Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to connect its Generating Facility to Transmission Provider's Transmission System to be eligible to deliver the Generating Facility's electric output using the existing firm or nonfirm capacity of Transmission Provider's Transmission System on an as available basis. Energy Resource Interconnection Service in and of itself does not convey transmission service.

Engineering & Procurement (E&P) Agreement shall mean an agreement that authorizes Transmission Provider to begin engineering and procurement of long lead-time items necessary for the establishment of the interconnection in order to advance the implementation of the Interconnection Request.

Environmental Law shall mean Applicable Laws or Regulations relating to pollution or protection of the environment or natural resources.

Federal Power Act shall mean the Federal Power Act, as amended, 16 U.S.C. §§ 791a et seq.

FERC shall mean the Federal Energy Regulatory Commission (Commission) or its successor.

Force Majeure shall mean any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, breakage or accident to machinery or equipment, any order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, or any other cause beyond a Party's control. A Force Majeure event does not include acts of negligence or intentional wrongdoing by the Party claiming Force Majeure.

Generating Facility shall mean Interconnection Customer's device(s) for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer's Interconnection Facilities.

Generating Facility Capacity shall mean the net capacity of the Generating Facility or the aggregate net capacity of the Generating Facility where it includes more than one device for the production and/or storage for later injection of electricity.

Good Utility Practice shall mean any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Governmental Authority shall mean any federal, state, local or other governmental regulatory or administrative agency, court, commission, department, board, or other governmental subdivision, legislature, rulemaking board, tribunal, or other governmental authority having jurisdiction over the Parties, their respective facilities, or the respective services they provide, and exercising or entitled to exercise any administrative, executive, police, or taxing authority or power; provided, however, that such term does not include Interconnection Customer, Transmission Provider, or any Affiliate thereof.

Hazardous Substances shall mean any chemicals, materials or substances defined as or included in the definition of "hazardous substances," "hazardous wastes," "hazardous materials," "hazardous constituents," "restricted hazardous materials," "extremely hazardous substances," "toxic substances," "radioactive substances," "contaminants," "pollutants," "toxic pollutants" or words of similar meaning and regulatory effect under any applicable Environmental Law, or any other chemical, material or substance,

exposure to which is prohibited, limited or regulated by any applicable Environmental Law.

Initial Synchronization Date shall mean the date upon which the Generating Facility is initially synchronized and upon which Trial Operation begins.

In-Service Date shall mean the date upon which Interconnection Customer reasonably expects it will be ready to begin use of Transmission Provider's Interconnection Facilities to obtain back feed power.

Interconnection Customer shall mean any entity, including Transmission Provider, Transmission Owner or any of the Affiliates or subsidiaries of either, that proposes to interconnect its Generating Facility with Transmission Provider's Transmission System.

Interconnection Customer's Interconnection Facilities shall mean all facilities and equipment, as identified in Appendix A of the Standard Large Generator Interconnection Agreement, that are located between the Generating Facility and the Point of Change of Ownership, including any modification, addition, or upgrades to such facilities and equipment necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Customer's Interconnection Facilities are sole use facilities.

Interconnection Facilities shall mean Transmission Provider's Interconnection Facilities and Interconnection Customer's Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Interconnection Facilities Study shall mean a study conducted by Transmission Provider or a third party consultant for Interconnection Customer to determine a list of facilities (including Transmission Provider's Interconnection Facilities and Network Upgrades as identified in the Cluster Study), the cost of those facilities, and the time required to interconnect the Generating Facility with Transmission Provider's Transmission System. The scope of the study is defined in Section 8 of this LGIP.

Interconnection Facilities Study Agreement shall mean the form of agreement contained in Appendix 3 of this LGIP for conducting the Interconnection Facilities Study.

Interconnection Facilities Study Report shall mean the report issued following completion of an Interconnection Facilities Study pursuant to Section 8 of this LGIP.

Interconnection Request shall mean an Interconnection Customer's request, in the form of Appendix 1 to this LGIP, in accordance with the Tariff, to interconnect a new Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Generating Facility that is interconnected with Transmission Provider's Transmission System.

Interconnection Service shall mean the service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling it to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Standard Large Generator Interconnection Agreement and, if applicable, Transmission Provider's Tariff.

Interconnection Study shall mean any of the following studies: the Cluster Study, the Cluster Restudy, the Surplus Interconnection Service Study, the Interconnection Facilities Study, the Affected System Study, Optional Interconnection Study, and Material Modification assessment, described in this LGIP.

IRS shall mean the Internal Revenue Service.

Joint Operating Committee shall be a group made up of representatives from Interconnection Customers and Transmission Provider to coordinate operating and technical considerations of Interconnection Service.

Large Generating Facility shall mean a Generating Facility having a Generating Facility Capacity of more than 20 MW.

LGIA Deposit shall mean the deposit Interconnection Customer submits when returning the executed LGIA, or within ten (10) Business Days of requesting that the LGIA be filed unexecuted at the Commission, in accordance with Section 11.3 of this LGIP.

Loss shall mean any and all losses relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's performance, or non-performance of its obligations under the Standard Large Generator Interconnection Agreement on behalf of the Indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the Indemnifying Party.

Material Modification shall mean those modifications that have a material impact on the cost or timing of any Interconnection Request with an equal or later Queue Position.

Metering Equipment shall mean all metering equipment installed or to be installed at the Generating Facility pursuant to the Standard Large Generator

Interconnection Agreement at the metering points, including but not limited to instrument transformers, MWh-meters, data acquisition equipment, transducers, remote terminal unit, communications equipment, phone lines, and fiber optics.

Multiparty Affected System Facilities Construction Agreement shall mean the agreement contained in Appendix 12 to this LGIP that is made among Transmission Provider and multiple Affected System Interconnection Customers to facilitate the construction of and to set forth cost responsibility for necessary Affected System Network Upgrades on Transmission Provider's Transmission System.

Multiparty Affected System Study Agreement shall mean the agreement contained in Appendix 10 to this LGIP that is made among Transmission Provider and multiple Affected System Interconnection Customers to conduct an Affected System Study pursuant to Section 9 of this LGIP.

Network Resource shall mean any designated generating resource owned, purchased, or leased by a Network Customer under the Network Integration Transmission Service Tariff. Network Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Network Customer's Network Load on a non-interruptible basis.

Network Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to integrate its Large Generating Facility with Transmission Provider's Transmission System (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an RTO or ISO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service in and of itself does not convey transmission service.

Network Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Transmission System required at or beyond the point at which the Interconnection Facilities connect to Transmission Provider's Transmission System to accommodate the interconnection of the Large Generating Facility to Transmission Provider's Transmission System.

Notice of Dispute shall mean a written notice of a dispute or claim that arises out of or in connection with the Standard Large Generator Interconnection Agreement or its performance.

Optional Interconnection Study shall mean a sensitivity analysis based on assumptions specified by Interconnection Customer in the Optional Interconnection Study Agreement.

Optional Interconnection Study Agreement shall mean the form of agreement contained in Appendix 4 of this LGIP for conducting the Optional Interconnection Study.

Party or Parties shall mean Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Permissible Technological Advancement shall mean a new, upgraded, updated or improved technology that an Interconnection Customer intends to utilize in the design, construction or operation of generation or transmission facilities but does not (a) include a change in the generation technology or fuel type or (b) constitute a Material Modification.

Point of Change of Ownership shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where Interconnection Customer's Interconnection Facilities connect to Transmission Provider's Interconnection Facilities.

Point of Interconnection shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where the Interconnection Facilities connect to Transmission Provider's Transmission System.

Proportional Impact Method shall mean a technical analysis conducted by Transmission Provider to determine the degree to which each Generating Facility in the Cluster Study contributes to the need for a specific System Network Upgrade.

Provisional Interconnection Service shall mean Interconnection Service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling that Transmission System to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Provisional Large Generator Interconnection Agreement and, if applicable, the Tariff.

Provisional Large Generator Interconnection Agreement shall mean the interconnection agreement for Provisional Interconnection Service established between Transmission Provider and/or Transmission Owner and Interconnection Customer. This agreement shall take the form of the Standard Large Generator Interconnection Agreement, modified for provisional purposes.

Queue Position shall mean the order of a valid Interconnection Request, relative to all other pending valid Interconnection Requests, established pursuant to Section 4.1 of this LGIP.

Reasonable Efforts shall mean, with respect to an action required to be attempted or taken by a Party under the Standard Large Generator Interconnection Agreement, efforts that are timely and consistent with Good Utility Practice and are otherwise substantially equivalent to those a Party would use to protect its own interests.

Scoping Meeting shall mean the meeting between representatives of Interconnection Customer(s) and Transmission Provider conducted for the purpose of discussing the proposed Interconnection Request and any alternative interconnection options, exchanging information including any transmission data and earlier study evaluations that would be reasonably expected to impact such interconnection options, refining information and models provided by Interconnection Customer(s), discussing the Cluster Study materials posted to OASIS pursuant to Section 3.5 of this LGIP, and analyzing such information.

Site Control shall mean the exclusive land right to develop, construct, operate, and maintain the Generating Facility over the term of expected operation of the Generating Facility. Site Control may be demonstrated by documentation establishing: (1) ownership of, a leasehold interest in, or a right to develop a site of sufficient size to construct and operate the Generating Facility; (2) an option to purchase or acquire a leasehold site of sufficient size to construct and operate the Generating Facility; or (3) any other documentation that clearly demonstrates the right of Interconnection Customer to exclusively occupy a site of sufficient size to construct and operate the Generating Facility. Transmission Provider will maintain acreage requirements for each Generating Facility type on its OASIS or public website.

Small Generating Facility shall mean a Generating Facility that has a Generating Facility Capacity of no more than 20 MW.

Stand Alone Network Upgrades shall mean Network Upgrades that are not part of an Affected System that Interconnection Customer may construct without affecting day-to-day operations of the Transmission System during their construction. Both Transmission Provider and Interconnection Customer must agree as to what constitutes Stand Alone Network Upgrades and identify them in Appendix A to the Standard Large Generator Interconnection Agreement. If Transmission Provider and Interconnection Customer disagree about whether a particular Network Upgrade is a Stand Alone Network Upgrade, Transmission Provider must provide Interconnection Customer a written technical explanation outlining why Transmission Provider does not consider the Network Upgrade to be a Stand Alone Network Upgrade within fifteen (15) Business Days of its determination.

Standard Large Generator Interconnection Agreement (LGIA) shall mean the form of interconnection agreement applicable to an Interconnection Request pertaining to a Large Generating Facility that is included in Transmission Provider's Tariff.

Standard Large Generator Interconnection Procedures (LGIP) shall mean the interconnection procedures applicable to an Interconnection Request pertaining to a Large Generating Facility that are included in Transmission Provider's Tariff.

Substation Network Upgrades shall mean Network Upgrades that are required at the substation located at the Point of Interconnection.

Surplus Interconnection Service shall mean any unneeded portion of Interconnection Service established in a Standard Large Generator Interconnection Agreement, such that if Surplus Interconnection Service is utilized, the total amount of Interconnection Service at the Point of Interconnection would remain the same.

System Network Upgrades shall mean Network Upgrades that are required beyond the substation located at the Point of Interconnection.

System Protection Facilities shall mean the equipment, including necessary protection signal communications equipment, required to protect (1) Transmission Provider's Transmission System from faults or other electrical disturbances occurring at the Generating Facility and (2) the Generating Facility from faults or other electrical system disturbances occurring on Transmission Provider's Transmission System or on other delivery systems or other generating systems to which Transmission Provider's Transmission System is directly connected.

Tariff shall mean Transmission Provider's Tariff through which open access transmission service and Interconnection Service are offered, as filed with FERC, and as amended or supplemented from time to time, or any successor tariff.

Transitional Cluster Study shall mean an Interconnection Study evaluating a Cluster of Interconnection Requests during the transition to the Cluster Study Process, as set forth in Section 5.1.1.2 of this LGIP.

Transitional Cluster Study Agreement shall mean the agreement contained in Appendix 7 to this LGIP that is made between Transmission Provider and Interconnection Customer to conduct a Transitional Cluster Study pursuant to Section 5.1.1.2 of this LGIP.

Transitional Cluster Study Report shall mean the report issued following completion of a Transitional Cluster Study pursuant to Section 5.1.1.2 of this LGIP.

Transitional Serial Interconnection Facilities Study shall mean an Interconnection Facilities Study evaluating an Interconnection Request on a serial basis during the transition to the Cluster Study Process, as set forth in Section 5.1.1.1 of this LGIP.

Transitional Serial Interconnection Facilities Study Agreement shall mean the agreement contained in Appendix 8 to this LGIP that is made between Transmission Provider and Interconnection Customer to conduct a Transitional Serial Interconnection Facilities Study pursuant to Section 5.1.1.1 of this LGIP.

Transitional Serial Interconnection Facilities Study Report shall mean the report issued following completion of a Transitional Serial Interconnection Facilities Study pursuant to Section 5.1.1.1 of this LGIP.

Transitional Withdrawal Penalty shall mean the penalty assessed by Transmission Provider to Interconnection Customer that has entered the Transitional Cluster Study or Transitional Serial Interconnection Facilities Study and chooses to withdraw or is deemed withdrawn from Transmission Provider's interconnection queue or whose Generating Facility does not otherwise reach Commercial Operation. The calculation of the Transitional Withdrawal Penalty is set forth in Sections 5.1.1.1 and 5.1.1.2 of this LGIP.

Transmission Owner shall mean an entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Standard Large Generator Interconnection Agreement to the extent necessary.

Transmission Provider shall mean the public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission Provider's Interconnection Facilities shall mean all facilities and equipment owned, controlled, or operated by Transmission Provider from the Point of Change of Ownership to the Point of Interconnection as identified in Appendix A to the Standard Large Generator Interconnection Agreement, including any modifications, additions or upgrades to such facilities and equipment. Transmission Provider's Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Transmission System shall mean the facilities owned, controlled or operated by Transmission Provider or Transmission Owner that are used to provide transmission service under the Tariff.

Trial Operation shall mean the period during which Interconnection Customer is engaged in on-site test operations and commissioning of the Generating Facility prior to Commercial Operation.

Withdrawal Penalty shall mean the penalty assessed by Transmission Provider to an Interconnection Customer that chooses to withdraw or is deemed withdrawn from Transmission Provider's interconnection queue or whose Generating Facility does not otherwise reach Commercial Operation. The calculation of the Withdrawal Penalty is set forth in Section 3.7.1 of this LGIP.

Section 2. Scope and Application

2.1 Application of Standard Large Generator Interconnection Procedures.

Sections 2 through 13 of this LGIP apply to processing an Interconnection Request pertaining to a Large Generating Facility.

2.2 Comparability.

Transmission Provider shall receive, process and analyze all Interconnection Requests in a timely manner as set forth in this LGIP. Transmission Provider shall process and analyze Interconnection Requests from all Interconnection Customers comparably, regardless of whether the Generating Facilities are owned by Transmission Provider, its subsidiaries or Affiliates or others.

2.3 Base Case Data.

Transmission Provider shall maintain base power flow, short circuit and stability databases, including all underlying assumptions, and contingency list on either its OASIS site or a password-protected website, subject to confidentiality provisions in LGIP Section 13.1. In addition, Transmission Provider shall maintain network models and underlying assumptions on either its OASIS site or a password-protected website. Such network models and underlying assumptions should reasonably represent those used during the most recent Interconnection Study and be representative of current system conditions. If Transmission Provider posts this information on a password-protected website, a link to the information must be provided on Transmission Provider's OASIS site. Transmission Provider is permitted to require that Interconnection Customers, OASIS site users and password-protected website users sign a confidentiality agreement before the release of commercially sensitive information or Critical Energy Infrastructure Information in the Base Case data. Such databases and lists, hereinafter referred to as Base Cases, shall include all (1) generation projects and (2) transmission projects, including merchant transmission projects that are proposed for the Transmission System for which a transmission expansion plan has been submitted and approved by the applicable authority.

2.4 No Applicability to Transmission Service.

Nothing in this LGIP shall constitute a request for transmission service or confer upon an Interconnection Customer any right to receive transmission service.

Section 3. Interconnection Requests**3.1 Interconnection Requests.****3.1.1 Study Deposits.**

3.1.1.1 Study Deposit. Interconnection Customer shall submit to Transmission Provider, during a Cluster Request Window, an Interconnection Request in the form of Appendix 1 to this LGIP, a non-refundable application fee of \$5,000, and a refundable study deposit of:

(a) \$35,000 plus \$1,000 per MW for Interconnection Requests < 80 MW; or

(b) \$150,000 for Interconnection Requests \geq 80 MW < 200 MW; or

(c) \$250,000 for Interconnection Requests \geq 200 MW.

Transmission Provider shall apply the study deposit toward the cost of the Cluster Study Process.

3.1.2 Submission.

Interconnection Customer shall submit a separate Interconnection Request for each site. Where multiple Generating Facilities share a site, Interconnection Customer(s) may submit separate

Interconnection Requests or a single Interconnection Request. An Interconnection Request to evaluate one site at two different voltage levels shall be treated as two Interconnection Requests.

At Interconnection Customer's option, Transmission Provider and Interconnection Customer will identify alternative Point(s) of Interconnection and configurations at a Scoping Meeting within the Customer Engagement Window to evaluate in this process and attempt to eliminate alternatives in a reasonable fashion given resources and information available. Interconnection Customer will select the definitive Point of Interconnection to be studied no later than the execution of the Cluster Study Agreement. For purposes of clustering Interconnection Requests, Transmission Provider may propose changes to the requested Point of Interconnection to facilitate efficient interconnection of Interconnection Customers at common Point(s) of Interconnection. Transmission Provider shall notify Interconnection Customers in writing of any intended changes to the requested Point of Interconnection within the Customer Engagement Window, and the Point of Interconnection shall only change upon mutual agreement.

Transmission Provider shall have a process in place to consider requests for Interconnection Service below the Generating Facility Capacity. These requests for Interconnection Service shall be studied at the level of Interconnection Service requested for purposes of Interconnection Facilities, Network Upgrades, and associated costs, but may be subject to other studies at the full Generating Facility Capacity to ensure safety and reliability of the system, with the study costs borne by Interconnection Customer. If after the additional studies are complete, Transmission Provider determines that additional Network Upgrades are necessary, then Transmission Provider must: (1) specify which additional Network Upgrade costs are based on which studies; and (2) provide a detailed explanation of why the additional Network Upgrades are necessary. Any Interconnection Facility and/or Network Upgrade costs required for safety and reliability also would be borne by Interconnection Customer. Interconnection Customers may be subject to additional control technologies as well as testing and validation of those technologies consistent with Article 6 of the LGIA. The necessary

control technologies and protection systems shall be established in Appendix C of that executed, or requested to be filed unexecuted, LGIA.

Transmission Provider shall have a process in place to study Generating Facilities that include at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect the proposed charging behavior of the Generating Facility as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions. If Transmission Provider finds Interconnection Customer's requested operating assumptions conflict with Good Utility Practice, Transmission Provider must provide Interconnection Customer an explanation in writing of why the submitted operating assumptions are insufficient or inappropriate by no later than thirty (30) Calendar Days before the end of the Customer Engagement Window and allow Interconnection Customer to revise and resubmit requested operating assumptions one time at least ten (10) Calendar Days prior to the end of the Customer Engagement Window. Transmission Provider shall study these requests for Interconnection Service, with the study costs borne by Interconnection Customer, using the submitted operating assumptions for purposes of Interconnection Facilities, Network Upgrades, and associated costs. These requests for Interconnection Service also may be subject to other studies at the full Generating Facility Capacity to ensure safety and reliability of the system, with the study costs borne by Interconnection Customer. Interconnection Customer's Generating Facility may be subject to additional control technologies as well as testing and validation of such additional control technologies consistent with Article 6 of the LGIA. The necessary control technologies and protection systems shall be set forth in Appendix C of Interconnection Customer's LGIA.

3.2 Identification of Types of Interconnection Services.

At the time the Interconnection Request is submitted, Interconnection Customer must request either Energy Resource Interconnection Service or Network Resource Interconnection Service, as described; provided,

however, any Interconnection Customer requesting Network Resource Interconnection Service may also request that it be concurrently studied for Energy Resource Interconnection Service, up to the point when an Interconnection Facilities Study Agreement is executed. Interconnection Customer may then elect to proceed with Network Resource Interconnection Service or to proceed under a lower level of interconnection service to the extent that only certain upgrades will be completed.

3.2.1 Energy Resource Interconnection Service.

3.2.1.1 The Product. Energy Resource Interconnection Service allows Interconnection Customer to connect the Large Generating Facility to the Transmission System and be eligible to deliver the Large Generating Facility's output using the existing firm or non-firm capacity of the Transmission System on an "as available" basis. Energy Resource Interconnection Service does not in and of itself convey any right to deliver electricity to any specific customer or Point of Delivery.

3.2.1.2 The Study. The study consists of short circuit/fault duty, steady state (thermal and voltage) and stability analyses. The short circuit/fault duty analysis would identify direct Interconnection Facilities required and the Network Upgrades necessary to address short circuit issues associated with the Interconnection Facilities. The stability and steady state studies would identify necessary upgrades to allow full output of the proposed Large Generating Facility, except for Generating Facilities that include at least one electric storage resource that request to use operating assumptions pursuant to Section 3.1.2, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions, and would also identify the maximum

allowed output, at the time the study is performed, of the interconnecting Large Generating Facility without requiring additional Network Upgrades.

3.2.2 Network Resource Interconnection Service.

3.2.2.1 The Product. Transmission Provider must conduct the necessary studies and construct the Network Upgrades needed to integrate the Large Generating Facility (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an ISO or RTO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service allows Interconnection Customer's Large Generating Facility to be designated as a Network Resource, up to the Large Generating Facility's full output, on the same basis as existing Network Resources interconnected to Transmission Provider's Transmission System, and to be studied as a Network Resource on the assumption that such a designation will occur.

3.2.2.2 The Study. The Interconnection Study for Network Resource Interconnection Service shall assure that Interconnection Customer's Large Generating Facility meets the requirements for Network Resource Interconnection Service and as a general matter, that such Large Generating Facility's interconnection is also studied with Transmission Provider's Transmission System at peak load, under a variety of severely stressed conditions, to determine whether, with the Large Generating Facility at full output, except for Generating Facilities that include at least one electric storage resource that request to use, and for which Transmission Provider approves, operating assumptions pursuant to Section 3.1.2, the aggregate of generation in the local area can be delivered to the aggregate of load on Transmission Provider's

Transmission System, consistent with Transmission Provider's reliability criteria and procedures. This approach assumes that some portion of existing Network Resources are displaced by the output of Interconnection Customer's Large Generating Facility. Network Resource Interconnection Service in and of itself does not convey any right to deliver electricity to any specific customer or Point of Delivery. Transmission Provider may also study the Transmission System under non-peak load conditions. However, upon request by Interconnection Customer, Transmission Provider must explain in writing to Interconnection Customer why the study of non-peak load conditions is required for reliability purposes.

3.3 Utilization of Surplus Interconnection Service.

Transmission Provider must provide a process that allows an Interconnection Customer to utilize or transfer Surplus Interconnection Service at an existing Point of Interconnection. The original Interconnection Customer or one of its affiliates shall have priority to utilize Surplus Interconnection Service. If the existing Interconnection Customer or one of its affiliates does not exercise its priority, then that service may be made available to other potential Interconnection Customers.

3.3.1 Surplus Interconnection Service Requests.

Surplus Interconnection Service requests may be made by the existing Interconnection Customer or one of its affiliates or may be submitted once Interconnection Customer has executed the LGIA or requested that the LGIA be filed unexecuted. Surplus Interconnection Service requests also may be made by another Interconnection Customer. Transmission Provider shall provide a process for evaluating Interconnection Requests for Surplus Interconnection Service. Studies for Surplus Interconnection Service shall consist of reactive power, short circuit/fault duty, stability analyses, and any other appropriate studies. Steady-state (thermal/voltage) analyses may be performed as necessary to ensure that all required reliability conditions are studied. If the Surplus Interconnection Service was not studied under off-peak conditions,

off-peak steady state analyses shall be performed to the required level necessary to demonstrate reliable operation of the Surplus Interconnection Service. If the original system impact study report or Cluster Study Report is not available for the Surplus Interconnection Service, both off-peak and peak analysis may need to be performed for the existing Generating Facility associated with the request for Surplus Interconnection Service. The reactive power, short circuit/fault duty, stability, and steady-state analyses for Surplus Interconnection Service will identify any additional Interconnection Facilities and/or Network Upgrades necessary.

Transmission Provider shall study Surplus Interconnection Service requests for a Generating Facility that includes at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect the proposed charging behavior of the Generating Facility as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions.

3.3.2 Process for Surplus Interconnection Service

A request for Surplus Interconnection Service may be initiated by transmitting information to the Transmission Provider specifying the Large Generator Interconnection for which such service is requested, and that the request be treated pursuant to Section 3.3 of the LGIP. The cover transmittal should also indicate whether or not the request is related to service provided to the original Interconnection Customer or its affiliate's Large Generator Interconnection.

Should the Transmission Provider receive a request for Surplus Interconnection Service at a Point of Interconnection from a third party relating to an existing Large Generator Interconnection, the original Interconnection Customer or its affiliates shall have priority. Transmission Provider will notify the original Interconnection Customer of any competing request, and that original Interconnection Customer will have ten (10) days to exercise its priority rights. The prospective Interconnection Customer with the competing request will be notified within ten (10) days of any exercise of priority rights. Failure to exercise priority rights by the original Interconnection Customer will result in all excess capacity available through Surplus Interconnection Service being released to other potential Interconnection Customers for a period up to one hundred and eighty (180) days.

Nothing in this Section 3.3.2 should be construed as limiting the right of the original Large Generator Interconnection Customer to either release all claims to priority on a permanent basis or to transfer its priority right to Surplus Interconnection Service to a third party.

Once the priority right of the original Interconnection Customer or its affiliates has been properly exercised, waived (either expressly or through the expiration of the ten (10) day window set out above), released or transferred, the request for Surplus Interconnection Service shall be studied pursuant to the criteria set forth in Section 3.3.1. The timeline and requirements for the study process shall be as follows:

1. The surplus Interconnection Customer must execute an appropriate study agreement and provide a study deposit in the amount of \$10,000 within five (5) Business Days after execution of the agreement.
2. The \$10,000 deposit will be applied to the actual cost of all studies referenced in Section 3.3.1. Any difference in actual cost will be paid by, or refunded to, the surplus Interconnection Customer.
3. In the event that the Transmission Provider and Interconnection Customer cannot agree upon the study agreement, the agreement may be filed on an unexecuted basis with the Commission.
4. Studies performed under Section 3.3.1 shall be completed outside the interconnection study queue set out in Section 3 to the LGIP, and completed within sixty (60) calendar days after execution of a study agreement and receipt of the study deposit.
5. Results of all studies required under Section 3.3.1 shall be communicated to the potential Interconnection Customer as soon as practicable.

Surplus Interconnection Service shall be documented in an agreement between the original Interconnection Customer, surplus Interconnection Customer and Transmission Provider and shall be executed prior to the commencement of service. All agreements shall be filed in accordance with the Commission's regulations governing service agreements under the Transmission Provider's Tariff.

3.4 Valid Interconnection Request.

3.4.1 Cluster Request Window.

Transmission Provider shall accept Interconnection Requests during a forty-five (45) Calendar Day period (the Cluster Request

Window). The initial Cluster Request Window shall open for Interconnection Requests beginning one hundred eighty (180) Calendar Days after the conclusion of the transition process set out in Section 5.1 of this LGIP and successive Cluster Request Windows shall open annually every February 1 thereafter.

3.4.2 Initiating an Interconnection Request.

An Interconnection Customer seeking to join a Cluster shall submit its Interconnection Request to Transmission Provider within, and no later than the close of, the Cluster Request Window.

Interconnection Requests submitted outside of the Cluster Request Window will not be considered. To initiate an Interconnection Request, Interconnection Customer must submit all of the following:

- (i) Applicable study deposit amount, pursuant to Section 3.1.1.1 of this LGIP,
- (ii) A completed application in the form of Appendix 1,
- (iii) Demonstration of no less than ninety percent (90%) Site Control or (1) a signed affidavit from an officer of the company indicating that Site Control is unobtainable due to regulatory limitations as such term is defined by Transmission Provider; and (2) documentation sufficiently describing and explaining the source and effects of such regulatory limitations, including a description of any conditions that must be met to satisfy the regulatory limitations and the anticipated time by which Interconnection Customer expects to satisfy the regulatory requirements and (3) a deposit in lieu of Site Control of \$10,000 per MW, subject to a minimum of \$500,000 and a maximum of \$2,000,000. Interconnection Requests from multiple Interconnection Customers for multiple Generating Facilities that share a site must include a contract or other agreement that allows for shared land use,
- (iv) Generating Facility Capacity (MW) (and requested Interconnection Service level if the requested Interconnection Service is less than the Generating Facility Capacity),

(v) If applicable, (1) the requested operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) to be used by Transmission Provider that reflect the proposed charging behavior of the Generating Facility that includes at least one electric storage resource, and (2) a description of any control technologies (software and/or hardware) that will limit the operation of the Generating Facility to the operating assumptions submitted by Interconnection Customer,

(vi) A Commercial Readiness Deposit equal to two times the study deposit described in Section 3.1.1.1 of this LGIP in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider. This Commercial Readiness Deposit is refunded to Interconnection Customer according to Section 3.7 of this LGIP,

(vii) A Point of Interconnection, and

(viii) Whether the Interconnection Request shall be studied for Network Resource Interconnection Service or for Energy Resource Interconnection Service, consistent with Section 3.2 of this LGIP.

An Interconnection Customer that submits a deposit in lieu of Site Control due to demonstrated regulatory limitations must demonstrate that it is taking identifiable steps to secure the necessary regulatory approvals from the applicable federal, state, and/or tribal entities before execution of the Cluster Study Agreement. Such deposit will be held by Transmission Provider until Interconnection Customer provides the required Site Control demonstration for its point in the Cluster Study Process. Interconnection Customers facing qualifying regulatory limitations must demonstrate one hundred percent (100%) Site Control within one hundred eighty (180) Calendar Days of the effective date of the LGIA.

Interconnection Customer shall promptly inform Transmission Provider of any material change to Interconnection Customer's demonstration of Site Control under Section 3.4.2(iii) of this LGIP. If Transmission Provider determines, based on Interconnection Customer's information, that Interconnection Customer no longer satisfies the Site Control requirement, Transmission Provider shall

give Interconnection Customer ten (10) Business Days to demonstrate satisfaction with the applicable requirement subject to Transmission Provider's approval. Absent such, Transmission Provider shall deem the Interconnection Request withdrawn pursuant to Section 3.7 of this LGIP.

The expected In-Service Date of the new Large Generating Facility or increase in capacity of the existing Generating Facility shall be no more than the process window for the regional expansion planning period (or in the absence of a regional planning process, the process window for Transmission Provider's expansion planning period) not to exceed seven (7) years from the date the Interconnection Request is received by Transmission Provider, unless Interconnection Customer demonstrates that engineering, permitting and construction of the new Large Generating Facility or increase in capacity of the existing Generating Facility will take longer than the regional expansion planning period. The In-Service Date may succeed the date the Interconnection Request is received by Transmission Provider by a period up to ten (10) years, or longer where Interconnection Customer and Transmission Provider agree, such agreement not to be unreasonably withheld.

3.4.3 Acknowledgment of Interconnection Request.

Transmission Provider shall acknowledge receipt of the Interconnection Request within five (5) Business Days of receipt of the request and attach a copy of the received Interconnection Request to the acknowledgement.

3.4.4 Deficiencies in Interconnection Request.

An Interconnection Request will not be considered to be a valid request until all items in Section 3.4.2 of this LGIP have been received by Transmission Provider during the Cluster Request Window. If an Interconnection Request fails to meet the requirements set forth in Section 3.4.2 of this LGIP, Transmission Provider shall notify Interconnection Customer within five (5) Business Days of receipt of the initial Interconnection Request of the reasons for such failure and that the Interconnection Request does not constitute a valid request. Interconnection Customer shall provide Transmission Provider the additional requested information

needed to constitute a valid request within ten (10) Business Days after receipt of such notice but no later than the close of the Cluster Request Window. At any time, if Transmission Provider finds that the technical data provided by Interconnection Customer is incomplete or contains errors, Interconnection Customer and Transmission Provider shall work expeditiously and in good faith to remedy such issues. In the event that Interconnection Customer fails to comply with this Section 3.4.4 of this LGIP, Transmission Provider shall deem the Interconnection Request withdrawn (without the cure period provided under Section 3.7 of this LGIP), the application fee is forfeited to Transmission Provider, and the study deposit and Commercial Readiness Deposit shall be returned to Interconnection Customer.

3.4.5 Customer Engagement Window.

Upon the close of each Cluster Request Window, Transmission Provider shall open a sixty (60) Calendar Day period (Customer Engagement Window). During the Customer Engagement Window, Transmission Provider shall hold a Scoping Meeting with all interested Interconnection Customers. Notwithstanding the preceding requirements and upon written consent of all Interconnection Customers within the Cluster, Transmission Provider may shorten the Customer Engagement Window and begin the Cluster Study. Within ten (10) Business Days of the opening of the Customer Engagement Window, Transmission Provider shall post on its OASIS a list of Interconnection Requests for that Cluster. The list shall identify, for each anonymized Interconnection Request: (1) the requested amount of Interconnection Service; (2) the location by county and state; (3) the station or transmission line or lines where the interconnection will be made; (4) the projected In-Service Date; (5) the type of Interconnection Service requested; and (6) the type of Generating Facility or Facilities to be constructed, including fuel types, such as coal, natural gas, solar, or wind. Transmission Provider must ensure that project information is anonymized and does not reveal the identity or commercial information of Interconnection Customers with submitted requests. During the Customer Engagement Window, Transmission Provider shall provide to Interconnection Customer a non-binding updated good faith estimate of the cost and timeframe for completing the cluster

Study and a Cluster Study Agreement to be executed prior to the close of the Customer Engagement Window.

At the end of the Customer Engagement Window, all Interconnection Requests deemed valid that have executed a Cluster Study Agreement in the form of Appendix 2 to this LGIP shall be included in the Cluster Study. Any Interconnection Requests for which Interconnection Customer has not executed a Cluster Study Agreement shall be deemed withdrawn (without the cure period provided under Section 3.7 of this LGIP) by Transmission Provider, the application fee shall be forfeited to Transmission Provider, and Transmission Provider shall return the study deposit and Commercial Readiness Deposit to Interconnection Customer. Immediately following the Customer Engagement Window, Transmission Provider shall initiate the Cluster Study described in Section 7 of this LGIP.

3.4.6 Cluster Study Scoping Meeting.

During the Customer Engagement Window, Transmission Provider shall hold a Scoping Meeting with all Interconnection Customers whose valid Interconnection Requests were received in that Cluster Request Window.

The purpose of the Cluster Study Scoping Meeting shall be to discuss alternative interconnection options, to exchange information including any transmission data and earlier study evaluations that would reasonably be expected to impact such interconnection options, to discuss the Cluster Study materials posted to OASIS pursuant to Section 3.5 of this LGIP, if applicable, and to analyze such information. Transmission Provider and Interconnection Customer(s) will bring to the meeting such technical data, including, but not limited to: (i) general facility loadings, (ii) general instability issues, (iii) general short circuit issues, (iv) general voltage issues, and (v) general reliability issues as may be reasonably required to accomplish the purpose of the meeting. Transmission Provider and Interconnection Customer(s) will also bring to the meeting personnel and other resources as may be

reasonably required to accomplish the purpose of the meeting in the time allocated for the meeting. On the basis of the meeting, Interconnection Customer(s) shall designate its Point of Interconnection. The duration of the meeting shall be sufficient to accomplish its purpose. If the Cluster Study Scoping Meeting consists of more than one Interconnection Customer, Transmission Provider shall issue, no later than fifteen (15) Business Days after the commencement of the Customer Engagement Window, and Interconnection Customer shall execute a non-disclosure agreement prior to a group Cluster Study Scoping Meeting, which will provide for confidentiality of identifying information or commercially sensitive information pertaining to any other Interconnection Customers.

3.5. OASIS Posting.

3.5.1 OASIS Posting.

Transmission Provider will maintain on its OASIS a list of all Interconnection Requests. The list will identify, for each Interconnection Request: (i) the maximum summer and winter megawatt electrical output; (ii) the location by county and state; (iii) the station or transmission line or lines where the interconnection will be made; (iv) the projected In-Service Date; (v) the status of the Interconnection Request, including Queue Position; (vi) the type of Interconnection Service being requested; (vii) the availability of any studies related to the Interconnection Request; (viii) the date of the Interconnection Request; (ix) the type of Generating Facility to be constructed; and (x) for Interconnection Requests that have not resulted in a completed interconnection, an explanation as to why it was not completed. Except in the case of an Affiliate, the list will not disclose the identity of Interconnection Customer until Interconnection Customer executes an LGIA or requests that Transmission Provider file an unexecuted LGIA with FERC. Before holding a Scoping Meeting with its Affiliate, Transmission Provider shall post on OASIS an advance notice of its intent to do so. Transmission Provider shall post to its OASIS site any deviations from the study timelines set forth herein. Interconnection Study reports and Optional Interconnection Study reports shall be posted to Transmission Provider's OASIS site subsequent to the

meeting between Interconnection Customer and Transmission Provider to discuss the applicable study results. Transmission Provider shall also post any known deviations in the Large Generating Facility's In-Service Date.

3.5.2 Requirement to Post Interconnection Study Metrics.

Transmission Provider will maintain on its OASIS or its website summary statistics related to processing Interconnection Studies pursuant to Interconnection Requests, updated quarterly. If Transmission Provider posts this information on its website, a link to the information must be provided on Transmission Provider's OASIS site. For each calendar quarter, Transmission Provider must calculate and post the information detailed in Sections 3.5.2.1 through 3.5.2.4 of this LGIP.

3.5.2.1 Interconnection Cluster Study Processing Time.

(A) Number of Interconnection Requests that had Cluster Studies completed within Transmission Provider's coordinated region during the reporting quarter,

(B) Number of Interconnection Requests that had Cluster Studies completed within Transmission Provider's coordinated region during the reporting quarter that were completed more than one hundred fifty (150) Calendar Days after the close of the Customer Engagement Window,

(C) At the end of the reporting quarter, the number of active valid Interconnection Requests with ongoing incomplete Cluster Studies where such Interconnection Requests had executed a Cluster Study Agreement received by Transmission Provider more than one hundred fifty (150) Calendar Days before the reporting quarter end,

(D) Mean time (in days), Cluster Studies completed within Transmission Provider's coordinated region during the reporting quarter, from the commencement of the Cluster Study to the date when Transmission Provider provided the completed Cluster Study Report to Interconnection Customer,

(E) Mean time (in days), Cluster Studies were completed within Transmission Provider's coordinated region during the reporting quarter, from the close of the Cluster Request Window to the date when Transmission Provider provided the completed Cluster Study Report to Interconnection Customer,

(F) Percentage of Cluster Studies exceeding one hundred fifty (150) Calendar Days to complete this reporting quarter, calculated as the sum of Section 3.5.2.1(B) plus Section 3.5.2.1(C) divided by the sum of Section 3.5.2.1(A) plus Section 3.5.2.1(C) of this LGIP.

3.5.2.2 Cluster Restudies Processing Time.

(A) Number of Interconnection Requests that had Cluster Restudies completed within Transmission Provider's coordinated region during the reporting quarter,

(B) Number of Interconnection Requests that had Cluster Restudies completed within Transmission Provider's coordinated region during the reporting quarter that were completed more than one hundred fifty (150) Calendar Days after Transmission Provider

notifies Interconnection Customers in the Cluster that a Cluster Restudy is required pursuant to Section 7.5(4) of this LGIP,

(C) At the end of the reporting quarter, the number of active valid Interconnection Requests with ongoing incomplete Cluster Restudies where Transmission Provider notified Interconnection Customers in the Cluster that a Cluster Restudy is required pursuant to Section 7.5(4) of this LGIP more than one hundred fifty (150) Calendar Days before the reporting quarter end,

(D) Mean time (in days), Cluster Restudies completed within Transmission Provider's coordinated region during the reporting quarter, from the date when Transmission Provider notifies Interconnection Customers in the Cluster that a Cluster Restudy is required pursuant to Section 7.5(4) of this LGIP to the date when Transmission Provider provided the completed Cluster Restudy Report to Interconnection Customer,

(E) Mean time (in days), Cluster Restudies completed within Transmission Provider's coordinated region during the reporting quarter, from the close of the Cluster Request Window to the date when Transmission Provider provided the completed Cluster Restudy Report to Interconnection Customer,

(F) Percentage of Cluster Restudies exceeding one hundred fifty (150) Calendar Days to complete this reporting quarter, calculated as the sum of Section 3.5.2.2(B) plus Section 3.5.2.2(C) divided by the sum of Section 3.5.2.2(A) plus Section 3.5.2.2(C) of this LGIP.

3.5.2.3 Interconnection Facilities Studies Processing Time.

(A) Number of Interconnection Requests that had Interconnection Facilities Studies that are completed within Transmission Provider's coordinated region during the reporting quarter,

(B) Number of Interconnection Requests that had Interconnection Facilities Studies that are completed within Transmission Provider's coordinated region during the reporting quarter that were completed more than 90 days with a cost variance of 20% or 180 days with a cost variance of 10% after receipt by Transmission Provider of Interconnection Customer's executed Interconnection Facilities Study Agreement,

(C) At the end of the reporting quarter, the number of active valid Interconnection Service requests with ongoing incomplete Interconnection Facilities Studies where such Interconnection Requests had executed Interconnection Facilities Studies Agreement received by Transmission Provider more than 90 days with a cost variance of 20% or 180 days with a cost variance of 10% before the reporting quarter end,

(D) Mean time (in days), for Interconnection Facilities Studies completed within Transmission Provider's coordinated region during the reporting quarter, calculated from the date when Transmission Provider received the executed Interconnection Facilities Study Agreement to the date when Transmission Provider provided the completed Interconnection Facilities Study to Interconnection Customer,

(E) Mean time (in days), Interconnection Facilities Studies completed within Transmission Provider's coordinated region during the reporting quarter, from the close of the Cluster Request Window to the date when Transmission Provider provided the completed Interconnection Facilities Study to Interconnection Customer,

(F) Percentage of delayed Interconnection Facilities Studies this reporting quarter, calculated as the sum of Section 3.5.2.3(B) plus Section 3.5.2.3(C) divided by the sum of Section 3.5.2.3(A) plus Section 3.5.2.3(C) of this LGIP.

3.5.2.4 Interconnection Service Requests Withdrawn from Interconnection Queue.

(A) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue during the reporting quarter,

(B) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue during the reporting quarter before completion of any Interconnection Studies or execution of any Interconnection Study agreements,

(C) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue during the reporting quarter before completion of a Cluster Study,

(D) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue

during the reporting quarter before completion of an Interconnection Facilities Study,

(E) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue after completion of an Interconnection Facilities Study but before execution of an LGIA or Interconnection Customer requests the filing of an unexecuted, new LGIA,

(F) Number of Interconnection Requests withdrawn from Transmission Provider's interconnection queue after execution of an LGIA or Interconnection Customer requests the filing of an unexecuted, new LGIA

(G) Mean time (in days), for all withdrawn Interconnection Requests, from the date when the request was determined to be valid to when Transmission Provider received the request to withdraw from the queue.

3.5.3

Transmission Provider is required to post on OASIS or its website the measures in Section 3.5.2.1(A) through Section 3.5.2.4(G) for each calendar quarter within thirty (30) Calendar Days of the end of the calendar quarter. Transmission Provider will keep the quarterly measures posted on OASIS or its website for three (3) calendar years with the first required report to be in the first quarter of 2020. If Transmission Provider retains this information on its website, a link to the information must be provided on Transmission Provider's OASIS site.

3.5.4

In the event that any of the values calculated in Sections 3.5.2.1(E), 3.5.2.2(E) or 3.5.2.3(E) exceeds twenty-five percent (25%) for two

(2) consecutive calendar quarters, Transmission Provider will have to comply with the measures below for the next four (4) consecutive calendar quarters and must continue reporting this information until Transmission Provider reports four (4) consecutive calendar quarters without the values calculated in Sections 3.5.2.1(E), 3.5.2.2(E) or 3.5.2.3(E) exceeding twenty-five percent (25%) for two (2) consecutive calendar quarters:

(i) Transmission Provider must submit a report to the Commission describing the reason for each Cluster Study, Cluster Restudy, or individual Interconnection Facilities Study pursuant to one or more Interconnection Request(s) that exceeded its deadline (i.e., 150, 90 or 180 Calendar Days) for completion. Transmission Provider must describe the reasons for each study delay and any steps taken to remedy these specific issues and, if applicable, prevent such delays in the future. The report must be filed at the Commission within forty-five (45) Calendar Days of the end of the calendar quarter.

(ii) Transmission Provider shall aggregate the total number of employee-hours and third party consultant hours expended towards Interconnection Studies within its coordinated region that quarter and post on OASIS or its website. If Transmission Provider posts this information on its website, a link to the information must be provided on Transmission Provider's OASIS site. This information is to be posted within thirty (30) Calendar Days of the end of the calendar quarter.

3.6 Coordination with Affected Systems.

Transmission Provider will coordinate the conduct of any studies required to determine the impact of the Interconnection Request on Affected Systems with Affected System Operators. Interconnection Customer will cooperate with Transmission Provider and Affected System Operator in all matters related to the conduct of studies and the determination of modifications to Affected Systems.

A Transmission Provider whose system may be impacted by a proposed interconnection on another transmission provider's transmission system shall cooperate with transmission provider with whom interconnection has been requested in all matters related to the conduct of studies and the determination of modifications to Transmission Provider's Transmission System.

3.6.1 Initial Notification.

Transmission Provider must notify Affected System Operator of a potential Affected System impact caused by an Interconnection Request within ten (10) Business Days of the completion of the Cluster Study.

At the time of initial notification, Transmission Provider must provide Interconnection Customer with a list of potential Affected Systems, along with relevant contact information.

3.6.2 Notification of Cluster Restudy.

Transmission Provider must notify Affected System Operator of a Cluster Restudy concurrently with its notification of such Cluster Restudy to Interconnection Customers.

3.6.3 Notification of Cluster Restudy Completion.

Upon the completion of Transmission Provider's Cluster Restudy, Transmission Provider will notify Affected System Operator of a potential Affected System impact caused by an Interconnection Request within ten (10) Business Days of the completion of the Cluster Restudy, regardless of whether that potential Affected System impact was previously identified. At the time of the notification of the completion of the Cluster Restudy to the Affected System Operator, Transmission Provider must provide Interconnection Customer with a list of potential Affected System Operators, along with relevant contact information.

3.7 Withdrawal.

Interconnection Customer may withdraw its Interconnection Request at any time by written notice of such withdrawal to Transmission Provider. In addition, if Interconnection Customer fails to adhere to all requirements of this LGIP, except as provided in Section 13.5 (Disputes), Transmission Provider shall deem the Interconnection Request to be withdrawn and shall provide written notice to Interconnection Customer of the deemed withdrawal and an explanation of the reasons for such deemed withdrawal. Upon receipt of such written notice, Interconnection Customer shall have fifteen (15) Business Days in which to either respond with information or actions that cures the deficiency or to notify Transmission Provider of its intent to pursue Dispute Resolution.

Withdrawal shall result in the loss of Interconnection Customer's Queue Position. If an Interconnection Customer disputes the withdrawal and loss of its Queue Position, then during Dispute Resolution, Interconnection Customer's Interconnection Request is eliminated from the queue until such time that the outcome of Dispute Resolution would restore its Queue Position. An Interconnection Customer that withdraws or is deemed to have withdrawn its Interconnection Request shall pay to Transmission Provider all costs that Transmission Provider prudently incurs with respect to that Interconnection Request prior to Transmission Provider's receipt of notice described above. Interconnection Customer must pay all monies due to Transmission Provider before it is allowed to obtain any Interconnection Study data or results.

If Interconnection Customer withdraws its Interconnection Request or is deemed withdrawn by Transmission Provider under Section 3.7 of this LGIP, Transmission Provider shall (i) update the OASIS Queue Position posting; (ii) impose the Withdrawal Penalty described in Section 3.7.1 of this LGIP; and (iii) refund to Interconnection Customer any portion of the refundable portion of Interconnection Customer's study deposit that exceeds the costs that Transmission Provider has incurred, including interest calculated in accordance with Section 35.19a(a)(2) of FERC's regulations. Transmission Provider shall also refund any portion of the Commercial Readiness Deposit not applied to the Withdrawal Penalty and, if applicable, the deposit in lieu of site control. In the event of such withdrawal, Transmission Provider, subject to the confidentiality provisions of Section 13.1 of this LGIP, shall provide, at Interconnection Customer's request, all information that Transmission Provider developed for any

completed study conducted up to the date of withdrawal of the Interconnection Request.

3.7.1 Withdrawal Penalty.

Interconnection Customer shall be subject to a Withdrawal Penalty if it withdraws its Interconnection Request or is deemed withdrawn, or the Generating Facility does not otherwise reach Commercial Operation unless: (1) the withdrawal does not have a material impact on the cost or timing of any Interconnection Request in the same Cluster; (2) Interconnection Customer withdraws after receiving Interconnection Customer's most recent Cluster Restudy Report and the Network Upgrade costs assigned to the Interconnection Request identified in that report have increased by more than twenty-five percent (25%) compared to costs identified in Interconnection Customer's preceding Cluster Study Report or Cluster Restudy Report; or (3) Interconnection Customer withdraws after receiving Interconnection Customer's Interconnection Facilities Study Report and the Network Upgrade costs assigned to the Interconnection Request identified in that report have increased by more than one hundred percent (100%) compared to costs identified in the Cluster Study Report or Cluster Restudy Report.

3.7.1.1 Calculation of the Withdrawal Penalty.

If Interconnection Customer withdraws its Interconnection Request or is deemed withdrawn prior to the commencement of the initial Cluster Study, Interconnection Customer shall not be subject to a Withdrawal Penalty. If Interconnection Customer withdraws, is deemed withdrawn, or otherwise does not reach Commercial Operation at any point after the commencement of the initial Cluster Study, that Interconnection Customer's Withdrawal Penalty will be the greater of: (1) Interconnection Customer's study deposit required under Section 3.1.1.1 of this LGIP; or (2) as follows in (a)–(d):

(a) If Interconnection Customer withdraws or is deemed withdrawn during the Cluster Study or after receipt of a Cluster Study Report, but prior to commencement of the Cluster Restudy or Interconnection Facilities Study if no Cluster Restudy is required, Interconnection Customer shall be charged two (2) times its actual allocated cost of all studies performed for Interconnection Customers in the Cluster up until that point in the Interconnection Study process.

(b) If Interconnection Customer withdraws or is deemed withdrawn during the Cluster Restudy or after receipt of any applicable restudy reports issued pursuant to Section 7.5 of this LGIP, but prior to commencement of the Interconnection Facilities Study, Interconnection Customer shall be charged five percent (5%) its estimated Network Upgrade costs.

(c) If Interconnection Customer withdraws or is deemed withdrawn during the Interconnection Facilities Study, after receipt of the Interconnection Facilities Study Report issued pursuant to Section 8.3 of this LGIP, or after receipt of the draft LGIA but before Interconnection Customer has executed an LGIA or has requested that its LGIA be filed unexecuted, and has satisfied the other requirements described in Section 11.3 of this LGIP (i.e., Site Control demonstration, LGIA Deposit, reasonable evidence of one or more milestones in the development of the Generating Facility), Interconnection Customer shall be charged ten percent (10%) its estimated Network Upgrade costs.

(d) If Interconnection Customer has executed an LGIA or has requested that its LGIA be filed unexecuted and has satisfied the other requirements described in Section 11.3 of this LGIP (i.e., Site Control demonstration, LGIA Deposit, reasonable evidence of one or more milestones in the development of the Generating Facility) and subsequently withdraws its Interconnection Request or if Interconnection Customer's Generating Facility otherwise does not reach Commercial Operation, that Interconnection Customer's Withdrawal Penalty shall be twenty percent (20%) its estimated Network Upgrade costs.

3.7.1.2 Distribution of the Withdrawal Penalty.

3.7.1.2.1 Initial Distribution of Withdrawal Penalties Prior to Assessment of Network Upgrade Costs Previously Shared with Withdrawn Interconnection Customers in the Same Cluster.

For a single Cluster, Transmission Provider shall hold all Withdrawal Penalty funds until all Interconnection Customers in that Cluster have either: (1) withdrawn or been deemed withdrawn; (2) executed an LGIA; or (3) requested an LGIA to be filed unexecuted. Any Withdrawal Penalty funds collected from the Cluster shall first be used to fund studies conducted under the Cluster Study Process for Interconnection Customers in the same Cluster that have executed the LGIA or requested the LGIA to be filed unexecuted. Next, after the Withdrawal Penalty funds are applied to relevant study costs in the same Cluster, Transmission Provider will apply the remaining Withdrawal Penalty funds to reduce net increases, for Interconnection Customers in the same Cluster, in Interconnection Customers' Network Upgrade cost assignment and associated financial security requirements under

Article 11.5 of the pro forma LGIA attributable to the impacts of withdrawn Interconnection Customers that shared an obligation with the remaining Interconnection Customers to fund a Network Upgrade, as described in more detail in Sections 3.7.1.2.3 and 3.7.1.2.4. The total amount of funds used to fund these studies under the Cluster Study Process or those applied to any net increases in Network Upgrade costs for Interconnection Customers in the same Cluster shall not exceed the total amount of Withdrawal Penalty funds collected from the Cluster.

Withdrawal Penalty funds shall first be applied as a refund to invoiced study costs for Interconnection Customers in the same Cluster that did not withdraw within thirty (30) Calendar Days of such Interconnection Customers executing their LGIA or requesting to have their LGIA filed unexecuted. Distribution of Withdrawal Penalty funds within one specific Cluster for study costs shall not exceed the total actual Cluster Study Process costs for the Cluster. Withdrawal Penalty funds applied to study costs shall be allocated within the same Cluster to Interconnection Customers in a manner consistent with Transmission Provider's method in Section 13.3 of this LGIP for allocating the costs of Interconnection Studies conducted on a clustered basis. Transmission Provider shall post the balance of Withdrawal Penalty funds held by Transmission Provider but not yet dispersed on its OASIS site and update this posting on a quarterly basis.

If an Interconnection Customer withdraws after it executes, or requests the unexecuted filing of, its LGIA, Transmission Provider shall first apply such Interconnection Customer's Withdrawal Penalty funds to any restudy costs required due to Interconnection Customer's withdrawal as a credit to as-yet-to be

invoiced study costs to be charged to the remaining Interconnection Customers in the same Cluster in a manner consistent with Transmission Provider's method in Section 13.3 of this LGIP for allocating the costs of Interconnection Studies conducted on a clustered basis. Distribution of the Withdrawal Penalty funds for such restudy costs shall not exceed the total actual restudy costs.

3.7.1.2.2 Assessment of Network Upgrade Costs Previously Shared with Withdrawn Interconnection Customers in the Same Cluster.

If Withdrawal Penalty funds remain for the same Cluster after the Withdrawal Penalty funds are applied to relevant study costs, Transmission Provider will determine if the withdrawn Interconnection Customers, at any point in the Cluster Study Process, shared cost assignment for one or more Network Upgrades with any remaining Interconnection Customers in the same Cluster based on the Cluster Study Report, Cluster Restudy Report(s), Interconnection Facilities Study Report, and any subsequent issued restudy report issued for the Cluster.

In Section 3.7.1.2 of this LGIP, shared cost assignments for Network Upgrades refers to the cost of Network Upgrades still needed for the same Cluster for which an Interconnection Customer, prior to withdrawing its Interconnection Request, shared the obligation to fund along with Interconnection Customers that have executed an LGIA, or requested the LGIA to filed unexecuted.

If Transmission Provider's assessment determines that there are no shared cost assignments for any Network Upgrades in the same Cluster for the withdrawn Interconnection Customer, or determines that the

withdrawn Interconnection Customer's withdrawal did not cause a net increase in the shared cost assignment for any remaining Interconnection Customers' Network Upgrade(s) in the same Cluster, Transmission Provider will return any remaining Withdrawal Penalty funds to the withdrawn Interconnection Customer(s). Such remaining Withdrawal Penalty funds will be returned to withdrawn Interconnection Customers based on the proportion of each withdrawn Interconnection Customer's contribution to the total amount of Withdrawal Penalty funds collected for the Cluster (i.e., the total amount before the initial disbursement required under Section 3.7.1.2.1 of this LGIP). Transmission Provider must make such disbursement within sixty (60) Calendar Days of the date on which all Interconnection Customers in the same Cluster have either: (1) withdrawn or been deemed withdrawn; (2) executed an LGIA; or (3) requested an LGIA to be filed unexecuted. For the withdrawn Interconnection Customers that Transmission Provider determines have caused a net increase in the shared cost assignment for one or more Network Upgrade(s) in the same Cluster under Section 3.7.1.2.3(a) of this LGIP, Transmission Provider will determine each such withdrawn Interconnection Customers' Withdrawal Penalty funds remaining balance that will be applied toward net increases in Network Upgrade shared costs calculated under Sections 3.7.1.2.3(a) and 3.7.1.2.3(b) of this LGIP based on each such withdrawn Interconnection Customer's proportional contribution to the total amount of Withdrawal Penalty funds collected for the same Cluster (i.e., the total amount before the initial disbursement requirement under Section 3.7.1.2.1 of this LGIP).

If Transmission Provider's assessment determines that there are shared cost assignments for Network Upgrades in the same Cluster, Transmission Provider will calculate the remaining Interconnection

Customers' net increase in cost assignment for Network Upgrades due to a shared cost assignment for Network Upgrades with the withdrawn Interconnection Customer and distribute Withdrawal Penalty funds as described in Section 3.7.1.2.3, depending on whether the withdrawal occurred before the withdrawing Interconnection Customer executed the LGIA (or filed unexecuted), as described in Section 3.7.1.2.3(a) of this LGIP, or after such execution (or filing unexecuted) of an LGIA, as described in Section 3.7.1.2.3(b) of this LGIP.

As discussed in Section 3.7.1.2.4 of this LGIP, Transmission Provider will amend executed (or filed unexecuted) LGIAs of the remaining Interconnection Customers in the same Cluster to apply the remaining Withdrawal Penalty funds to reduce net increases in Interconnection Customers' Network Upgrade cost assignment and associated financial security requirements under Article 11.5 of the pro forma LGIA attributable to the impacts of withdrawn Interconnection Customers on Interconnection Customers remaining in the same Cluster that had a shared cost assignment for Network Upgrades with the withdrawn Interconnection Customers.

3.7.1.2.3 Impact Calculations.

3.7.1.2.3(a) Impact Calculation for Withdrawals During the Cluster Study Process.

If an Interconnection Customer withdraws before it executes, or requests the unexecuted filing of, its LGIA, Transmission Provider will distribute in the following manner the Withdrawal Penalty funds to reduce the Network Upgrade cost impact on the remaining Interconnection Customers in the same Cluster who had a shared cost assignment for a

Network Upgrade with the withdrawn Interconnection Customer.

To calculate the reduction in the remaining Interconnection Customers' net increase in Network Upgrade costs and associated financial security requirements under Article 11.5 of the pro forma LGIA, Transmission Provider will determine the financial impact of a withdrawing Interconnection Customer on other Interconnection Customers in the same Cluster that shared an obligation to fund the same Network Upgrade(s). Transmission Provider shall calculate this financial impact once all Interconnection Customers in the same Cluster either: (1) have withdrawn or have been deemed withdrawn; (2) executed an LGIA; or (3) request an LGIA to be filed unexecuted. Transmission Provider will perform the financial impact calculation using the following steps.

First, Transmission Provider must determine which withdrawn Interconnection Customers shared an obligation to fund Network Upgrades with Interconnection Customers from the same Cluster that have LGIAs that are executed or have been requested to be filed unexecuted. Next, Transmission Provider shall perform the calculation of the financial impact of a withdrawal on another Interconnection Request in the same Cluster by performing a comparison of the Network Upgrade cost estimates between each of the following:

(1) Cluster Study phase to Cluster Restudy phase (if Cluster Restudy was necessary);

(2) Cluster Restudy phase to Interconnection Facilities Study phase (if a Cluster Restudy was necessary);

(3) Cluster Study phase to Interconnection Facilities Study phase (if no Cluster Restudy was performed);

(4) Interconnection Facilities Study phase to any subsequent restudy that was performed before the execution or filing of an unexecuted LGIA;

(5) the restudy to the executed, or filed unexecuted, LGIA (if a restudy was performed after the Interconnection Facilities Study phase and before the execution or filing of an unexecuted LGIA).

If, based on the above calculations, Transmission Provider determines:

(i) that the costs assigned to an Interconnection Customer in the same Cluster for Network Upgrades that a withdrawn Interconnection Customer shared cost assignment for increased between any two studies, and

(ii) after the impacted Interconnection Customer's LGIA was executed or filed unexecuted, Interconnection Customer's cost assignment for the relevant Network Upgrade is greater than it was prior to the withdrawal of Interconnection Customer in the same Cluster that shared cost assignment for the Network Upgrade,

then Transmission Provider shall apply the withdrawn Interconnection Customer's Withdrawal Penalty funds that has not already been applied to study costs in the amount of the financial impact by reducing, in the same Cluster, the remaining Interconnection

Customer's Network Upgrade costs and associated financial security requirements under Article 11.5 of the pro forma LGIA.

If Transmission Provider determines that more than one Interconnection Customer in the same Cluster was financially impacted by the same withdrawn Interconnection Customer, Transmission Provider will apply the relevant withdrawn Interconnection Customer's Withdrawal Penalty funds that has not already been applied to study costs to reduce the financial impact to each Interconnection Customer based on each Interconnection Customer's proportional share of the financial impact, as determined by either the Proportional Impact Method if it is a System Network Upgrade or on a per capita basis if it is a Substation Network Upgrade, as described under Section 4.2.1 of this LGIP.

3.7.1.2.3(b) Impact Calculation for Withdrawals in the Same Cluster After the Cluster Study Process.

If an Interconnection Customer withdraws after it executes, or requests the unexecuted filing of, its LGIA, Transmission Provider will distribute in the following manner the remaining Withdrawal Penalty funds to reduce the Network Upgrade cost impact on the remaining Interconnection Customers in the same Cluster who had a shared cost assignment with the withdrawn Interconnection Customer for one or more Network Upgrades.

Transmission Provider will determine the financial impact on the remaining Interconnection Customers in the same Cluster within thirty (30) Calendar Days after the withdrawal occurs. Transmission Provider will determine that financial impact by comparing the Network Upgrade cost funding obligations

Interconnection Customers shared with the withdrawn Interconnection Customer before the withdrawal of Interconnection Customer and after the withdrawal of Interconnection Customer. If that comparison indicates an increase in Network Upgrade costs for an Interconnection Customer, Transmission Provider shall apply the withdrawn Interconnection Customer's Withdrawal Penalty funds to the increased costs each impacted Interconnection Customer in the same Cluster experienced associated with such Network Upgrade(s) in proportion to each Interconnection Customer's increased cost assignment, as determined by Transmission Provider.

3.7.1.2.4 Amending LGIA to Apply Reductions to Interconnection Customer's Assigned Network Upgrade Costs and Associated Financial Security Requirement with Respect to Withdrawals in the Same Cluster.

Within thirty (30) Calendar Days of all Interconnection Customers in the same Cluster having: (1) withdrawn or been deemed withdrawn; (2) executed an LGIA; or (3) requested an LGIA to be filed unexecuted, Transmission Provider must perform the calculations described in Section 3.7.1.2.3(a) of this LGIP and provide such Interconnection Customers with an amended LGIA that provides the reduction in Network Upgrade cost assignment and associated reduction to Interconnection Customer's financial security requirements, under Article 11.5 of the pro forma LGIA, due from Interconnection Customer to Transmission Provider.

Where an Interconnection Customer executes the LGIA (or requests the filing of an unexecuted LGIA) and is later withdrawn or its LGIA is terminated, Transmission Provider must, within thirty (30) Calendar Days of such withdrawal or termination,

perform the calculations described in Section 3.7.1.2.3(b) of this LGIP and provide such Interconnection Customers in the same Cluster with an amended LGIA that provides the reduction in Network Upgrade cost assignment and associated reduction to Interconnection Customer's financial security requirements, under Article 11.5 of the pro forma LGIA, due from Interconnection Customer to Transmission Provider.

Any repayment by Transmission Provider to Interconnection Customer under Article 11.4 of the pro forma LGIA of amounts advanced for Network Upgrades after the Generating Facility achieves Commercial Operation shall be limited to Interconnection Customer's total amount of Network Upgrade costs paid and associated financial security provided to Transmission Provider under Article 11.5 of the pro forma LGIA.

3.7.1.2.5

Final Distribution of Withdrawal Penalty Funds.

If Withdrawal Penalty funds remain for the Cluster after the Withdrawal Penalty funds are applied to relevant study costs and net increases in shared cost assignments for Network Upgrades to remaining Interconnection Customers, Transmission Provider will return any remaining Withdrawal Penalty funds to the withdrawn Interconnection Customers in the same Cluster net of the amount of each withdrawn Interconnection Customer's Withdrawal Penalty funds applied to study costs and net increases in shared cost assignments for Network Upgrades to remaining Interconnection Customers.

3.8 Identification of Contingent Facilities.

Transmission Provider shall post in this section a method for identifying the Contingent Facilities to be provided to Interconnection Customer at the

conclusion of the Cluster Study and included in Interconnection Customer's Large Generator Interconnection Agreement. The method shall be sufficiently transparent to determine why a specific Contingent Facility was identified and how it relates to the Interconnection Request. Transmission Provider shall also provide, upon request of Interconnection Customer, the estimated Interconnection Facility and/or Network Upgrade costs and estimated in-service completion time of each identified Contingent Facility when this information is readily available and not commercially sensitive.

3.8 Identification of Contingent Facilities. The Cluster Study shall identify any Contingent Facilities that may impact the results of the Cluster Study and explain how each Contingent Facility was identified and how it relates to the Interconnection Request.

3.8.1 Method for Identifying Contingent Facilities

The following process, outlined below, is to be followed by Transmission Provider to identify Contingent Facilities, if any, upon which the Interconnection Customer's costs, timing, and study findings are dependent. Any Contingent Facilities that are identified will be provided to Interconnection Customer within the LGIP Interconnection Cluster Study.

- i) During each Cluster Study, Transmission Provider will review higher queued interconnection requests to determine whether any of the request(s) have unbuilt Interconnection Facilities and/or Network Upgrades that may be necessary to provide the Interconnection Customer's requested interconnection. Such unbuilt facilities and/or upgrades will be noted as potential Contingent Facilities and used in various impact studies (as described in Section 3.8.1.ii).
- ii) Near completion of the Cluster Study, the Transmission Provider will finalize the list of Contingent Facilities by removing each previously identified potential Contingent Facility and, if applicable, any Affected System facility modifications from the study cases, and perform steady state, short circuit, voltage stability, and/or transient stability analyses to determine if the Transmission System is unable to demonstrate acceptable system performance. Acceptable system performance, as used in this context for purposes of identifying Contingent Facilities, is determined during the analysis by meeting the performance requirements outlined in Table 1 of NERC standard TPL-001-4. The studied system shall remain stable, cascading and uncontrolled islanding shall not occur and applicable facility ratings shall not be exceeded during pre and post contingency for all study cases/

seasonal models. Acceptable system performance shall also mean that system operating limits shall not be exceeded for all pre and post contingency scenarios and the system must demonstrate compliance with the “SPP 2019 TPL-001-4 Planning Assessment Scope” (or its annual successor), which requires pre-contingency voltage between .95 and 1.05 per unit of nominal, post-contingency voltage between .90 and 1.05 per unit of nominal, no post-contingency voltage deviation greater than .10 per unit, and no transmission lines/ conductors are overloaded (greater than 100% of the modeled line rating) during pre and post-contingency scenarios.

- iii) If the Transmission System fails to demonstrate acceptable system performance (based on the analysis performed for each potential Contingent Facility as described in Section 3.8.1.ii), the potential contingent facility will be confirmed as a Contingent Facility. Potential contingent facilities that are associated with communications, protection, and automation systems necessary for the operation of the Generating Facility or associated with delivery of its output, are also deemed Contingent Facilities.
- iv) In the Cluster Study report, Transmission Provider will list each Contingent Facility and why it was identified as such.

3.8.2. Estimates Available for Contingent Facilities. Upon request of the Interconnection Customer, the Transmission Provider shall provide the estimated costs of Interconnection Facilities and/or Network Upgrades and estimated in-service completion times of each Contingent Facility identified in the Cluster Study performed pursuant to Section 7.3 of the LGIP, if, and to the extent, Transmission Provider determines such information is readily available and not commercially sensitive.

3.8.3 Inclusion of Contingent Facilities in LGIA. Any Contingent Facilities identified for Interconnection Customer at the conclusion of a Cluster Study, performed pursuant to Section 7.3 of this LGIP, will subsequently be included in such Interconnection Customer’s Large Generator Interconnection Agreement, to the extent they are still applicable.

3.9 Penalties for Failure to Meet Study Deadlines.

(1) Transmission Provider shall be subject to a penalty if it fails to complete a Cluster Study, Cluster Restudy, Interconnection Facilities Study, or Affected Systems Study by the applicable deadline set forth in this LGIP. Transmission Provider must pay the penalty for each late Cluster Study, Cluster Restudy, and Interconnection Facilities Study on a pro rata basis per Interconnection Request to all Interconnection Customer(s) included in the relevant study that did not withdraw, or were not deemed withdrawn, from Transmission Provider's interconnection queue before the missed study deadline, in proportion to each Interconnection Customer's final study cost. Transmission Provider must pay the penalty for a late Affected Systems Study on a pro rata basis per interconnection request to all Affected System Interconnection Customer(s) included in the relevant Affected System Study that did not withdraw, or were not deemed withdrawn, from the host transmission provider's interconnection queue before the missed study deadline, in proportion to each Interconnection Customer's final study cost. The study delay penalty for each late study shall be distributed no later than forty-five (45) Calendar Days after the late study has been completed.

(2) For penalties assessed in accordance with this Section, the penalty amount will be equal to: \$1,000 per Business Day for delays of Cluster Studies beyond the applicable deadline set forth in this LGIP; \$2,000 per Business Day for delays of Cluster Restudies beyond the applicable deadline set forth in this LGIP; \$2,000 per Business Day for delays of Affected System Studies beyond the applicable deadline set forth in this LGIP; and \$2,500 per Business Day for delays of Interconnection Facilities Studies beyond the applicable deadline set forth in this LGIP. The total amount of a penalty assessed under this Section shall not exceed: (a) one hundred percent (100%) of the initial study deposit(s) received for all of the Interconnection Requests in the Cluster for Cluster Studies and Cluster Restudies; (b) one hundred percent (100%) of the initial study deposit received for the single Interconnection Request in the study for Interconnection Facilities Studies; and (c) one hundred percent (100%) of the study deposit(s) that Transmission Provider collects for conducting the Affected System Study.

(3) Transmission Provider may appeal to the Commission any penalties imposed under this Section. Any such appeal must be filed no later than forty-five (45) Calendar Days after the late study has been completed. While an appeal to the Commission is pending, Transmission Provider shall

remain liable for the penalty, but need not distribute the penalty until forty-five (45) Calendar Days after (1) the deadline for filing a rehearing request has ended, if no requests for rehearing of the appeal have been filed, or (2) the date that any requests for rehearing of the Commission's decision on the appeal are no longer pending before the Commission. The Commission may excuse Transmission Provider from penalties under this Section for good cause.

(4) No penalty will be assessed under this Section where a study is delayed by ten (10) Business Days or less. If the study is delayed by more than ten (10) Business Days, the penalty amount will be calculated from the first Business Day Transmission Provider misses the applicable study deadline.

(5) If (a) Transmission Provider needs to extend the deadline for a particular study subject to penalties under this Section and (b) all Interconnection Customers or Affected System Interconnection Customers included in the relevant study mutually agree to such an extension, the deadline for that study shall be extended thirty (30) Business Days from the original deadline. In such a scenario, no penalty will be assessed for Transmission Provider missing the original deadline.

(6) No penalties shall be assessed until the third Cluster Study cycle (including any Transitional Cluster Study cycle, but not Transitional Serial Interconnection Facilities Studies) after the Commission-approved effective date of Transmission Provider's filing made in compliance with the Final Rule in Docket No. RM22-14-000.

(7) Transmission Provider must maintain on its OASIS or its public website summary statistics related to penalties assessed under this Section, updated quarterly. For each calendar quarter, Transmission Provider must calculate and post (1) the total amount of penalties assessed under this Section during the previous reporting quarter and (2) the highest penalty assessed under this Section paid to a single Interconnection Customer or Affected System Interconnection Customer during the previous reporting quarter. Transmission Provider must post on its OASIS or its website these penalty amounts for each calendar quarter within thirty (30) Calendar Days of the end of the calendar quarter. Transmission Provider must maintain the

quarterly measures posted on its OASIS or its website for three (3) calendar years with the first required posting to be the third Cluster Study cycle (including any Transitional Cluster Study cycle, but not Transitional Serial Interconnection Facilities Studies) after Transmission Provider transitions to the Cluster Study Process.

Section 4. Interconnection Request Evaluation Process.

an Interconnection Customer has submitted a valid Interconnection Request pursuant to Section 3.4 of this LGIP, such Interconnection Request shall become part of Transmission Provider's interconnection queue for further processing pursuant to the following procedures.

4.1 Queue Position.

4.1.1 Assignment of Queue Position.

Transmission Provider shall assign a Queue Position as follows: the Queue Position within the queue shall be assigned based upon the date and time of receipt of all items required pursuant to the provisions of Section 3.4 of this LGIP. All Interconnection Requests submitted and validated in a single Cluster Request Window shall be considered equally queued.

4.1.2 Higher Queue Position.

A higher Queue Position assigned to an Interconnection Request is one that has been placed "earlier" in the queue in relation to another Interconnection Request that is assigned a lower Queue Position. All requests studied in a single Cluster shall be considered equally queued. Interconnection Customers that are part of Clusters initiated earlier in time than an instant queue shall be considered to have a higher Queue Position than Interconnection Customers that are part of Clusters initiated later than an instant queue.

4.2. General Study Process.

Interconnection Studies performed within the Cluster Study Process shall be conducted in such a manner to ensure the efficient implementation of the

applicable regional transmission expansion plan in light of the Transmission System's capabilities at the time of each study and consistent with Good Utility Practice.

Transmission Provider may use subgroups in the Cluster Study Process. In all instances in which Transmission Provider elects to use subgroups in the Cluster Study Process, Transmission Provider must publish the criteria used to define and determine subgroups on its OASIS or public website.

4.2.1 Cost Allocation for Interconnection Facilities and Network Upgrades.

(1) For Network Upgrades identified in Cluster Studies, Transmission Provider shall calculate each Interconnection Customer's share of the costs as follows:

(a) Substation Network Upgrades, including all switching stations, shall be allocated first per capita to Interconnection Facilities interconnecting to the substation at the same voltage level, and then per capita to each Generating Facility sharing the Interconnection Facility.

(b) System Network Upgrades shall be allocated based on the proportional impact of each individual Generating Facility in the Cluster Study on the need for a specific System Network Upgrade. The proportional impact of such Network Upgrades shall be calculated as follows: All transmission lines and transformers identified as Network Upgrades shall be allocated using distribution factor or similar analysis. Voltage support related Network Upgrades shall be allocated using a voltage impact analysis which will identify each Generating Facility's contribution to the voltage violation. Network Upgrades associated with upgrading existing breakers due to short circuit current exceeding breaker capability shall be allocated proportionally based on the short circuit current contribution of each request.

(c) An Interconnection Customer that funds Substation Network Upgrades and/or System Network Upgrades shall be entitled to transmission credits as provided in Article 11.4 of the LGIA.

(2) The costs of any needed Interconnection Facilities identified in the Cluster Study Process will be directly assigned to Interconnection Customer(s) using such facilities. Where Interconnection Customers in the Cluster agree to share Interconnection Facilities, the cost of such Interconnection Facilities shall be allocated based on the number of Generating Facilities sharing use of such Interconnection Facilities on a per capita basis (i.e., on a per Generating Facility basis), unless Parties mutually agree to a different cost sharing arrangement.

4.3 Transferability of Queue Position.

An Interconnection Customer may transfer its Queue Position to another entity only if such entity acquires the specific Generating Facility identified in the Interconnection Request and the Point of Interconnection does not change.

4.4 Modifications.

Interconnection Customer shall submit to Transmission Provider, in writing, modifications to any information provided in the Interconnection Request. Interconnection Customer shall retain its Queue Position if the modifications are in accordance with Sections 4.4.1, 4.4.2, or 4.4.5 of this LGIP, or are determined not to be Material Modifications pursuant to Section 4.4.3 of this LGIP.

Notwithstanding the above, during the course of the Interconnection Studies, either Interconnection Customer or Transmission Provider may identify changes to the planned interconnection that may improve the costs and benefits (including reliability) of the interconnection, and the ability of the proposed change to accommodate the Interconnection Request. To the extent the identified changes are acceptable to Transmission Provider and

Interconnection Customer, such acceptance not to be unreasonably withheld, Transmission Provider shall modify the Point of Interconnection prior to return of the executed Cluster Study Agreement, and Interconnection Customer shall retain its Queue Position.

4.4.1 Prior to the return of the executed Cluster Study Agreement to Transmission Provider, modifications permitted under this Section shall include specifically: (a) a decrease of up to sixty percent (60%) of electrical output (MW) of the proposed project, through either (1) a decrease in plant size or (2) a decrease in Interconnection Service level (consistent with the process described in Section 3.1 of this LGIP) accomplished by applying Transmission Provider-approved injection-limiting equipment; (b) modifying the technical parameters associated with the Large Generating Facility technology or the Large Generating Facility step-up transformer impedance characteristics; and (c) modifying the interconnection configuration. For plant increases, the incremental increase in plant output will go in the next Cluster Request Window for the purposes of cost allocation and study analysis.

4.4.2 Prior to the return of the executed Interconnection Facilities Study Agreement to Transmission Provider, the modifications permitted under this Section shall include specifically: (a) additional fifteen percent (15%) decrease of electrical output of the proposed project through either (1) a decrease in plant size (MW) or (2) a decrease in Interconnection Service level (consistent with the process described in Section 3.1) accomplished by applying Transmission Provider-approved injection-limiting equipment; (b) Large Generating Facility technical parameters associated with modifications to Large Generating Facility technology and transformer impedances; provided, however, the incremental costs associated with those modifications are the responsibility of the requesting Interconnection Customer; and (c) a Permissible Technological Advancement for the Large Generating Facility after the submission of the Interconnection Request. Section 4.4.6 of this LGIP specifies a separate technological change procedure including the requisite information and process that will be followed to assess whether Interconnection Customer's proposed technological advancement under Section 4.4.2(c) of this LGIP is a Material

Modification. Section 1 of this LGIP contains a definition of Permissible Technological Advancement.

4.4.3 Prior to making any modification other than those specifically permitted by Sections 4.4.1, 4.4.2, and 4.4.5 of this LGIP, Interconnection Customer may first request that Transmission Provider evaluate whether such modification is a Material Modification. In response to Interconnection Customer's request, Transmission Provider shall evaluate the proposed modifications prior to making them and inform Interconnection Customer in writing of whether the modifications would constitute a Material Modification. Any change to the Point of Interconnection, except those deemed acceptable under Sections 3.1.2 or 4.4 of this LGIP or so allowed elsewhere, shall constitute a Material Modification. Interconnection Customer may then withdraw the proposed modification or proceed with a new Interconnection Request for such modification. Transmission Provider shall study the addition of a Generating Facility that includes at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect the proposed charging behavior of the Generating Facility as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions.

4.4.3.1 Section Omitted.

4.4.4 Upon receipt of Interconnection Customer's request for modification permitted under this Section 4.4 of this LGIP, Transmission Provider shall commence and perform any necessary additional studies as soon as practicable, but in no event shall Transmission Provider commence such studies later than thirty (30) Calendar Days after receiving notice of Interconnection Customer's request. Any additional studies resulting from such modification shall be done at Interconnection Customer's cost. Any such request for modification of the Interconnection Request must be accompanied

by any resulting updates to the models described in Attachment A to Appendix 1 of this LGIP.

4.4.5 Extensions of less than three (3) cumulative years in the Commercial Operation Date of the Large Generating Facility to which the Interconnection Request relates are not material and should be handled through construction sequencing. For purposes of this section, the Commercial Operation Date reflected in the initial Interconnection Request shall be used to calculate the permissible extension prior to Interconnection Customer executing an LGIA or requesting that the LGIA be filed unexecuted. After an LGIA is executed or requested to be filed unexecuted, the Commercial Operation Date reflected in the LGIA shall be used to calculate the permissible extension. Such cumulative extensions may not exceed three years including both extensions requested after execution of the LGIA by Interconnection Customer or the filing of an unexecuted LGIA by Transmission Provider and those requested prior to execution of the LGIA by Interconnection Customer or the filing of an unexecuted LGIA by Transmission Provider.

4.4.6 Technological Change Procedure. In accordance with Section 4.4.2, at any time prior to the execution of the Interconnection Facilities Study Agreement the Interconnection Customer may submit a request if it seeks to incorporate technological advancements into its proposed Large Generating Facility. The technological advancement request should include an analysis and other supporting information to explain how it affects its original Interconnection Request, including a demonstration that (i) the technological advancement request will result in equal to or better than the electrical performance expected prior to the technology change, and (ii) would not cause any reliability standard criteria (including any applicable TPL or PRC standards), short circuit capability limits, steady-state thermal and voltage limits, or dynamic system stability and response impacts. If the Transmission Provider determines that additional studies are needed to evaluate whether a technological advancement is a material modification, a deposit in the amount of \$10,000 will be required to reimburse the Transmission Provider for the time and effort needed to complete

the study. The Transmission Provider shall describe to the Interconnection Customer any costs incurred to conduct any necessary additional studies, provide its costs to the Interconnection Customer, and either refund any overage or charge for any shortage for costs that exceed the deposit amount. If it is determined that the technological advancement request does not change the specifications for the Large Generating Facility submitted by the Interconnection Customer to the Transmission Provider, the request shall be deemed a Permissible Technological Advancement and no further action shall be required. If the study results changes the submitted specifications, the request to change the Large Generating Facility's technology shall be deemed a Material Modification in accordance with Section 4.4.3. The Transmission Provider will make a determination regarding the proposed technological advancement request and provide a written explanation within thirty (30) days of receiving the request.

Section 5. Procedures for Interconnection Requests Submitted Prior to Effective Date of the Cluster Study Revisions

5.1 Procedures for Transitioning to the Cluster Study Process.

5.1.1 Any Interconnection Customer assigned a Queue Position as of thirty (30) Calendar Days after May 16, 2024 (the filing date of this LGIP) shall retain that Queue Position subject to the requirements in Sections 5.1.1.1 and 5.1.1.2 of this LGIP. Any Interconnection Customer that fails to meet these requirements shall have its Interconnection Request deemed withdrawn by Transmission Provider pursuant to Section 3.7 of this LGIP. In such case, Transmission Provider shall not assess Interconnection Customer any Withdrawal Penalty.

Any Interconnection Customer that has received a final Interconnection Facilities Study Report before the commencement of the studies under the transition process set forth in this Section shall be tendered an LGIA pursuant to Section 11 of this LGIP, and shall not be required to enter this transition process.

5.1.1.1 Transitional Serial Study.

An Interconnection Customer that has been tendered an Interconnection Facilities Study Agreement as of thirty (30) Calendar Days after May 16, 2024 (the filing date of this LGIP) may opt to proceed with an Interconnection Facilities Study. Transmission Provider shall tender each eligible Interconnection Customer a Transitional Serial Interconnection Facilities Study Agreement, in the form of Appendix 8 to this LGIP, no later than the Commission-approved effective date of this LGIP. Transmission Provider shall proceed with the Interconnection Facilities Study, provided that Interconnection Customer: (1) meets each of the following requirements; and (2) executes the Transitional Serial Interconnection Facilities Study Agreement within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP. If an eligible Interconnection Customer does not meet these requirements, its Interconnection Request shall be deemed withdrawn without penalty. Transmission Provider must commence the Transitional Serial Interconnection Facilities Study at the conclusion of this sixty (60) Calendar Day period. Transitional Serial Interconnection Facilities Study costs shall be allocated according to the method described in Section 13.3 of this LGIP.

All of the following must be included when an Interconnection Customer returns the Transitional Serial Interconnection Facilities Study Agreement:

(1) A deposit equal to one hundred percent (100%) of the costs identified for Transmission Provider's Interconnection Facilities and Network Upgrades in Interconnection Customer's system impact study report. If Interconnection Customer does not withdraw, the deposit shall be trued up to actual costs once they are known and applied to future construction costs described in Interconnection Customer's eventual

LGIA. Any amounts in excess of the actual construction costs shall be returned to Interconnection Customer within thirty (30) Calendar Days of the issuance of a final invoice for construction costs, in accordance with Article 12.2 of the pro forma LGIA. If Interconnection Customer withdraws or otherwise does not reach Commercial Operation, Transmission Provider shall refund the remaining deposit after the final invoice for study costs and Transitional Withdrawal Penalty is settled. The deposit shall be in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider, where cash deposits shall be treated according to Section 3.7 of this LGIP.

(2) Exclusive Site Control for 100% of the proposed Generating Facility.

Transmission Provider shall conduct each Transitional Serial Interconnection Facilities Study and issue the associated Transitional Serial Interconnection Facilities Study Report within one hundred fifty (150) Calendar Days of the Commission-approved effective date of this LGIP.

After Transmission Provider issues each Transitional Interconnection Facilities Study Report, Interconnection Customer shall proceed pursuant to Section 11 of this LGIP. If Interconnection Customer withdraws its Interconnection Request or if Interconnection Customer's Generating Facility otherwise does not reach Commercial Operation, a Transitional Withdrawal Penalty shall be imposed on Interconnection Customer equal to nine (9) times Interconnection Customer's total study cost incurred since entering Transmission Provider's interconnection

queue (including the cost of studies conducted under Section 5 of this LGIP).

5.1.1.2

Transitional Cluster Study.

An Interconnection Customer with an assigned Queue Position as of thirty (30) Calendar Days after May 16, 2024 (the filing date of this LGIP) may opt to proceed with a Transitional Cluster Study. Transmission Provider shall tender each eligible Interconnection Customer a Transitional Cluster Study Agreement, in the form of Appendix 7 to this LGIP, no later than the Commission-approved effective date of this LGIP. Transmission Provider shall proceed with the Transitional Cluster Study that includes each Interconnection Customer that: (1) meets each of the following requirements listed as (1)–(3) in this section; and (2) executes the Transitional Cluster Study Agreement within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP. All Interconnection Requests that enter the Transitional Cluster Study shall be considered to have an equal Queue Position that is lower than Interconnection Customer(s) proceeding with Transitional Serial Interconnection Facilities Study. If an eligible Interconnection Customer does not meet these requirements, its Interconnection Request shall be deemed withdrawn without penalty. Transmission Provider must commence the Transitional Cluster Study at the conclusion of this sixty (60) Calendar Day period. All identified Transmission Provider's Interconnection Facilities and Network Upgrade costs shall be allocated according to Section 4.2.1 of this LGIP. Transitional Cluster Study costs shall be allocated according to the method described in Section 13.3 of this LGIP.

Interconnection Customer may make a one-time extension to its requested Commercial Operation Date upon entry into the Transitional Cluster Study, where

any such extension shall not result in a Commercial Operation Date later than December 31, 2027.

All of the following must be included when an Interconnection Customer returns the Transitional Cluster Study Agreement:

(1) A selection of either Energy Resource Interconnection Service or Network Resource Interconnection Service.

(2) A deposit of five million dollars (\$5,000,000) in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider, where cash deposits will be treated according to Section 3.7 of this LGIP. If Interconnection Customer does not withdraw, the deposit shall be reconciled with and applied towards future construction costs described in the LGIA. Any amounts in excess of the actual construction costs shall be returned to Interconnection Customer within thirty (30) Calendar Days of the issuance of a final invoice for construction costs, in accordance with Article 12.2 of the pro forma LGIA. If Interconnection Customer withdraws or otherwise does not reach Commercial Operation, Transmission Provider must refund the remaining deposit once the final invoice for study costs and Transitional Withdrawal Penalty is settled.

(3) Exclusive Site Control for 100% of the proposed Generating Facility.

Transmission Provider shall conduct the Transitional Cluster Study and issue both an associated interim Transitional Cluster Study Report and an associated

final Transitional Cluster Study Report. The interim Transitional Cluster Study Report shall provide the following information:

- identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
- identification of any thermal overload or voltage limit violations resulting from the interconnection;
- identification of any instability or inadequately damped response to system disturbances resulting from the interconnection; and
- Transmission Provider's Interconnection Facilities and Network Upgrades that are expected to be required as a result of the Interconnection Request(s) and a non-binding, good faith estimate of cost responsibility and a non-binding, good faith estimated time to construct.

In addition to the information provided in the interim Transitional Cluster Study Report, the final Transitional Cluster Study Report shall provide a description of, estimated cost of, and schedule for construction of Transmission Provider's Interconnection Facilities and Network Upgrades required to interconnect the Generating Facility to the Transmission System that resolve issues identified in the interim Transitional Cluster Study Report.

The interim and final Transitional Cluster Study Reports shall be issued within three hundred (300) and three hundred sixty (360) Calendar Days of the

Commission-approved effective date of this LGIP, respectively, and shall be posted on Transmission Provider's OASIS consistent with the posting of other study results pursuant to Section 3.5.1 of this LGIP. Interconnection Customer shall have thirty (30) Calendar Days to comment on the interim Transitional Cluster Study Report, once it has been received.

After Transmission Provider issues the final Transitional Cluster Study Report, Interconnection Customer shall proceed pursuant to Section 11 of this LGIP. If Interconnection Customer withdraws its Interconnection Request or if Interconnection Customer's Generating Facility otherwise does not reach Commercial Operation, a Transitional Withdrawal Penalty will be imposed on Interconnection Customer equal to nine (9) times Interconnection Customer's total study cost incurred since entering Transmission Provider's interconnection queue (including the cost of studies conducted under Section 5 of this LGIP).

5.1.2 Transmission Providers with Existing Cluster Study Processes or Currently in Transition

If Transmission Provider is not conducting a transition process under Section 5.1.1, it will continue processing Interconnection Requests under its current Cluster Study Process. Within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP, Interconnection Customers that have not executed an LGIA or requested an LGIA to be filed unexecuted must meet the requirements of Sections 3.4.2, 7.5, or 8.1 of this LGIP, based on Interconnection Customer's Queue Position.

Any Interconnection Customer that fails to meet these requirements within sixty (60) Calendar Days of the Commission-approved effective date of this LGIP shall have its Interconnection Request deemed withdrawn by Transmission Provider pursuant to Section 3.7 of this LGIP. In such case, Transmission Provider shall not assess Interconnection Customer any Withdrawal Penalty.

5.2 New Transmission Provider.

If Transmission Provider transfers control of its Transmission System to a successor Transmission Provider during the period when an Interconnection Request is pending, the original Transmission Provider shall transfer to the successor Transmission Provider any amount of the deposit or payment with interest thereon that exceeds the cost that it incurred to evaluate the request for interconnection. Any difference between such net amount and the deposit or payment required by this LGIP shall be paid by or refunded to Interconnection Customer, as appropriate. The original Transmission Provider shall coordinate with the successor Transmission Provider to complete any Interconnection Study, as appropriate, that the original Transmission Provider has begun but has not completed. If Transmission Provider has tendered a draft LGIA to Interconnection Customer but Interconnection Customer has not either executed the LGIA or requested the filing of an unexecuted LGIA with FERC, unless otherwise provided, Interconnection Customer must complete negotiations with the successor Transmission Provider.

Section 6. Interconnection Information Access

6.1 Publicly Posted Interconnection Information.

Transmission Provider shall maintain and make publicly available: (1) an interactive visual representation of the estimated incremental injection capacity (in megawatts) available at each point of interconnection in Transmission Provider's footprint under N-1 conditions, and (2) a table of metrics concerning the estimated impact of a potential Generating Facility on Transmission Provider's Transmission System based on a user-specified addition of a particular number of megawatts at a particular voltage level at a particular point of interconnection. At a minimum, for each transmission facility impacted by the user-specified megawatt addition, the following information will be provided in the table: (1) the distribution factor; (2) the megawatt impact (based on the megawatt values of the proposed Generating Facility and the distribution factor); (3) the percentage impact on each impacted transmission facility (based on the megawatt values of the proposed Generating Facility and the facility rating); (4) the percentage of power flow on each impacted transmission facility before the injection of the proposed project; (5) the percentage power flow on each impacted transmission facility after the injection of the proposed Generating Facility.

These metrics must be calculated based on the power flow model of the Transmission System with the transfer simulated from each point of interconnection to the whole Transmission Provider's footprint (to approximate Network Resource Interconnection Service), and with the incremental capacity at each point of interconnection decremented by the existing and queued Generating Facilities (based on the existing or requested interconnection service limit of the generation). These metrics must be updated within thirty (30) Calendar Days after the completion of each Cluster Study and Cluster Restudy. This information must be publicly posted, without a password or a fee. The website will define all underlying assumptions, including the name of the most recent Cluster Study or Restudy used in the Base Case.

Section 7. Cluster Study

7.1 Cluster Study Agreement.

No later than five (5) Business Days after the close of a Cluster Request Window, Transmission Provider shall tender to each Interconnection Customer that submitted a valid Interconnection Request a Cluster Study Agreement in the form of Appendix 2 to this LGIP. The Cluster Study Agreement shall require Interconnection Customer to compensate Transmission Provider for the actual cost of the Cluster Study pursuant to Section 13.3 of this LGIP. The specifications, assumptions, or other provisions in the appendices of the Cluster Study Agreement provided pursuant to Section 7.1 of this LGIP shall be subject to change by Transmission Provider following the conclusion of the Scoping Meeting.

7.2 Execution of Cluster Study Agreement.

Interconnection Customer shall execute the Cluster Study Agreement and deliver the executed Cluster Study Agreement to Transmission Provider no later than the close of the Customer Engagement Window.

If Interconnection Customer does not provide all required technical data when it delivers the Cluster Study Agreement, Transmission Provider shall notify Interconnection Customer of the deficiency within five (5) Business Days of the receipt of the executed Cluster Study Agreement and Interconnection Customer shall cure the deficiency within ten (10) Business Days of receipt of the notice, provided, however, such deficiency does not include failure to deliver the executed Cluster Study Agreement or study deposit.

7.3 Scope of Cluster Study.

The Cluster Study shall evaluate the impact of the proposed interconnection on the reliability of the Transmission System. The Cluster Study will consider the Base Case as well as all Generating Facilities (and with respect to (iii) below, any identified Network Upgrades associated with such higher queued interconnection) that, on the date the Cluster Study is commenced: (i) are directly interconnected to the Transmission System; (ii) are interconnected to Affected Systems and may have an impact on the Interconnection Request; (iii) have a pending higher queued Interconnection Request to interconnect to the Transmission System; and (iv) have no Queue Position but have executed an LGIA or requested that an unexecuted LGIA be filed with FERC.

For purposes of determining necessary Interconnection Facilities and Network Upgrades, the Cluster Study shall use the level of Interconnection Service requested by Interconnection Customers in the Cluster, except where Transmission Provider otherwise determines that it must study the full Generating Facility Capacity due to safety or reliability concerns.

The Cluster Study will consist of power flow, stability, and short circuit analyses, the results of which are documented in a single Cluster Study Report, as applicable. At the conclusion of the Cluster Study, Transmission Provider shall issue a Cluster Study Report. The Cluster Study Report will state the assumptions upon which it is based; state the results of the analyses; and provide the requirements or potential impediments to providing the requested Interconnection Service, including a preliminary indication of the cost and length of time that would be necessary to correct any problems identified in those analyses and implement the interconnection. The Cluster Study Report shall identify the Interconnection Facilities and Network Upgrades expected to be required to reliably interconnect the Generating Facilities in that Cluster Study at the requested Interconnection Service level and shall provide non-binding cost estimates for required Network Upgrades. The Cluster Study Report shall identify each Interconnection Customer's estimated allocated costs for Interconnection Facilities and Network Upgrades pursuant to the method in Section 4.2.1 of this LGIP. Transmission

Provider shall hold an open stakeholder meeting pursuant to Section 7.4 of this LGIP.

For purposes of determining necessary Interconnection Facilities and Network Upgrades, the Cluster Study shall use operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect the proposed charging behavior of a Generating Facility that includes at least one electric storage resource as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise requires the use of different operating assumptions. Transmission Provider may require the inclusion of control technologies sufficient to limit the operation of the Generating Facility per the operating assumptions as set forth in the Interconnection Request and to respond to dispatch instructions by Transmission Provider. As determined by Transmission Provider, Interconnection Customer may be subject to testing and validation of those control technologies consistent with Article 6 of the LGIA.

The Cluster Study shall evaluate the use of static synchronous compensators, static VAR compensators, advanced power flow control devices, transmission switching, synchronous condensers, voltage source converters, advanced conductors, and tower lifting. Transmission Provider shall evaluate each identified alternative transmission technology and determine whether the above technologies should be used, consistent with Good Utility Practice, Applicable Reliability Standards, and Applicable Laws and Regulations. Transmission Provider shall include an explanation of the results of Transmission Provider's evaluation for each technology in the Cluster Study Report.

The Cluster Study Report will provide a list of facilities that are required as a result of the Interconnection Requests within the Cluster and a non-binding good faith estimate of cost responsibility and a non-binding good faith estimated time to construct.

7.4 Cluster Study Procedures.

Transmission Provider shall coordinate the Cluster Study with any Affected System Operator that is affected by the Interconnection Request pursuant to Section 3.6 of this LGIP. Transmission Provider shall utilize existing studies to the extent practicable when it performs the Cluster Study. Interconnection Requests for a Cluster Study may be submitted only within the Cluster Request Window and Transmission Provider shall initiate the Cluster Study Process pursuant to Section 7 of this LGIP.

Transmission Provider shall complete the Cluster Study within one hundred fifty (150) Calendar Days of the close of the Customer Engagement Window.

Within ten (10) Business Days of simultaneously furnishing a Cluster Study Report to each Interconnection Customer within the Cluster and posting such report on OASIS, Transmission Provider shall convene a Cluster Study Report Meeting.

At the request of Interconnection Customer or at any time Transmission Provider determines that it will not meet the required time frame for completing the Cluster Study, Transmission Provider shall notify Interconnection Customers as to the schedule status of the Cluster Study. If Transmission Provider is unable to complete the Cluster Study within the time period, it shall notify Interconnection Customers and provide an estimated completion date with an explanation of the reasons why additional time is required. Upon request, Transmission Provider shall provide Interconnection Customers all supporting documentation, workpapers and relevant pre-Interconnection Request and post-Interconnection Request power flow, short circuit and stability databases for the Cluster Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

7.5 Cluster Study Restudies.

(1) Within twenty (20) Calendar Days after the Cluster Study Report Meeting, Interconnection Customer must provide the following:

- (a) Demonstration of continued Site Control pursuant to Section 3.4.2(iii) of this LGIP; and

(b) An additional deposit that brings the total Commercial Readiness Deposit submitted to Transmission Provider to five percent (5%) of Interconnection Customer's Network Upgrade cost assignment identified in the Cluster Study in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider. Transmission Provider shall refund the deposit to Interconnection Customer upon withdrawal in accordance with Section 3.7 of this LGIP.

Interconnection Customer shall promptly inform Transmission Provider of any material change to Interconnection Customer's demonstration of Site Control under Section 3.4.2(iii) of this LGIP. Upon Transmission Provider determining that Interconnection Customer no longer satisfies the Site Control requirement, Transmission Provider shall notify Interconnection Customer. Within ten (10) Business Days of such notification, Interconnection Customer must demonstrate compliance with the applicable requirement subject to Transmission Provider's approval, not to be unreasonably withheld. Absent such demonstration, Transmission Provider shall deem the subject Interconnection Request withdrawn pursuant to Section 3.7 of this LGIP.

(2) If no Interconnection Customer withdraws from the Cluster after completion of the Cluster Study or Cluster Restudy or is deemed withdrawn pursuant to Section 3.7 of this LGIP after completion of the Cluster Study or Cluster Restudy, Transmission Provider shall notify Interconnection Customers in the Cluster that a Cluster Restudy is not required.

(3) If one or more Interconnection Customers withdraw from the Cluster or are deemed withdrawn pursuant to Section 3.7 of this LGIP, Transmission Provider shall determine if a Cluster Restudy is necessary within thirty (30) Calendar Days after the Cluster Study Report Meeting. If Transmission Provider determines a Cluster Restudy is not necessary, Transmission Provider shall notify Interconnection Customers in the Cluster that a Cluster Restudy is not required and Transmission Provider shall provide an updated Cluster Study Report within thirty (30) Calendar Days of such determination.

(4) If one or more Interconnection Customers withdraws from the Cluster or is deemed withdrawn pursuant to Section 3.7 of this LGIP, and Transmission Provider determines a Cluster Restudy is necessary as a result, Transmission Provider shall notify Interconnection Customers in the Cluster and post on OASIS that a Cluster Restudy is required within thirty (30) Calendar Days after the Cluster Study Report Meeting. Transmission Provider shall continue with such restudies until Transmission Provider determines that no further restudies are required. If an Interconnection Customer withdraws or is deemed withdrawn pursuant to Section 3.7 of this LGIP during the Interconnection Facilities Study, or after other Interconnection Customers in the same Cluster have executed LGIAs, or requested that unexecuted LGIAs be filed, and Transmission Provider determines a Cluster Restudy is necessary, the Cluster shall be restudied. If a Cluster Restudy is required due to a higher queued project withdrawing from the queue, or a modification of a higher or equally queued project subject to Section 4.4 of this LGIP, Transmission Provider shall so notify affected Interconnection Customers in writing. Except as provided in Section 3.7 of this LGIP in the case of withdrawing Interconnection Customers, any cost of Restudy shall be borne by Interconnection Customers being restudied.

(5) The scope of any Cluster Restudy shall be consistent with the scope of an initial Cluster Study pursuant to Section 7.3 of this LGIP. Transmission Provider shall complete the Cluster Restudy within one hundred fifty (150) Calendar Days of Transmission Provider informing Interconnection Customers in the Cluster that restudy is needed. The results of the Cluster Restudy shall be combined into a single report (Cluster Restudy Report). Transmission Provider shall hold a meeting with Interconnection Customers in the Cluster (Cluster Restudy Report Meeting) within ten (10) Business Days of simultaneously furnishing the Cluster Restudy Report to each Interconnection Customer in the Cluster Restudy and publishing the Cluster Restudy Report on OASIS.

If additional restudies are required, Interconnection Customer and Transmission Provider shall follow the procedures of this Section 7.5 of this LGIP until such time that Transmission Provider determines that no further restudies are required. Transmission Provider shall notify each Interconnection Customer within the Cluster when no further restudies are required.

Section 8. Interconnection Facilities Study

8.1 Interconnection Facilities Study Agreement.

Within five (5) Business Days following Transmission Provider notifying each Interconnection Customer within the Cluster that no further Cluster Restudy is required (per Section 7.5 of this LGIP), Transmission Provider shall provide to Interconnection Customer an Interconnection Facilities Study Agreement in the form of Appendix 3 to this LGIP. Interconnection Customer shall compensate Transmission Provider for the actual cost of the Interconnection Facilities Study. Within five (5) Business Days following the Cluster Report Meeting or Cluster Restudy Report Meeting if applicable, Transmission Provider shall provide to Interconnection Customer a non-binding good faith estimate of the cost and timeframe for completing the Interconnection Facilities Study. Interconnection Customer shall execute the Interconnection Facilities Study Agreement and deliver the executed Interconnection Facilities Study Agreement to Transmission Provider within thirty (30) Calendar Days after its receipt, together with:

(1) any required technical data;

(2) Demonstration of one-hundred percent (100%) Site Control or demonstration of a regulatory limitation and applicable deposit in lieu of Site Control provided to Transmission Provider in accordance with Section 3.4.2 of this LGIP; and

(3) An additional deposit that brings the total Commercial Readiness Deposit submitted to Transmission Provider to ten percent (10%) of Interconnection Customer's Network Upgrade cost assignment identified in the Cluster Study or Cluster Restudy, if applicable, in the form of an irrevocable letter of credit, cash, a surety bond, or other form of security that is reasonably acceptable to Transmission Provider. Transmission Provider shall refund the deposit to Interconnection Customer upon withdrawal in accordance with Section 3.7 of this LGIP.

Interconnection Customer shall promptly inform Transmission Provider of any material change to Interconnection Customer's demonstration of Site Control under Section 3.4.2(iii) of this LGIP. Upon Transmission Provider determining separately that Interconnection Customer no longer satisfies the Site Control requirement, Transmission Provider shall notify Interconnection Customer. Within ten (10) Business Days of such notification, Interconnection Customer must demonstrate compliance with the applicable requirement subject to Transmission Provider's approval, not to be unreasonably withheld. Absent such demonstration, Transmission Provider shall deem the subject Interconnection Request withdrawn pursuant to Section 3.7 of this LGIP.

8.2 Scope of Interconnection Facilities Study.

The Interconnection Facilities Study shall be specific to each Interconnection Request and performed on an individual, i.e., non-clustered, basis. The Interconnection Facilities Study shall specify and provide a non-binding estimate of the cost of the equipment, engineering, procurement and construction work needed to implement the conclusions of the Cluster Study Report (and any associated restudies) in accordance with Good Utility Practice to physically and electrically connect the Interconnection Facilities to the Transmission System. The Interconnection Facilities Study shall also identify the electrical switching configuration of the connection equipment, including, without limitation: the transformer, switchgear, meters, and other station equipment; the nature and estimated cost of any Transmission Provider's Interconnection Facilities and Network Upgrades necessary to accomplish the interconnection; and an estimate of the time required to complete the construction and installation of such facilities. The Interconnection Facilities Study will also identify any potential control equipment for (1) requests for Interconnection Service that are lower than the Generating Facility Capacity, and/or (2) requests to study a Generating Facility that includes at least one electric storage resource using operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) that reflect its proposed charging behavior, as requested by Interconnection Customer, unless Transmission Provider determines that Good Utility Practice, including Applicable Reliability Standards, otherwise require the use of different operating assumptions.

8.3 Interconnection Facilities Study Procedures.

Transmission Provider shall coordinate the Interconnection Facilities Study with any Affected System Operator pursuant to Section 3.6 of this LGIP. Transmission Provider shall utilize existing studies to the extent practicable in performing the Interconnection Facilities Study. Transmission Provider shall complete the study and issue a draft Interconnection Facilities Study Report to Interconnection Customer within the following number of days after receipt of an executed Interconnection Facilities Study Agreement: ninety (90) Calendar Days after receipt of an executed Interconnection Facilities Study Agreement, with no more than a +/- twenty percent (20%) cost estimate contained in the report; or one hundred eighty (180) Calendar Days, if Interconnection Customer requests a +/- ten percent (10%) cost estimate.

At the request of Interconnection Customer or at any time Transmission Provider determines that it will not meet the required time frame for completing the Interconnection Facilities Study, Transmission Provider shall notify Interconnection Customer as to the schedule status of the Interconnection Facilities Study. If Transmission Provider is unable to complete the Interconnection Facilities Study and issue a draft Interconnection Facilities Study Report within the time required, it shall notify Interconnection Customer and provide an estimated completion date and an explanation of the reasons why additional time is required.

Interconnection Customer may, within thirty (30) Calendar Days after receipt of the draft Interconnection Facilities Study Report, provide written comments to Transmission Provider, which Transmission Provider shall include in completing the final Interconnection Facilities Study Report. Transmission Provider shall issue the final Interconnection Facilities Study Report within fifteen (15) Business Days of receiving Interconnection Customer's comments or promptly upon receiving Interconnection Customer's statement that it will not provide comments. Transmission Provider may reasonably extend such fifteen (15) Business Day period upon notice to Interconnection Customer if Interconnection Customer's comments require Transmission Provider to perform additional analyses or make other significant modifications prior to the issuance of the final Interconnection Facilities Study Report. Upon request, Transmission Provider shall provide Interconnection Customer supporting documentation, workpapers, and databases or data developed in the

preparation of the Interconnection Facilities Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

8.4 Meeting with Transmission Provider.

Within ten (10) Business Days of providing a draft Interconnection Facilities Study Report to Interconnection Customer, Transmission Provider and Interconnection Customer shall meet to discuss the results of the Interconnection Facilities Study.

8.5 Restudy.

If restudy of the Interconnection Facilities Study is required due to a higher or equally queued project withdrawing from the queue or a modification of a higher or equally queued project pursuant to Section 4.4 of this LGIP, Transmission Provider shall so notify Interconnection Customer in writing. Transmission Provider shall ensure that such restudy takes no longer than sixty (60) Calendar Days from the date of notice. Except as provided in Section 3.7 of this LGIP in the case of withdrawing Interconnection Customers, any cost of restudy shall be borne by Interconnection Customer being restudied.

Section 9. Affected System Study.

9.1 Applicability.

This Section 9 outlines the duties of Transmission Provider when it receives notification that an Affected System Interconnection Customer's proposed interconnection to its host transmission provider may impact Transmission Provider's Transmission System.

9.2 Response to Notifications.

9.2.1 Response to Initial Notification.

When Transmission Provider receives initial notification either following the Cluster Study or a Cluster Restudy that an Affected System Interconnection Customer's proposed interconnection to its host transmission provider may impact Transmission Provider's

Transmission System, Transmission Provider must respond in writing within twenty (20) Business Days whether it intends to conduct an Affected System Study.

By fifteen (15) Business Days after Transmission Provider responds with its affirmative intent to conduct an Affected System Study, Transmission Provider shall share with Affected System Interconnection Customer(s) and the Affected System Interconnection Customer's host transmission provider a non-binding good faith estimate of the cost and the schedule to complete the Affected System Study.

9.2.2 Response to Notification of Cluster Restudy.

Within five (5) Business Days of receipt of notification of Cluster Restudy, Transmission Provider will send written notification to Affected System Interconnection Customer(s) involved in the Cluster Restudy and the host transmission provider that Transmission Provider intends to delay a planned or in-progress Affected System Study until after completion of the Cluster Restudy. If Transmission Provider decides to delay the Affected System Study, it is not required to meet its obligations under Section 9 of this LGIP until the time that it receives notification from the host transmission provider that the Cluster Restudy is complete. If Transmission Provider decides to move forward with its Affected System Study despite the Cluster Restudy, then it must meet all requirements under Section 9 of this LGIP.

9.3 Affected System Queue Position.

Transmission Provider must assign an Affected System Queue Position to Affected System Interconnection Customer(s) that require(s) an Affected System Study. Such Affected System Queue Position shall be assigned based upon the date of execution of the Affected System Study Agreement. Relative to Transmission Provider's Interconnection Customers, this Affected System Queue Position shall be higher-queued than any Cluster that has not yet received its Cluster Study Report and shall be lower-queued than any Cluster that has already received its Cluster Study Report. Consistent with Section 9.7 of this LGIP, Transmission Provider shall study the Affected System Interconnection Customer(s) via Clustering, and all Affected System Interconnection Customers studied in the same Cluster under Section 9.7 of this LGIP shall be equally queued. For Affected

System Interconnection Customers that are equally queued, the Affected System Queue Position shall have no bearing on the assignment of Affected System Network Upgrades identified in the applicable Affected System Study. The costs of the Affected System Network Upgrades shall be allocated among the Affected System Interconnection Customers in accordance with Section 9.9 of this LGIP.

9.4 Affected System Study Agreement/Multiparty Affected System Study Agreement.

Unless otherwise agreed, Transmission Provider shall provide to Affected System Interconnection Customer(s) an Affected System Study Agreement/Multiparty Affected System Study Agreement, in the form of Appendix 9 or Appendix 10 to this LGIP, as applicable, within ten (10) Business Days of Transmission Provider sharing the schedule for the Affected System Study per Section 9.2.1 of this LGIP.

Upon Affected System Interconnection Customer(s)' receipt of the Affected System Study Report, Affected System Interconnection Customer(s) shall compensate Transmission Provider for the actual cost of the Affected System Study. Any difference between the study deposit and the actual cost of the Affected System Study shall be paid by or refunded to the Affected System Interconnection Customer(s). Any invoices for the Affected System Study shall include a detailed and itemized accounting of the cost of the study. Affected System Interconnection Customer(s) shall pay any excess costs beyond the already-paid Affected System Study deposit or be reimbursed for any costs collected over the actual cost of the Affected System Study within thirty (30) Calendar Days of receipt of an invoice thereof. If Affected System Interconnection Customer(s) fail to pay such undisputed costs within the time allotted, it shall lose its Affected System Queue Position. Transmission Provider shall notify Affected System Interconnection Customer's host transmission provider of such failure to pay.

9.5 Execution of Affected System Study Agreement/Multiparty Affected System Study Agreement.

Affected System Interconnection Customer(s) shall execute the Affected System Study Agreement/Multiparty Affected System Study Agreement, deliver the executed Affected System Study Agreement/Multiparty

Affected System Study Agreement to Transmission Provider, and provide the Affected System Study deposit within ten (10) Business Days of receipt. If Transmission Provider notifies Affected System Interconnection Customer(s) that it will delay the Affected System Study pursuant to Section 9.2.2 of this LGIP, Affected System Interconnection Customer(s) are neither required to execute and return the previously tendered Affected System Study/Multiparty Affected System Study Agreement nor provide the Affected System Study deposit for the previously tendered Affected System Study/Multiparty Affected System Study Agreement.

If Affected System Interconnection Customer does not provide all required technical data when it delivers the Affected System Study Agreement/Multiparty Affected System Study Agreement, Transmission Provider shall notify the deficient Affected System Interconnection Customer, as well as the host transmission provider with which Affected System Interconnection Customer seeks to interconnect, of the technical data deficiency within five (5) Business Days of the receipt of the executed Affected System Study Agreement/Multiparty Affected System Study Agreement and the deficient Affected System Interconnection Customer shall cure the technical deficiency within ten (10) Business Days of receipt of the notice: provided, however, that such deficiency does not include failure to deliver the executed Affected System Study Agreement/Multiparty Affected System Study Agreement or deposit for the Affected System Study Agreement/Multiparty Affected System Study Agreement. If Affected System Interconnection Customer does not cure the technical data deficiency within the cure period or fails to execute the Affected System Study Agreement/Multiparty Affected System Study Agreement or provide the deposit, the Affected System Interconnection Customer shall lose its Affected System Queue Position.

9.6 Scope of Affected System Study.

The Affected System Study shall evaluate the impact that any Affected System Interconnection Customer's proposed interconnection to another transmission provider's transmission system will have on the reliability of Transmission Provider's Transmission System. The Affected System Study shall consider the Base Case as well as all Generating Facilities (and with respect to (iii) below, any identified Affected System Network Upgrades associated with such higher-queued Interconnection Request)

that, on the date the Affected System Study is commenced: (i) are directly interconnected to Transmission Provider's Transmission System; (ii) are directly interconnected to another transmission provider's transmission system and may have an impact on Affected System Interconnection Customer's interconnection request; (iii) have a pending higher-queued Interconnection Request to interconnect to Transmission Provider's Transmission System; and (iv) have no queue position but have executed an LGIA or requested that an unexecuted LGIA be filed with FERC. Transmission Provider has no obligation to study impacts of Affected System Interconnection Customers of which it is not notified.

The Affected System Study shall consist of a power flow, stability, and short circuit analysis. The Affected System Study Report will: state the assumptions upon which it is based; state the results of the analyses; and provide the potential impediments to Affected System Interconnection Customer's receipt of interconnection service on its host transmission provider's transmission system, including a preliminary indication of the cost and length of time that would be necessary to correct any problems identified in those analyses and implement the interconnection. For purposes of determining necessary Affected System Network Upgrades, the Affected System Study shall consider the level of interconnection service requested in megawatts by Affected System Interconnection Customer, unless otherwise required to study the full generating facility capacity due to safety or reliability concerns. The Affected System Study Report shall provide a list of facilities that are required as a result of Affected System Interconnection Customer's proposed interconnection to another transmission provider's system, a non-binding good faith estimate of cost responsibility, and a non-binding good faith estimated time to construct. The Affected System Study may consist of a system impact study, a facilities study, or some combination thereof.

9.7 Affected System Study Procedures.

Transmission Provider shall use Clustering in conducting the Affected System Study and shall use existing studies to the extent practicable, when multiple Affected System Interconnection Customers that are part of a single Cluster may cause the need for Affected System Network Upgrades. Transmission Provider shall complete the Affected System Study and provide the Affected System Study Report to Affected System Interconnection Customer(s) and the host transmission provider with whom

interconnection has been requested within one hundred fifty (150) Calendar Days after the receipt of the Affected System Study Agreement and deposit.

At the request of Affected System Interconnection Customer, Transmission Provider shall notify Affected System Interconnection Customer as to the status of the Affected System Study. If Transmission Provider is unable to complete the Affected System Study within the requisite time period, it shall notify Affected System Interconnection Customer(s), as well as transmission provider with which Affected System Interconnection Customer seeks to interconnect, and shall provide an estimated completion date with an explanation of the reasons why additional time is required. If Transmission Provider does not meet the deadlines in this Section, Transmission Provider shall be subject to the financial penalties as described in Section 3.9 of this LGIP. Upon request, Transmission Provider shall provide Affected System Interconnection Customer(s) with all supporting documentation, workpapers and relevant power flow, short circuit and stability databases for the Affected System Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

Transmission Provider must study an Affected System Interconnection Customer using the Energy Resource Interconnection Service modeling standard used for Interconnection Requests on its own Transmission System, regardless of the level of interconnection service that Affected System Interconnection Customer is seeking from the host transmission provider with whom it seeks to interconnect.

9.8 Meeting with Transmission Provider.

Within ten (10) Business Days of providing the Affected System Study Report to Affected System Interconnection Customer(s), Transmission Provider and Affected System Interconnection Customer(s) shall meet to discuss the results of the Affected System Study.

9.9 Affected System Cost Allocation.

Transmission Provider shall allocate Affected System Network Upgrade costs identified during the Affected System Study to Affected System Interconnection Customer(s) using a proportional impact method, consistent with Section 4.2.1(1)(b) of this LGIP.

9.10 Tender of Affected Systems Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement.

Transmission Provider shall tender to Affected System Interconnection Customer(s) an Affected System Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement, as applicable, in the form of Appendix 11 or 12 to this LGIP, within thirty (30) Calendar Days of providing the Affected System Study Report. Within ten (10) Business Days of the receipt of the Affected System Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement, the Affected System Interconnection Customer(s) must execute the agreement or request the agreement to be filed unexecuted with FERC. Transmission Provider shall execute the agreement or file the agreement unexecuted within five (5) Business Days after receiving direction from Affected System Interconnection Customer(s). Affected System Interconnection Customer's failure to execute the Affected System Facilities Construction Agreement/Multiparty Affected System Facilities Construction Agreement, or failure to request the agreement to be filed unexecuted with FERC, shall result in the loss of its Affected System Queue Position.

9.11 Restudy.

If restudy of the Affected System Study is required, Transmission Provider shall notify Affected System Interconnection Customer(s) in writing within thirty (30) Calendar Days of discovery of the need for restudy. Such restudy shall take no longer than sixty (60) Calendar Days from the date of notice. Any cost of restudy shall be borne by the Affected System Interconnection Customer(s) being restudied.

Section 10. Optional Interconnection Study

10.1 Optional Interconnection Study Agreement.

On or after the date when Interconnection Customer receives Cluster Study results, Interconnection Customer may request, and Transmission Provider shall perform a reasonable number of Optional Interconnection Studies. The request shall describe the assumptions that Interconnection Customer wishes Transmission Provider to study within the scope described in

Section 10.2 of this LGIP. Within five (5) Business Days after receipt of a request for an Optional Interconnection Study, Transmission Provider shall provide to Interconnection Customer an Optional Interconnection Study Agreement in the form of Appendix 4.

The Optional Interconnection Study Agreement shall: (i) specify the technical data that Interconnection Customer must provide for each phase of the Optional Interconnection Study, (ii) specify Interconnection Customer's assumptions as to which Interconnection Requests with earlier queue priority dates will be excluded from the Optional Interconnection Study case and assumptions as to the type of Interconnection Service for Interconnection Requests remaining in the Optional Interconnection Study case, and (iii) Transmission Provider's estimate of the cost of the Optional Interconnection Study. To the extent known by Transmission Provider, such estimate shall include any costs expected to be incurred by any Affected System Operator whose participation is necessary to complete the Optional Interconnection Study. Notwithstanding the above, Transmission Provider shall not be required as a result of an Optional Interconnection Study request to conduct any additional Interconnection Studies with respect to any other Interconnection Request.

Interconnection Customer shall execute the Optional Interconnection Study Agreement within ten (10) Business Days of receipt and deliver the Optional Interconnection Study Agreement, the technical data and a \$10,000 deposit to Transmission Provider.

10.2 Scope of Optional Interconnection Study.

The Optional Interconnection Study will consist of a sensitivity analysis based on the assumptions specified by Interconnection Customer in the Optional Interconnection Study Agreement. The Optional Interconnection Study will also identify Transmission Provider's Interconnection Facilities and the Network Upgrades, and the estimated cost thereof, that may be required to provide transmission service or Interconnection Service based upon the results of the Optional Interconnection Study. The Optional Interconnection Study shall be performed solely for informational purposes. Transmission Provider shall use Reasonable Efforts to coordinate the study with any Affected Systems that may be affected by the types of Interconnection Services that are being studied. Transmission Provider

shall utilize existing studies to the extent practicable in conducting the Optional Interconnection Study.

10.3 Optional Interconnection Study Procedures.

The executed Optional Interconnection Study Agreement, the prepayment, and technical and other data called for therein must be provided to Transmission Provider within ten (10) Business Days of Interconnection Customer receipt of the Optional Interconnection Study Agreement. Transmission Provider shall use Reasonable Efforts to complete the Optional Interconnection Study within a mutually agreed upon time period specified within the Optional Interconnection Study Agreement. If Transmission Provider is unable to complete the Optional Interconnection Study within such time period, it shall notify Interconnection Customer and provide an estimated completion date and an explanation of the reasons why additional time is required. Any difference between the study payment and the actual cost of the study shall be paid to Transmission Provider or refunded to Interconnection Customer, as appropriate. Upon request, Transmission Provider shall provide Interconnection Customer supporting documentation and workpapers and databases or data developed in the preparation of the Optional Interconnection Study, subject to confidentiality arrangements consistent with Section 13.1 of this LGIP.

Section 11. Standard Large Generator Interconnection Agreement (LGIA)

11.1 Tender.

Interconnection Customer shall tender comments on the draft Interconnection Facilities Study Report within thirty (30) Calendar Days of receipt of the report. Within thirty (30) Calendar Days after the comments are submitted or after Interconnection Customer notifies Transmission Provider that it will not provide comments, Transmission Provider shall tender a draft LGIA, together with draft appendices. The draft LGIA shall be in the form of Transmission Provider's FERC-approved standard form LGIA, which is in Appendix 5. Interconnection Customer shall execute and return the LGIA and completed draft appendices within thirty (30) Calendar Days, unless (1) the sixty (60) Calendar Day negotiation period under Section 11.2 of this LGIP has commenced, or (2) LGIA execution, or filing unexecuted, has been delayed to await the Affected System Study Report pursuant to Section 11.2.1 of this LGIP.

11.2 Negotiation.

Notwithstanding Section 11.1 of this LGIP, at the request of Interconnection Customer, Transmission Provider shall begin negotiations with Interconnection Customer concerning the appendices to the LGIA at any time after Interconnection Customer executes the Interconnection Facilities Study Agreement. Transmission Provider and Interconnection Customer shall negotiate concerning any disputed provisions of the appendices to the draft LGIA for not more than sixty (60) Calendar Days after tender of the final Interconnection Facilities Study Report. If Interconnection Customer determines that negotiations are at an impasse, it may request termination of the negotiations at any time after tender of the draft LGIA pursuant to Section 11.1 of this LGIP and request submission of the unexecuted LGIA with FERC or initiate Dispute Resolution procedures pursuant to Section 13.5 of this LGIP. If Interconnection Customer requests termination of the negotiations, but within sixty (60) Calendar Days thereafter fails to request either the filing of the unexecuted LGIA or initiate Dispute Resolution, it shall be deemed to have withdrawn its Interconnection Request. Unless otherwise agreed by the Parties, if Interconnection Customer has not executed the LGIA, requested filing of an unexecuted LGIA, or initiated Dispute Resolution procedures pursuant to Section 13.5 of this LGIP within sixty (60) Calendar Days of tender of draft LGIA, it shall be deemed to have withdrawn its Interconnection Request. Transmission Provider shall provide to Interconnection Customer a final LGIA within fifteen (15) Business Days after the completion of the negotiation process.

11.2.1 Delay in LGIA Execution, or Filing Unexecuted, to Await Affected System Study Report.

If Interconnection Customer has not received its Affected System Study Report from the Affected System Operator prior to the date that it would be required to execute its LGIA (or request that its LGIA be filed unexecuted) pursuant to Section 11.1 of this LGIP, Transmission Provider shall, upon request of Interconnection Customer, extend this deadline to thirty (30) Calendar Days after Interconnection Customer's receipt of the Affected System Study Report. If Interconnection Customer, after delaying LGIA execution, or requesting unexecuted filing, to await Affected System Study Report, decides to proceed to LGIA execution, or request

unexecuted filing, without those results, it may notify Transmission Provider of its intent to proceed with LGIA execution (or request that its LGIA be filed unexecuted) pursuant to Section 11.1 of this LGIP. If Transmission Provider determines that further delay to the LGIA execution date would cause a material impact on the cost or timing of an equal- or lower-queued Interconnection Customer, Transmission Provider must notify Interconnection Customer of such impacts and set the deadline to execute the LGIA (or request that the LGIA be filed unexecuted) to thirty (30) Calendar Days after such notice is provided.

11.3 Execution and Filing.

Simultaneously with submitting the executed LGIA to Transmission Provider, or within ten (10) Business Days after Interconnection Customer requests that Transmission Provider file the LGIA unexecuted at the Commission, Interconnection Customer shall provide Transmission Provider with the following: (1) demonstration of continued Site Control pursuant to Section 8.1(2) of this LGIP; and (2) the LGIA Deposit equal to twenty percent (20%) of Interconnection Customer's estimated Network Upgrade costs identified in the draft LGIA minus the total amount of Commercial Readiness Deposits that Interconnection Customer has provided to Transmission Provider for its Interconnection Request. Transmission Provider shall use LGIA Deposit as (or as a portion of) Interconnection Customer's security required under LGIA Article 11.5. Interconnection Customer may not request to suspend its LGIA under LGIA Article 5.16 until Interconnection Customer has provided (1) and (2) to Transmission Provider. If Interconnection Customer fails to provide (1) and (2) to Transmission Provider within the thirty (30) Calendar Days allowed for returning the executed LGIA and appendices under LGIP Section 11.1, or within ten (10) Business Days after Interconnection Customer requests that Transmission Provider file the LGIA unexecuted at the Commission as allowed in this Section 11.3 of this LGIP, the Interconnection Request will be deemed withdrawn pursuant to Section 3.7 of this LGIP.

At the same time, Interconnection Customer also shall provide reasonable evidence that one or more of the following milestones in the development of the Large Generating Facility, at Interconnection Customer election, has been achieved (unless such milestone is inapplicable due to the

characteristics of the Generating Facility): (i) the execution of a contract for the supply or transportation of fuel to the Large Generating Facility; (ii) the execution of a contract for the supply of cooling water to the Large Generating Facility; (iii) execution of a contract for the engineering for, procurement of major equipment for, or construction of, the Large Generating Facility; (iv) execution of a contract (or comparable evidence) for the sale of electric energy or capacity from the Large Generating Facility; or (v) application for an air, water, or land use permit.

Interconnection Customer shall either: (i) execute two originals of the tendered LGIA and return them to Transmission Provider; or (ii) request in writing that Transmission Provider file with FERC an LGIA in unexecuted form. As soon as practicable, but not later than ten (10) Business Days after receiving either the two executed originals of the tendered LGIA (if it does not conform with a FERC-approved Standard Large Generator Interconnection Agreement) or the request to file an unexecuted LGIA, Transmission Provider shall file the LGIA with FERC, together with its explanation of any matters as to which Interconnection Customer and Transmission Provider disagree and support for the costs that Transmission Provider proposes to charge to Interconnection Customer under the LGIA. An unexecuted LGIA should contain terms and conditions deemed appropriate by Transmission Provider for the Interconnection Request. If the Parties agree to proceed with design, procurement, and construction of facilities and upgrades under the agreed-upon terms of the unexecuted LGIA, they may proceed pending FERC action.

11.4 Commencement of Interconnection Activities.

If Interconnection Customer executes the final LGIA, Transmission Provider and Interconnection Customer shall perform their respective obligations in accordance with the terms of the LGIA, subject to modification by FERC. Upon submission of an unexecuted LGIA, Interconnection Customer and Transmission Provider shall promptly comply with the unexecuted LGIA, subject to modification by FERC.

Section 12. Construction of Transmission Provider's Interconnection Facilities and Network Upgrades

12.1 Schedule.

Transmission Provider and Interconnection Customer shall negotiate in good faith concerning a schedule for the construction of Transmission Provider's Interconnection Facilities and the Network Upgrades.

12.2 Construction Sequencing.**12.2.1 General.**

In general, the In-Service Date of an Interconnection Customer seeking interconnection to the Transmission System will determine the sequence of construction of Network Upgrades.

12.2.2 Advance Construction of Network Upgrades that are an Obligation of an Entity other than Interconnection Customer.

An Interconnection Customer with an LGIA, in order to maintain its In-Service Date, may request that Transmission Provider advance to the extent necessary the completion of Network Upgrades that: (i) were assumed in the Interconnection Studies for such Interconnection Customer, (ii) are necessary to support such In-Service Date, and (iii) would otherwise not be completed, pursuant to a contractual obligation of an entity other than Interconnection Customer that is seeking interconnection to the Transmission System, in time to support such In-Service Date. Upon such request, Transmission Provider will use Reasonable Efforts to advance the construction of such Network Upgrades to accommodate such request; provided that Interconnection Customer commits to pay Transmission Provider: (i) any associated expediting costs and (ii) the cost of such Network Upgrades.

Transmission Provider will refund to Interconnection Customer both the expediting costs and the cost of Network Upgrades, in accordance with Article 11.4 of the LGIA. Consequently, the entity with a contractual obligation to construct such Network Upgrades shall be obligated to pay

only that portion of the costs of the Network Upgrades that Transmission Provider has not refunded to Interconnection Customer. Payment by that entity shall be due on the date that it would have been due had there been no request for advance construction. Transmission Provider shall forward to Interconnection Customer the amount paid by the entity with a contractual obligation to construct the Network Upgrades as payment in full for the outstanding balance owed to Interconnection Customer. Transmission Provider then shall refund to that entity the amount that it paid for the Network Upgrades, in accordance with Article 11.4 of the LGIA.

12.2.3 Advancing Construction of Network Upgrades that are Part of an Expansion Plan of Transmission Provider.

An Interconnection Customer with an LGIA, in order to maintain its In-Service Date, may request that Transmission Provider advance to the extent necessary the completion of Network Upgrades that: (i) are necessary to support such In-Service Date and (ii) would otherwise not be completed, pursuant to an expansion plan of Transmission Provider, in time to support such In-Service Date. Upon such request, Transmission Provider will use Reasonable Efforts to advance the construction of such Network Upgrades to accommodate such request; provided that Interconnection Customer commits to pay Transmission Provider any associated expediting costs. Interconnection Customer shall be entitled to transmission credits, if any, for any expediting costs paid.

12.2.4 Amended Interconnection Cluster Study Report.

An Interconnection Cluster Study Report will be amended to determine the facilities necessary to support the requested In-Service Date. This amended study report will include those transmission and Large Generating Facilities that are expected to be in service on or before the requested In-Service Date.

Section 13. Miscellaneous

13.1 Confidentiality.

Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied by either of the Parties to the other prior to the execution of an LGIA.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential.

If requested by either Party, the other Party shall provide in writing, the basis for asserting that the information referred to in this Article warrants confidential treatment, and the requesting Party may disclose such writing to the appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

13.1.1 Scope.

Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a third party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of the LGIA; or (6) is required, in accordance with Section 13.1.6 of this LGIP, Order of Disclosure, to be

disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under the

LGIA. Information designated as Confidential Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the other Party that it no longer is confidential.

13.1.2 Release of Confidential Information.

Neither Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), employees, consultants, or to parties who may be or considering providing financing to or equity participation with Interconnection Customer, or to potential purchasers or assignees of Interconnection Customer, on a need-to-know basis in connection with these procedures, unless such person has first been advised of the confidentiality provisions of this Section 13.1 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Section 13.1.

13.1.3 Rights.

Each Party retains all rights, title, and interest in the Confidential Information that each Party discloses to the other Party. The disclosure by each Party to the other Party of Confidential Information shall not be deemed a waiver by either Party or any other person or entity of the right to protect the Confidential Information from public disclosure.

13.1.4 No Warranties.

By providing Confidential Information, neither Party makes any warranties or representations as to its accuracy or

completeness. In addition, by supplying Confidential Information, neither Party obligates itself to provide any particular information or Confidential Information to the other Party nor to enter into any further agreements or proceed with any other relationship or joint venture.

13.1.5 Standard of Care.

Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under these procedures or its regulatory requirements.

13.1.6 Order of Disclosure.

If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires either Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the other Party with prompt notice of such request(s) or requirement(s) so that the other Party may seek an appropriate protective order or waive compliance with the terms of the LGIA. Notwithstanding the absence of a protective order or waiver, the Party may disclose such Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance that confidential treatment will be accorded any Confidential Information so furnished.

13.1.7 Remedies.

The Parties agree that monetary damages would be inadequate to compensate a Party for the other Party's Breach of its obligations under this Section 13.1. Each Party accordingly agrees that the other Party shall be entitled to equitable relief, by way of injunction or otherwise, if the first

Party Breaches or threatens to Breach its obligations under this Section 13.1, which equitable relief shall be granted without bond or proof of damages, and the receiving Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Section 13.1, but shall be in addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. No Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Section 13.1.

13.1.8 Disclosure to FERC, its Staff, or a State.

Notwithstanding anything in this Section 13.1 to the contrary, and pursuant to 18 CFR section 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to the LGIP, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information. In providing the information to FERC or its staff, the Party must, consistent with 18 CFR section 388.112, request that the information be treated as confidential and non-public by FERC and its staff and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Party to the LGIA when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR section 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner, consistent with applicable state rules and regulations.

13.1.9 Subject to the exception in Section 13.1.8 of this LGIP, any information that a Party claims is competitively sensitive, commercial or financial information (“Confidential Information”) shall not be disclosed by the other Party to any person not employed or retained by the other Party, except to the extent disclosure is (i) required by law; (ii) reasonably deemed by the disclosing Party to be required to be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (iii) otherwise permitted by consent of the other Party, such consent not to be unreasonably withheld; or (iv) necessary to fulfill its obligations under this LGIP or as a transmission service provider or a Balancing Authority Area operator including disclosing the Confidential Information to an RTO or ISO or to a subregional, regional or national reliability organization or planning group. The Party asserting confidentiality shall notify the other Party in writing of the information it claims is confidential. Prior to any disclosures of the other Party’s Confidential Information under this subparagraph, or if any third party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the disclosing Party agrees to promptly notify the other Party in writing and agrees to assert confidentiality and cooperate with the other Party in seeking to protect the Confidential Information from public disclosure by confidentiality agreement, protective order or other reasonable measures.

13.1.10 This provision shall not apply to any information that was or is hereafter in the public domain (except as a result of a Breach of this provision).

13.1.11 Transmission Provider shall, at Interconnection Customer’s election, destroy, in a confidential manner, or return the Confidential Information provided at the time of Confidential Information is no longer needed.

13.2 Delegation of Responsibility.

Transmission Provider may use the services of subcontractors as it deems appropriate to perform its obligations under this LGIP. Transmission Provider shall remain primarily liable to Interconnection Customer for the performance of such subcontractors and compliance with its obligations of this LGIP. The subcontractor shall keep all information provided confidential and shall use such information solely for the performance of such obligation for which it was provided and no other purpose.

13.3 Obligation for Study Costs.

In the event an Interconnection Customer withdraws its Interconnection Request prior to the commencement of the Cluster Study, Interconnection Customer must pay Transmission Provider the actual costs of processing its Interconnection Request. In the event an Interconnection Customer withdraws after the commencement of the Cluster Study, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Interconnection Studies. The costs of any interconnection study conducted on a clustered basis shall be allocated among each Interconnection Customer within the cluster as follows:

Transmission Provider shall determine each Interconnection Customer's share of the costs of the Cluster Study by allocating: (1) fifty percent (50%) of the applicable study costs to Interconnection Customers on a per capita basis based on number of Interconnection Requests included in the applicable Cluster; and (2) fifty percent (50%) of the applicable study costs to Interconnection Customers on a pro-rata basis based on requested megawatts included in the applicable Cluster. The Interconnection Facilities Study portion of the Definitive Interconnection Study Process is an individual study and costs for each Interconnection Facilities Study are directly assigned to the Interconnection Customer associated with such study.

Any difference between the study deposit and the actual cost of the Interconnection Studies shall be paid by or refunded to, except as otherwise provided herein, to Interconnection Customers. Any invoices for Interconnection Studies shall include a detailed and itemized accounting of the cost of each Interconnection Study. Interconnection Customers shall pay any such undisputed costs within thirty (30) Calendar Days of receipt of an invoice therefor. If Interconnection Customer fails to pay such

undisputed costs within the time allotted, its Interconnection Request shall be deemed withdrawn from the Cluster Study Process and will be subject to Withdrawal Penalties pursuant to Section 3.7 of this LGIP.

13.4 Third Parties Conducting Studies.

If (i) at the time of the signing of an Interconnection Study Agreement there is disagreement as to the estimated time to complete an Interconnection Study, (ii) Interconnection Customer receives notice pursuant to Sections 6.3, 7.4 or 8.3 of this LGIP that Transmission Provider will not complete an Interconnection Study within the applicable timeframe for such Interconnection Study, or (iii) Interconnection Customer receives neither the Interconnection Study nor a notice under Sections 6.3, 7.4 or 8.3 of this LGIP within the applicable timeframe for such Interconnection Study, then Interconnection Customer may require Transmission Provider to utilize a third party consultant reasonably acceptable to Interconnection Customer and Transmission Provider to perform such Interconnection Study under the direction of Transmission Provider. At other times, Transmission Provider may also utilize a third party consultant to perform such Interconnection Study, either in response to a general request of Interconnection Customer, or on its own volition.

In all cases, use of a third party consultant shall be in accord with Article 26 of the LGIA (Subcontractors) and limited to situations where Transmission Provider determines that doing so will help maintain or accelerate the study process for Interconnection Customer's pending Interconnection Request and not interfere with Transmission Provider's progress on Interconnection Studies for other pending Interconnection Requests. In cases where Interconnection Customer requests use of a third party consultant to perform such Interconnection Study, Interconnection Customer and Transmission Provider shall negotiate all of the pertinent terms and conditions, including reimbursement arrangements and the estimated study completion date and study review deadline. Transmission Provider shall convey all workpapers, data bases, study results and all other supporting documentation prepared to date with respect to the Interconnection Request as soon as soon as practicable upon Interconnection Customer's request subject to the confidentiality provision in Section 13.1 of this LGIP. In any case, such third party contract may be entered into with either Interconnection Customer or Transmission Provider at Transmission Provider's discretion. In the case of (iii) Interconnection Customer

maintains its right to submit a claim to Dispute Resolution to recover the costs of such third party study. Such third party consultant shall be required to comply with this LGIP, Article 26 of the LGIA (Subcontractors), and the relevant Tariff procedures and protocols as would apply if Transmission Provider were to conduct the Interconnection Study and shall use the information provided to

it solely for purposes of performing such services and for no other purposes. Transmission Provider shall cooperate with such third party consultant and Interconnection Customer to complete and issue the Interconnection Study in the shortest reasonable time.

13.5 Disputes.

13.5.1 Submission.

In the event either Party has a dispute, or asserts a claim, that arises out of or in connection with the LGIA, the LGIP, or their performance, such Party (the “disputing Party”) shall provide the other Party with written notice of the dispute or claim (“Notice of Dispute”). Such dispute or claim shall be referred to a designated senior representative of each Party for resolution on an informal basis as promptly as practicable after receipt of the Notice of Dispute by the other Party. In the event the designated representatives are unable to resolve the claim or dispute through unassisted or assisted negotiations within thirty (30) Calendar Days of the other Party’s receipt of the Notice of Dispute, such claim or dispute may, upon mutual agreement of the Parties, be submitted to arbitration and resolved in accordance with the arbitration procedures set forth below. In the event the Parties do not agree to submit such claim or dispute to arbitration, each Party may exercise whatever rights and remedies it may have in equity or at law consistent with the terms of this LGIA.

13.5.2 External Arbitration Procedures.

Any arbitration initiated under these procedures shall be conducted before a single neutral arbitrator appointed by the Parties. If the Parties fail to agree upon a single arbitrator within ten (10) Calendar Days of the submission of the

dispute to arbitration, each Party shall choose one arbitrator who shall sit on a three-member arbitration panel. The two arbitrators so chosen shall within twenty (20) Calendar Days select a third arbitrator to chair the arbitration panel. In either case, the arbitrators shall be knowledgeable in electric utility matters, including electric transmission and bulk power issues, and shall not have any current or past substantial business or financial relationships with any party to the arbitration (except prior arbitration). The arbitrator(s) shall provide each of the Parties an opportunity to be heard and, except as otherwise provided herein, shall conduct the arbitration in accordance with the Commercial Arbitration Rules of the American Arbitration Association (“Arbitration Rules”) and any applicable FERC regulations or RTO rules; provided, however, in the event of a conflict between the Arbitration Rules and the terms of this Section 13, the terms of this Section 13 shall prevail.

13.5.3 Arbitration Decisions.

Unless otherwise agreed by the Parties, the arbitrator(s) shall render a decision within ninety (90) Calendar Days of appointment and shall notify the Parties in writing of such decision and the reasons therefor. The arbitrator(s) shall be authorized only to interpret and apply the provisions of the LGIA and LGIP and shall have no power to modify or change any provision of the LGIA and LGIP in any manner. The decision of the arbitrator(s) shall be final and binding upon the Parties, and judgment on the award may be entered in any court having jurisdiction. The decision of the arbitrator(s) may be appealed solely on the grounds that the conduct of the arbitrator(s), or the decision itself, violated the standards set forth in the Federal Arbitration Act or the Administrative Dispute Resolution Act. The final decision of the arbitrator must also be filed with FERC if it affects jurisdictional rates, terms and conditions of service, Interconnection Facilities, or Network Upgrades.

13.5.4 Costs.

Each Party shall be responsible for its own costs incurred during the arbitration process and for the following costs, if applicable: (1) the cost of the arbitrator chosen by the Party to sit on the three member panel and one half of the cost of the third arbitrator chosen; or (2) one half the cost of the single arbitrator jointly chosen by the Parties.

13.5.5

Non-binding dispute resolution procedures.

If a Party has submitted a Notice of Dispute pursuant to Section 13.5.1 of this LGIP, and the Parties are unable to resolve the claim or dispute through unassisted or assisted negotiations within the thirty (30) Calendar Days provided in that section, and the Parties cannot reach mutual agreement to pursue the Section 13.5 arbitration process, a Party may request that Transmission Provider engage in Non-binding Dispute Resolution pursuant to this Section by providing written notice to Transmission Provider (“Request for Non-binding Dispute Resolution”). Conversely, either Party may file a Request for Non-binding Dispute Resolution pursuant to this Section without first seeking mutual agreement to pursue the Section 13.5 arbitration process.

The process in this Section 13.5.5 shall serve as an alternative to, and not a replacement of, the Section 13.5 arbitration process. Pursuant to this process, a Transmission Provider must within thirty (30) Calendar Days of receipt of the Request for Non-binding Dispute Resolution appoint a neutral decision-maker that is an independent subcontractor that shall not have any current or past substantial business or financial relationships with either Party. Unless otherwise agreed by the Parties, the decision-maker shall render a decision within sixty (60) Calendar Days of appointment and shall notify the Parties in writing of such decision and reasons therefore.

This decision-maker shall be authorized only to interpret and apply the provisions of the LGIP and LGIA and shall have no power to modify or change any provision of the LGIP and LGIA in any manner. The result reached in this process is not binding, but, unless otherwise agreed, the Parties may cite the record and decision in the non-binding dispute resolution process in future dispute resolution processes, including in a Section 13.5 arbitration, or in a Federal Power Act section

206 complaint. Each Party shall be responsible for its own costs incurred during the process and the cost of the decision-maker shall be divided equally among each Party to the dispute.

13.6 Local Furnishing Bonds.

13.6.1 Transmission Providers That Own Facilities Financed by Local Furnishing Bonds.

This provision is applicable only to a Transmission Provider that has financed facilities for the local furnishing of electric energy with tax-exempt bonds, as described in Section 142(f) of the Internal Revenue Code (“local furnishing bonds”). Notwithstanding any other provision of this LGIA and LGIP, Transmission Provider shall not be required to provide Interconnection Service to Interconnection Customer pursuant to this LGIA and LGIP if the provision of such Transmission Service would jeopardize the tax-exempt status of any local furnishing bond(s) used to finance Transmission Provider’s facilities that would be used in providing such Interconnection Service.

13.6.2 Alternative Procedures for Requesting Interconnection Service.

If Transmission Provider determines that the provision of Interconnection Service requested by Interconnection Customer would jeopardize the tax-exempt status of any local furnishing bond(s) used to finance its facilities that would be used in providing such Interconnection Service, it shall advise Interconnection Customer within thirty (30) Calendar Days of receipt of the Interconnection Request.

Interconnection Customer thereafter may renew its request for interconnection using the process specified in Section 5.2(ii) of Transmission Provider’s Tariff.

13.7 Engineering & Procurement ('E&P') Agreement.

Prior to executing an LGIA, an Interconnection Customer may, in order to advance the implementation of its interconnection, request and Transmission Provider shall offer Interconnection Customer, an E&P Agreement that authorizes Transmission Provider to begin engineering and procurement of long lead-time items necessary for the establishment of the interconnection. However, Transmission Provider shall not be obligated to offer an E&P Agreement if Interconnection Customer is in Dispute Resolution as a result of an allegation that Interconnection Customer has failed to meet any milestones or comply with any prerequisites specified in other parts of the LGIP. The E&P Agreement is an optional procedure and it will not alter Interconnection Customer's Queue Position or In-Service Date. The E&P Agreement shall provide for Interconnection Customer to pay the cost of all activities authorized by Interconnection Customer and to make advance payments or provide other satisfactory security for such costs.

Interconnection Customer shall pay the cost of such authorized activities and any cancellation costs for equipment that is already ordered for its interconnection, which cannot be mitigated as hereafter described, whether or not such items or equipment later become unnecessary. If Interconnection Customer withdraws its Interconnection Request or either Party terminates the E&P Agreement, to the extent the equipment ordered can be canceled under reasonable terms, Interconnection Customer shall be obligated to pay the associated cancellation costs. To the extent that the equipment cannot be reasonably canceled, Transmission Provider may elect: (i) to take title to the equipment, in which event Transmission Provider shall refund Interconnection Customer any amounts paid by Interconnection Customer for such equipment and shall pay the cost of delivery of such equipment, or (ii) to transfer title to and deliver such equipment to Interconnection Customer, in which event Interconnection Customer shall pay any unpaid balance and cost of delivery of such equipment.

APPENDIX 1 to LGIP**INTERCONNECTION REQUEST FOR A
LARGE GENERATING FACILITY**

1. The undersigned Interconnection Customer submits this request to interconnect its Large Generating Facility with Transmission Provider's Transmission System pursuant to a Tariff.

2. This Interconnection Request is for (check one):
 A proposed new Large Generating Facility.
 An increase in the generating capacity or a Material Modification of an existing Generating Facility.

3. The type of interconnection service requested (check one):
 Energy Resource Interconnection Service
 Network Resource Interconnection Service

4. Check here only if Interconnection Customer requesting Network Resource Interconnection Service also seeks to have its Generating Facility studied for Energy Resource Interconnection Service

5. Interconnection Customer provides the following information:
 - a. Address or location of the proposed new Large Generating Facility site (to the extent known) or, in the case of an existing Generating Facility, the name and specific location of the existing Generating Facility;

 - b. Maximum summer at _____ degrees C and winter at _____ degrees C megawatt electrical output of the proposed new Large Generating Facility or the amount of megawatt increase in the generating capacity of an existing Generating Facility;

 - c. General description of the equipment configuration;

- d. Commercial Operation Date (Day, Month, and Year);
 - e. Name, address, telephone number, and e-mail address of Interconnection Customer's contact person;
 - f. Approximate location of the proposed Point of Interconnection (optional);
 - g. Interconnection Customer Data (set forth in Attachment A);
 - h. Primary frequency response operating range for electric storage resources;
 - i. Requested capacity (in MW) of Interconnection Service (if lower than the Generating Facility Capacity);
 - j. If applicable, (1) the requested operating assumptions (i.e., whether the interconnecting Generating Facility will or will not charge at peak load) to be used by Transmission Provider that reflect the proposed charging behavior of a Generating Facility that includes at least one electric storage resource, and (2) a description of any control technologies (software and/or hardware) that will limit the operation of the Generating Facility to its intended operation.
6. Applicable deposit amount as specified in the LGIP.
7. Evidence of Site Control as specified in the LGIP (check one)
- Is attached to this Interconnection Request
- Will be provided at a later date in accordance with this LGIP
8. This Interconnection Request shall be submitted to the representative indicated below:

{To be completed by Transmission Provider}

9. Representative of Interconnection Customer to contact:

{To be completed by Interconnection Customer}

10. This Interconnection Request is submitted by:

Name of Interconnection Customer: _____

By (signature): _____

Name (type or print): _____

Title: _____

Date: _____

Attachment A to Appendix 1

Interconnection Request

LARGE GENERATING FACILITY DATA

UNIT RATINGS

kVA _____ °F _____ Voltage _____

Power Factor _____

Speed (RPM) _____

Connection (e.g. Wye)

Short Circuit Ratio _____

Frequency, Hertz _____

Stator Amperes at Rated kVA _____

Field Volts _____

Max Turbine MW _____ °F _____

Primary frequency response operating range for electric storage resources:

Minimum State of Charge: _____

Maximum State of Charge: _____

COMBINED TURBINE-GENERATOR-EXCITER INERTIA DATA

Inertia Constant, H = _____ kW sec/kVA

Moment-of-Inertia, $WR^2 =$ _____ lb. ft.²

REACTANCE DATA (PER UNIT-RATED KVA)

	DIRECT AXIS	QUADRATURE AXIS
Synchronous – saturated	X_{dv} _____	X_{qv} _____
Synchronous – unsaturated	X_{di} _____	X_{qi} _____
Transient – saturated	X'_{dv} _____	X'_{qv} _____
Transient – unsaturated	X'_{di} _____	X'_{qi} _____
Subtransient – saturated	X''_{dv} _____	X''_{qv} _____
Subtransient – unsaturated	X''_{di} _____	X''_{qi} _____
Negative Sequence – saturated	X_{2v} _____	
Negative Sequence – unsaturated	X_{2i} _____	

Zero Sequence – saturated

X_{0v} _____

Zero Sequence – unsaturated

X_{0i} _____

Leakage Reactance

X_{lm} _____

FIELD TIME CONSTANT DATA (SEC)

Open Circuit	T'_{do}	_____	T'_{qo}	_____
Three-Phase Short Circuit Transient	T'_{d3}	_____	T'_q	_____
Line to Line Short Circuit Transient	T'_{d2}	_____		
Line to Neutral Short Circuit Transient	T'_{d1}	_____		
Short Circuit Subtransient	T''_d	_____	T''_q	_____
Open Circuit Subtransient	T''_{do}	_____	T''_{qo}	_____

ARMATURE TIME CONSTANT DATA (SEC)

Three Phase Short Circuit	T_{a3}	_____
Line to Line Short Circuit	T_{a2}	_____
Line to Neutral Short Circuit	T_{a1}	_____

NOTE: If requested information is not applicable, indicate by marking "N/A."

**MW CAPABILITY AND PLANT CONFIGURATION
LARGE GENERATING FACILITY DATA**

ARMATURE WINDING RESISTANCE DATA (PER UNIT)

Positive R_1 _____

Negative R_2 _____

Zero R_0 _____

Rotor Short Time Thermal Capacity $I_2^2t =$ _____

Field Current at Rated kVA, Armature Voltage and PF = _____ amps

Field Current at Rated kVA and Armature Voltage, 0 PF = _____ amps

Three Phase Armature Winding Capacitance = _____ microfarad

Field Winding Resistance = _____ ohms _____ °C

Armature Winding Resistance (Per Phase) = _____ ohms _____ °C

CURVES

Provide Saturation, Vee, Reactive Capability, Capacity Temperature Correction curves.
Designate normal and emergency Hydrogen Pressure operating range for multiple curves.

GENERATOR STEP-UP TRANSFORMER DATA RATINGS

Capacity Self-cooled/
Maximum Nameplate
_____ / _____ kVA

Voltage Ratio(Generator Side/System side/Tertiary)
_____ / _____ / _____
kV

Winding Connections (Low V/High V/Tertiary V (Delta or Wye))
_____ / _____ / _____

Fixed Taps Available _____

Present Tap Setting _____

IMPEDANCE

Positive Z_1 (on self-cooled kVA rating) _____ % _____
X/R

Zero Z_0 (on self-cooled kVA rating) _____ % _____
X/R

EXCITATION SYSTEM DATA

Identify appropriate IEEE model block diagram of excitation system and power system stabilizer (PSS) for computer representation in power system stability simulations and the corresponding excitation system and PSS constants for use in the model.

GOVERNOR SYSTEM DATA

Identify appropriate IEEE model block diagram of governor system for computer representation in power system stability simulations and the corresponding governor system constants for use in the model.

WIND GENERATORS

Number of generators to be interconnected pursuant to this Interconnection Request:

Elevation: _____ _____ Single Phase _____ Three Phase

Inverter manufacturer, model name, number, and version:

List of adjustable setpoints for the protective equipment or software:

Note: A completed General Electric Company Power Systems Load Flow (PSLF) data sheet or other compatible formats, such as IEEE and PTI power flow models, must be supplied with the Interconnection Request. If other data sheets are more appropriate to the proposed device, then they shall be provided and discussed at Scoping Meeting.

INDUCTION GENERATORS

- (*) Field Volts: _____
- (*) Field Amperes: _____
- (*) Motoring Power (kW): _____
- (*) Neutral Grounding Resistor (If Applicable): _____
- (*) I_2^2t or K (Heating Time Constant): _____
- (*) Rotor Resistance: _____
- (*) Stator Resistance: _____
- (*) Stator Reactance: _____
- (*) Rotor Reactance: _____
- (*) Magnetizing Reactance: _____
- (*) Short Circuit Reactance: _____
- (*) Exciting Current: _____
- (*) Temperature Rise: _____
- (*) Frame Size: _____
- (*) Design Letter: _____
- (*) Reactive Power Required In Vars (No Load): _____
- (*) Reactive Power Required In Vars (Full Load): _____
- (*) Total Rotating Inertia, H: _____ Per Unit on KVA Base

Note: Please consult Transmission Provider prior to submitting the Interconnection Request to determine if the information designated by (*) is required.

MODELS FOR NON-SYNCHRONOUS GENERATORS

For a non-synchronous Large Generating Facility, Interconnection Customer shall provide (1) a validated user-defined root mean squared (RMS) positive sequence dynamics model; (2) an appropriately parameterized generic library RMS positive sequence dynamics model, including model block diagram of the inverter control and plant control systems, as defined by the selection in Table 1 or a model otherwise approved by the Western Electricity Coordinating Council, that corresponds to Interconnection Customer's Large Generating Facility; and (3) if applicable, a validated electromagnetic transient model if Transmission Provider performs an electromagnetic transient study as part of the interconnection study process. A user-defined model is a set of programming code created by equipment manufacturers or developers that captures the latest features of controllers that are mainly software based and represents the entities' control strategies but does not necessarily correspond to any generic library model. Interconnection Customer must also demonstrate that the model is validated by providing evidence that the equipment behavior is consistent with the model behavior (e.g., an attestation from Interconnection Customer that the model accurately represents the entire Large Generating Facility; attestations from each equipment manufacturer that the user defined model accurately represents the component of the Large Generating Facility; or test data).

Table 1: Acceptable Generic Library RMS Positive Sequence Dynamics Models

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
pvd1		PVD1	Distributed PV system model
der_a	DERAU1	DER_A	Distributed energy resource model
regc_a	REGCAU1, REGCA1	REGC_A	Generator/converter model
regc_b	REGCBU1	REGC_B	Generator/converter model
wt1g	WT1G1	WT1G and WT1G1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)
wt2g	WT2G1	WT2G and WT2G1	Generator model for generic Type-2 wind turbines

wt2e	WT2E1	WT2E and WT2E1	Rotor resistance control model for wound-rotor induction wind-turbine generator wt2g
reec_a	REECAU1, REECA1	REEC_A	Renewable energy electrical control model
reec_c	REECCU1	REEC_C	Electrical control model for battery energy storage system
reec_d	REECDU1	REEC_D	Renewable energy electrical control model
wt1t	WT12T1	WT1T and WT12T1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)
wt1p_b	wt1p_b	WT12A1U_B	Generic wind turbine pitch controller for WTGs of Types 1 and 2
wt2t	WT12T1	WT2T	Wind turbine model for Type-2 wind turbines (directly connected induction generator wind turbines with an external rotor resistance)
wtgt_a	WTDTAU1, WTDTA1	WTGT_A	Wind turbine drive train model
wtga_a	WTARAU1, WTARA1	WTGA_A	Simple aerodynamic model
wtgp_a	WTPTAU1, WTPTA1	WTGPT_A	Wind Turbine Generator Pitch controller
wtgq_a	WTTQAU1, WTTQA1	WTGTRQ_A	Wind Turbine Generator Torque controller
wtgwgo_a	WTGWGOAU	WTGWGO_A	Supplementary control model for Weak Grids
wtgibffr_a	WTGIBFFRA	WTGIBFFR_A	Inertial-base fast frequency response control
wtgp_b	WTPTBU1	WTGPT_B	Wind Turbine Generator Pitch controller
wtgt_b	WTDTBUI	WTGT_B	Drive train model
repc_a	Type 4: REPCAU1	REPC_A	Power Plant Controller

	(v33), REPCA1 (v34) Type 3: REPCTAU1 (v33), REPCTA1 (v34)		
repc_b	PLNTBU1	REPC_B	<p>Power Plant Level Controller for controlling several plants/devices</p> <p>In regard to Siemens PSS/E*: Names of other models for interface with other devices: REA3XBU1, REAX4BU1- for interface with Type 3 and 4 renewable machines SWSAXBU1- for interface with SVC (modeled as switched shunt in powerflow) SYNAXBU1- for interface with synchronous condenser FCTAXBUI- for interface with FACTS device</p>
repc_c	REPCCU	REPC_C	Power plant controller

**APPENDIX 2 to LGIP
CLUSTER STUDY AGREEMENT**

THIS AGREEMENT is made and entered into this ____ day of _____, 20__ by and between _____, a _____ organized and existing under the laws of the State of _____, (“Interconnection Customer,”) and _____ a _____ organized and existing under the laws of the State of _____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a Cluster Study to assess the impact of interconnecting the Large Generating Facility to the Transmission System, and of any Affected Systems; and

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be performed a Cluster Study consistent with Section 7.0 of this LGIP in accordance with the Tariff.

- 3.0 The scope of the Cluster Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Cluster Study will be based upon the technical information provided by Interconnection Customer in the Interconnection Request, subject to any modifications in accordance with Section 4.4 of this LGIP. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the Cluster Study.
- 5.0 The Cluster Study Report shall provide the following information:
- identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection and
 - description and non-binding, good faith estimated cost of facilities required to interconnect the Large Generating Facility to the Transmission System and to address the identified short circuit, instability, and power flow issues.
- 6.0 Transmission Provider's good faith estimate for the time of completion of the Cluster Study is {insert date}.

Upon receipt of the Cluster Study Report, Transmission Provider shall charge and Interconnection Customer shall pay its share of the actual costs of the Cluster Study, consistent with Section 13.3 of this LGIP.

Any difference between the deposit and the actual cost of the study shall be paid by or refunded to Interconnection Customer, as appropriate.

7.0 Miscellaneous. The Cluster Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP and the LGIA.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____ By:

Title: _____ Title:

Date: _____ Date:

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

**Attachment A To Appendix 2
Cluster Study Agreement**

**ASSUMPTIONS USED IN CONDUCTING THE
CLUSTER STUDY**

The Cluster Study will be based upon the technical information provided by Interconnection Customer in the Interconnection Request, subject to any modifications in accordance with Section 4.4 of this LGIP, and the following assumptions:

Designation of Point of Interconnection and configuration to be studied.

Designation of alternative Point(s) of Interconnection and configuration.

{Above assumptions to be completed by Interconnection Customer and other assumptions to be provided by Interconnection Customer and Transmission Provider}

**APPENDIX 3 to LGIP
INTERCONNECTION FACILITIES STUDY AGREEMENT**

THIS AGREEMENT is made and entered into this _____ day of _____, 20____ by and between _____, a _____ organized and existing under the laws of the State of _____

_____, (“Interconnection Customer,”) and

_____ organized and existing under the laws of the State of _____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Transmission Provider has completed a Cluster Study (the “Cluster Study”) and provided the results of said study to Interconnection Customer; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform an Interconnection Facilities Study to specify and estimate the cost of the equipment, engineering, procurement and construction work needed to implement the conclusions of the Cluster Study in accordance with Good Utility Practice to physically and electrically connect the Large Generating Facility to the Transmission System.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in Transmission Provider’s FERC-approved LGIP.

- 2.0 Interconnection Customer elects and Transmission Provider shall cause an Interconnection Facilities Study consistent with Section 8.0 of this LGIP to be performed in accordance with the Tariff.
- 3.0 The scope of the Interconnection Facilities Study shall be subject to the assumptions set forth in Attachment A and the data provided in Attachment B to this Agreement.
- 4.0 The Interconnection Facilities Study Report (i) shall provide a description, estimated cost of (consistent with Attachment A), schedule for required facilities to interconnect the Large Generating Facility to the Transmission System and (ii) shall address the short circuit, instability, and power flow issues identified in the Cluster Study.
- 5.0 Interconnection Customer shall provide a Commercial Readiness Deposit per Section 8.1 of this LGIP to enter the Interconnection Facilities Study. The time for completion of the Interconnection Facilities Study is specified in Attachment A.
- 6.0 Miscellaneous. The Interconnection Facilities Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP and the LGIA.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____ By:

Title: _____ Title:

Date: _____ Date:

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

**Attachment A To Appendix 3
Interconnection Facilities
Study Agreement**

**INTERCONNECTION CUSTOMER SCHEDULE ELECTION FOR
CONDUCTING THE INTERCONNECTION FACILITIES STUDY**

Transmission Provider shall complete the study and issue a draft Interconnection Facilities Study Report to Interconnection Customer within the following number of days after receipt of an executed copy of this Interconnection Facilities Study Agreement:

- ninety (90) Calendar Days with no more than a +/- 20 percent cost estimate contained in the report, or
- one hundred eighty (180) Calendar Days with no more than a +/- 10 percent cost estimate contained in the report.

Attachment B to Appendix 3
Interconnection Facilities
Study Agreement

DATA FORM TO BE PROVIDED BY INTERCONNECTION CUSTOMER
WITH THE
INTERCONNECTION FACILITIES STUDY AGREEMENT

Provide location plan and simplified one-line diagram of the plant and station facilities. For staged projects, please indicate future generation, transmission circuits, etc.

One set of metering is required for each generation connection to the new ring bus or existing Transmission Provider station. Number of generation connections:

On the one-line diagram indicate the generation capacity attached at each metering location. (Maximum load on CT/PT)

On the one-line diagram indicate the location of auxiliary power. (Minimum load on CT/PT) Amps

Will an alternate source of auxiliary power be available during CT/PT maintenance?

_____ Yes _____ No

Will a transfer bus on the generation side of the metering require that each meter set be designed for the total plant generation? _____ Yes _____ No (Please indicate on one line diagram).

What type of control system or PLC will be located at Interconnection Customer's Large Generating Facility?

What protocol does the control system or PLC use?

Please provide a 7.5-minute quadrangle of the site. Sketch the plant, station, transmission line, and property line.

Physical dimensions of the proposed interconnection station:

Bus length from generation to interconnection station:

Line length from interconnection station to Transmission Provider's transmission line.

**APPENDIX 4 to LGIP
OPTIONAL INTERCONNECTION STUDY AGREEMENT**

THIS AGREEMENT is made and entered into this ____ day of _____, 20__ by and between _____, a _____ organized and existing under the laws of the State of _____, (“Interconnection Customer,”) and _____ a _____ organized and existing under the laws of the State of _____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party, ” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer is proposing to establish an interconnection with the Transmission System; and

WHEREAS, Interconnection Customer has submitted to Transmission Provider an Interconnection Request; and

WHEREAS, on or after the date when Interconnection Customer receives the Cluster Study results, Interconnection Customer has further requested that Transmission Provider prepare an Optional Interconnection Study;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in Transmission Provider's FERC-approved LGIP.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause an Optional Interconnection Study consistent with Section 10.0 of this LGIP to be performed in accordance with the Tariff.
- 3.0 The scope of the Optional Interconnection Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Optional Interconnection Study shall be performed solely for informational purposes.
- 5.0 The Optional Interconnection Study report shall provide a sensitivity analysis based on the assumptions specified by Interconnection Customer in Attachment A to this Agreement. The Optional Interconnection Study will identify Transmission Provider's Interconnection Facilities and the Network Upgrades, and the estimated cost thereof, that may be required to provide transmission service or interconnection service based upon the assumptions specified by Interconnection Customer in Attachment A.
- 6.0 Interconnection Customer shall provide a deposit of \$10,000 for the performance of the Optional Interconnection Study. Transmission Provider's good faith estimate for the time of completion of the Optional Interconnection Study is {insert date}.

Upon receipt of the Optional Interconnection Study, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Optional Study.

Any difference between the initial payment and the actual cost of the study shall be paid by or refunded to Interconnection Customer, as appropriate.

7.0 Miscellaneous. The Optional Interconnection Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP and the LGIA.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____

Title: _____

Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

APPENDIX 5 to LGIP
LARGE GENERATOR INTERCONNECTION AGREEMENT
(SEE LGIA)

APPENDIX 6 to LGIP
INTERCONNECTION PROCEDURES FOR A WIND GENERATING PLANT

Appendix 6 sets forth procedures specific to a wind generating plant. All other requirements of this LGIP continue to apply to wind generating plant interconnections.

A. Special Procedures Applicable to Wind Generators

The wind plant Interconnection Customer, in completing the Interconnection Request required by Section 3.3 of this LGIP, may provide to Transmission Provider a set of preliminary electrical design specifications depicting the wind plant as a single equivalent generator. Upon satisfying these and other applicable Interconnection Request conditions, the wind plant may enter the queue and receive the base case data as provided for in this LGIP.

No later than six months after submitting an Interconnection Request completed in this manner, the wind plant Interconnection Customer must submit completed detailed electrical design specifications and other data (including collector system layout data) needed to allow Transmission Provider to complete the Cluster Study.

**APPENDIX 7 to LGIP
TRANSITIONAL CLUSTER STUDY AGREEMENT**

THIS AGREEMENT is made and entered into this ____ day of _____, 20__ by and between _____, a _____ organized and existing under the laws of the State of _____ (“Interconnection Customer”), and _____, a _____ organized and existing under the laws of the State of _____ (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____;

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a “Transitional Cluster Study,” which combines the Cluster Study and Interconnection Facilities Study, in a single cluster study, followed by any needed restudies, to specify and estimate the cost of the equipment, engineering, procurement, and construction work needed to physically and electrically connect the Large Generating Facility to Transmission Provider’s Transmission System; and

WHEREAS, Interconnection Customer has a valid Queue Position as of the {Transmission Provider to insert Commission-approved effective date of compliance filing}.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Interconnection Customer elects, and Transmission Provider shall cause to be performed, a Transitional Cluster Study.
- 3.0 The Transitional Cluster Study shall be based upon the technical information provided by Interconnection Customer in the Interconnection Request. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the Transitional Cluster Study and Interconnection Customer shall provide such data as quickly as reasonable.
- 4.0 Pursuant to Section 5.1.1.2 of this LGIP, the interim Transitional Cluster Study Report shall provide the information below:
 - identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection; and
 - Transmission Provider's Interconnection Facilities and Network Upgrades that are expected to be required as a result of the Interconnection Request(s) and a non-binding, good faith estimate of

cost responsibility and a non-binding, good faith estimated time to construct.

- 5.0 Pursuant to Section 5.1.1.2 of this LGIP, the final Transitional Cluster Study Report shall: (1) provide all the information included in the interim Transitional Cluster Study Report; (2) provide a description of, estimated cost of, and schedule for required facilities to interconnect the Generating Facility to the Transmission System; and (3) address the short circuit, instability, and power flow issues identified in the interim Transitional Cluster Study Report.
- 6.0 Interconnection Customer has met the requirements described in Section 5.1.1.2 of this LGIP.
- 7.0 Interconnection Customer previously provided a deposit for the performance of Interconnection Studies. Upon receipt of the final Transitional Cluster Study Report, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Transitional Cluster Study. Any difference between the study deposit and the actual cost of the study shall be paid by or refunded to Interconnection Customer, in accordance with the provisions of Section 13.3 of this LGIP.
- 8.0 Miscellaneous. The Transitional Cluster Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP and the LGIA.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____

Title: _____

Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

APPENDIX 8 to LGIP
TRANSITIONAL SERIAL INTERCONNECTION FACILITIES STUDY
AGREEMENT

THIS AGREEMENT is made and entered into this ____ day of ____, 20__, by and between _____, a _____ organized and existing under the laws of the State of _____ (“Interconnection Customer”) and _____, a _____ organized and existing under the laws of the State of _____ (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Large Generating Facility or generating capacity addition to an existing Large Generating Facility consistent with the Interconnection Request submitted by Interconnection Customer dated _____; and

WHEREAS, Interconnection Customer desires to interconnect the Large Generating Facility with the Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to continue processing its Interconnection Facilities Study to specify and estimate the cost of the equipment, engineering, procurement, and construction work needed to implement the conclusions of the final interconnection system impact study (from the previously effective serial study process) in accordance with Good Utility Practice to physically and electrically connect the Large Generating Facility to the Transmission System; and

WHEREAS, Transmission Provider has provided an Interconnection Facilities Study Agreement to Interconnection Customer on or before {Transmission Provider to insert Commission-approved effective date of compliance filing}.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be performed an Interconnection Facilities Study consistent with Section 8 of this LGIP.
- 3.0 The scope of the Interconnection Facilities Study shall be subject to the assumptions set forth in Attachment A to this Agreement, which shall be the same assumptions as the previous Interconnection Facilities Study Agreement executed by Interconnection Customer.
- 4.0 The Interconnection Facilities Study Report shall: (1) provide a description, estimated cost of (consistent with Attachment A), and schedule for required facilities to interconnect the Large Generating Facility to the Transmission System; and (2) address the short circuit, instability, and power flow issues identified in the most recently published Cluster Study Report.
- 5.0 Interconnection Customer has met the requirements described in Section 5.1.1.1 of this LGIP. The time for completion of the Interconnection Facilities Study is specified in Attachment A, and shall be no later than one hundred fifty (150) Calendar Days after {Transmission Provider to insert Commission-approved effective date of compliance filing}.
- 6.0 Interconnection Customer previously provided a deposit of _____ dollars (\$___) for the performance of the Interconnection Facilities Study.

- 7.0 Upon receipt of the Interconnection Facilities Study results, Transmission Provider shall charge and Interconnection Customer shall pay the actual costs of the Interconnection Facilities Study.

- 8.0 Any difference between the study deposit and the actual cost of the study shall be paid by or refunded to Interconnection Customer, as appropriate.

- 9.0 Miscellaneous. The Interconnection Facilities Study Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, that reflect best practices in the electric industry, and that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP and this LGIA.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____

Title: _____

Date: _____

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

**Attachment A to Appendix 8
Transitional Serial Interconnection Facilities Study Agreement**

**ASSUMPTIONS USED IN CONDUCTING THE TRANSITIONAL SERIAL
INTERCONNECTION FACILITIES STUDY**

{Assumptions to be completed by Interconnection Customer and Transmission Provider}

APPENDIX 9 to LGIP
TWO-PARTY AFFECTED SYSTEM STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ___ day of _____, 20___, by and between _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer) and _____, a _____ organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customer and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Affected System Interconnection Customer is proposing to develop a {description of generating facility or generating capacity addition to an existing generating facility} consistent with the interconnection request submitted by Affected System Interconnection Customer to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customer desires to interconnect the {generating facility} with {name of host transmission provider}’s transmission system;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.

- 2.0 Transmission Provider shall coordinate with Affected System Interconnection Customer to perform an Affected System Study consistent with Section 9 of this LGIP.
- 3.0 The scope of the Affected System Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Affected System Study will be based upon the technical information provided by Affected System Interconnection Customer and {name of host transmission provider}. Transmission Provider reserves the right to request additional technical information from Affected System Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the Affected System Study.
- 5.0 The Affected System Study shall provide the following information:
 - identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection;
 - non-binding, good faith estimated cost and time required to construct facilities required on Transmission Provider's Transmission System to accommodate the interconnection of the {generating facility} to the transmission system of the host transmission provider; and

description of how such facilities will address the identified short circuit, instability, and power flow issues.

- 6.0 Affected System Interconnection Customer shall provide a deposit of _____ for performance of the Affected System Study. Upon receipt of the results of the Affected System Study by the Affected System Interconnection Customer, Transmission Provider shall charge, and Affected System Interconnection Customer shall pay, the actual cost of the Affected System Study. Any difference between the deposit and the actual cost of the Affected System Study shall be paid by or refunded to Affected System Interconnection Customer, as appropriate, including interest calculated in accordance with section 35.19a(a)(2) of FERC’s regulations.

- 7.0 This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability, and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Affected System Interconnection Customer}

By: _____

Title: _____

Date: _____

Project No. _____

**Attachment A to Appendix 9
Two-Party Affected System Study Agreement**

**ASSUMPTIONS USED IN CONDUCTING THE
AFFECTED SYSTEM STUDY**

The Affected System Study will be based upon the following assumptions:

{Assumptions to be completed by Affected System Interconnection Customer and
Transmission Provider}

APPENDIX 10 to LGIP
MULTIPARTY AFFECTED SYSTEM STUDY AGREEMENT

THIS AGREEMENT is made and entered into this ___ day of _____, 20___, by and among _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); and _____, a _____ organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customers and Transmission Provider each may be referred to as a “Party,” or collectively as the “Parties.” When it is not important to differentiate among them, Affected System Interconnection Customers each may be referred to as “Affected System Interconnection Customer” or collectively as the “Affected System Interconnection Customers.”

RECITALS

WHEREAS, Affected System Interconnection Customers are proposing to develop {description of generating facilities or generating capacity additions to an existing generating facility}, consistent with the interconnection requests submitted by Affected System Interconnection Customers to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customers desire to interconnect the {generating facilities} with {name of host transmission provider}’s transmission system;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated in this LGIP.
- 2.0 Transmission Provider shall coordinate with Affected System Interconnection Customers to perform an Affected System Study consistent with Section 9 of this LGIP.
- 3.0 The scope of the Affected System Study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The Affected System Study will be based upon the technical information provided by Affected System Interconnection Customers and {name of host transmission provider}. Transmission Provider reserves the right to request additional technical information from Affected System Interconnection Customers as may reasonably become necessary consistent with Good Utility Practice during the course of the Affected System Study.
- 5.0 The Affected System Study shall provide the following information:
 - identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - identification of any instability or inadequately damped response to system disturbances resulting from the interconnection;
 - non-binding, good faith estimated cost and time required to construct facilities required on Transmission Provider's Transmission System

to accommodate the interconnection of the {generating facilities} to the transmission system of the host transmission provider; and

description of how such facilities will address the identified short circuit, instability, and power flow issues.

6.0 Affected System Interconnection Customers shall each provide a deposit of _____ for performance of the Affected System Study. Upon receipt of the results of the Affected System Study by the Affected System Interconnection Customers, Transmission Provider shall charge, and Affected System Interconnection Customers shall pay, the actual cost of the Affected System Study. Any difference between the deposit and the actual cost of the Affected System Study shall be paid by or refunded to Affected System Interconnection Customers, as appropriate, including interest calculated in accordance with section 35.19a(a)(2) of FERC’s regulations.

7.0 This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability, and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of the LGIP.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider}

By: _____ By: _____

Title: _____ Title: _____

Date: _____ Date: _____

{Insert name of Affected System Interconnection Customer}

By: _____

Title: _____

Date: _____

Project No. _____

{Insert name of Affected System Interconnection Customer}

By: _____

Title: _____

Date: _____

Project No. _____

Attachment A to Appendix 10
Multiparty Affected System Study Agreement

ASSUMPTIONS USED IN CONDUCTING THE
MULTIPARTY AFFECTED SYSTEM STUDY

The Affected System Study will be based upon the following assumptions:

{Assumptions to be completed by Affected System Interconnection Customers and
Transmission Provider}

APPENDIX 11 TO LGIP
TWO-PARTY AFFECTED SYSTEM FACILITIES CONSTRUCTION
AGREEMENT

THIS AGREEMENT is made and entered into this ____ day of _____, 20__, by and between _____, organized and existing under the laws of the State of _____ (Affected System Interconnection Customer) and _____, an entity organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customer and Transmission Provider each may be referred to as a “Party” or collectively as the “Parties.”

RECITALS

WHEREAS, Affected System Interconnection Customer is proposing to develop a {description of generating facility or generating capacity addition to an existing generating facility} consistent with the interconnection request submitted by Affected System Interconnection Customer to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customer desires to interconnect the {generating facility} to {name of host transmission provider}’s transmission system; and

WHEREAS, additions, modifications, and upgrade(s) must be made to certain existing facilities of Transmission Provider’s Transmission System to accommodate such interconnection; and

WHEREAS, Affected System Interconnection Customer has requested, and Transmission Provider has agreed, to enter into this Agreement for the purpose of facilitating the construction of necessary Affected System Network Upgrade(s);

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

ARTICLE 1
DEFINITIONS

When used in this Agreement, with initial capitalization, the terms specified and not otherwise defined in this Agreement shall have the meanings indicated in this LGIP.

ARTICLE 2
TERM OF AGREEMENT

2.1 Effective Date. This Agreement shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by FERC.

2.2 Term.

2.2.1 General. This Agreement shall become effective as provided in Article 2.1 and shall continue in full force and effect until the earlier of (1) the final repayment, where applicable, by Transmission Provider of the amount funded by Affected System Interconnection Customer for Transmission Provider's design, procurement, construction and installation of the Affected System Network Upgrade(s) provided in Appendix A; (2) the Parties agree to mutually terminate this Agreement; (3) earlier termination is permitted or provided for under Appendix A of this Agreement; or (4) Affected System Interconnection Customer terminates this Agreement after providing Transmission Provider with written notice at least sixty (60) Calendar Days prior to the proposed termination date, provided that Affected System Interconnection Customer has no outstanding contractual obligations to Transmission Provider under this Agreement. No termination of this Agreement shall be effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination. The term of this Agreement may be adjusted upon

mutual agreement of the Parties if (1) the commercial operation date for the {generating facility} is adjusted in accordance with the rules and procedures established by {name of host transmission provider} or (2) the in-service date for the Affected System Network Upgrade(s) is adjusted in accordance with the rules and procedures established by Transmission Provider.

2.2.2 Termination Upon Default. Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 5 of this Agreement where Breach and Breaching Party are defined in Article 5. Defaulting Party shall mean the Party that is in Default. In the event of a Default by a Party, the non-Defaulting Party shall have the termination rights described in Articles 5 and 6; provided, however, Transmission Provider may not terminate this Agreement if Affected System Interconnection Customer is the Defaulting Party and compensates Transmission Provider within thirty (30) Calendar Days for the amount of damages billed to Affected System Interconnection Customer by Transmission Provider for any such damages, including costs and expenses, incurred by Transmission Provider as a result of such Default.

2.2.3 Consequences of Termination. In the event of a termination by either Party, other than a termination by Affected System Interconnection Customer due to a Default by Transmission Provider, Affected System Interconnection Customer shall be responsible for the payment to Transmission Provider of all amounts then due and payable for construction and installation of the Affected System Network Upgrade(s) (including, without limitation, any equipment ordered related to such construction), plus all out-of-pocket expenses incurred by Transmission Provider in connection with the construction and installation of the Affected System Network Upgrade(s), through the date of termination, and, in the event of the termination of the entire Agreement, any actual costs which Transmission Provider reasonably incurs in (1) winding up work and construction demobilization and (2) ensuring the safety of persons and property and the integrity and safe and reliable operation of Transmission Provider's Transmission System. Transmission Provider shall use Reasonable Efforts to minimize such costs.

- 2.2.4 Reservation of Rights.** Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Affected System Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement pursuant to section 206 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations thereunder, except to the extent that the Parties otherwise mutually agree as provided herein.
- 2.3 Filing.** Transmission Provider shall file this Agreement (and any amendment hereto) with the appropriate Governmental Authority, if required. Affected System Interconnection Customer may request that any information so provided be subject to the confidentiality provisions of Article 8. If Affected System Interconnection Customer has executed this Agreement, or any amendment thereto, Affected System Interconnection Customer shall reasonably cooperate with Transmission Provider with respect to such filing and to provide any information reasonably requested by Transmission Provider needed to comply with applicable regulatory requirements.
- 2.4 Survival.** This Agreement shall continue in effect after termination, to the extent necessary, to provide for final billings and payments and for costs incurred hereunder, including billings and payments pursuant to this Agreement; to permit the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and to permit each Party to have access to the lands of the other Party pursuant to this Agreement or other applicable agreements, to disconnect, remove, or salvage its own facilities and equipment.
- 2.5 Termination Obligations.** Upon any termination pursuant to this Agreement, Affected System Interconnection Customer shall be responsible for the payment of all costs or other contractual obligations incurred prior to the termination date,

including previously incurred capital costs, penalties for early termination, and costs of removal and site restoration.

ARTICLE 3

CONSTRUCTION OF AFFECTED SYSTEM NETWORK UPGRADE(S)

3.1 Construction.

3.1.1 Transmission Provider Obligations. Transmission Provider shall (or shall cause such action to) design, procure, construct, and install, and Affected System Interconnection Customer shall pay, consistent with Article 3.2, the costs of all Affected System Network Upgrade(s) identified in Appendix A. All Affected System Network Upgrade(s) designed, procured, constructed, and installed by Transmission Provider pursuant to this Agreement shall satisfy all requirements of applicable safety and/or engineering codes and comply with Good Utility Practice, and further, shall satisfy all Applicable Laws and Regulations. Transmission Provider shall not be required to undertake any action which is inconsistent with its standard safety practices, its material and equipment specifications, its design criteria and construction procedures, its labor agreements, or any Applicable Laws and Regulations.

3.1.2 Suspension of Work.

3.1.2.1 Right to Suspend. Affected System Interconnection Customer must provide to Transmission Provider written notice of its request for suspension. Only the milestones described in the Appendices of this Agreement are subject to suspension under this Article 3.1.2. Affected System Network Upgrade(s) will be constructed on the schedule described in the Appendices of this Agreement unless: (1) construction is prevented by the order of a Governmental Authority; (2) the Affected System Network Upgrade(s) are not needed by any other Interconnection Customer; or (3) Transmission Provider determines that a Force Majeure event

prevents construction. In the event of (1), (2), or (3), any security paid to Transmission Provider under Article 4.1 of this Agreement shall be released by Transmission Provider upon the determination by Transmission Provider that the Affected System Network Upgrade(s) will no longer be constructed. If suspension occurs, Affected System Interconnection Customer shall be responsible for the costs which Transmission Provider incurs (i) in accordance with this Agreement prior to the suspension; (ii) in suspending such work, including any costs incurred to perform such work as may be necessary to ensure the safety of persons and property and the integrity of Transmission Provider's Transmission System and, if applicable, any costs incurred in connection with the cancellation of contracts and orders for material which Transmission Provider cannot reasonably avoid; and (iii) reasonably incurs in winding up work and construction demobilization; provided, however, that, prior to canceling any such contracts or orders, Transmission Provider shall obtain Affected System Interconnection Customer's authorization. Affected System Interconnection Customer shall be responsible for all costs incurred in connection with Affected System Interconnection Customer's failure to authorize cancellation of such contracts or orders.

Interest on amounts paid by Affected System Interconnection Customer to Transmission Provider for the design, procurement, construction, and installation of the Affected System Network Upgrade(s) shall not accrue during periods in which Affected System Interconnection Customer has suspended construction under this Article 3.1.2.

Transmission Provider shall invoice Affected System Interconnection Customer pursuant to Article 4 and will use Reasonable Efforts to minimize its costs. In the event Affected System Interconnection Customer suspends work by Affected System Transmission Provider required under this Agreement pursuant to this Article 3.1.2.1, and has not requested Affected System Transmission Provider to recommence the work required under this Agreement on or

before the expiration of three (3) years following commencement of such suspension, this Agreement shall be deemed terminated. The three-year period shall begin on the date the suspension is requested, or the date of the written notice to Affected System Transmission Provider, whichever is earlier, if no effective date of suspension is specified.

3.1.3 Construction Status. Transmission Provider shall keep Affected System Interconnection Customer advised periodically as to the progress of its design, procurement and construction efforts, as described in Appendix A. Affected System Interconnection Customer may, at any time and reasonably, request a progress report from Transmission Provider. If, at any time, Affected System Interconnection Customer determines that the completion of the Affected System Network Upgrade(s) will not be required until after the specified in-service date, Affected System Interconnection Customer will provide written notice to Transmission Provider of such later date upon which the completion of the Affected System Network Upgrade(s) would be required. Transmission Provider may delay the in-service date of the Affected System Network Upgrade(s) accordingly.

3.1.4 Timely Completion. Transmission Provider shall use Reasonable Efforts to design, procure, construct, install, and test the Affected System Network Upgrade(s) in accordance with the schedule set forth in Appendix A, which schedule may be revised from time to time by mutual agreement of the Parties. If any event occurs that will affect the time or ability to complete the Affected System Network Upgrade(s), Transmission Provider shall promptly notify Affected System Interconnection Customer. In such circumstances, Transmission Provider shall, within fifteen (15) Calendar Days of such notice, convene a meeting with Affected System Interconnection Customer to evaluate the alternatives available to Affected System Interconnection Customer. Transmission Provider shall also make available to Affected System Interconnection Customer all studies and work papers related to the event and corresponding delay, including all information that is in the possession of Transmission Provider that is reasonably needed by Affected System Interconnection Customer to evaluate alternatives, subject to confidentiality arrangements consistent with Article 8. Transmission Provider shall, at Affected System Interconnection Customer's request and expense, use Reasonable Efforts to

accelerate its work under this Agreement to meet the schedule set forth in Appendix A, provided that (1) Affected System Interconnection Customer authorizes such actions, such authorization to be withheld, conditioned, or delayed by Affected System Interconnection Customer only if it can demonstrate that the acceleration would have a material adverse effect on it; and (2) the Affected System Interconnection Customer funds costs associated therewith in advance.

3.2 Interconnection Costs.

3.2.1 Costs. Affected System Interconnection Customer shall pay to Transmission Provider costs (including taxes and financing costs) associated with seeking and obtaining all necessary approvals and of designing, engineering, constructing, and testing the Affected System Network Upgrade(s), as identified in Appendix A, in accordance with the cost recovery method provided herein. Unless Transmission Provider elects to fund the Affected System Network Upgrade(s), they shall be initially funded by Affected System Interconnection Customer.

3.2.1.1 Lands of Other Property Owners. If any part of the Affected System Network Upgrade(s) is to be installed on property owned by persons other than Affected System Interconnection Customer or Transmission Provider, Transmission Provider shall, at Affected System Interconnection Customer's expense, use efforts similar in nature and extent to those that it typically undertakes on its own behalf or on behalf of its Affiliates, including use of its eminent domain authority to the extent permitted and consistent with Applicable Laws and Regulations and, to the extent consistent with such Applicable Laws and Regulations, to procure from such persons any rights of use, licenses, rights-of-way, and easements that are necessary to construct, operate, maintain, test, inspect, replace, or remove the Affected System Network Upgrade(s) upon such property.

3.2.2 Repayment.

- 3.2.2.1 Repayment.** Consistent with Articles 11.4.1 and 11.4.2 of Transmission Provider's pro forma LGIA, Affected System Interconnection Customer shall be entitled to a cash repayment by Transmission Provider of the amount paid to Transmission Provider, if any, for the Affected System Network Upgrade(s), including any tax gross-up or other tax-related payments associated with the Affected System Network Upgrade(s), and not refunded to Affected System Interconnection Customer pursuant to Article 3.3.1 or otherwise. The Parties may mutually agree to a repayment schedule, to be outlined in Appendix A, not to exceed twenty (20) years from the commercial operation date, for the complete repayment for all applicable costs associated with the Affected System Network Upgrade(s). Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 CFR 35.19 a(a)(2)(iii) from the date of any payment for Affected System Network Upgrade(s) through the date on which Affected System Interconnection Customer receives a repayment of such payment pursuant to this subparagraph. Interest shall not accrue during periods in which Affected System Interconnection Customer has suspended construction pursuant to Article 3.1.2. Affected System Interconnection Customer may assign such repayment rights to any person.
- 3.2.2.2 Impact of Failure to Achieve Commercial Operation.** If the Affected System Interconnection Customer's generating facility fails to achieve commercial operation, but it or another generating facility is later constructed and makes use of the Affected System Network Upgrade(s), Transmission Provider shall at that time reimburse Affected System Interconnection Customer for the amounts advanced for the Affected System Network Upgrade(s). Before any such reimbursement can occur, Affected System Interconnection Customer (or the entity that ultimately constructs the generating facility, if different), is responsible for identifying the entity to which the reimbursement must be made.

3.3 Taxes.

3.3.1 Indemnification for Contributions in Aid of Construction. With regard only to payments made by Affected System Interconnection Customer to Transmission Provider for the installation of the Affected System Network Upgrade(s), Transmission Provider shall not include a gross-up for income taxes in the amounts it charges Affected System Interconnection Customer for the installation of the Affected System Network Upgrade(s) unless (1) Transmission Provider has determined, in good faith, that the payments or property transfers made by Affected System Interconnection Customer to Transmission Provider should be reported as income subject to taxation, or (2) any Governmental Authority directs Transmission Provider to report payments or property as income subject to taxation. Affected System Interconnection Customer shall reimburse Transmission Provider for such costs on a fully grossed-up basis, in accordance with this Article, within thirty (30) Calendar Days of receiving written notification from Transmission Provider of the amount due, including detail about how the amount was calculated.

The indemnification obligation shall terminate at the earlier of (1) the expiration Of the ten (10)-year testing period and the applicable statute of limitation, as it may be extended by Transmission Provider upon request of the Internal Revenue Service, to keep these years open for audit or adjustment, or (2) the occurrence of a subsequent taxable event and the payment of any related indemnification obligations as contemplated by this Article. Notwithstanding the foregoing provisions of this Article 3.3.1, and to the extent permitted by law, to the extent that the receipt of such payments by Transmission Provider is determined by any Governmental Authority to constitute income by Transmission Provider subject to taxation, Affected System Interconnection Customer shall protect, indemnify, and hold harmless Transmission Provider and its Affiliates, from all claims by any such Governmental Authority for any tax, interest, and/or penalties associated with such determination. Upon receiving written notification of such determination from the Governmental Authority, Transmission Provider shall provide Affected System Interconnection Customer with written notification within thirty (30) Calendar Days of such determination and notification. Transmission

Provider, upon the timely written request by Affected System Interconnection Customer and at Affected System Interconnection Customer's expense, shall appeal, protest, seek abatement of, or otherwise oppose such determination. Transmission Provider reserves the right to make all decisions with regard to the prosecution of such appeal, protest, abatement, or other contest, including the compromise or settlement of the claim; provided that Transmission Provider shall cooperate and consult in good faith with Affected System Interconnection Customer regarding the conduct of such contest. Affected System Interconnection Customer shall not be required to pay Transmission Provider for the tax, interest, and/or penalties prior to the seventh (7th) Calendar Day before the date on which Transmission Provider (1) is required to pay the tax, interest, and/or penalties or other amount in lieu thereof pursuant to a compromise or settlement of the appeal, protest, abatement, or other contest; (2) is required to pay the tax, interest, and/or penalties as the result of a final, non-appealable order by a Governmental Authority; or (3) is required to pay the tax, interest, and/or penalties as a prerequisite to an appeal, protest, abatement, or other contest. In the event such appeal, protest, abatement, or other contest results in a determination that Transmission Provider is not liable for any portion of any tax, interest, and/or penalties for which Affected System Interconnection Customer has already made payment to Transmission Provider, Transmission Provider shall promptly refund to Affected System Interconnection Customer any payment attributable to the amount determined to be non-taxable, plus any interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)) or other payments Transmission Provider receives or which Transmission Provider may be entitled with respect to such payment. Affected System Interconnection Customer shall provide Transmission Provider with credit assurances sufficient to meet Affected System Interconnection Customer's estimated liability for reimbursement of Transmission Provider for taxes, interest, and/or penalties under this Article 3.3.1. Such estimated liability shall be stated in Appendix A.

To the extent that Transmission Provider is a limited liability company and not a corporation, and has elected to be taxed as a partnership, then the following shall apply: Transmission Provider represents, and the Parties acknowledge, that Transmission Provider is a limited liability company and is treated as a partnership for federal income tax purposes. Any payment made by Affected System Interconnection Customer to Transmission Provider for Affected System Network Upgrade(s) is to be treated as an

upfront payment. It is anticipated by the Parties that any amounts paid by Affected System Interconnection Customer to Transmission Provider for Affected System Network Upgrade(s) will be reimbursed to Affected System Interconnection Customer in accordance with the terms of this Agreement, provided Affected System Interconnection Customer fulfills its obligations under this Agreement.

3.3.2 Private Letter Ruling. At Affected System Interconnection Customer's request and expense, Transmission Provider shall file with the Internal Revenue Service a request for a private letter ruling as to whether any property transferred or sums paid, or to be paid, by Affected System Interconnection Customer to Transmission Provider under this Agreement are subject to federal income taxation. Affected System Interconnection Customer will prepare the initial draft of the request for a private letter ruling and will certify under penalties of perjury that all facts represented in such request are true and accurate to the best of Affected System Interconnection Customer's knowledge. Transmission Provider and Affected System Interconnection Customer shall cooperate in good faith with respect to the submission of such request.

3.3.3 Other Taxes. Upon the timely request by Affected System Interconnection Customer, and at Affected System Interconnection Customer's sole expense, Transmission Provider shall appeal, protest, seek abatement of, or otherwise contest any tax (other than federal or state income tax) asserted or assessed against Transmission Provider for which Affected System Interconnection Customer may be required to reimburse Transmission Provider under the terms of this Agreement. Affected System Interconnection Customer shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission Provider's documented reasonable costs of prosecuting such appeal, protest, abatement, or other contest. Affected System Interconnection Customer and Transmission Provider shall cooperate in good faith with respect to any such contest. Unless the payment of such taxes is a prerequisite to an appeal or abatement or cannot be deferred, no amount shall be payable by Affected System Interconnection Customer to Transmission Provider for such taxes until they are assessed by a final, non-appealable order by any court or agency of competent jurisdiction. In the event that a tax payment is withheld and ultimately due and payable after appeal, Affected System Interconnection Customer will be responsible

for all taxes, interest and penalties, other than penalties attributable to any delay caused by Transmission Provider. Each Party shall cooperate with the other Party to maintain each Party's tax status. Nothing in this Agreement is intended to adversely affect any Party's tax-exempt status with respect to the issuance of bonds including, but not limited to, local furnishing bonds, as described in section 142(f) of the Internal Revenue Code.

ARTICLE 4

SECURITY, BILLING, AND PAYMENTS

- 4.1 Provision of Security.** By the earlier of (1) thirty (30) Calendar Days prior to the due date for Affected System Interconnection Customer's first payment under the payment schedule specified in Appendix A, or (2) the first date specified in Appendix A for the ordering of equipment by Transmission Provider for installing the Affected System Network Upgrade(s), Affected System Interconnection Customer shall provide Transmission Provider, at Affected System Interconnection Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to Transmission Provider. Such security for payment shall be in an amount sufficient to cover the costs for constructing, procuring, and installing the applicable portion of Affected System Network Upgrade(s) and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider for these purposes.

The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider and contain terms and conditions that guarantee payment of any amount that may be due from Affected System Interconnection Customer, up to an agreed-to maximum amount. The letter of credit must be issued by a financial institution reasonably acceptable to Transmission Provider and must specify a reasonable expiration date. The surety bond must be issued by an insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.

- 4.2 Invoice.** Each Party shall submit to the other Party, on a monthly basis, invoices of amounts due, if any, for the preceding month. Each invoice shall state the month to which the invoice applies and fully describe the services and equipment

provided. The Parties may discharge mutual debts and payment obligations due and owing to each other on the same date through netting, in which case all amounts a Party owes to the other Party under this Agreement, including interest payments, shall be netted so that only the net amount remaining due shall be paid by the owing Party.

- 4.3 Payment.** Invoices shall be rendered to the paying Party at the address specified by the Parties. The Party receiving the invoice shall pay the invoice within thirty (30) Calendar Days of receipt. All payments shall be made in immediately available funds payable to the other Party, or by wire transfer to a bank named and account designated by the invoicing Party. Payment of invoices by a Party will not constitute a waiver of any rights or claims that Party may have under this Agreement.
- 4.4 Final Invoice.** Within six (6) months after completion of the construction of the Affected System Network Upgrade(s), Transmission Provider shall provide an invoice of the final cost of the construction of the Affected System Network Upgrade(s) and shall set forth such costs in sufficient detail to enable Affected System Interconnection Customer to compare the actual costs with the estimates and to ascertain deviations, if any, from the cost estimates. Transmission Provider shall refund, with interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)), to Affected System Interconnection Customer any amount by which the actual payment by Affected System Interconnection Customer for estimated costs exceeds the actual costs of construction within thirty (30) Calendar Days of the issuance of such final construction invoice.
- 4.5 Interest.** Interest on any unpaid amounts shall be calculated in accordance with 18 CFR 35.19a(a)(2)(iii).
- 4.6 Payment During Dispute.** In the event of a billing dispute among the Parties, Transmission Provider shall continue to construct the Affected System Network Upgrade(s) under this Agreement as long as Affected System Interconnection Customer: (1) continues to make all payments not in dispute; and (2) pays to Transmission Provider or into an independent escrow account the portion of the invoice in dispute, pending resolution of such dispute. If Affected System Interconnection Customer fails to meet these two requirements, then Transmission Provider may provide notice to Affected System Interconnection Customer of a

Default pursuant to Article 5. Within thirty (30) Calendar Days after the resolution of the dispute, the Party that owes money to another Party shall pay the amount due with interest calculated in accordance with the methodology set forth in 18 CFR 35.19a(a)(2)(iii).

ARTICLE 5

BREACH, CURE AND DEFAULT

5.1 Events of Breach. A Breach of this Agreement shall include the:

(a) Failure to pay any amount when due;

(b) Failure to comply with any material term or condition of this Agreement, including but not limited to any material Breach of a representation, warranty, or covenant made in this Agreement;

(c) Failure of a Party to provide such access rights, or a Party's attempt to revoke access or terminate such access rights, as provided under this Agreement; or

(d) Failure of a Party to provide information or data to another Party as required under this Agreement, provided the Party entitled to the information or data under this Agreement requires such information or data to satisfy its obligations under this Agreement.

5.2 Definition. Breaching Party shall mean the Party that is in Breach.

5.3 Notice of Breach, Cure, and Default. Upon the occurrence of an event of Breach, the Party not in Breach, when it becomes aware of the Breach, shall give written notice of the Breach to the Breaching Party and to any other person representing a Party to this Agreement identified in writing to the other Party in

advance. Such notice shall set forth, in reasonable detail, the nature of the Breach, and where known and applicable, the steps necessary to cure such Breach.

5.3.1 Upon receiving written notice of the Breach hereunder, the Breaching Party shall have a period to cure such Breach (hereinafter referred to as the “Cure Period”) which shall be sixty (60) Calendar Days.

5.3.2 In the event the Breaching Party fails to cure within the Cure Period, the Breaching Party will be in Default of this Agreement, and the non-Defaulting Party may terminate this Agreement in accordance with Article 6.2 of this Agreement or take whatever action at law or in equity as may appear necessary or desirable to enforce the performance or observance of any rights, remedies, obligations, agreement, or covenants under this Agreement.

5.4 Rights in the Event of Default. Notwithstanding the foregoing, upon the occurrence of a Default, the non-Defaulting Party shall be entitled to exercise all rights and remedies it may have in equity or at law.

ARTICLE 6

TERMINATION OF AGREEMENT

6.1 Expiration of Term. Except as otherwise specified in this Article 6, the Parties’ obligations under this Agreement shall terminate at the conclusion of the term of this Agreement.

6.2 Termination. In addition to the termination provisions set forth in Article 2.2, a Party may terminate this Agreement upon the Default of the other Party in accordance with Article 5.2.2 of this Agreement. Subject to the limitations set forth in Article 6.3, in the event of a Default, the termination of this Agreement by the non-Defaulting Party shall require a filing at FERC of a notice of termination, which filing must be accepted for filing by FERC.

6.3 Disposition of Facilities Upon Termination of Agreement.

6.3.1 Transmission Provider Obligations. Upon termination of this Agreement, unless otherwise agreed to by the Parties in writing, Transmission Provider:

- (a) shall, prior to the construction and installation of any portion of the Affected System Network Upgrade(s) and to the extent possible, cancel any pending orders of, or return, such equipment or material for such Affected System Network Upgrade(s);
- (b) may keep in place any portion of the Affected System Network Upgrade(s) already constructed and installed; and,
- (c) shall perform such work as may be necessary to ensure the safety of persons and property and to preserve the integrity of Transmission Provider's Transmission System (e.g., construction demobilization to return the system to its original state, wind-up work).

6.3.2 Affected System Interconnection Customer Obligations. Upon billing by Transmission Provider, Affected System Interconnection Customer shall reimburse Transmission Provider for any costs incurred by Transmission Provider in performance of the actions required or permitted by Article 6.3.1 and for the cost of any Affected System Network Upgrade(s) described in Appendix A. Transmission Provider shall use Reasonable Efforts to minimize costs and shall offset the amounts owed by any salvage value of facilities, if applicable. Affected System Interconnection Customer shall pay these costs pursuant to Article 4.3 of this Agreement.

6.3.3 Pre-construction or Installation. Upon termination of this Agreement and prior to the construction and installation of any portion of the Affected System Network Upgrade(s), Transmission Provider may, at its option, retain any portion of such Affected System Network Upgrade(s) not cancelled or returned in accordance with Article 6.3.1(a), in which case Transmission Provider shall be responsible for all costs associated with procuring such Affected System Network Upgrade(s). To the extent that

Affected System Interconnection Customer has already paid Transmission Provider for any or all of such costs, Transmission Provider shall refund Affected System Interconnection Customer for those payments. If Transmission Provider elects to not retain any portion of such facilities, Transmission Provider shall convey and make available to Affected System Interconnection Customer such facilities as soon as practicable after Affected System Interconnection Customer's payment for such facilities.

- 6.4 Survival of Rights.** Termination or expiration of this Agreement shall not relieve either Party of any of its liabilities and obligations arising hereunder prior to the date termination becomes effective, and each Party may take whatever judicial or administrative actions as appear necessary or desirable to enforce its rights hereunder. The applicable provisions of this Agreement will continue in effect after expiration, or early termination hereof to the extent necessary to provide for (1) final billings, billing adjustments, and other billing procedures set forth in this Agreement; (2) the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and (3) the confidentiality provisions set forth in Article 8.

ARTICLE 7

SUBCONTRACTORS

- 7.1 Subcontractors.** Nothing in this Agreement shall prevent a Party from utilizing the services of subcontractors, as it deems appropriate, to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services, and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

- 7.1.1 Responsibility of Principal.** The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. In accordance with the provisions of this Agreement, each Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor it hires as if no subcontract had been made. Any applicable obligation imposed by this Agreement upon a Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

7.1.2 No Third-Party Beneficiary. Except as may be specifically set forth to the contrary herein, no subcontractor or any other party is intended to be, nor will it be deemed to be, a third-party beneficiary of this Agreement.

7.1.3 No Limitation by Insurance. The obligations under this Article 7 will not be limited in any way by any limitation of any insurance policies or coverages, including any subcontractor's insurance.

ARTICLE 8

CONFIDENTIALITY

8.1 Confidentiality. Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied to the other Party prior to the execution of this Agreement.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential. The Parties shall maintain as confidential any information that is provided and identified by a Party as Critical Energy Infrastructure Information (CEII), as that term is defined in 18 CFR 388.113(c).

Such confidentiality will be maintained in accordance with this Article 8. If requested by the receiving Party, the disclosing Party shall provide in writing, the basis for asserting that the information referred to in this Article warrants confidential treatment, and the requesting Party may disclose such writing to the appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

8.1.1 Term. During the term of this Agreement, and for a period of three (3) years after the expiration or termination of this Agreement, except as otherwise provided in this Article 8 or with regard to CEII, each Party shall

hold in confidence and shall not disclose to any person Confidential Information. CEII shall be treated in accordance with FERC policies and regulations.

8.1.2 Scope. Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a non-Party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of this Agreement; or (6) is required, in accordance with Article 8.1.6 of this Agreement, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under this Agreement. Information designated as Confidential Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the receiving Party that it no longer is confidential.

8.1.3 Release of Confidential Information. No Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), subcontractors, employees, agents, consultants, or to non-Parties that may be or are considering providing financing to or equity participation with Affected System Interconnection Customer, or to potential purchasers or assignees of Affected System Interconnection Customer, on a need-to-know basis in connection with this Agreement, unless such person has first been advised of the confidentiality provisions of this Article 8 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Article 8.

- 8.1.4 Rights.** Each Party shall retain all rights, title, and interest in the Confidential Information that it discloses to the receiving Party. The disclosure by a Party to the receiving Party of Confidential Information shall not be deemed a waiver by the disclosing Party or any other person or entity of the right to protect the Confidential Information from public disclosure.
- 8.1.5 Standard of Care.** Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication, or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under this Agreement or its regulatory requirements.
- 8.1.6 Order of Disclosure.** If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires either Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the disclosing Party with prompt notice of such request(s) or requirement(s) so that the disclosing Party may seek an appropriate protective order or waive compliance with the terms of this Agreement. Notwithstanding the absence of a protective order or waiver, the Party may disclose such Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance that confidential treatment will be accorded any Confidential Information so furnished.
- 8.1.7 Termination of Agreement.** Upon termination of this Agreement for any reason, each Party shall, within ten (10) Business Days of receipt of a written request from the other Party, use Reasonable Efforts to destroy, erase, or delete (with such destruction, erasure, and deletion certified in writing to the requesting Party) or return to the requesting Party any and all written or electronic Confidential Information received from the requesting Party, except that each Party may keep one copy for archival purposes, provided that the obligation to treat it as Confidential Information in accordance with this Article 8 shall survive such termination.

8.1.8 Remedies. The Parties agree that monetary damages would be inadequate to compensate a Party for the other Party's Breach of its obligations under this Article 8. Each Party accordingly agrees that the disclosing Party shall be entitled to equitable relief, by way of injunction or otherwise, if the receiving Party Breaches or threatens to Breach its obligations under this Article 8, which equitable relief shall be granted without bond or proof of damages, and the breaching Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Article 8, but it shall be in addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. Neither Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Article 8.

8.1.9 Disclosure to FERC, its Staff, or a State Regulatory Body.

Notwithstanding anything in this Article 8 to the contrary, and pursuant to 18 CFR 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from a Party that is otherwise required to be maintained in confidence pursuant to this Agreement, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information. In providing the information to FERC or its staff, the Party must, consistent with 18 CFR 388.112, request that the information be treated as confidential and non-public by FERC and its staff and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party to this Agreement prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Party to the Agreement when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

8.1.10 Subject to the exception in Article 8.1.9, any information that a disclosing Party claims is competitively sensitive, commercial, or financial information under this Agreement shall not be disclosed by the receiving Party to any person not employed or retained by the receiving Party, except to the extent disclosure is (1) required by law; (2) reasonably deemed by the disclosing Party to be required to be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (3) otherwise permitted by consent of the disclosing Party, such consent not to be unreasonably withheld; or (4) necessary to fulfill its obligations under this Agreement or as Transmission Provider or a balancing authority, including disclosing the Confidential Information to a regional or national reliability organization. The Party asserting confidentiality shall notify the receiving Party in writing of the information that Party claims is confidential. Prior to any disclosures of that Party's Confidential Information under this subparagraph, or if any non-Party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the Party that received the Confidential Information from the disclosing Party agrees to promptly notify the disclosing Party in writing and agrees to assert confidentiality and cooperate with the disclosing Party in seeking to protect the Confidential Information from public disclosure by confidentiality agreement, protective order, or other reasonable measures.

ARTICLE 9

INFORMATION ACCESS AND AUDIT RIGHTS

- 9.1 Information Access.** Each Party shall make available to the other Party information necessary to verify the costs incurred by the other Party for which the requesting Party is responsible under this Agreement and carry out obligations and responsibilities under this Agreement, provided that the Parties shall not use such information for purposes other than those set forth in this Article 9.1 and to enforce their rights under this Agreement.
- 9.2 Audit Rights.** Subject to the requirements of confidentiality under Article 8 of this Agreement, the accounts and records related to the design, engineering, procurement, and construction of the Affected System Network Upgrade(s) shall be subject to audit during the period of this Agreement and for a period of

twenty-four (24) months following Transmission Provider's issuance of a final invoice in accordance with Article 4.4. Affected System Interconnection Customer at its expense shall have the right, during normal business hours, and upon prior reasonable notice to Transmission Provider, to audit such accounts and records. Any audit authorized by this Article 9.2 shall be performed at the offices where such accounts and records are maintained and shall be limited to those portions of such accounts and records that relate to obligations under this Agreement.

ARTICLE 10

NOTICES

10.1 General. Any notice, demand, or request required or permitted to be given by a Party to the other Party, and any instrument required or permitted to be tendered or delivered by a Party in writing to another Party, may be so given, tendered, or delivered, as the case may be, by depositing the same with the United States Postal Service with postage prepaid, for transmission by certified or registered mail, addressed to the Parties, or personally delivered to the Parties, at the address set out below:

To Transmission Provider:

To Affected System Interconnection Customer:

10.2 Billings and Payments. Billings and payments shall be sent to the addresses shown in Article 10.1 unless otherwise agreed to by the Parties.

10.3 Alternative Forms of Notice. Any notice or request required or permitted to be given by a Party to the other Party and not required by this Agreement to be given in writing may be so given by telephone, facsimile or email to the telephone numbers and email addresses set out below:

To Transmission Provider:

To Affected System Interconnection Customer:

- 10.4 Execution and Filing.** Affected System Interconnection Customer shall either: (i) execute two originals of this tendered Agreement and return them to Transmission Provider; or (ii) request in writing that Transmission Provider file with FERC this Agreement in unexecuted form. As soon as practicable, but not later than ten (10) Business Days after receiving either the two executed originals of this tendered Agreement (if it does not conform with a FERC-approved standard form of this Agreement) or the request to file this Agreement unexecuted, Transmission Provider shall file this Agreement with FERC, together with its explanation of any matters as to which Affected System Interconnection Customer and Transmission Provider disagree and support for the costs that Transmission Provider proposes to charge to Affected System Interconnection Customer under this Agreement. An unexecuted version of this Agreement should contain terms and conditions deemed appropriate by Transmission Provider for the Affected System Interconnection Customer's generating facility. If the Parties agree to proceed with design, procurement, and construction of facilities and upgrades under the agreed-upon terms of the unexecuted version of this Agreement, they may proceed pending FERC action.

ARTICLE 11

MISCELLANEOUS

- 11.1** This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP.

{Signature Page to Follow}

IN WITNESS WHEREOF, the Parties have executed this Agreement in multiple originals, each of which shall constitute and be an original Agreement among the Parties.

Transmission Provider

{Transmission Provider}

By: _____

Name: _____

Title: _____

Affected System Interconnection Customer

{Affected System Interconnection Customer}

By: _____

Name: _____

Title: _____

Project No. _____

**Attachment A to Appendix 11
Two-Party Affected System Facilities Construction Agreement**

**AFFECTED SYSTEM NETWORK UPGRADE(S), COST ESTIMATES AND
RESPONSIBILITY, CONSTRUCTION SCHEDULE AND MONTHLY
PAYMENT SCHEDULE**

This Appendix A is a part of the Affected System Facilities Construction Agreement between Affected System Interconnection Customer and Transmission Provider.

1.1 Affected System Network Upgrade(s) to be installed by Transmission Provider.

{description}

1.2 First Equipment Order (including permitting).

{description}

1.2.1. Permitting and Land Rights – Transmission Provider Affected System Network Upgrade(s)

{description}

1.3 Construction Schedule. Where applicable, construction of the Affected System Network Upgrade(s) is scheduled as follows and will be periodically updated as necessary:

Table 1: Transmission Provider Construction Activities

MILESTONE NUMBER	DESCRIPTION	START DATE	END DATE

Note: Construction schedule assumes that Transmission Provider has obtained final authorizations and security from Affected System Interconnection Customer and all necessary permits from Governmental Authorities as necessary prerequisites to commence construction of any of the Affected System Network Upgrade(s).

1.4 Payment Schedule.

1.4.1 Timing of and Adjustments to Affected System Interconnection Customer’s Payments and Security.

{description}

1.4.2 Monthly Payment Schedule. Affected System Interconnection Customer’s payment schedule is as follows.

{description}

Table 2: Affected System Interconnection Customer’s Payment/Security Obligations for Affected System Network Upgrade(s).

MILESTONE NUMBER	DESCRIPTION	DATE

Note: Affected System Interconnection Customer’s payment or provision of security as provided in this Agreement operates as a condition precedent to Transmission Provider’s obligations to construct any Affected System Network Upgrade(s), and failure to meet this schedule will constitute a Breach pursuant to Article 5.1 of this Agreement.

1.5 Permits, Licenses, and Authorizations.

{description}

Attachment B to Appendix 11

Two-Party Affected System Facilities Construction Agreement

NOTIFICATION OF COMPLETED CONSTRUCTION

This Appendix B is a part of the Affected Systems Facilities Construction Agreement between Affected System Interconnection Customer and Transmission Provider. Where applicable, when Transmission Provider has completed construction of the Affected System Network Upgrade(s), Transmission Provider shall send notice to Affected System Interconnection Customer in substantially the form following:

{Date}

{Affected System Interconnection Customer Address}

Re: Completion of Affected System Network Upgrade(s)

Dear {Name or Title}:

This letter is sent pursuant to the Affected System Facilities Construction Agreement between {Transmission Provider} and {Affected System Interconnection Customer}, dated _____, 20__.

On {Date}, Transmission Provider completed to its satisfaction all work on the Affected System Network Upgrade(s) required to facilitate the safe and reliable interconnection and operation of Affected System Interconnection Customer's {description of generating facility}. Transmission Provider confirms that the Affected System Network Upgrade(s) are in place.

Thank you.

{Signature}

{Transmission Provider Representative}

**Attachment C to Appendix 11
Two-Party Affected System Facilities Construction Agreement**

EXHIBITS

This Appendix C is a part of the Affected System Facilities Construction Agreement between Affected System Interconnection Customer and Transmission Provider.

**Exhibit A1
Transmission Provider Site Map**

**Exhibit A2
Site Plan**

**Exhibit A3
Affected System Network Upgrade(s) Plan & Profile**

**Exhibit A4
Estimated Cost of Affected System Network Upgrade(s)**

	Location	Facilities to Be Constructed by Transmission Provider	Estimate in Dollars
		Total:	

APPENDIX 12 TO LGIP
MULTIPARTY AFFECTED SYSTEM FACILITIES CONSTRUCTION
AGREEMENT

THIS AGREEMENT is made and entered into this ____ day of _____, 20__, by and among _____, organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); _____, a _____ organized and existing under the laws of the State of _____ (Affected System Interconnection Customer); and _____, an entity organized and existing under the laws of the State of _____ (Transmission Provider). Affected System Interconnection Customers and Transmission Provider each may be referred to as a “Party” or collectively as the “Parties.” When it is not important to differentiate among them, Affected System Interconnection Customers each may be referred to as “Affected System Interconnection Customer” or collectively as “Affected System Interconnection Customers.”

RECITALS

WHEREAS, Affected System Interconnection Customers are proposing to develop {description of generating facilities or generating capacity additions to an existing generating facility}, consistent with the interconnection requests submitted by Affected System Interconnection Customers to {name of host transmission provider}, dated _____, for which {name of host transmission provider} found impacts on Transmission Provider’s Transmission System; and

WHEREAS, Affected System Interconnection Customers desire to interconnect the {generating facilities} to {name of host transmission provider}’s transmission system; and

WHEREAS, additions, modifications, and upgrade(s) must be made to certain existing facilities of Transmission Provider’s Transmission System to accommodate such interconnection; and

WHEREAS, Affected System Interconnection Customers have requested, and Transmission Provider has agreed, to enter into this Agreement for the purpose of facilitating the construction of necessary Affected System Network Upgrade(s);

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

ARTICLE 1 DEFINITIONS

When used in this Agreement, with initial capitalization, the terms specified and not otherwise defined in this Agreement shall have the meanings indicated in this LGIP.

ARTICLE 2 TERM OF AGREEMENT

2.1 Effective Date. This Agreement shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by FERC.

2.2 Term.

2.2.1 General. This Agreement shall become effective as provided in Article 2.1 and shall continue in full force and effect until the earlier of (1) the final repayment, where applicable, by Transmission Provider of the amount funded by Affected System Interconnection Customers for Transmission Provider's design, procurement, construction, and installation of the Affected System Network Upgrade(s) provided in Appendix A; (2) the Parties agree to mutually terminate this Agreement; (3) earlier termination is permitted or provided for under Appendix A of this Agreement; or (4) Affected System Interconnection Customers terminate this Agreement after providing Transmission Provider with written notice at least sixty (60) Calendar Days prior to the proposed termination date,

provided that Affected System Interconnection Customers have no outstanding contractual obligations to Transmission Provider under this Agreement. No termination of this Agreement shall be effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination. The term of this Agreement may be adjusted upon mutual agreement of the Parties if the commercial operation date(s) for the {generating facilities} is adjusted in accordance with the rules and procedures established by {name of host transmission provider} or the in-service date for the Affected System Network Upgrade(s) is adjusted in accordance with the rules and procedures established by Transmission Provider.

2.2.2 Termination Upon Default. Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 5 of this Agreement where Breach and Breaching Party are defined in Article 5. Defaulting Party shall mean the Party that is in Default. In the event of a Default by a Party, each non-Defaulting Party shall have the termination rights described in Articles 5 and 6; provided, however, Transmission Provider may not terminate this Agreement if an Affected System Interconnection Customer is the Defaulting Party and compensates Transmission Provider within thirty (30) Calendar Days for the amount of damages billed to Affected System Interconnection Customer(s) by Transmission Provider for any such damages, including costs and expenses incurred by Transmission Provider as a result of such Default. Notwithstanding the foregoing, Default by one or more Affected System Interconnection Customers shall not provide the other Affected System Interconnection Customer(s), either individually or in concert, with the right to terminate the entire Agreement. The non-Defaulting Party/Parties may, individually or in concert, initiate the removal of an Affected System Interconnection Customer that is a Defaulting Party from this Agreement. Transmission Provider shall not terminate this Agreement or the participation of any Affected System Interconnection Customer without provision being made for Transmission Provider to be fully reimbursed for all of its costs incurred under this Agreement.

2.2.3 Consequences of Termination. In the event of a termination by a Party, other than a termination by Affected System Interconnection Customer(s) due to a Default by Transmission Provider, each Affected System Interconnection Customer whose participation in this Agreement is

terminated shall be responsible for the payment to Transmission Provider of all amounts then due and payable for construction and installation of the Affected System Network Upgrade(s) (including, without limitation, any equipment ordered related to such construction), plus all out-of-pocket expenses incurred by Transmission Provider in connection with the construction and installation of the Affected System Network Upgrade(s), through the date of termination, and, in the event of the termination of the entire Agreement, any actual costs which Transmission Provider reasonably incurs in (1) winding up work and construction demobilization and (2) ensuring the safety of persons and property and the integrity and safe and reliable operation of Transmission Provider's Transmission System. Transmission Provider shall use Reasonable Efforts to minimize such costs. The cost responsibility of other Affected System Interconnection Customers shall be adjusted, as necessary, based on the payments by an Affected System Interconnection Customer that is terminated from the Agreement.

2.2.4 Reservation of Rights. Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Affected System Interconnection Customers shall have the right to make a unilateral filing with FERC to modify this Agreement pursuant to section 206 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations thereunder, except to the extent that the Parties otherwise mutually agree as provided herein.

2.3 Filing. Transmission Provider shall file this Agreement (and any amendment hereto) with the appropriate Governmental Authority, if required. Affected System Interconnection Customers may request that any information so provided be subject to the confidentiality provisions of Article 8. Each Affected System Interconnection Customer that has executed this Agreement, or any amendment thereto, shall reasonably cooperate with Transmission Provider with respect to

such filing and to provide any information reasonably requested by Transmission Provider needed to comply with applicable regulatory requirements.

- 2.4 Survival.** This Agreement shall continue in effect after termination, to the extent necessary, to provide for final billings and payments and for costs incurred hereunder, including billings and payments pursuant to this Agreement; to permit the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and to permit each Party to have access to the lands of the other Party pursuant to this Agreement or other applicable agreements, to disconnect, remove, or salvage its own facilities and equipment.
- 2.5 Termination Obligations.** Upon any termination pursuant to this Agreement or termination of the participation in this Agreement of an Affected System Interconnection Customer, each Affected System Interconnection Customer shall be responsible for the payment of its proportionate share of all costs or other contractual obligations incurred prior to the termination date, including previously incurred capital costs, penalties for early termination, and costs of removal and site restoration. The cost responsibility of the other Affected System Interconnection Customers shall be adjusted as necessary.

ARTICLE 3

CONSTRUCTION OF AFFECTED SYSTEM NETWORK UPGRADE(S)

3.1 Construction.

3.1.1 Transmission Provider Obligations. Transmission Provider shall (or shall cause such action to) design, procure, construct, and install, and Affected System Interconnection Customers shall pay, consistent with Article 3.2, the costs of all Affected System Network Upgrade(s) identified in Appendix A. All Affected System Network Upgrade(s) designed, procured, constructed, and installed by Transmission Provider pursuant to this Agreement shall satisfy all requirements of applicable safety and/or engineering codes and comply with Good Utility Practice, and further, shall satisfy all Applicable Laws and Regulations. Transmission Provider shall

not be required to undertake any action which is inconsistent with its standard safety practices, its material and equipment specifications, its design criteria and construction procedures, its labor agreements, or any Applicable Laws and Regulations.

3.1.2 Suspension of Work.

3.1.2.1 Right to Suspend. Affected System Interconnection Customers must jointly provide to Transmission Provider written notice of their request for suspension. Only the milestones described in the Appendices of this Agreement are subject to suspension under this Article 3.1.2. Affected System Network Upgrade(s) will be constructed on the schedule described in the Appendices of this Agreement unless: (1) construction is prevented by the order of a Governmental Authority; (2) the Affected System Network Upgrade(s) are not needed by any other Interconnection Customer; or (3) Transmission Provider determines that a Force Majeure event prevents construction. In the event of (1), (2), or (3), any security paid to Transmission Provider under Article 4.1 of this Agreement shall be released by Transmission Provider upon the determination by Transmission Provider that the Affected System Network Upgrade(s) will no longer be constructed. If suspension occurs, Affected System Interconnection Customers shall be responsible for the costs which Transmission Provider incurs (i) in accordance with this Agreement prior to the suspension; (ii) in suspending such work, including any costs incurred to perform such work as may be necessary to ensure the safety of persons and property and the integrity of Transmission Provider's Transmission System and, if applicable, any costs incurred in connection with the cancellation of contracts and orders for material which Transmission Provider cannot reasonably avoid; and (iii) reasonably incurs in winding up work and construction demobilization; provided, however, that, prior to canceling any such contracts or orders, Transmission Provider shall obtain Affected System Interconnection Customers' authorization. Affected System Interconnection Customers shall be responsible for all costs

incurred in connection with Affected System Interconnection Customers' failure to authorize cancellation of such contracts or orders.

Interest on amounts paid by Affected System Interconnection Customers to Transmission Provider for the design, procurement, construction, and installation of the Affected System Network Upgrade(s) shall not accrue during periods in which Affected System Interconnection Customers have suspended construction under this Article 3.1.2.

Transmission Provider shall invoice Affected System Interconnection Customers pursuant to Article 4 and will use Reasonable Efforts to minimize its costs. In the event Affected System Interconnection Customers suspend work by Affected System Transmission Provider required under this Agreement pursuant to this Article 3.1.2.1, and have not requested Affected System Transmission Provider to recommence the work required under this Agreement on or before the expiration of three (3) years following commencement of such suspension, this Agreement shall be deemed terminated. The three-year period shall begin on the date the suspension is requested, or the date of the written notice to Affected System Transmission Provider, whichever is earlier, if no effective date of suspension is specified.

3.1.3 Construction Status. Transmission Provider shall keep Affected System Interconnection Customers advised periodically as to the progress of its design, procurement, and construction efforts, as described in Appendix A. An Affected System Interconnection Customer may, at any time and reasonably, request a progress report from Transmission Provider. If, at any time, an Affected System Interconnection Customer determines that the completion of the Affected System Network Upgrade(s) will not be required until after the specified in-service date, such Affected System Interconnection Customer will provide written notice to all other Parties of such later date for which the completion of the Affected System Network Upgrade(s) would be required. Transmission Provider may delay the in-service date of the Affected System Network Upgrade(s) accordingly,

but only if agreed to by all other Affected System Interconnection Customers.

3.1.4 Timely Completion. Transmission Provider shall use Reasonable Efforts to design, procure, construct, install, and test the Affected System Network Upgrade(s) in accordance with the schedule set forth in Appendix A, which schedule may be revised from time to time by mutual agreement of the Parties. If any event occurs that will affect the time or ability to complete the Affected System Network Upgrade(s), Transmission Provider shall promptly notify all other Parties. In such circumstances, Transmission Provider shall, within fifteen (15) Calendar Days of such notice, convene a meeting with Affected System Interconnection Customers to evaluate the alternatives available to Affected System Interconnection Customers. Transmission Provider shall also make available to Affected System Interconnection Customers all studies and work papers related to the event and corresponding delay, including all information that is in the possession of transmission Provider that is reasonably needed by Affected System Interconnection Customers to evaluate alternatives, subject to confidentiality arrangements consistent with Article 8. Transmission Provider shall, at any Affected System Interconnection Customer's request and expense, use Reasonable Efforts to accelerate its work under this Agreement to meet the schedule set forth in Appendix A, provided that (1) Affected System Interconnection Customers jointly authorize such actions, such authorizations to be withheld, conditioned, or delayed by a given Affected System Interconnection Customer only if it can demonstrate that the acceleration would have a material adverse effect on it; and (2) the requesting Affected System Interconnection Customer(s) funds the costs associated therewith in advance, or all Affected System Interconnection Customers agree in advance to fund such costs based on such other allocation method as they may adopt.

3.2 Interconnection Costs.

3.2.1 Costs. Affected System Interconnection Customers shall pay to Transmission Provider costs (including taxes and financing costs) associated with seeking and obtaining all necessary approvals and of

designing, engineering, constructing, and testing the Affected System Network Upgrade(s), as identified in Appendix A, in accordance with the cost recovery method provided herein. Except as expressly otherwise agreed, Affected System Interconnection Customers shall be collectively responsible for these costs, based on their proportionate share of cost responsibility, as provided in Appendix A. Unless Transmission Provider elects to fund the Affected System Network Upgrade(s), they shall be initially funded by the applicable Affected System Interconnection Customer.

3.2.1.1 Lands of Other Property Owners. If any part of the Affected System Network Upgrade(s) is to be installed on property owned by persons other than Affected System Interconnection Customers or Transmission Provider, Transmission Provider shall, at Affected System Interconnection Customers' expense, use efforts similar in nature and extent to those that it typically undertakes on its own behalf or on behalf of its Affiliates, including use of its eminent domain authority to the extent permitted and consistent with Applicable Laws and Regulations and, to the extent consistent with such Applicable Laws and Regulations, to procure from such persons any rights of use, licenses, rights-of-way, and easements that are necessary to construct, operate, maintain, test, inspect, replace, or remove the Affected System Network Upgrade(s) upon such property.

3.2.2 Repayment.

3.2.2.1 Repayment. Consistent with articles 11.4.1 and 11.4.2 of Transmission Provider's pro forma LGIA, each Affected System Interconnection Customer shall be entitled to a cash repayment by Transmission Provider of the amount each Affected System Interconnection Customer paid to Transmission Provider, if any, for the Affected System Network Upgrade(s), including any tax gross-up or other tax-related payments associated with the Affected System Network Upgrade(s), and not refunded to Affected System Interconnection Customer pursuant to Article 3.3.1 or

otherwise. The Parties may mutually agree to a repayment schedule, to be outlined in Appendix A, not to exceed twenty (20) years from the commercial operation date, for the complete repayment for all applicable costs associated with the Affected System Network Upgrade(s). Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 CFR 35.19 a(a)(2)(iii) from the date of any payment for Affected System Network Upgrade(s) through the date on which Affected System Interconnection Customers receive a repayment of such payment pursuant to this subparagraph. Interest shall not accrue during periods in which Affected System Interconnection Customers have suspended construction pursuant to Article 3.1.2.1. Affected System Interconnection Customers may assign such repayment rights to any person.

3.2.2.2 Impact of Failure to Achieve Commercial Operation. If an Affected System Interconnection Customer's generating facility fails to achieve commercial operation, but it or another generating facility is later constructed and makes use of the Affected System Network Upgrade(s), Transmission Provider shall at that time reimburse such Affected System Interconnection Customers for the portion of the Affected System Network Upgrade(s) it funded. Before any such reimbursement can occur, Affected System Interconnection Customer (or the entity that ultimately constructs the generating facility, if different), is responsible for identifying the entity to which the reimbursement must be made.

3.3 Taxes.

3.3.1 Indemnification for Contributions in Aid of Construction. With regard only to payments made by Affected System Interconnection Customers to Transmission Provider for the installation of the Affected System Network Upgrade(s), Transmission Provider shall not include a gross-up for income taxes in the amounts it charges Affected System Interconnection Customers for the installation of the Affected System Network Upgrade(s) unless (1)

Transmission Provider has determined, in good faith, that the payments or property transfers made by Affected System Interconnection Customers to Transmission Provider should be reported as income subject to taxation, or (2) any Governmental Authority directs Transmission Provider to report payments or property as income subject to taxation. Affected System Interconnection Customers shall reimburse Transmission Provider for such costs on a fully grossed-up basis, in accordance with this Article, within thirty (30) Calendar Days of receiving written notification from Transmission Provider of the amount due, including detail about how the amount was calculated.

The indemnification obligation shall terminate at the earlier of (1) the expiration of the ten (10)-year testing period and the applicable statute of limitation, as it may be extended by Transmission Provider upon request of the Internal Revenue Service, to keep these years open for audit or adjustment, or (2) the occurrence of a subsequent taxable event and the payment of any related indemnification obligations as contemplated by this Article. Notwithstanding the foregoing provisions of this Article 3.3.1, and to the extent permitted by law, to the extent that the receipt of such payments by Transmission Provider is determined by any Governmental Authority to constitute income by Transmission Provider subject to taxation, Affected System Interconnection Customers shall protect, indemnify, and hold harmless Transmission Provider and its Affiliates, from all claims by any such Governmental Authority for any tax, interest, and/or penalties associated with such determination. Upon receiving written notification of such determination from the Governmental Authority, Transmission Provider shall provide Affected System Interconnection Customers with written notification within thirty (30) Calendar Days of such determination and notification. Transmission Provider, upon the timely written request by any one or more Affected System Interconnection Customer(s) and at the expense of such Affected System Interconnection Customer(s), shall appeal, protest, seek abatement of, or otherwise oppose such determination. Transmission Provider reserves the right to make all decisions with regard to the prosecution of such appeal, protest, abatement or other contest, including the compromise or settlement of the claim; provided that Transmission Provider shall cooperate and consult in good faith with the requesting Affected System Interconnection Customer(s) regarding the conduct of such contest. Affected System Interconnection Customer(s) shall not be required to pay Transmission Provider for the tax, interest, and/or penalties prior to the

seventh (7th) Calendar Day before the date on which Transmission Provider (1) is required to pay the tax, interest, and/or penalties or other amount in lieu thereof pursuant to a compromise or settlement of the appeal, protest, abatement, or other contest; (2) is required to pay the tax, interest, and/or penalties as the result of a final, non-appealable order by a Governmental Authority; or (3) is required to pay the tax, interest, and/or penalties as a prerequisite to an appeal, protest, abatement, or other contest. In the event such appeal, protest, abatement, or other contest results in a determination that Transmission Provider is not liable for any portion of any tax, interest, and/or penalties for which any Affected System Interconnection Customer(s) has already made payment to Transmission Provider, Transmission Provider shall promptly refund to such Affected System Interconnection Customer(s) any payment attributable to the amount determined to be non-taxable, plus any interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)) or other payments Transmission Provider receives or to which Transmission Provider may be entitled with respect to such payment. Each Affected System Interconnection Customer shall provide Transmission Provider with credit assurances sufficient to meet each Affected System Interconnection Customer's estimated liability for reimbursement of Transmission Provider for taxes, interest, and/or penalties under this Article 3.3.1. Such estimated liability shall be stated in Appendix A.

To the extent that Transmission Provider is a limited liability company and not a corporation, and has elected to be taxed as a partnership, then the following shall apply: Transmission Provider represents, and the Parties acknowledge, that Transmission Provider is a limited liability company and is treated as a partnership for federal income tax purposes. Any payment made by Affected System Interconnection Customers to Transmission Provider for Affected System Network Upgrade(s) is to be treated as an upfront payment. It is anticipated by the Parties that any amounts paid by each Affected System Interconnection Customer to Transmission Provider for Affected System Network Upgrade(s) will be reimbursed to such Affected System Interconnection Customer in accordance with the terms of this Agreement, provided such Affected System Interconnection Customer fulfills its obligations under this Agreement.

3.3.2 Private Letter Ruling. At the request and expense of any Affected System Interconnection Customer(s), Transmission Provider shall file with

the Internal Revenue Service a request for a private letter ruling as to whether any property transferred or sums paid, or to be paid, by such Affected System Interconnection Customer(s) to Transmission Provider under this Agreement are subject to federal income taxation. Each Affected System Interconnection Customer desiring such a request will prepare the initial draft of the request for a private letter ruling and will certify under penalties of perjury that all facts represented in such request are true and accurate to the best of such Affected System Interconnection Customer's knowledge. Transmission Provider and such Affected System Interconnection Customer(s) shall cooperate in good faith with respect to the submission of such request.

3.3.3 Other Taxes. Upon the timely request by any one or more Affected System Interconnection Customer(s), and at such Affected System Interconnection Customer(s)' sole expense, Transmission Provider shall appeal, protest, seek abatement of, or otherwise contest any tax (other than federal or state income tax) asserted or assessed against Transmission Provider for which such Affected System Interconnection Customer(s) may be required to reimburse Transmission Provider under the terms of this Agreement. Affected System Interconnection Customer(s) who requested the action shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission Provider's documented reasonable costs of prosecuting such appeal, protest, abatement, or other contest. The requesting Affected System Interconnection Customer(s) and Transmission Provider shall cooperate in good faith with respect to any such contest. Unless the payment of such taxes is a prerequisite to an appeal or abatement or cannot be deferred, no amount shall be payable by Affected System Interconnection Customer(s) to Transmission Provider for such taxes until they are assessed by a final, non-appealable order by any court or agency of competent jurisdiction. In the event that a tax payment is withheld and ultimately due and payable after appeal, Affected System Interconnection Customer(s) will be responsible for all taxes, interest, and penalties, other than penalties attributable to any delay caused by Transmission Provider. Each Party shall cooperate with the other Party to maintain each Party's tax status. Nothing in this Agreement is intended to adversely affect any Party's tax-exempt status with respect to the issuance of bonds including, but not limited to, local furnishing bonds, as described in section 142(f) of the Internal Revenue Code.

ARTICLE 4

SECURITY, BILLING, AND PAYMENTS

- 4.1 Provision of Security.** By the earlier of (1) thirty (30) Calendar Days prior to the due date for each Affected System Interconnection Customer's first payment under the payment schedule specified in Appendix A, or (2) the first date specified in Appendix A for the ordering of equipment by Transmission Provider for installing the Affected System Network Upgrade(s), each Affected System Interconnection Customer shall provide Transmission Provider, at each Affected System Interconnection Customer's option, a guarantee, a surety bond, letter of credit, or other form of security that is reasonably acceptable to Transmission Provider. Such security for payment shall be in an amount sufficient to cover the costs for constructing, procuring, and installing the applicable portion of Affected System Network Upgrade(s) and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider for these purposes.

The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider and contain terms and conditions that guarantee payment of any amount that may be due from such Affected System Interconnection Customer, up to an agreed-to maximum amount. The letter of credit must be issued by a financial institution reasonably acceptable to Transmission Provider and must specify a reasonable expiration date. The surety bond must be issued by an insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.

- 4.2 Invoice.** Each Party shall submit to the other Parties, on a monthly basis, invoices of amounts due, if any, for the preceding month. Each invoice shall state the month to which the invoice applies and fully describe the services and equipment provided. The Parties may discharge mutual debts and payment obligations due and owing to each other on the same date through netting, in which case all amounts a Party owes to another Party under this Agreement, including interest payments, shall be netted so that only the net amount remaining due shall be paid by the owing Party.
- 4.3 Payment.** Invoices shall be rendered to the paying Party at the address specified by the Parties. The Party receiving the invoice shall pay the invoice within thirty

(30) Calendar Days of receipt. All payments shall be made in immediately available funds payable to the other Party, or by wire transfer to a bank named and account designated by the invoicing Party. Payment of invoices by a Party will not constitute a waiver of any rights or claims that Party may have under this Agreement.

- 4.4 Final Invoice.** Within six (6) months after completion of the construction of the Affected System Network Upgrade(s) Transmission Provider shall provide an invoice of the final cost of the construction of the Affected System Network Upgrade(s) and shall set forth such costs in sufficient detail to enable each Affected System Interconnection Customer to compare the actual costs with the estimates and to ascertain deviations, if any, from the cost estimates. Transmission Provider shall refund, with interest (calculated in accordance with 18 CFR 35.19a(a)(2)(iii)), to each Affected System Interconnection Customer any amount by which the actual payment by Affected System Interconnection Customer for estimated costs exceeds the actual costs of construction within thirty (30) Calendar Days of the issuance of such final construction invoice.
- 4.5 Interest.** Interest on any unpaid amounts shall be calculated in accordance with 18 CFR 35.19a(a)(2)(iii).
- 4.6 Payment During Dispute.** In the event of a billing dispute among the Parties, Transmission Provider shall continue to construct the Affected System Network Upgrade(s) under this Agreement as long as each Affected System Interconnection Customer: (1) continues to make all payments not in dispute; and (2) pays to Transmission Provider or into an independent escrow account the portion of the invoice in dispute, pending resolution of such dispute. If any Affected System Interconnection Customer fails to meet these two requirements, then Transmission Provider may provide notice to such Affected System Interconnection Customer of a Default pursuant to Article 5. Within thirty (30) Calendar Days after the resolution of the dispute, the Party that owes money to another Party shall pay the amount due with interest calculated in accordance with the methodology set forth in 18 CFR 35.19a(a)(2)(iii).

ARTICLE 5

BREACH, CURE, AND DEFAULT

5.1 Events of Breach. A Breach of this Agreement shall include the:

- (a) Failure to pay any amount when due;
- (b) Failure to comply with any material term or condition of this Agreement, including but not limited to any material Breach of a representation, warranty, or covenant made in this Agreement;
- (c) Failure of a Party to provide such access rights, or a Party's attempt to revoke access or terminate such access rights, as provided under this Agreement; or
- (d) Failure of a Party to provide information or data to another Party as required under this Agreement, provided the Party entitled to the information or data under this Agreement requires such information or data to satisfy its obligations under this Agreement.

5.2 Definition. Breaching Party shall mean the Party that is in Breach.

5.3 Notice of Breach, Cure, and Default. Upon the occurrence of an event of Breach, any Party aggrieved by the Breach, when it becomes aware of the Breach, shall give written notice of the Breach to the Breaching Party and to any other person representing a Party to this Agreement identified in writing to the other Party in advance. Such notice shall set forth, in reasonable detail, the nature of the Breach, and where known and applicable, the steps necessary to cure such Breach.

5.2.1 Upon receiving written notice of the Breach hereunder, the Breaching Party shall have a period to cure such Breach (hereinafter referred to as the "Cure Period") which shall be sixty (60) Calendar Days. If an Affected System Interconnection Customer is the Breaching Party and the Breach results from a failure to provide payments or security under Article 4.1 of this

Agreement, the other Affected System Interconnection Customers, either individually or in concert, may cure the Breach by paying the amounts owed or by providing adequate security, without waiver of contribution rights against the breaching Affected System Interconnection Customer. Such cure for the Breach of an Affected System Interconnection Customer is subject to the reasonable consent of Transmission Provider.

Transmission Provider may also cure such Breach by funding the proportionate share of the Affected System Network Upgrade costs related to the Breach of Affected System Interconnection Customer. Transmission Provider must notify all Parties that it will exercise this option within thirty (30) Calendar Days of notification that an Affected System Interconnection Customer has failed to provide payments or security under Article 4.1.

5.2.2 In the event the Breach is not cured within the Cure Period, the Breaching Party will be in Default of this Agreement, and the non-Defaulting Parties may (1) act in concert to amend the Agreement to remove an Affected System Interconnection Customer that is in Default from this Agreement for cause and to make other changes as necessary, or (2) either in concert or individually take whatever action at law or in equity as may appear necessary or desirable to enforce the performance or observance of any rights, remedies, obligations, agreement, or covenants under this Agreement.

5.3 Rights in the Event of Default. Notwithstanding the foregoing, upon the occurrence of Default, the non-Defaulting Parties shall be entitled to exercise all rights and remedies it may have in equity or at law.

ARTICLE 6

TERMINATION OF AGREEMENT

- 6.1 Expiration of Term.** Except as otherwise specified in this Article 6, the Parties' obligations under this Agreement shall terminate at the conclusion of the term of this Agreement.
- 6.2 Termination and Removal.** Subject to the limitations set forth in Article 6.3, in the event of a Default, termination of this Agreement, as to a given Affected System Interconnection Customer or in its entirety, shall require a filing at FERC of a notice of termination, which filing must be accepted for filing by FERC.

6.3 Disposition of Facilities Upon Termination of Agreement.

6.3.1 Transmission Provider Obligations. Upon termination of this Agreement, unless otherwise agreed to by the Parties in writing, Transmission Provider:

(a) shall, prior to the construction and installation of any portion of the Affected System Network Upgrade(s) and to the extent possible, cancel any pending orders of, or return, such equipment or material for such Affected System Network Upgrade(s);

(b) may keep in place any portion of the Affected System Network Upgrade(s) already constructed and installed; and,

(c) shall perform such work as may be necessary to ensure the safety of persons and property and to preserve the integrity of Transmission Provider's Transmission System (e.g., construction demobilization to return the system to its original state, wind-up work).

6.3.2 Affected System Interconnection Customer Obligations. Upon billing by Transmission Provider, each Affected System Interconnection Customer shall reimburse Transmission Provider for its share of any costs incurred by Transmission Provider in performance of the actions required or permitted by Article 6.3.1 and for its share of the cost of any Affected System Network Upgrade(s) described in Appendix A. Transmission Provider shall use Reasonable Efforts to minimize costs and shall offset the amounts owed by any salvage value of facilities, if applicable. Each Affected System Interconnection Customer shall pay these costs pursuant to Article 4.3 of this Agreement.

6.3.3 Pre-construction or Installation. Upon termination of this Agreement and prior to the construction and installation of any portion of the Affected System Network Upgrade(s), Transmission Provider may, at its option, retain any portion of such Affected System Network Upgrade(s) not cancelled or returned in accordance with Article 6.3.1(a), in which case Transmission Provider shall be responsible for all costs associated with procuring such Affected System Network Upgrade(s). To the extent that an Affected System Interconnection Customer has already paid

Transmission Provider for any or all of such costs, Transmission Provider shall refund Affected System Interconnection Customer for those payments. If Transmission Provider elects to not retain any portion of such facilities, and one or more of Affected System Interconnection Customers wish to purchase such facilities, Transmission Provider shall convey and make available to the applicable Affected System Interconnection Customer(s) such facilities as soon as practicable after Affected System Interconnection Customer(s)' payment for such facilities.

- 6.4 Survival of Rights.** Termination or expiration of this Agreement shall not relieve any Party of any of its liabilities and obligations arising hereunder prior to the date termination becomes effective, and each Party may take whatever judicial or administrative actions as appear necessary or desirable to enforce its rights hereunder. The applicable provisions of this Agreement will continue in effect after expiration, or early termination hereof, to the extent necessary to provide for (1) final billings, billing adjustments, and other billing procedures set forth in this Agreement; (2) the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this Agreement was in effect; and (3) the confidentiality provisions set forth in Article 8.

ARTICLE 7

SUBCONTRACTORS

- 7.1 Subcontractors.** Nothing in this Agreement shall prevent a Party from utilizing the services of subcontractors, as it deems appropriate, to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services, and each Party shall remain primarily liable to the other Parties for the performance of such subcontractor.

- 7.1.1 Responsibility of Principal.** The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. In accordance with the provisions of this Agreement, each Party shall be fully responsible to the other Parties for the acts or omissions of any subcontractor it hires as if no subcontract had been made. Any applicable obligation imposed by this Agreement upon a Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

7.1.2 No Third-Party Beneficiary. Except as may be specifically set forth to the contrary herein, no subcontractor or any other party is intended to be, nor will it be deemed to be, a third-party beneficiary of this Agreement.

7.1.3 No Limitation by Insurance. The obligations under this Article 7 will not be limited in any way by any limitation of any insurance policies or coverages, including any subcontractor's insurance.

ARTICLE 8 CONFIDENTIALITY

8.1 Confidentiality. Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied to the other Parties prior to the execution of this Agreement.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential. The Parties shall maintain as confidential any information that is provided and identified by a Party as Critical Energy Infrastructure Information (CEII), as that term is defined in 18 CFR 388.113(c).

Such confidentiality will be maintained in accordance with this Article 8. If requested by the receiving Party, the disclosing Party shall provide in writing, the basis for asserting that the information referred to in this Article warrants confidential treatment, and the requesting Party may disclose such writing to the appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

8.1.1 Term. During the term of this Agreement, and for a period of three (3) years after the expiration or termination of this Agreement, except as otherwise provided in this Article 8 or with regard to CEII,

each Party shall hold in confidence and shall not disclose to any person Confidential Information. CEII shall be treated in accordance with FERC policies and regulations.

8.1.2 Scope. Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a non-Party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of this Agreement; or (6) is required, in accordance with Article 8.1.6 of this Agreement, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under this Agreement. Information designated as Confidential Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the receiving Party that it no longer is confidential.

8.1.3 Release of Confidential Information. No Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), subcontractors, employees, agents, consultants, or to non-Parties that may be or are considering providing financing to or equity participation with Affected System Interconnection Customer(s), or to potential purchasers or assignees of Affected System Interconnection Customer(s), on a need-to-know basis in connection with this Agreement, unless such person has first been advised of the confidentiality provisions of this Article 8 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Article 8.

- 8.1.4 Rights.** Each Party shall retain all rights, title, and interest in the Confidential Information that it discloses to the receiving Party. The disclosure by a Party to the receiving Party of Confidential Information shall not be deemed a waiver by the disclosing Party or any other person or entity of the right to protect the Confidential Information from public disclosure.
- 8.1.5 Standard of Care.** Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication, or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under this Agreement or its regulatory requirements.
- 8.1.6 Order of Disclosure.** If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires any Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the disclosing Party with prompt notice of such request(s) or requirement(s) so that the disclosing Party may seek an appropriate protective order or waive compliance with the terms of this Agreement. Notwithstanding the absence of a protective order or waiver, the Party may disclose such Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance that confidential treatment will be accorded any Confidential Information so furnished.
- 8.1.7 Termination of Agreement.** Upon termination of this Agreement for any reason, each Party shall, within ten (10) Business Days of receipt of a written request from the other Party, use Reasonable Efforts to destroy, erase, or delete (with such destruction, erasure, and deletion certified in writing to the requesting Party) or return to the requesting Party any and all written or electronic Confidential Information received from the requesting Party, except that each

Party may keep one copy for archival purposes, provided that the obligation to treat it as Confidential Information in accordance with this Article 8 shall survive such termination.

8.1.8 Remedies. The Parties agree that monetary damages would be inadequate to compensate a Party for another Party's Breach of its obligations under this Article 8. Each Party accordingly agrees that the disclosing Party shall be entitled to equitable relief, by way of injunction or otherwise, if the receiving Party Breaches or threatens to Breach its obligations under this Article 8, which equitable relief shall be granted without bond or proof of damages, and the Breaching Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Article 8, but it shall be in addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. No Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Article 8.

8.1.9 Disclosure to FERC, its Staff, or a State Regulatory Body.

Notwithstanding anything in this Article 8 to the contrary, and pursuant to 18 CFR 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from a Party that is otherwise required to be maintained in confidence pursuant to this Agreement, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information. In providing the information to FERC or its staff, the Party must, consistent with 18 CFR 388.112, request that the information be treated as confidential and non-public by FERC and its staff and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Parties to this Agreement prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Parties to the Agreement when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such

information would be made public, pursuant to 18 CFR 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

8.1.10 Subject to the exception in Article 8.1.9, any information that a disclosing Party claims is competitively sensitive, commercial, or financial information under this Agreement shall not be disclosed by the receiving Party to any person not employed or retained by the receiving Party, except to the extent disclosure is (1) required by law; (2) reasonably deemed by the disclosing Party to be required to be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (3) otherwise permitted by consent of the disclosing Party, such consent not to be unreasonably withheld; or (4) necessary to fulfill its obligations under this Agreement or as Transmission Provider or a balancing authority, including disclosing the Confidential Information to a regional or national reliability organization. The Party asserting confidentiality shall notify the receiving Party in writing of the information that Party claims is confidential. Prior to any disclosures of that Party's Confidential Information under this subparagraph, or if any non-Party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the Party that received the Confidential Information from the disclosing Party agrees to promptly notify the disclosing Party in writing and agrees to assert confidentiality and cooperate with the disclosing Party in seeking to protect the Confidential Information from public disclosure by confidentiality agreement, protective order, or other reasonable measures.

ARTICLE 9

INFORMATION ACCESS AND AUDIT RIGHTS

9.1 Information Access. Each Party shall make available to the other Parties information necessary to verify the costs incurred by the other Parties for which the requesting Party is responsible under this Agreement and carry out obligations and responsibilities under this Agreement, provided that the Parties shall not use

such information for purposes other than those set forth in this Article 9.1 and to enforce their rights under this Agreement.

- 9.2 Audit Rights.** Subject to the requirements of confidentiality under Article 8 of this Agreement, the accounts and records related to the design, engineering, procurement, and construction of the Affected System Network Upgrade(s) shall be subject to audit during the period of this Agreement and for a period of twenty-four (24) months following Transmission Provider's issuance of a final invoice in accordance with Article 4.4. Affected System Interconnection Customers may, jointly or individually, at the expense of the requesting Party(ies), during normal business hours, and upon prior reasonable notice to Transmission Provider, audit such accounts and records. Any audit authorized by this Article 9.2 shall be performed at the offices where such accounts and records are maintained and shall be limited to those portions of such accounts and records that relate to obligations under this Agreement.

ARTICLE 10

NOTICES

- 10.1 General.** Any notice, demand, or request required or permitted to be given by a Party to the other Parties, and any instrument required or permitted to be tendered or delivered by a Party in writing to another Party, may be so given, tendered, or delivered, as the case may be, by depositing the same with the United States Postal Service with postage prepaid, for transmission by certified or registered mail, addressed to the Parties, or personally delivered to the Parties, at the address set out below:

To Transmission Provider:

To Affected System Interconnection Customers:

10.2 Billings and Payments. Billings and payments shall be sent to the addresses shown in Article 10.1 unless otherwise agreed to by the Parties.

10.3 Alternative Forms of Notice. Any notice or request required or permitted to be given by a Party to the other Parties and not required by this Agreement to be given in writing may be so given by telephone, facsimile, or email to the telephone numbers and email addresses set out below:

To Transmission Provider:

To Affected System Interconnection Customers:

10.4 Execution and Filing. Affected System Interconnection Customers shall either: (i) execute two originals of this tendered Agreement and return them to Transmission Provider; or (ii) request in writing that Transmission Provider file with FERC this Agreement in unexecuted form. As soon as practicable, but not later than ten (10) Business Days after receiving either the two executed originals of this tendered Agreement (if it does not conform with a FERC-approved standard form of this Agreement) or the request to file this Agreement unexecuted, Transmission Provider shall file this Agreement with FERC, together with its explanation of any matters as to which Affected System Interconnection Customers and Transmission Provider disagree and support for the costs that Transmission Provider proposes to charge to Affected System Interconnection Customers under this Agreement. An unexecuted version of this Agreement should contain terms and conditions deemed appropriate by Transmission Provider for the Affected System Interconnection Customers' generating facilities. If the Parties agree to proceed with design, procurement, and construction of facilities

and upgrades under the agreed-upon terms of the unexecuted version of this Agreement, they may proceed pending FERC action.

ARTICLE 11

MISCELLANEOUS

- 11.1** This Agreement shall include standard miscellaneous terms including, but not limited to, indemnities, representations, disclaimers, warranties, governing law, amendment, execution, waiver, enforceability, and assignment, which reflect best practices in the electric industry, that are consistent with regional practices, Applicable Laws and Regulations, and the organizational nature of each Party. All of these provisions, to the extent practicable, shall be consistent with the provisions of this LGIP.

{Signature Page to Follow}

IN WITNESS WHEREOF, the Parties have executed this Agreement in multiple originals, each of which shall constitute and be an original Agreement among the Parties.

Transmission Provider

{Transmission Provider}

By: _____

Name: _____

Title: _____

Affected System Interconnection Customer

{Affected System Interconnection Customer}

By: _____

Name: _____

Title: _____

Project No. _____

Affected System Interconnection Customer

{Affected System Interconnection Customer}

By: _____

Name: _____

Title: _____

Project No. _____

**Attachment A to Appendix 12
Multiparty Affected System Facilities Construction Agreement**

**AFFECTED SYSTEM NETWORK UPGRADE(S), COST ESTIMATES AND
RESPONSIBILITY, CONSTRUCTION SCHEDULE, AND MONTHLY
PAYMENT SCHEDULE**

This Appendix A is a part of the Multiparty Affected System Facilities Construction Agreement among Affected System Interconnection Customers and Transmission Provider.

1.1 Affected System Network Upgrade(s) to be installed by Transmission Provider.

{description}

1.2 First Equipment Order (including permitting).

{description}

1.2.1. Permitting and Land Rights – Transmission Provider Affected System Network Upgrade(s)

{description}

1.3 Construction Schedule. Where applicable, construction of the Affected System Network Upgrade(s) is scheduled as follows and will be periodically updated as necessary:

Table 3: Transmission Provider Construction Activities

MILESTONE NUMBER	DESCRIPTION	START DATE	END DATE

Note: Construction schedule assumes that Transmission Provider has obtained final authorizations and security from Affected System Interconnection Customers and all necessary permits from Governmental Authorities as necessary prerequisites to commence construction of any of the Affected System Network Upgrade(s).

1.4 Payment Schedule.

1.4.1 Timing of and Adjustments to Affected System Interconnection Customers’ Payments and Security.

{description}

1.4.2 Monthly Payment Schedule. Affected System Interconnection Customers’ payment schedule is as follows.

{description}

* Affected System Interconnection Customers' proportionate responsibility for each payment is as follows:

Affected System Interconnection Customer 1 ____._%

Affected System Interconnection Customer 2 ____._%

Affected System Interconnection Customer N ____._%

Note: Affected System Interconnection Customers' payment or provision of security as provided in this Agreement operates as a condition precedent to Transmission Provider's obligations to construct any Affected System Network Upgrade(s), and failure to meet this schedule will constitute a Breach pursuant to Article 5.1 of this Agreement.

1.5 Permits, Licenses, and Authorizations.

{description}

Attachment B to Appendix 12
Multiparty Affected System Facilities Construction Agreement

NOTIFICATION OF COMPLETED CONSTRUCTION

This Appendix B is a part of the Multiparty Affected System Facilities Construction Agreement among Affected System Interconnection Customers and Transmission Provider. Where applicable, when Transmission Provider has completed construction of the Affected System Network Upgrade(s), Transmission Provider shall send notice to Affected System Interconnection Customers in substantially the form following:

{Date}

{Affected System Interconnection Customers Addresses}

Re: CompleRecord Content Description, Tariff Record Title, Record Version Number, Option Code:
OATT Attachment N, ATTACHMENT N Standard Large Generator Int. Agreement, 5.0.0, A
Record Narrative Name:
Tariff Record ID: 62
Tariff Record Collation Value: 62004 Tariff Record Parent Identifier: 0
Proposed Date: 2024-05-17
Priority Order: 501
Record Change Type: CHANGE
Record Content Type: 1
Associated Filing Identifier:

ATTACHMENT N

**STANDARD LARGE GENERATOR
INTERCONNECTION AGREEMENT (LGIA)
TABLE OF CONTENTS**

	Page
<u>Recitals</u>	- 1 -
<u>Article 1. Definitions</u>	- 2 -
<u>Article 2. Effective Date, Term, and Termination</u>	- 13 -
<u>2.1 Effective Date</u>	- 13 -
<u>2.2 Term of Agreement</u>	- 13 -
<u>2.3 Termination Procedures</u>	- 13 -
<u>2.3.1 Written Notice</u>	- 13 -
<u>2.3.2 Default</u>	- 13 -
<u>2.4 Termination Costs</u>	- 14 -
<u>2.5 Disconnection</u>	- 15 -
<u>2.6 Survival</u>	- 15 -
<u>Article 3. Regulatory Filings</u>	- 16 -
<u>3.1 Filing</u>	- 16 -
<u>Article 4. Scope of Service</u>	- 16 -
<u>4.1 Interconnection Product Options</u>	- 16 -
<u>4.1.1 Energy Resource Interconnection Service</u>	- 16 -
<u>4.1.2 Network Resource Interconnection Service</u>	- 18 -
<u>4.2 Provision of Service</u>	- 20 -
<u>4.3 Performance Standards</u>	- 20 -

[4.4 No Transmission Delivery Service](#) - 21 -
[4.5 Interconnection Customer Provided Services](#) - 21 -

[Article 5. Interconnection Facilities Engineering, Procurement, and Construction](#)

..... - 21 -

[5.1 Options](#) - 21 -
 [5.1.1 Standard Option](#) - 21 -
 [5.1.2 Alternate Option](#) - 22 -
 [5.1.3 Option to Build](#) - 22 -
 [5.1.4 Negotiated Option](#) - 23 -
[5.2 General Conditions Applicable to Option to Build](#) - 23 -
[5.3 Liquidated Damages](#) - 26 -
[5.4 Power System Stabilizers](#) - 27 -
[5.5 Equipment Procurement](#) - 27 -
[5.6 Construction Commencement](#) - 28 -
[5.7 Work Progress](#) - 28 -
[5.8 Information Exchange](#) - 29 -
[5.9 Other Interconnection Options](#) - 29 -
 [5.9.1 Limited Operation](#) - 29 -
 [5.9.2 Provisional Interconnection Service](#) - 29 -
[5.10 Interconnection Customer's Interconnection Facilities \('ICIF'\)](#) - 30 -
 [5.10.1 Interconnection Customer's Interconnection Facility Specifications](#) - 31 -
 - 31 -
 [5.10.2 Transmission Provider's Review](#) - 31 -
 [5.10.3 ICIF Construction](#) - 31 -
[5.11 Transmission Provider's Interconnection Facilities Construction](#) - 32 -
[5.12 Access Rights](#) - 32 -
[5.13 Lands of Other Property Owners](#) - 33 -
[5.14 Permits](#) - 33 -
[5.15 Early Construction of Base Case Facilities](#) - 33 -
[5.16 Suspension](#) - 34 -
[5.17 Taxes](#) - 34 -
 [5.17.1 Interconnection Customer Payments Not Taxable](#) - 34 -
 [5.17.2 Representations and Covenants](#) - 35 -
 [5.17.3 Indemnification for the Cost Consequences of Current Tax Liability Imposed Upon Transmission Provider](#) - 35 -
 [5.17.4 Tax Gross-Up Amount](#) - 37 -
 [5.17.5 Private Letter Ruling or Change or Clarification of Law](#) - 38 -
 [5.17.6 Subsequent Taxable Events](#) - 38 -
 [5.17.7 Contests](#) - 39 -
 [5.17.8 Refund](#) - 40 -

5.17.9 Taxes Other Than Income Taxes - 41 -

5.17.10 Transmission Owners Who Are Not Transmission Providers - 42 -

5.18 Tax Status - 42 -

5.19 Modification - 42 -

5.19.1 General - 42 -

5.19.2 Standards - 43 -

5.19.3 Modification Costs - 43 -

Article 6. Testing and Inspection - 44 -

6.1 Pre-Commercial Operation Date Testing and Modifications - 44 -

6.2 Post-Commercial Operation Date Testing and Modifications - 44 -

6.3 Right to Observe Testing - 44 -

6.4 Right to Inspect - 44 -

Article 7. Metering - 45 -

7.1 General - 45 -

7.2 Check Meters - 45 -

7.3 Standards - 46 -

7.4 Testing of Metering Equipment - 46 -

7.5 Metering Data - 46 -

Article 8. Communications - 47 -

8.1 Interconnection Customer Obligations - 47 -

8.2 Remote Terminal Unit - 47 -

8.3 No Annexation - 48 -

8.4 Provision of Data from a Variable Energy Resource - 48 -

Article 9. Operations - 49 -

9.1 General - 49 -

9.2 Balancing Authority Area Notification - 49 -

9.3 Transmission Provider Obligations - 49 -

9.4 Interconnection Customer Obligations - 49 -

9.5 Start-Up and Synchronization - 50 -

9.6 Reactive Power and Primary Frequency Response - 50 -

9.6.1 Power Factor Design Criteria - 50 -

9.6.2 Voltage Schedules - 51 -

9.6.3 Payment for Reactive Power - 52 -

9.6.4 Primary Frequency Response - 52 -

9.7 Outages and Interruptions - 56 -

9.7.1 Outages - 57 -

9.7.2	Interruption of Service	- 58 -
9.7.3	Ride Through Capability and Performance	- 59 -
9.7.4	System Protection and Other Control Requirements	- 60 -
9.7.5	Requirements for Protection	- 62 -
9.7.6	Power Quality	- 62 -
9.8	Switching and Tagging Rules	- 62 -
9.9	Use of Interconnection Facilities by Third Parties	- 63 -
9.9.1	Purpose of Interconnection Facilities	- 63 -
9.9.2	Third Party Users	- 63 -
9.10	Disturbance Analysis Data Exchange	- 63 -
Article 10.	Maintenance	- 64 -
10.1	Transmission Provider Obligations	- 64 -
10.2	Interconnection Customer Obligations	- 64 -
10.3	Coordination	- 64 -
10.4	Secondary Systems	- 64 -
10.5	Operating and Maintenance Expenses	- 65 -
Article 11.	Performance Obligation	- 65 -
11.1	Interconnection Customer Interconnection Facilities	- 65 -
11.2	Transmission Provider’s Interconnection Facilities	- 65 -
11.3	Network Upgrades and Distribution Upgrades	- 65 -
11.4	Transmission Credits	- 65 -
11.4.1	Repayment of Amounts Advanced for Network Upgrades	- 66 -
11.4.2	Special Provisions for Affected Systems	- 67 -
11.5	Provision of Security	- 67 -
11.6	Interconnection Customer Compensation	- 69 -
11.6.1	Interconnection Customer Compensation for Actions During Emergency Condition	- 69 -
Article 12.	Invoice	- 69 -
12.1	General	- 69 -
12.2	Final Invoice	- 70 -
12.3	Payment	- 70 -
12.4	Disputes	- 70 -
Article 13.	Emergencies	- 71 -
13.1	Definition	- 71 -
13.2	Obligations	- 71 -
13.3	Notice	- 71 -
13.4	Immediate Action	- 72 -

- [13.5 Transmission Provider Authority](#) - 72 -
 - [13.5.1 General](#)..... - 72 -
 - [13.5.2 Reduction and Disconnection](#) - 73 -
- [13.6 Interconnection Customer Authority](#)..... - 73 -
- [13.7 Limited Liability](#) - 74 -
- [Article 14. Regulatory Requirements and Governing Law](#)**..... - **74** -
 - [14.1 Regulatory Requirements](#)..... - 74 -
 - [14.2 Governing Law](#) - 74 -
- [Article 15. Notices](#)** - **75** -
 - [15.1 General](#) - 75 -
 - [15.2 Billings and Payments](#)..... - 75 -
 - [15.3 Alternative Forms of Notice](#) - 75 -
 - [15.4 Operations and Maintenance Notice](#)..... - 75 -
- [Article 16. Force Majeure](#)** - **76** -
 - [16.1 Force Majeure](#)..... - 76 -
- [Article 17. Default](#)** - **76** -
 - [17.1 Default](#) - 76 -
 - [17.1.1 General](#)..... - 76 -
 - [17.1.2 Right to Terminate](#)..... - 77 -
 - [17.2 Violation of Operating Assumptions for Generating Facilities](#) - 77 -
- [Article 18. Indemnity, Consequential Damages and Insurance](#)**..... - **77** -
 - [18.1 Indemnity](#)..... - 78 -
 - [18.1.1 Indemnified Person](#) - 78 -
 - [18.1.2 Indemnifying Party](#) - 78 -
 - [18.1.3 Indemnity Procedures](#) - 78 -
 - [18.2 Consequential Damages](#)..... - 79 -
 - [18.3 Insurance](#) - 80 -
- [Article 19. Assignment](#)** - **83** -
 - [19.1 Assignment](#) - 83 -
- [Article 20. Severability](#)** - **83** -
 - [20.1 Severability](#) - 83 -
- [Article 21. Comparability](#)**..... - **84** -
 - [21.1 Comparability](#)..... - 84 -
- [Article 22. Confidentiality](#)** - **84** -

- [22.1 Confidentiality](#)..... - 84 -
 - [22.1.1 Term](#)..... - 84 -
 - [22.1.2 Scope](#)..... - 85 -
 - [22.1.3 Release of Confidential Information](#)..... - 85 -
 - [22.1.4 Rights](#)..... - 86 -
 - [22.1.5 No Warranties](#)..... - 86 -
 - [22.1.6 Standard of Care](#)..... - 86 -
 - [22.1.7 Order of Disclosure](#)..... - 86 -
 - [22.1.8 Termination of Agreement](#)..... - 87 -
 - [22.1.9 Remedies](#)..... - 87 -
 - [22.1.10 Disclosure to FERC, its Staff, or a State](#)..... - 87 -
- [Article 23. Environmental Releases](#)..... - 89 -**
- [Article 24. Information Requirements](#)..... - 89 -**
 - [24.1 Information Acquisition](#)..... - 89 -
 - [24.2 Information Submission by Transmission Provider](#)..... - 89 -
 - [24.3 Updated Information Submission by Interconnection Customer](#)..... - 90 -
 - [24.4 Information Supplementation](#)..... - 90 -
- [Article 25. Information Access and Audit Rights](#)..... - 91 -**
 - [25.1 Information Access](#)..... - 91 -
 - [25.2 Reporting of Non-Force Majeure Events](#)..... - 92 -
 - [25.3 Audit Rights](#)..... - 92 -
 - [25.4 Audit Rights Periods](#)..... - 92 -
 - [25.4.1 Audit Rights Period for Construction-Related Accounts and Records](#)..... - 92 -
 - [25.4.2 Audit Rights Period for All Other Accounts and Records](#)..... - 93 -
 - [25.5 Audit Results](#)..... - 93 -
- [Article 26. Subcontractors](#)..... - 93 -**
 - [26.1 General](#)..... - 93 -
 - [26.2 Responsibility of Principal](#)..... - 93 -
 - [26.3 No Limitation by Insurance](#)..... - 94 -
- [Article 27. Disputes](#)..... - 94 -**
 - [27.1 Submission](#)..... - 94 -
 - [27.2 External Arbitration Procedures](#)..... - 94 -
 - [27.3 Arbitration Decisions](#)..... - 95 -
 - [27.4 Costs](#)..... - 95 -

Article 28. Representations, Warranties, and Covenants - 95 -

28.1 General - 96 -

28.1.1 Good Standing..... - 96 -

28.1.2 Authority..... - 96 -

28.1.3 No Conflict - 96 -

28.1.4 Consent and Approval..... - 96 -

Article 29. Joint Operating Committee..... - 97 -

29.1 Joint Operating Committee - 97 -

Article 30. Miscellaneous - 98 -

30.1 Binding Effect..... - 98 -

30.2 Conflicts - 98 -

30.3 Rules of Interpretation - 98 -

30.4 Entire Agreement..... - 99 -

30.5 No Third Party Beneficiaries..... - 99 -

30.6 Waiver - 100 -

30.7 Headings..... - 100 -

30.8 Multiple Counterparts..... - 100 -

30.9 Amendment - 100 -

30.10 Modification by the Parties - 100 -

30.11 Reservation of Rights - 100 -

30.12 No Partnership..... - 101 -

Appendix A – Interconnection Facilities, Network Upgrades, and Distribution Upgrades

Appendix B – Milestones

Appendix C – Interconnection Details

Appendix D – Security Arrangements Details

Appendix E – Commercial Operation Date

Appendix F – Addresses for Delivery of Notices and Billings

Appendix G – Interconnection Requirements for a Wind Generating Plant

Appendix H – Operating Assumptions for Generating Facility

STANDARD LARGE GENERATOR INTERCONNECTION AGREEMENT

THIS STANDARD LARGE GENERATOR INTERCONNECTION AGREEMENT (“Agreement”) is made and entered into this ____ day of _____ 20__, by and between _____, a _____ organized and existing under the laws of the State/Commonwealth of _____ (“Interconnection Customer” with a Large Generating Facility), and _____, a _____ organized and existing under the laws of the State/Commonwealth of _____ (“Transmission Provider and/or Transmission Owner”). Interconnection Customer and Transmission Provider each may be referred to as a “Party” or collectively as the “Parties.”

Recitals

WHEREAS, Transmission Provider operates the Transmission System; and

WHEREAS, Interconnection Customer intends to own, lease and/or control and operate the Generating Facility identified as a Large Generating Facility in Appendix C to this Agreement; and,

WHEREAS, Interconnection Customer and Transmission Provider have agreed to enter into this Agreement for the purpose of interconnecting the Large Generating Facility with the Transmission System;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein, it is agreed:

When used in this Standard Large Generator Interconnection Agreement, terms with initial capitalization that are not defined in Article 1 shall have the meanings specified in the Article in which they are used or the Open Access Transmission Tariff (Tariff).

Article 1. Definitions

Adverse System Impact shall mean the negative effects due to technical or operational limits on conductors or equipment being exceeded that may compromise the safety and reliability of the electric system.

Affected System shall mean an electric system other than Transmission Provider's Transmission System that may be affected by the proposed interconnection.

Affected System Operator shall mean the entity that operates an Affected System.

Affiliate shall mean, with respect to a corporation, partnership or other entity, each such other corporation, partnership or other entity that directly or indirectly, through one or more intermediaries, controls, is controlled by, or is under common control with, such corporation, partnership or other entity.

Ancillary Services shall mean those services that are necessary to support the transmission of capacity and energy from resources to loads while maintaining reliable operation of Transmission Provider's Transmission System in accordance with Good Utility Practice.

Applicable Laws and Regulations shall mean all duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Applicable Reliability Standards shall mean the requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Balancing Authority shall mean an entity that integrates resource plans ahead of time, maintains demand and resource balance within a Balancing Authority Area, and supports interconnection frequency in real time.

Balancing Authority Area shall mean the collection of generation, transmission, and loads within the metered boundaries of the Balancing Authority. The Balancing Authority maintains load-resource balance within this area.

Base Case shall mean the base case power flow, short circuit, and stability data bases used for the Interconnection Studies by Transmission Provider or Interconnection Customer.

Breach shall mean the failure of a Party to perform or observe any material term or condition of the Standard Large Generator Interconnection Agreement.

Breaching Party shall mean a Party that is in Breach of the Standard Large Generator Interconnection Agreement.

Business Day shall mean Monday through Friday, excluding Federal Holidays.

Calendar Day shall mean any day including Saturday, Sunday or a Federal Holiday.

Cluster shall mean a group of one or more Interconnection Requests that are studied together for the purpose of conducting a Cluster Study.

Cluster Restudy shall mean a restudy of a Cluster Study conducted pursuant to Section 7.5 of the LGIP.

Cluster Study shall mean the evaluation of one or more Interconnection Requests within a Cluster as described in Section 7 of the LGIP.

Clustering shall mean the process whereby one or more Interconnection Requests are studied together, instead of serially, as described in Section 7 of the LGIP.

Commercial Operation shall mean the status of a Generating Facility that has commenced generating electricity for sale, excluding electricity generated during Trial Operation.

Commercial Operation Date of a unit shall mean the date on which the Generating Facility commences Commercial Operation as agreed to by the Parties pursuant to Appendix E to the Standard Large Generator Interconnection Agreement.

Confidential Information shall mean any confidential, proprietary or trade secret information of a plan, specification, pattern, procedure, design, device, list, concept, policy or compilation relating to the present or planned business of a Party, which is designated as confidential by the Party supplying the information, whether conveyed orally, electronically, in writing, through inspection, or otherwise.

Contingent Facilities shall mean those unbuilt Interconnection Facilities and Network Upgrades upon which the Interconnection Request's costs, timing, and study findings are dependent, and if delayed or not built, could cause a need for restudies of the Interconnection Request or a reassessment of the Interconnection Facilities and/or Network Upgrades and/or costs and timing.

Default shall mean the failure of a Breaching Party to cure its Breach in accordance with Article 17 of the Standard Large Generator Interconnection Agreement.

Dispute Resolution shall mean the procedure for resolution of a dispute between the Parties in which they will first attempt to resolve the dispute on an informal basis.

Distribution System shall mean Transmission Provider's facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which distribution systems operate differ among areas.

Distribution Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Generating Facility and render the transmission service necessary to effect Interconnection Customer's wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Effective Date shall mean the date on which the Standard Large Generator Interconnection Agreement becomes effective upon execution by the Parties subject to acceptance by FERC, or if filed unexecuted, upon the date specified by FERC.

Electric Reliability Organization shall mean the North American Electric Reliability Corporation (NERC) or its successor organization.

Emergency Condition shall mean a condition or situation: (1) that in the judgment of the Party making the claim is imminently likely to endanger life or property; or (2) that, in the case of a Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or

damage to Transmission Provider's Transmission System, Transmission Provider's Interconnection Facilities or the electric systems of others to which Transmission Provider's Transmission System is directly connected; or (3) that, in the case of Interconnection Customer, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Generating Facility or Interconnection Customer's Interconnection Facilities. System restoration and black start shall be considered Emergency Conditions; provided, that Interconnection Customer is not obligated by the Standard Large Generator Interconnection Agreement to possess black start capability.

Energy Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to connect its Generating Facility to Transmission Provider's Transmission System to be eligible to deliver the Generating Facility's electric output using the existing firm or nonfirm capacity of Transmission Provider's Transmission System on an as available basis. Energy Resource Interconnection Service in and of itself does not convey transmission service.

Engineering & Procurement (E&P) Agreement shall mean an agreement that authorizes Transmission Provider to begin engineering and procurement of long lead-time items necessary for the establishment of the interconnection in order to advance the implementation of the Interconnection Request.

Environmental Law shall mean Applicable Laws or Regulations relating to pollution or protection of the environment or natural resources.

Federal Power Act shall mean the Federal Power Act, as amended, 16 U.S.C. §§ 791a et seq.

FERC shall mean the Federal Energy Regulatory Commission (Commission) or its successor.

Force Majeure shall mean any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, breakage or accident to machinery or equipment, any order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, or any other cause beyond a Party's control. A Force Majeure event does not include acts of negligence or intentional wrongdoing by the Party claiming Force Majeure.

Generating Facility shall mean Interconnection Customer's devices for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer's Interconnection Facilities.

Generating Facility Capacity shall mean the net capacity of the Generating Facility or the aggregate net capacity of the Generating Facility where it includes more than one device for the production and/or storage for later injection of electricity.

Good Utility Practice shall mean any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Governmental Authority shall mean any federal, state, local or other governmental regulatory or administrative agency, court, commission, department, board, or other governmental subdivision, legislature, rulemaking board, tribunal, or other governmental authority having jurisdiction over the Parties, their respective facilities, or the respective services they provide, and exercising or entitled to exercise any administrative, executive, police, or taxing authority or power; provided, however, that such term does not include Interconnection Customer, Transmission Provider, or any Affiliate thereof.

Hazardous Substances shall mean any chemicals, materials or substances defined as or included in the definition of “hazardous substances,” “hazardous wastes,” “hazardous materials,” “hazardous constituents,” “restricted hazardous materials,” “extremely hazardous substances,” “toxic substances,” “radioactive substances,” “contaminants,” “pollutants,” “toxic pollutants” or words of similar meaning and regulatory effect under any applicable Environmental Law, or any other chemical, material or substance, exposure to which is prohibited, limited or regulated by any applicable Environmental Law.

Initial Synchronization Date shall mean the date upon which the Generating Facility is initially synchronized and upon which Trial Operation begins.

In-Service Date shall mean the date upon which Interconnection Customer reasonably expects it will be ready to begin use of Transmission Provider’s Interconnection Facilities to obtain back feed power.

Interconnection Customer shall mean any entity, including Transmission Provider, Transmission Owner or any of the Affiliates or subsidiaries of either, that proposes to interconnect its Generating Facility with Transmission Provider’s Transmission System.

Interconnection Customer’s Interconnection Facilities shall mean all facilities and equipment, as identified in Appendix A of the Standard Large Generator Interconnection Agreement, that are located between the Generating Facility and the Point of Change of Ownership, including any modification, addition, or upgrades to such

facilities and equipment necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Customer's Interconnection Facilities are sole use facilities.

Interconnection Facilities shall mean Transmission Provider's Interconnection Facilities and Interconnection Customer's Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Generating Facility to Transmission Provider's Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Interconnection Facilities Study shall mean a study conducted by Transmission Provider or a third party consultant for Interconnection Customer to determine a list of facilities (including Transmission Provider's Interconnection Facilities and Network Upgrades as identified in the Cluster Study), the cost of those facilities, and the time required to interconnect the Generating Facility with Transmission Provider's Transmission System. The scope of the study is defined in Section 8 of the LGIP.

Interconnection Facilities Study Agreement shall mean the form of agreement contained in Appendix 3 of the Standard Large Generator Interconnection Procedures for conducting the Interconnection Facilities Study.

Interconnection Request shall mean an Interconnection Customer's request, in the form of Appendix 1 to the LGIP, in accordance with the Tariff, to interconnect a new Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Generating Facility that is interconnected with Transmission Provider's Transmission System.

Interconnection Service shall mean the service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling it to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Standard Large Generator Interconnection Agreement and, if applicable, Transmission Provider's Tariff.

Interconnection Study shall mean any of the following studies: the Cluster Study, the Cluster Restudy, the Surplus Interconnection Service Study, the Interconnection Facilities Study, the Affected System Study, Optional Interconnection Study, and Material Modification assessment, described in the LGIP.

IRS shall mean the Internal Revenue Service.

Joint Operating Committee shall be a group made up of representatives from Interconnection Customers and Transmission Provider to coordinate operating and technical considerations of Interconnection Service.

Large Generating Facility shall mean a Generating Facility having a Generating Facility Capacity of more than 20 MW.

LGIA Deposit shall mean the deposit Interconnection Customer submits when returning the executed LGIA, or within ten (10) Business Days of requesting that the LGIA be filed unexecuted at the Commission, in accordance with Section 11.3 of the LGIP.

Loss shall mean any and all losses relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's performance, or non-performance of its obligations under the Standard Large Generator Interconnection Agreement on behalf of the Indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the Indemnifying Party.

Material Modification shall mean those modifications that have a material impact on the cost or timing of any Interconnection Request with an equal or later Queue Position.

Metering Equipment shall mean all metering equipment installed or to be installed at the Generating Facility pursuant to the Standard Large Generator Interconnection Agreement at the metering points, including but not limited to instrument transformers, MWh-meters, data acquisition equipment, transducers, remote terminal unit, communications equipment, phone lines, and fiber optics.

Network Resource shall mean any designated generating resource owned, purchased, or leased by a Network Customer under the Network Integration Transmission Service Tariff. Network Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Network Customer's Network Load on a non-interruptible basis.

Network Resource Interconnection Service shall mean an Interconnection Service that allows Interconnection Customer to integrate its Large Generating Facility with Transmission Provider's Transmission System (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an RTO or ISO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service in and of itself does not convey transmission service.

Network Upgrades shall mean the additions, modifications, and upgrades to Transmission Provider's Transmission System required at or beyond the point at which

the Interconnection Facilities connect to Transmission Provider's Transmission System to accommodate the interconnection of the Large Generating Facility to Transmission Provider's Transmission System.

Notice of Dispute shall mean a written notice of a dispute or claim that arises out of or in connection with the Standard Large Generator Interconnection Agreement or its performance.

Optional Interconnection Study shall mean a sensitivity analysis based on assumptions specified by Interconnection Customer in the Optional Interconnection Study Agreement.

Optional Interconnection Study Agreement shall mean the form of agreement contained in Appendix 4 of the LGIP for conducting the Optional Interconnection Study.

Party or Parties shall mean Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Point of Change of Ownership shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where Interconnection Customer's Interconnection Facilities connect to Transmission Provider's Interconnection Facilities.

Point of Interconnection shall mean the point, as set forth in Appendix A to the Standard Large Generator Interconnection Agreement, where the Interconnection Facilities connect to Transmission Provider's Transmission System.

Proportional Impact Method shall mean a technical analysis conducted by Transmission Provider to determine the degree to which each Generating Facility in the Cluster Study contributes to the need for a specific System Network Upgrade.

Provisional Interconnection Service shall mean Interconnection Service provided by Transmission Provider associated with interconnecting Interconnection Customer's Generating Facility to Transmission Provider's Transmission System and enabling that Transmission System to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Provisional Large Generator Interconnection Agreement and, if applicable, the Tariff.

Provisional Large Generator Interconnection Agreement shall mean the interconnection agreement for Provisional Interconnection Service established between Transmission Provider and/or the Transmission Owner and Interconnection Customer. This agreement shall take the form of the Standard Large Generator Interconnection Agreement, modified for provisional purposes.

Queue Position shall mean the order of a valid Interconnection Request, relative to all other pending valid Interconnection Requests, established pursuant to Section 4.1 of this LGIP.

Reasonable Efforts shall mean, with respect to an action required to be attempted or taken by a Party under the Standard Large Generator Interconnection Agreement, efforts that are timely and consistent with Good Utility Practice and are otherwise substantially equivalent to those a Party would use to protect its own interests.

Scoping Meeting shall mean the meeting between representatives of Interconnection Customer(s) and Transmission Provider conducted for the purpose of discussing the proposed Interconnection Request and any alternative interconnection options, exchanging information including any transmission data and earlier study evaluations that would be reasonably expected to impact such interconnection options, refining information and models provided by Interconnection Customer(s), discussing the Cluster Study materials posted to OASIS pursuant to Section 3.5 of the LGIP, and analyzing such information.

Site Control shall mean the exclusive land right to develop, construct, operate, and maintain the Generating Facility over the term of expected operation of the Generating Facility. Site Control may be demonstrated by documentation establishing: (1) ownership of, a leasehold interest in, or a right to develop a site of sufficient size to construct and operate the Generating Facility; (2) an option to purchase or acquire a leasehold site of sufficient size to construct and operate the Generating Facility for such purpose; or (3) any other documentation that clearly demonstrates the right of Interconnection Customer to exclusively occupy a site of sufficient size to construct and operate the Generating Facility. Transmission Provider will maintain acreage requirements for each Generating Facility type on its OASIS or public website.

Small Generating Facility shall mean a Generating Facility that has a Generating Facility Capacity of no more than 20 MW.

Stand Alone Network Upgrades shall mean Network Upgrades that are not part of an Affected System that an Interconnection Customer may construct without affecting day-to-day operations of the Transmission System during their construction. Both Transmission Provider and Interconnection Customer must agree as to what constitutes Stand Alone Network Upgrades and identify them in Appendix A to the Standard Large Generator Interconnection Agreement. If Transmission Provider and Interconnection Customer disagree about whether a particular Network Upgrade is a Stand Alone Network Upgrade, Transmission Provider must provide Interconnection Customer a written technical explanation outlining why Transmission Provider does not consider the Network Upgrade to be a Stand Alone Network Upgrade within fifteen (15) Business Days of its determination.

Standard Large Generator Interconnection Agreement (LGIA) shall mean the form of interconnection agreement applicable to an Interconnection Request pertaining to a Large Generating Facility that is included in Transmission Provider's Tariff.

Standard Large Generator Interconnection Procedures (LGIP) shall mean the interconnection procedures applicable to an Interconnection Request pertaining to a Large Generating Facility that are included in Transmission Provider's Tariff.

Substation Network Upgrades shall mean Network Upgrades that are required at the substation located at the Point of Interconnection.

Surplus Interconnection Service shall mean any unneeded portion of Interconnection Service established in a Standard Large Generator Interconnection Agreement, such that if Surplus Interconnection Service is utilized the total amount of Interconnection Service at the Point of Interconnection would remain the same.

System Network Upgrades shall mean Network Upgrades that are required beyond the substation located at the Point of Interconnection.

System Protection Facilities shall mean the equipment, including necessary protection signal communications equipment, required to protect (1) Transmission Provider's Transmission System from faults or other electrical disturbances occurring at the Generating Facility and (2) the Generating Facility from faults or other electrical system disturbances occurring on Transmission Provider's Transmission System or on other delivery systems or other generating systems to which Transmission Provider's Transmission System is directly connected.

Tariff shall mean Transmission Provider's Tariff through which open access transmission service and Interconnection Service are offered, as filed with FERC, and as amended or supplemented from time to time, or any successor tariff.

Transmission Owner shall mean an entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Standard Large Generator Interconnection Agreement to the extent necessary.

Transmission Provider shall mean the public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission Provider's Interconnection Facilities shall mean all facilities and equipment owned, controlled, or operated by Transmission Provider from the Point of Change of Ownership to the Point of Interconnection as identified in Appendix A to the

Standard Large Generator Interconnection Agreement, including any modifications, additions or upgrades to such facilities and equipment. Transmission Provider's Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades, Stand Alone Network Upgrades or Network Upgrades.

Transmission System shall mean the facilities owned, controlled or operated by Transmission Provider or Transmission Owner that are used to provide transmission service under the Tariff.

Trial Operation shall mean the period during which Interconnection Customer is engaged in on-site test operations and commissioning of the Generating Facility prior to Commercial Operation.

Variable Energy Resource shall mean a device for the production of electricity that is characterized by an energy source that: (1) is renewable; (2) cannot be stored by the facility owner or operator; and (3) has variability that is beyond the control of the facility owner or operator.

Withdrawal Penalty shall mean the penalty assessed by Transmission Provider to an Interconnection Customer that chooses to withdraw or is deemed withdrawn from Transmission Provider's interconnection queue or whose Generating Facility does not otherwise reach Commercial Operation. The calculation of the Withdrawal Penalty is set forth in Section 3.7.1 of the LGIP.

Article 2. Effective Date, Term, and Termination

2.1 **Effective Date.** This LGIA shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by FERC. Transmission Provider shall promptly file this LGIA with FERC upon execution in accordance with Article 3.1, if required.

2.2 **Term of Agreement.** Subject to the provisions of Article 2.3, this LGIA shall remain in effect for a period of ten (10) years from the Effective Date or such other longer period as Interconnection Customer may request (Term to be specified in individual agreements) and shall be automatically renewed for each successive one-year period thereafter.

2.3 Termination Procedures.

- 2.3.1** Written Notice. This LGIA may be terminated by Interconnection Customer after giving Transmission Provider ninety (90) Calendar Days advance written notice, or by Transmission Provider notifying FERC after the Generating Facility permanently ceases Commercial Operation.
- 2.3.2** Default. Either Party may terminate this LGIA in accordance with Article 17.
- 2.3.3** Notwithstanding Articles 2.3.1 and 2.3.2, no termination shall become effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination, including the filing with FERC of a notice of termination of this LGIA, which notice has been accepted for filing by FERC.
- 2.4** Termination Costs. If a Party elects to terminate this Agreement pursuant to Article 2.3 above, each Party shall pay all costs incurred (including any cancellation costs relating to orders or contracts for Interconnection Facilities and equipment) or charges assessed by the other Party, as of the date of the other Party's receipt of such notice of termination, that are the responsibility of the Terminating Party under this LGIA. In the event of termination by a Party, the Parties shall use commercially Reasonable Efforts to mitigate the costs, damages and charges arising as a consequence of termination. Upon termination of this LGIA, unless otherwise ordered or approved by FERC:
- 2.4.1** With respect to any portion of Transmission Provider's Interconnection Facilities that have not yet been constructed or installed, Transmission Provider shall to the extent possible and with Interconnection Customer's authorization cancel any pending orders of, or return, any materials or equipment for, or contracts for construction of, such facilities; provided that in the event Interconnection Customer elects not to authorize such cancellation, Interconnection Customer shall assume all payment obligations with respect to such materials, equipment, and contracts, and Transmission Provider shall deliver such material and equipment, and, if necessary, assign such contracts, to Interconnection Customer as soon as practicable, at Interconnection Customer's expense. To the extent that

Interconnection Customer has already paid Transmission Provider for any or all such costs of materials or equipment not taken by Interconnection Customer, Transmission Provider shall promptly refund such amounts to Interconnection Customer, less any costs, including penalties incurred by Transmission Provider to cancel any pending orders of or return such materials, equipment, or contracts.

If an Interconnection Customer terminates this LGIA, it shall be responsible for all costs incurred in association with that Interconnection Customer's interconnection, including any cancellation costs relating to orders or contracts for Interconnection Facilities and equipment, and other expenses including any Network Upgrades for which Transmission Provider has incurred expenses and has not been reimbursed by Interconnection Customer.

- 2.4.2** Transmission Provider may, at its option, retain any portion of such materials, equipment, or facilities that Interconnection Customer chooses not to accept delivery of, in which case Transmission Provider shall be responsible for all costs associated with procuring such materials, equipment, or facilities.
- 2.4.3** With respect to any portion of the Interconnection Facilities, and any other facilities already installed or constructed pursuant to the terms of this LGIA, Interconnection Customer shall be responsible for all costs associated with the removal, relocation or other disposition or retirement of such materials, equipment, or facilities.
- 2.5** Disconnection. Upon termination of this LGIA, the Parties will take all appropriate steps to disconnect the Large Generating Facility from the Transmission System. All costs required to effectuate such disconnection shall be borne by the terminating Party, unless such termination resulted from the non-terminating Party's Default of this LGIA or such non-terminating Party otherwise is responsible for these costs under this LGIA.
- 2.6** Survival. This LGIA shall continue in effect after termination to the extent necessary to provide for final billings and payments and for costs incurred

hereunder, including billings and payments pursuant to this LGIA; to permit the determination and enforcement of liability and indemnification obligations arising from acts or events that occurred while this LGIA was in effect; and to permit each Party to have access to the lands of the other Party pursuant to this LGIA or other applicable agreements, to disconnect, remove or salvage its own facilities and equipment.

Article 3. Regulatory Filings

- 3.1 **Filing.** Transmission Provider shall file this LGIA (and any amendment hereto) with the appropriate Governmental Authority, if required. Interconnection Customer may request that any information so provided be subject to the confidentiality provisions of Article 22. If Interconnection Customer has executed this LGIA, or any amendment thereto, Interconnection Customer shall reasonably cooperate with Transmission Provider with respect to such filing and to provide any information reasonably requested by Transmission Provider needed to comply with applicable regulatory requirements.

Article 4. Scope of Service

- 4.1 **Interconnection Product Options.** Interconnection Customer has selected the following (checked) type of Interconnection Service:

4.1.1 Energy Resource Interconnection Service.

- 4.1.1.1 **The Product.** Energy Resource Interconnection Service allows Interconnection Customer to connect the Large Generating Facility to the Transmission System and be eligible to deliver the Large Generating Facility's output using the existing firm or non-firm capacity of the Transmission System on an "as available" basis. To the extent Interconnection Customer wants to receive Energy

Resource Interconnection Service, Transmission Provider shall construct facilities identified in Attachment A.

4.1.1.2 Transmission Delivery Service Implications.

Under Energy Resource Interconnection Service, Interconnection Customer will be eligible to inject power from the Large Generating Facility into and deliver power across the interconnecting Transmission Provider's Transmission System on an "as available" basis up to the amount of MWs identified in the applicable stability and steady state studies to the extent the upgrades initially required to qualify for Energy Resource Interconnection Service have been constructed. Where eligible to do so (e.g., PJM, ISO-NE, NYISO), Interconnection Customer may place a bid to sell into the market up to the maximum identified Large Generating Facility output, subject to any conditions specified in the interconnection service approval, and the Large Generating Facility will be dispatched to the extent Interconnection Customer's bid clears. In all other instances, no transmission delivery service from the Large Generating Facility is assured, but Interconnection Customer may obtain Point-to-Point Transmission Service, Network Integration Transmission Service, or be used for secondary network transmission service, pursuant to Transmission Provider's Tariff, up to the maximum output identified in the stability and steady state studies. In those instances, in order for Interconnection Customer to obtain the right to deliver or inject energy beyond the Large Generating Facility Point of Interconnection or to improve its ability to do so, transmission delivery service must be obtained pursuant to the provisions of Transmission Provider's Tariff. Interconnection Customer's ability to inject its Large Generating Facility output beyond the Point of Interconnection, therefore, will depend on the existing capacity of Transmission Provider's Transmission System at such time as a transmission service request is made that would accommodate such delivery. The provision of firm Point-to-Point Transmission Service or Network Integration Transmission Service may require the construction of additional Network Upgrades.

4.1.2 Network Resource Interconnection Service.

4.1.2.1 The Product. Transmission Provider must conduct the necessary studies and construct the Network Upgrades needed to integrate the Large Generating Facility (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an ISO or RTO with market based congestion management, in the same manner as all Network Resources. To the extent Interconnection Customer wants to receive Network Resource Interconnection Service, Transmission Provider shall construct the facilities identified in Attachment A to this LGIA.

4.1.2.2 Transmission Delivery Service Implications. Network Resource Interconnection Service allows Interconnection Customer's Large Generating Facility to be designated by any Network Customer under the Tariff on Transmission Provider's Transmission System as a Network Resource, up to the Large Generating Facility's full output, on the same basis as existing Network Resources interconnected to Transmission Provider's Transmission System, and to be studied as a Network Resource on the assumption that such a designation will occur. Although Network Resource Interconnection Service does not convey a reservation of transmission service, any Network Customer under the Tariff can utilize its network service under the Tariff to obtain delivery of energy from the interconnected Interconnection Customer's Large Generating Facility in the same manner as it accesses Network Resources. A Large Generating Facility receiving Network Resource Interconnection Service may also be used to provide Ancillary Services after technical studies and/or periodic analyses are performed with respect to the Large Generating Facility's ability to provide any applicable Ancillary Services, provided that such studies and analyses have been or would be required in connection with the provision of such Ancillary Services by any existing

Network Resource. However, if an Interconnection Customer's Large Generating Facility has not been designated as a Network Resource by any load, it cannot be required to provide Ancillary Services except to the extent such requirements extend to all generating facilities that are similarly situated. The provision of Network Integration Transmission Service or firm Point-to-Point Transmission Service may require additional studies and the construction of additional upgrades. Because such studies and upgrades would be associated with a request for delivery service under the Tariff, cost responsibility for the studies and upgrades would be in accordance with FERC's policy for pricing transmission delivery services.

Network Resource Interconnection Service does not necessarily provide Interconnection Customer with the capability to physically deliver the output of its Large Generating Facility to any particular load on Transmission Provider's Transmission System without incurring congestion costs. In the event of transmission constraints on Transmission Provider's Transmission System, Interconnection Customer's Large Generating Facility shall be subject to the applicable congestion management procedures in Transmission Provider's Transmission System in the same manner as Network Resources.

There is no requirement either at the time of study or interconnection, or at any point in the future, that Interconnection Customer's Large Generating Facility be designated as a Network Resource by a Network Service Customer under the Tariff or that Interconnection Customer identify a specific buyer (or sink). To the extent a Network Customer does designate the Large Generating Facility as a Network Resource, it must do so pursuant to Transmission Provider's Tariff.

Once an Interconnection Customer satisfies the requirements for obtaining Network Resource Interconnection Service, any

future transmission service request for delivery from the Large Generating Facility within Transmission Provider's Transmission System of any amount of capacity and/or energy, up to the amount initially studied, will not require that any additional studies be performed or that any further upgrades associated with such Large Generating Facility be undertaken, regardless of whether or not such Large Generating Facility is ever designated by a Network Customer as a Network Resource and regardless of changes in ownership of the Large Generating Facility. However, the reduction or elimination of congestion or redispatch costs may require additional studies and the construction of additional upgrades.

To the extent Interconnection Customer enters into an arrangement for long term transmission service for deliveries from the Large Generating Facility outside Transmission Provider's Transmission System, such request may require additional studies and upgrades in order for Transmission Provider to grant such request.

- 4.2 Provision of Service. Transmission Provider shall provide Interconnection Service for the Large Generating Facility at the Point of Interconnection.
- 4.3 Performance Standards. Each Party shall perform all of its obligations under this LGIA in accordance with Applicable Laws and Regulations, Applicable Reliability Standards, and Good Utility Practice, and to the extent a Party is required or prevented or limited in taking any action by such regulations and standards, such Party shall not be deemed to be in Breach of this LGIA for its compliance therewith. If such Party is a Transmission Provider or Transmission Owner, then that Party shall amend the LGIA and submit the amendment to FERC for approval.
- 4.4 No Transmission Delivery Service. The execution of this LGIA does not constitute a request for, nor the provision of, any transmission delivery service under Transmission Provider's Tariff, and does not convey any right to deliver electricity to any specific customer or Point of Delivery.

- 4.5 Interconnection Customer Provided Services. The services provided by Interconnection Customer under this LGIA are set forth in Article 9.6 and Article 13.5.1. Interconnection Customer shall be paid for such services in accordance with Article 11.6.

Article 5. Interconnection Facilities Engineering, Procurement, and Construction

- 5.1 Options. Unless otherwise mutually agreed to between the Parties, Interconnection Customer shall select the In-Service Date, Initial Synchronization Date, and Commercial Operation Date; and either the Standard Option or Alternate Option set forth below, and such dates and selected option shall be set forth in Appendix B, Milestones. At the same time, Interconnection Customer shall indicate whether it elects to exercise the Option to Build set forth in Article 5.1.3 below. If the dates designated by Interconnection Customer are not acceptable to Transmission Provider, Transmission Provider shall so notify Interconnection Customer within thirty (30) Calendar Days. Upon receipt of the notification that Interconnection Customer's designated dates are not acceptable to Transmission Provider, Interconnection Customer shall notify Transmission Provider within thirty (30) Calendar Days whether it elects to exercise the Option to Build if it has not already elected to exercise the Option to Build.

- 5.1.1 Standard Option. Transmission Provider shall design, procure, and construct Transmission Provider's Interconnection Facilities and Network Upgrades, using Reasonable Efforts to complete Transmission Provider's Interconnection Facilities and Network Upgrades by the dates set forth in Appendix B, Milestones. Transmission Provider shall not be required to undertake any action which is inconsistent with its standard safety practices, its material and equipment specifications, its design criteria and construction procedures, its labor agreements, and Applicable Laws and Regulations. In the event Transmission Provider reasonably expects that it will not be able to complete Transmission Provider's Interconnection Facilities and Network Upgrades by the specified dates, Transmission Provider shall promptly provide written notice to Interconnection Customer and shall undertake Reasonable Efforts to meet the earliest dates thereafter.

- 5.1.2 **Alternate Option.** If the dates designated by Interconnection Customer are acceptable to Transmission Provider, Transmission Provider shall so notify Interconnection Customer within thirty (30) Calendar Days, and shall assume responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities by the designated dates.

If Transmission Provider subsequently fails to complete Transmission Provider's Interconnection Facilities by the In-Service Date, to the extent necessary to provide back feed power; or fails to complete Network Upgrades by the Initial Synchronization Date to the extent necessary to allow for Trial Operation at full power output, unless other arrangements are made by the Parties for such Trial Operation; or fails to complete the Network Upgrades by the Commercial Operation Date, as such dates are reflected in Appendix B, Milestones; Transmission Provider shall pay Interconnection Customer liquidated damages in accordance with Article 5.3, Liquidated Damages, provided, however, the dates designated by Interconnection Customer shall be extended day for day for each day that the applicable RTO or ISO refuses to grant clearances to install equipment.

- 5.1.3 **Option to Build.** Individual or Multiple Interconnection Customer shall have the option to assume responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades on the dates specified in Article 5.1.2, if the requirements of this Article 5.1.3 are met. When multiple Interconnection Customers exercise this option, multiple Interconnection Customers may agree to exercise this option provided (1) all Transmission Provider's Interconnection Facilities and Stand Alone Network upgrades constructed under this option are only required for Interconnection Customers in a single Cluster and (2) all impacted Interconnection Customers execute and provide to Transmission Provider an agreement regarding responsibilities and payment for the construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades planned to be built under this option. Transmission Provider and the individual Interconnection Customer or each of the multiple Interconnection Customers must agree as to what constitutes Stand Alone Network Upgrades and identify such Stand Alone Network Upgrades in Appendix A. Except for Stand Alone Network Upgrades, Interconnection Customer shall have no right to construct Network Upgrades under this option.

- 5.1.4 Negotiated Option. If the dates designated by Interconnection Customer are not acceptable to Transmission Provider, the Parties shall in good faith attempt to negotiate terms and conditions (including revision of the specified dates and liquidated damages, the provision of incentives, or the procurement and construction of all facilities other than Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades if Interconnection Customer elects to exercise the Option to Build under Article 5.1.3). If the Parties are unable to reach agreement on such terms and conditions, then pursuant to Article 5.1.1 (Standard Option), Transmission Provider shall assume responsibility for the design, procurement and construction of all facilities other than Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades if Interconnection Customer elects to exercise the Option to Build.
- 5.2 General Conditions Applicable to Option to Build. If Interconnection Customer assumes responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades,
- (1) Interconnection Customer shall engineer, procure equipment, and construct Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades (or portions thereof) using Good Utility Practice and using standards and specifications provided in advance by Transmission Provider;
 - (2) Interconnection Customer's engineering, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades shall comply with all requirements of law to which Transmission Provider would be subject in the engineering, procurement or construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades;
 - (3) Transmission Provider shall review and approve the engineering design, equipment acceptance tests, and the construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades;

(4) prior to commencement of construction, Interconnection Customer shall provide to Transmission Provider a schedule for construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades, and shall promptly respond to requests for information from Transmission Provider;

(5) at any time during construction, Transmission Provider shall have the right to gain unrestricted access to Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades and to conduct inspections of the same;

(6) at any time during construction, should any phase of the engineering, equipment procurement, or construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades not meet the standards and specifications provided by Transmission Provider, Interconnection Customer shall be obligated to remedy deficiencies in that portion of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades;

(7) Interconnection Customer shall indemnify Transmission Provider for claims arising from Interconnection Customer's construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades under the terms and procedures applicable to Article 18.1 Indemnity;

(8) Interconnection Customer shall transfer control of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades to Transmission Provider;

(9) Unless Parties otherwise agree, Interconnection Customer shall transfer ownership of Transmission Provider's Interconnection Facilities and Stand-Alone Network Upgrades to Transmission Provider;

(10) Transmission Provider shall approve and accept for operation and maintenance Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades to the extent engineered, procured, and constructed in accordance with this Article 5.2; and

(11) Interconnection Customer shall deliver to Transmission Provider "as-built" drawings, information, and any other documents that are reasonably required by Transmission Provider to assure that the Interconnection Facilities and Stand-Alone Network Upgrades are built to the standards and specifications required by Transmission Provider.

(12) If Interconnection Customer exercises the Option to Build pursuant to Article 5.1.3, Interconnection Customer shall pay Transmission Provider the agreed upon amount of {\$ PLACEHOLDER} for Transmission Provider to execute the responsibilities enumerated to Transmission Provider under Article 5.2. Transmission Provider shall invoice Interconnection Customer for this total amount to be divided on a monthly basis pursuant to Article 12.

5.3 Liquidated Damages. The actual damages to Interconnection Customer, in the event Transmission Provider's Interconnection Facilities or Network Upgrades are not completed by the dates designated by Interconnection Customer and accepted by Transmission Provider pursuant to subparagraphs 5.1.2 or 5.1.4, above, may include Interconnection Customer's fixed operation and maintenance costs and lost opportunity costs. Such actual damages are uncertain and impossible to determine at this time. Because of such uncertainty, any liquidated damages paid by Transmission Provider to Interconnection Customer in the event that Transmission Provider does not complete any portion of Transmission Provider's Interconnection Facilities or Network Upgrades by the applicable dates, shall be an amount equal to $\frac{1}{2}$ of 1 percent per day of the actual cost of Transmission Provider's Interconnection Facilities and Network Upgrades, in the aggregate, for which Transmission Provider has assumed responsibility to design, procure and construct.

However, in no event shall the total liquidated damages exceed 20 percent of the actual cost of Transmission Provider's Interconnection Facilities and Network Upgrades for which Transmission Provider has assumed responsibility to design,

procure, and construct. The foregoing payments will be made by Transmission Provider to Interconnection Customer as just compensation for the damages caused to Interconnection Customer, which actual damages are uncertain and impossible to determine at this time, and as reasonable liquidated damages, but not as a penalty or a method to secure performance of this LGIA. Liquidated damages, when the Parties agree to them, are the exclusive remedy for Transmission Provider's failure to meet its schedule.

No liquidated damages shall be paid to Interconnection Customer if: (1) Interconnection Customer is not ready to commence use of Transmission Provider's Interconnection Facilities or Network Upgrades to take the delivery of power for the Large Generating Facility's Trial Operation or to export power from the Large Generating Facility on the specified dates, unless Interconnection Customer would have been able to commence use of Transmission Provider's Interconnection Facilities or Network Upgrades to take the delivery of power for Large Generating Facility's Trial Operation or to export power from the Large Generating Facility, but for Transmission Provider's delay; (2) Transmission Provider's failure to meet the specified dates is the result of the action or inaction of Interconnection Customer or any other Interconnection Customer who has entered into an LGIA with Transmission Provider or any cause beyond Transmission Provider's reasonable control or reasonable ability to cure; (3) Interconnection Customer has assumed responsibility for the design, procurement and construction of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades; or (4) the Parties have otherwise agreed.

- 5.4 **Power System Stabilizers.** Interconnection Customer shall procure, install, maintain and operate Power System Stabilizers in accordance with the guidelines and procedures established by the Electric Reliability Organization. Transmission Provider reserves the right to reasonably establish minimum acceptable settings for any installed Power System Stabilizers, subject to the design and operating limitations of the Large Generating Facility. If the Large Generating Facility's Power System Stabilizers are removed from service or not capable of automatic operation, Interconnection Customer shall immediately notify Transmission Provider's system operator, or its designated representative. The requirements of this paragraph shall not apply to wind generators.
- 5.5 **Equipment Procurement.** If responsibility for construction of Transmission Provider's Interconnection Facilities or Network Upgrades is to be borne by

Transmission Provider, then Transmission Provider shall commence design of Transmission Provider's Interconnection Facilities or Network Upgrades and procure necessary equipment as soon as practicable after all of the following conditions are satisfied, unless the Parties otherwise agree in writing:

- 5.5.1** Transmission Provider has completed the Interconnection Facilities Study pursuant to the Interconnection Facilities Study Agreement;
 - 5.5.2** Transmission Provider has received written authorization to proceed with design and procurement from Interconnection Customer by the date specified in Appendix B, Milestones; and
 - 5.5.3** Interconnection Customer has provided security to Transmission Provider in accordance with Article 11.5 by the dates specified in Appendix B, Milestones.
- 5.6** Construction Commencement. Transmission Provider shall commence construction of Transmission Provider's Interconnection Facilities and Network Upgrades for which it is responsible as soon as practicable after the following additional conditions are satisfied:
- 5.6.1** Approval of the appropriate Governmental Authority has been obtained for any facilities requiring regulatory approval;
 - 5.6.2** Necessary real property rights and rights-of-way have been obtained, to the extent required for the construction of a discrete aspect of Transmission Provider's Interconnection Facilities and Network Upgrades;
 - 5.6.3** Transmission Provider has received written authorization to proceed with construction from Interconnection Customer by the date specified in Appendix B, Milestones; and

- 5.6.4** Interconnection Customer has provided security to Transmission Provider in accordance with Article 11.5 by the dates specified in Appendix B, Milestones.
- 5.7 **Work Progress.** The Parties will keep each other advised periodically as to the progress of their respective design, procurement and construction efforts. Either Party may, at any time, request a progress report from the other Party. If, at any time, Interconnection Customer determines that the completion of Transmission Provider's Interconnection Facilities will not be required until after the specified In-Service Date, Interconnection Customer will provide written notice to Transmission Provider of such later date upon which the completion of Transmission Provider's Interconnection Facilities will be required.
- 5.8 **Information Exchange.** As soon as reasonably practicable after the Effective Date, the Parties shall exchange information regarding the design and compatibility of the Parties' Interconnection Facilities and compatibility of the Interconnection Facilities with Transmission Provider's Transmission System, and shall work diligently and in good faith to make any necessary design changes.
- 5.9 Other Interconnection Options.**
- 5.9.1 **Limited Operation.** If any of Transmission Provider's Interconnection Facilities or Network Upgrades are not reasonably expected to be completed prior to the Commercial Operation Date of the Large Generating Facility, Transmission Provider shall, upon the request and at the expense of Interconnection Customer, perform operating studies on a timely basis to determine the extent to which the Large Generating Facility and Interconnection Customer's Interconnection Facilities may operate prior to the completion of Transmission Provider's Interconnection Facilities or Network Upgrades consistent with Applicable Laws and Regulations, Applicable Reliability Standards, Good Utility Practice, and this LGIA. Transmission Provider shall permit Interconnection Customer to operate the Large Generating Facility and Interconnection Customer's Interconnection Facilities in accordance with the results of such studies.

5.9.2 Provisional Interconnection Service. Upon the request of Interconnection Customer, and prior to completion of requisite Interconnection Facilities, Network Upgrades, Distribution Upgrades, or System Protection Facilities Transmission Provider may execute a Provisional Large Generator Interconnection Agreement or Interconnection Customer may request the filing of an unexecuted Provisional Large Generator Interconnection Agreement with Interconnection Customer for limited Interconnection Service at the discretion of Transmission Provider based upon an evaluation that will consider the results of available studies. Transmission Provider shall determine, through available studies or additional studies as necessary, whether stability, short circuit, thermal, and/or voltage issues would arise if Interconnection Customer interconnects without modifications to the Generating Facility or Transmission System. Transmission Provider shall determine whether any Interconnection Facilities, Network Upgrades, Distribution Upgrades, or System Protection Facilities that are necessary to meet the requirements of the Electric Reliability Organization, or any applicable Regional Entity for the interconnection of a new, modified and/or expanded Generating Facility are in place prior to the commencement of Interconnection Service from the Generating Facility. Where available studies indicate that such, Interconnection Facilities, Network Upgrades, Distribution Upgrades, and/or System Protection Facilities that are required for the interconnection of a new, modified and/or expanded Generating Facility are not currently in place, Transmission Provider will perform a study, at Interconnection Customer's expense, to confirm the facilities that are required for Provisional Interconnection Service. The maximum permissible output of the Generating Facility in the Provisional Large Generator Interconnection Agreement shall be studied and updated {on a frequency determined by Transmission Provider and at Interconnection Customer's expense}. Interconnection Customer assumes all risk and liabilities with respect to changes between the Provisional Large Generator Interconnection Agreement and the Large Generator Interconnection Agreement, including changes in output limits and Interconnection Facilities, Network Upgrades, Distribution Upgrades, and/or System Protection Facilities cost responsibilities.

5.10 Interconnection Customer's Interconnection Facilities ('ICIF'). Interconnection Customer shall, at its expense, design, procure, construct, own and install the ICIF, as set forth in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades.

- 5.10.1 Interconnection Customer's Interconnection Facility Specifications. Interconnection Customer shall submit initial specifications for the ICIF, including System Protection Facilities, to Transmission Provider at least one hundred eighty (180) Calendar Days prior to the Initial Synchronization Date; and final specifications for review and comment at least ninety (90) Calendar Days prior to the Initial Synchronization Date. Transmission Provider shall review such specifications to ensure that the ICIF are compatible with the technical specifications, operational control, and safety requirements of Transmission Provider and comment on such specifications within thirty (30) Calendar Days of Interconnection Customer's submission. All specifications provided hereunder shall be deemed confidential.
- 5.10.2 **Transmission Provider's Review.** Transmission Provider's review of Interconnection Customer's final specifications shall not be construed as confirming, endorsing, or providing a warranty as to the design, fitness, safety, durability or reliability of the Large Generating Facility, or the ICIF. Interconnection Customer shall make such changes to the ICIF as may reasonably be required by Transmission Provider, in accordance with Good Utility Practice, to ensure that the ICIF are compatible with the technical specifications, operational control, and safety requirements of Transmission Provider.
- 5.10.3 ICIF Construction. The ICIF shall be designed and constructed in accordance with Good Utility Practice. Within one hundred twenty (120) Calendar Days after the Commercial Operation Date, unless the Parties agree on another mutually acceptable deadline, Interconnection Customer shall deliver to Transmission Provider "as-built" drawings, information and documents for the ICIF, such as: a one-line diagram, a site plan showing the Large Generating Facility and the ICIF, plan and elevation drawings showing the layout of the ICIF, a relay functional diagram, relaying AC and DC schematic wiring diagrams and relay settings for all facilities associated with Interconnection Customer's step-up transformers, the facilities connecting the Large Generating Facility to the step-up

transformers and the ICIF, and the impedances (determined by factory tests) for the associated step-up transformers and the Large Generating Facility. Interconnection Customer shall provide Transmission Provider specifications for the excitation system, automatic voltage regulator, Large Generating Facility control and protection settings, transformer tap settings, and communications, if applicable.

- 5.11 **Transmission Provider's Interconnection Facilities Construction.** Transmission Provider's Interconnection Facilities shall be designed and constructed in accordance with Good Utility Practice. Upon request, within one hundred twenty (120) Calendar Days after the Commercial Operation Date, unless the Parties agree on another mutually acceptable deadline, Transmission Provider shall deliver to Interconnection Customer the following "as-built" drawings, information and documents for Transmission Provider's Interconnection Facilities {include appropriate drawings and relay diagrams}.

Transmission Provider will obtain control of Transmission Provider's Interconnection Facilities and Stand Alone Network Upgrades upon completion of such facilities.

- 5.12 **Access Rights.** Upon reasonable notice and supervision by a Party, and subject to any required or necessary regulatory approvals, a Party ("Granting Party") shall furnish at no cost to the other Party ("Access Party") any rights of use, licenses, rights of way and easements with respect to lands owned or controlled by the Granting Party, its agents (if allowed under the applicable agency agreement), or any Affiliate, that are necessary to enable the Access Party to obtain ingress and egress to construct, operate, maintain, repair, test (or witness testing), inspect, replace or remove facilities and equipment to: (i) interconnect the Large Generating Facility with the Transmission System; (ii) operate and maintain the Large Generating Facility, the Interconnection Facilities and the Transmission System; and (iii) disconnect or remove the Access Party's facilities and equipment upon termination of this LGIA. In exercising such licenses, rights of way and easements, the Access Party shall not unreasonably disrupt or interfere with normal operation of the Granting Party's business and shall adhere to the safety rules and procedures established in advance, as may be changed from time to time, by the Granting Party and provided to the Access Party.

- 5.13 **Lands of Other Property Owners.** If any part of Transmission Provider or Transmission Owner's Interconnection Facilities and/or Network Upgrades is to be installed on property owned by persons other than Interconnection Customer or Transmission Provider or Transmission Owner, Transmission Provider or Transmission Owner shall at Interconnection Customer's expense use efforts, similar in nature and extent to those that it typically undertakes on its own behalf or on behalf of its Affiliates, including use of its eminent domain authority, and to the extent consistent with state law, to procure from such persons any rights of use, licenses, rights of way and easements that are necessary to construct, operate, maintain, test, inspect, replace or remove Transmission Provider or Transmission Owner's Interconnection Facilities and/or Network Upgrades upon such property.
- 5.14 **Permits.** Transmission Provider or Transmission Owner and Interconnection Customer shall cooperate with each other in good faith in obtaining all permits, licenses, and authorizations that are necessary to accomplish the interconnection in compliance with Applicable Laws and Regulations. With respect to this paragraph, Transmission Provider or Transmission Owner shall provide permitting assistance to Interconnection Customer comparable to that provided to Transmission Provider's own, or an Affiliate's generation.
- 5.15 **Early Construction of Base Case Facilities.** Interconnection Customer may request Transmission Provider to construct, and Transmission Provider shall construct, using Reasonable Efforts to accommodate Interconnection Customer's In-Service Date, all or any portion of any Network Upgrades required for Interconnection Customer to be interconnected to the Transmission System which are included in the Base Case of the Interconnection Facilities Study for Interconnection Customer, and which also are required to be constructed for another Interconnection Customer, but where such construction is not scheduled to be completed in time to achieve Interconnection Customer's In-Service Date.
- 5.16 **Suspension.** Interconnection Customer reserves the right, upon written notice to Transmission Provider, to suspend at any time all work by Transmission Provider associated with the construction and installation of Transmission Provider's Interconnection Facilities and/or Network Upgrades required under this LGIA with the condition that Transmission System shall be left in a safe and reliable condition in accordance with Good Utility Practice and Transmission Provider's

safety and reliability criteria. In such event, Interconnection Customer shall be responsible for all reasonable and necessary costs which Transmission Provider (i) has incurred pursuant to this LGIA prior to the suspension and (ii) incurs in suspending such work, including any costs incurred to perform such work as may be necessary to ensure the safety of persons and property and the integrity of the Transmission System during such suspension and, if applicable, any costs incurred in connection with the cancellation or suspension of material, equipment and labor contracts which Transmission Provider cannot reasonably avoid; provided, however, that prior to canceling or suspending any such material, equipment or labor contract, Transmission Provider shall obtain Interconnection Customer's authorization to do so.

Transmission Provider shall invoice Interconnection Customer for such costs pursuant to Article 12 and shall use due diligence to minimize its costs. In the event Interconnection Customer suspends work by Transmission Provider required under this LGIA pursuant to this Article 5.16, and has not requested Transmission Provider to recommence the work required under this LGIA on or before the expiration of three (3) years following commencement of such suspension, this LGIA shall be deemed terminated. The three-year period shall begin on the date the suspension is requested, or the date of the written notice to Transmission Provider, if no effective date is specified.

5.17 Taxes.

5.17.1 Interconnection Customer Payments Not Taxable. The Parties intend that all payments or property transfers made by Interconnection Customer to Transmission Provider for the installation of Transmission Provider's Interconnection Facilities and the Network Upgrades shall be non-taxable, either as contributions to capital, or as an advance, in accordance with the Internal Revenue Code and any applicable state income tax laws and shall not be taxable as contributions in aid of construction or otherwise under the Internal Revenue Code and any applicable state income tax laws.

5.17.2 Representations and Covenants. In accordance with IRS Notice 2001-82 and IRS Notice 88-129, Interconnection Customer

represents and covenants that (i) ownership of the electricity generated at the Large Generating Facility will pass to another party prior to the transmission of the electricity on the Transmission System, (ii) for income tax purposes, the amount of any payments and the cost of any property transferred to Transmission Provider for Transmission Provider's Interconnection Facilities will be capitalized by Interconnection Customer as an intangible asset and recovered using the straight-line method over a useful life of twenty (20) years, and (iii) any portion of Transmission Provider's Interconnection Facilities that is a "dual-use intertie," within the meaning of IRS Notice 88-129, is reasonably expected to carry only a de minimis amount of electricity in the direction of the Large Generating Facility. For this purpose, "de minimis amount" means no more than 5 percent of the total power flows in both directions, calculated in accordance with the "5 percent test" set forth in IRS Notice 88-129. This is not intended to be an exclusive list of the relevant conditions that must be met to conform to IRS requirements for non-taxable treatment.

At Transmission Provider's request, Interconnection Customer shall provide Transmission Provider with a report from an independent engineer confirming its representation in clause (iii), above. Transmission Provider represents and covenants that the cost of Transmission Provider's Interconnection Facilities paid for by Interconnection Customer will have no net effect on the base upon which rates are determined.

5.17.3 Indemnification for the Cost Consequences of Current Tax Liability Imposed Upon Transmission Provider. Notwithstanding Article 5.17.1, Interconnection Customer shall protect, indemnify and hold harmless Transmission Provider from the cost consequences of any current tax liability imposed against Transmission Provider as the result of payments or property transfers made by Interconnection Customer to Transmission Provider under this LGIA for Interconnection Facilities, as well as any interest and penalties, other than interest and penalties attributable to any delay caused by Transmission Provider.

Transmission Provider shall not include a gross-up for the cost consequences of any current tax liability in the amounts it charges Interconnection Customer under this LGIA unless (i) Transmission Provider has determined, in good faith, that the payments or property transfers made by Interconnection Customer to Transmission Provider should be reported as income subject to taxation or (ii) any Governmental Authority directs Transmission Provider to report payments or property as income subject to taxation; provided, however, that Transmission Provider may require Interconnection Customer to provide security for Interconnection Facilities, in a form reasonably acceptable to Transmission Provider (such as a parental guarantee or a letter of credit), in an amount equal to the cost consequences of any current tax liability under this Article 5.17. Interconnection Customer shall reimburse Transmission Provider for such costs on a fully grossed-up basis, in accordance with Article 5.17.4, within thirty (30) Calendar Days of receiving written notification from Transmission Provider of the amount due, including detail about how the amount was calculated.

The indemnification obligation shall terminate at the earlier of (1) the expiration of the ten year testing period and the applicable statute of limitation, as it may be extended by Transmission Provider upon request of the IRS, to keep these years open for audit or adjustment, or (2) the occurrence of a subsequent taxable event and the payment of any related indemnification obligations as contemplated by this Article 5.17.

5.17.4 Tax Gross-Up Amount. Interconnection Customer's liability for the cost consequences of any current tax liability under this Article 5.17 shall be calculated on a fully grossed-up basis. Except as may otherwise be agreed to by the parties, this means that Interconnection Customer will pay Transmission Provider, in addition to the amount paid for the Interconnection Facilities and Network Upgrades, an amount equal to (1) the current taxes imposed on Transmission Provider ("Current Taxes") on the excess of (a) the gross income realized by Transmission Provider as a result of payments or property transfers made by Interconnection Customer to Transmission Provider under this LGIA (without regard to any

payments under this Article 5.17) (the “Gross Income Amount”) over (b) the present value of future tax deductions for depreciation that will be available as a result of such payments or property transfers (the “Present Value Depreciation Amount”), plus (2) an additional amount sufficient to permit Transmission Provider to receive and retain, after the payment of all Current Taxes, an amount equal to the net amount described in clause (1).

For this purpose, (i) Current Taxes shall be computed based on Transmission Provider’s composite federal and state tax rates at the time the payments or property transfers are received and Transmission Provider will be treated as being subject to tax at the highest marginal rates in effect at that time (the “Current Tax Rate”), and (ii) the Present Value Depreciation Amount shall be computed by discounting Transmission Provider’s anticipated tax depreciation deductions as a result of such payments or property transfers by Transmission Provider’s current weighted average cost of capital. Thus, the formula for calculating Interconnection Customer’s liability to Transmission Owner pursuant to this Article 5.17.4 can be expressed as follows: $(\text{Current Tax Rate} \times (\text{Gross Income Amount} - \text{Present Value of Tax Depreciation})) / (1 - \text{Current Tax Rate})$. Interconnection Customer’s estimated tax liability in the event taxes are imposed shall be stated in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades.

5.17.5 Private Letter Ruling or Change or Clarification of Law. At Interconnection Customer’s request and expense, Transmission Provider shall file with the IRS a request for a private letter ruling as to whether any property transferred or sums paid, or to be paid, by Interconnection Customer to Transmission Provider under this LGIA are subject to federal income taxation. Interconnection Customer will prepare the initial draft of the request for a private letter ruling, and will certify under penalties of perjury that all facts represented in such request are true and accurate to the best of Interconnection Customer's knowledge. Transmission Provider and Interconnection Customer shall cooperate in good faith with respect to the submission of such request.

Transmission Provider shall keep Interconnection Customer fully informed of the status of such request for a private letter ruling and shall execute either a privacy act waiver or a limited power of attorney, in a form acceptable to the IRS, that authorizes Interconnection Customer to participate in all discussions with the IRS regarding such request for a private letter ruling. Transmission Provider shall allow Interconnection Customer to attend all meetings with IRS officials about the request and shall permit Interconnection Customer to prepare the initial drafts of any follow-up letters in connection with the request.

- 5.17.6 Subsequent Taxable Events. If, within 10 years from the date on which the relevant Transmission Provider's Interconnection Facilities are placed in service, (i) Interconnection Customer Breaches the covenants contained in Article 5.17.2, (ii) a "disqualification event" occurs within the meaning of IRS Notice 88-129, or (iii) this LGIA terminates and Transmission Provider retains ownership of the Interconnection Facilities and Network Upgrades, Interconnection Customer shall pay a tax gross-up for the cost consequences of any current tax liability imposed on Transmission Provider, calculated using the methodology described in Article 5.17.4 and in accordance with IRS Notice 90-60.
- 5.17.7 **Contests.** In the event any Governmental Authority determines that Transmission Provider's receipt of payments or property constitutes income that is subject to taxation, Transmission Provider shall notify Interconnection Customer, in writing, within thirty (30) Calendar Days of receiving notification of such determination by a Governmental Authority. Upon the timely written request by Interconnection Customer and at Interconnection Customer's sole expense, Transmission Provider may appeal, protest, seek abatement of, or otherwise oppose such determination. Upon Interconnection Customer's written request and sole expense, Transmission Provider may file a claim for refund with respect to any taxes paid under this Article 5.17, whether or not it has received such a determination. Transmission Provider reserves the right to make all decisions with regard to the prosecution of such appeal, protest, abatement or other

contest, including the selection of counsel and compromise or settlement of the claim, but Transmission Provider shall keep Interconnection Customer informed, shall consider in good faith suggestions from Interconnection Customer about the conduct of the contest, and shall reasonably permit Interconnection Customer or an Interconnection Customer representative to attend contest proceedings.

Interconnection Customer shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission Provider's documented reasonable costs of prosecuting such appeal, protest, abatement or other contest. At any time during the contest, Transmission Provider may agree to a settlement either with Interconnection Customer's consent or after obtaining written advice from nationally-recognized tax counsel, selected by Transmission Provider, but reasonably acceptable to Interconnection Customer, that the proposed settlement represents a reasonable settlement given the hazards of litigation. Interconnection Customer's obligation shall be based on the amount of the settlement agreed to by Interconnection Customer, or if a higher amount, so much of the settlement that is supported by the written advice from nationally-recognized tax counsel selected under the terms of the preceding sentence. The settlement amount shall be calculated on a fully grossed-up basis to cover any related cost consequences of the current tax liability. Any settlement without Interconnection Customer's consent or such written advice will relieve Interconnection Customer from any obligation to indemnify Transmission Provider for the tax at issue in the contest.

- 5.17.8 Refund. In the event that (a) a private letter ruling is issued to Transmission Provider which holds that any amount paid or the value of any property transferred by Interconnection Customer to Transmission Provider under the terms of this LGIA is not subject to federal income taxation, (b) any legislative change or administrative announcement, notice, ruling or other determination makes it reasonably clear to Transmission Provider in good faith that any amount paid or the value of any property transferred by Interconnection Customer to Transmission Provider under the terms of this LGIA is not taxable to Transmission Provider, (c) any

abatement, appeal, protest, or other contest results in a determination that any payments or transfers made by Interconnection Customer to Transmission Provider are not subject to federal income tax, or (d) if Transmission Provider receives a refund from any taxing authority for any overpayment of tax attributable to any payment or property transfer made by Interconnection Customer to Transmission Provider pursuant to this LGIA, Transmission Provider shall promptly refund to Interconnection Customer the following:

(i) any payment made by Interconnection Customer under this Article 5.17 for taxes that is attributable to the amount determined to be non-taxable, together with interest thereon,

(ii) interest on any amounts paid by Interconnection Customer to Transmission Provider for such taxes which Transmission Provider did not submit to the taxing authority, calculated in accordance with the methodology set forth in FERC's regulations at 18 CFR §35.19a(a)(2)(iii) from the date payment was made by Interconnection Customer to the date Transmission Provider refunds such payment to Interconnection Customer, and

(iii) with respect to any such taxes paid by Transmission Provider, any refund or credit Transmission Provider receives or to which it may be entitled from any Governmental Authority, interest (or that portion thereof attributable to the payment described in clause (i), above) owed to Transmission Provider for such overpayment of taxes (including any reduction in interest otherwise payable by Transmission Provider to any Governmental Authority resulting from an offset or credit); provided, however, that Transmission Provider will remit such amount promptly to Interconnection Customer only after and to the extent that Transmission Provider has received a tax refund, credit or offset from any Governmental Authority for any applicable overpayment of income tax related to Transmission Provider's Interconnection Facilities.

The intent of this provision is to leave the Parties, to the extent practicable, in the event that no taxes are due with respect to any payment for Interconnection Facilities and Network Upgrades hereunder, in the same position they would have been in had no such tax payments been made.

- 5.17.9 Taxes Other Than Income Taxes.** Upon the timely request by Interconnection Customer, and at Interconnection Customer's sole expense, Transmission Provider may appeal, protest, seek abatement of, or otherwise contest any tax (other than federal or state income tax) asserted or assessed against Transmission Provider for which Interconnection Customer may be required to reimburse Transmission Provider under the terms of this LGIA. Interconnection Customer shall pay to Transmission Provider on a periodic basis, as invoiced by Transmission Provider, Transmission Provider's documented reasonable costs of prosecuting such appeal, protest, abatement, or other contest. Interconnection Customer and Transmission Provider shall cooperate in good faith with respect to any such contest. Unless the payment of such taxes is a prerequisite to an appeal or abatement or cannot be deferred, no amount shall be payable by Interconnection Customer to Transmission Provider for such taxes until they are assessed by a final, non-appealable order by any court or agency of competent jurisdiction. In the event that a tax payment is withheld and ultimately due and payable after appeal, Interconnection Customer will be responsible for all taxes, interest and penalties, other than penalties attributable to any delay caused by Transmission Provider.
- 5.17.10 Transmission Owners Who Are Not Transmission Providers. If Transmission Provider is not the same entity as the Transmission Owner, then (i) all references in this Article 5.17 to Transmission Provider shall be deemed also to refer to and to include the Transmission Owner, as appropriate, and (ii) this LGIA shall not become effective until such Transmission Owner shall have agreed in writing to assume all of the duties and obligations of Transmission Provider under this Article 5.17 of this LGIA.

5.18 **Tax Status.** Each Party shall cooperate with the other to maintain the other Party's tax status. Nothing in this LGIA is intended to adversely affect any Transmission Provider's tax exempt status with respect to the issuance of bonds including, but not limited to, Local Furnishing Bonds.

5.19 **Modification.**

5.19.1 **General.** Either Party may undertake modifications to its facilities. If a Party plans to undertake a modification that reasonably may be expected to affect the other Party's facilities, that Party shall provide to the other Party sufficient information regarding such modification so that the other Party may evaluate the potential impact of such modification prior to commencement of the work. Such information shall be deemed to be confidential hereunder and shall include information concerning the timing of such modifications and whether such modifications are expected to interrupt the flow of electricity from the Large Generating Facility. The Party desiring to perform such work shall provide the relevant drawings, plans, and specifications to the other Party at least ninety (90) Calendar Days in advance of the commencement of the work or such shorter period upon which the Parties may agree, which agreement shall not unreasonably be withheld, conditioned or delayed.

In the case of Large Generating Facility modifications that do not require Interconnection Customer to submit an Interconnection Request, Transmission Provider shall provide, within thirty (30) Calendar Days (or such other time as the Parties may agree), an estimate of any additional modifications to the Transmission System, Transmission Provider's Interconnection Facilities or Network Upgrades necessitated by such Interconnection Customer modification and a good faith estimate of the costs thereof.

5.19.2 **Standards.** Any additions, modifications, or replacements made to a Party's facilities shall be designed, constructed and operated in accordance with this LGIA and Good Utility Practice.

5.19.3 Modification Costs. Interconnection Customer shall not be directly assigned for the costs of any additions, modifications, or replacements that Transmission Provider makes to Transmission Provider's Interconnection Facilities or the Transmission System to facilitate the interconnection of a third party to Transmission Provider's Interconnection Facilities or the Transmission System, or to provide transmission service to a third party under Transmission Provider's Tariff. Interconnection Customer shall be responsible for the costs of any additions, modifications, or replacements to Interconnection Customer's Interconnection Facilities that may be necessary to maintain or upgrade such Interconnection Customer's Interconnection Facilities consistent with Applicable Laws and Regulations, Applicable Reliability Standards or Good Utility Practice.

Article 6. Testing and Inspection

- 6.1 Pre-Commercial Operation Date Testing and Modifications.** Prior to the Commercial Operation Date, Transmission Provider shall test Transmission Provider's Interconnection Facilities and Network Upgrades and Interconnection Customer shall test the Large Generating Facility and Interconnection Customer's Interconnection Facilities to ensure their safe and reliable operation. Similar testing may be required after initial operation. Each Party shall make any modifications to its facilities that are found to be necessary as a result of such testing. Interconnection Customer shall bear the cost of all such testing and modifications. Interconnection Customer shall generate test energy at the Large Generating Facility only if it has arranged for the delivery of such test energy.
- 6.2 Post-Commercial Operation Date Testing and Modifications.** Each Party shall at its own expense perform routine inspection and testing of its facilities and equipment in accordance with Good Utility Practice as may be necessary to ensure the continued interconnection of the Large Generating Facility with the Transmission System in a safe and reliable manner. Each Party shall have the right, upon advance written notice, to require reasonable additional testing of the other Party's facilities, at the requesting Party's expense, as may be in accordance with Good Utility Practice.

- 6.3 Right to Observe Testing. Each Party shall notify the other Party in advance of its performance of tests of its Interconnection Facilities. The other Party has the right, at its own expense, to observe such testing.
- 6.4 Right to Inspect. Each Party shall have the right, but shall have no obligation to: (i) observe the other Party's tests and/or inspection of any of its System Protection Facilities and other protective equipment, including Power System Stabilizers; (ii) review the settings of the other Party's System Protection Facilities and other protective equipment; and (iii) review the other Party's maintenance records relative to the Interconnection Facilities, the System Protection Facilities and other protective equipment. A Party may exercise these rights from time to time as it deems necessary upon reasonable notice to the other Party. The exercise or non-exercise by a Party of any such rights shall not be construed as an endorsement or confirmation of any element or condition of the Interconnection Facilities or the System Protection Facilities or other protective equipment or the operation thereof, or as a warranty as to the fitness, safety, desirability, or reliability of same. Any information that a Party obtains through the exercise of any of its rights under this Article 6.4 shall be deemed to be Confidential Information and treated pursuant to Article 22 of this LGIA.

Article 7. Metering

- 7.1 General. Each Party shall comply with the Electric Reliability Organization requirements. Unless otherwise agreed by the Parties, Transmission Provider shall install Metering Equipment at the Point of Interconnection prior to any operation of the Large Generating Facility and shall own, operate, test and maintain such Metering Equipment. Power flows to and from the Large Generating Facility shall be measured at or, at Transmission Provider's option, compensated to, the Point of Interconnection. Transmission Provider shall provide metering quantities, in analog and/or digital form, to Interconnection Customer upon request. Interconnection Customer shall bear all reasonable documented costs associated with the purchase, installation, operation, testing and maintenance of the Metering Equipment.
- 7.2 Check Meters. Interconnection Customer, at its option and expense, may install and operate, on its premises and on its side of the Point of Interconnection, one or

more check meters to check Transmission Provider's meters. Such check meters shall be for check purposes only and shall not be used for the measurement of power flows for purposes of this LGIA, except as provided in Article 7.4 below. The check meters shall be subject at all reasonable times to inspection and examination by Transmission Provider or its designee. The installation, operation and maintenance thereof shall be performed entirely by Interconnection Customer in accordance with Good Utility Practice.

- 7.3 Standards. Transmission Provider shall install, calibrate, and test revenue quality Metering Equipment in accordance with applicable ANSI standards.
- 7.4 Testing of Metering Equipment. Transmission Provider shall inspect and test all Transmission Provider-owned Metering Equipment upon installation and at least once every two (2) years thereafter. If requested to do so by Interconnection Customer, Transmission Provider shall, at Interconnection Customer's expense, inspect or test Metering Equipment more frequently than every two (2) years. Transmission Provider shall give reasonable notice of the time when any inspection or test shall take place, and Interconnection Customer may have representatives present at the test or inspection. If at any time Metering Equipment is found to be inaccurate or defective, it shall be adjusted, repaired or replaced at Interconnection Customer's expense, in order to provide accurate metering, unless the inaccuracy or defect is due to Transmission Provider's failure to maintain, then Transmission Provider shall pay. If Metering Equipment fails to register, or if the measurement made by Metering Equipment during a test varies by more than two percent from the measurement made by the standard meter used in the test, Transmission Provider shall adjust the measurements by correcting all measurements for the period during which Metering Equipment was in error by using Interconnection Customer's check meters, if installed. If no such check meters are installed or if the period cannot be reasonably ascertained, the adjustment shall be for the period immediately preceding the test of the Metering Equipment equal to one-half the time from the date of the last previous test of the Metering Equipment.
- 7.5 Metering Data. At Interconnection Customer's expense, the metered data shall be telemetered to one or more locations designated by Transmission Provider and one or more locations designated by Interconnection Customer. Such telemetered data shall be used, under normal operating conditions, as the official measurement

of the amount of energy delivered from the Large Generating Facility to the Point of Interconnection.

Article 8. Communications

- 8.1 **Interconnection Customer Obligations.** Interconnection Customer shall maintain satisfactory operating communications with Transmission Provider's Transmission System dispatcher or representative designated by Transmission Provider. Interconnection Customer shall provide standard voice line, dedicated voice line and facsimile communications at its Large Generating Facility control room or central dispatch facility through use of either the public telephone system, or a voice communications system that does not rely on the public telephone system. Interconnection Customer shall also provide the dedicated data circuit(s) necessary to provide Interconnection Customer data to Transmission Provider as set forth in Appendix D, Security Arrangements Details. The data circuit(s) shall extend from the Large Generating Facility to the location(s) specified by Transmission Provider. Any required maintenance of such communications equipment shall be performed by Interconnection Customer. Operational communications shall be activated and maintained under, but not be limited to, the following events: system paralleling or separation, scheduled and unscheduled shutdowns, equipment clearances, and hourly and daily load data.
- 8.2 **Remote Terminal Unit.** Prior to the Initial Synchronization Date of the Large Generating Facility, a Remote Terminal Unit, or equivalent data collection and transfer equipment acceptable to the Parties, shall be installed by Interconnection Customer, or by Transmission Provider at Interconnection Customer's expense, to gather accumulated and instantaneous data to be telemetered to the location(s) designated by Transmission Provider through use of a dedicated point-to-point data circuit(s) as indicated in Article 8.1. The communication protocol for the data circuit(s) shall be specified by Transmission Provider. Instantaneous bi-directional analog real power and reactive power flow information must be telemetered directly to the location(s) specified by Transmission Provider.

Each Party will promptly advise the other Party if it detects or otherwise learns of any metering, telemetry or communications equipment errors or malfunctions that require the attention and/or correction by the other Party. The Party owning such equipment shall correct such error or malfunction as soon as reasonably feasible.

- 8.3 No Annexation. Any and all equipment placed on the premises of a Party shall be and remain the property of the Party providing such equipment regardless of the mode and manner of annexation or attachment to real property, unless otherwise mutually agreed by the Parties.
- 8.4 Provision of Data from a Variable Energy Resource. Interconnection Customer whose Generating Facility contains at least one Variable Energy Resource shall provide meteorological and forced outage data to Transmission Provider to the extent necessary for Transmission Provider's development and deployment of power production forecasts for that class of Variable Energy Resources. Interconnection Customer with a Variable Energy Resource having wind as the energy source, at a minimum, will be required to provide Transmission Provider with site-specific meteorological data including: temperature, wind speed, wind direction, and atmospheric pressure. Interconnection Customer with a Variable Energy Resource having solar as the energy source, at a minimum, will be required to provide Transmission Provider with site-specific meteorological data including: temperature, atmospheric pressure, and irradiance. Transmission Provider and Interconnection Customer whose Generating Facility contains a Variable Energy Resource shall mutually agree to any additional meteorological data that are required for the development and deployment of a power production forecast. Interconnection Customer whose Generating Facility contains a Variable Energy Resource also shall submit data to Transmission Provider regarding all forced outages to the extent necessary for Transmission Provider's development and deployment of power production forecasts for that class of Variable Energy Resources. The exact specifications of the meteorological and forced outage data to be provided by Interconnection Customer to Transmission Provider, including the frequency and timing of data submittals, shall be made taking into account the size and configuration of the Variable Energy Resource, its characteristics, location, and its importance in maintaining generation resource adequacy and transmission system reliability in its area. All requirements for meteorological and forced outage data must be commensurate with the power production forecasting employed by Transmission Provider. Such requirements for meteorological and forced outage data are set forth in Appendix C, Interconnection Details, of this LGIA, as they may change from time to time.

Article 9. Operations

- 9.1 General. Each Party shall comply with the Electric Reliability Organization requirements. Each Party shall provide to the other Party all information that may reasonably be required by the other Party to comply with Applicable Laws and Regulations and Applicable Reliability Standards.
- 9.2 **Balancing Authority Area Notification.** At least three months before Initial Synchronization Date, Interconnection Customer shall notify Transmission Provider in writing of the Balancing Authority Area in which the Large Generating Facility will be located. If Interconnection Customer elects to locate the Large Generating Facility in a Balancing Authority Area other than the Balancing Authority Area in which the Large Generating Facility is physically located, and if permitted to do so by the relevant transmission tariffs, all necessary arrangements, including but not limited to those set forth in Article 7 and Article 8 of this LGIA, and remote Balancing Authority Area generator interchange agreements, if applicable, and the appropriate measures under such agreements, shall be executed and implemented prior to the placement of the Large Generating Facility in the other Balancing Authority Area.
- 9.3 **Transmission Provider Obligations.** Transmission Provider shall cause the Transmission System and Transmission Provider's Interconnection Facilities to be operated, maintained and controlled in a safe and reliable manner and in accordance with this LGIA. Transmission Provider may provide operating instructions to Interconnection Customer consistent with this LGIA and Transmission Provider's operating protocols and procedures as they may change from time to time. Transmission Provider will consider changes to its operating protocols and procedures proposed by Interconnection Customer.
- 9.4 **Interconnection Customer Obligations.** Interconnection Customer shall at its own expense operate, maintain and control the Large Generating Facility and Interconnection Customer's Interconnection Facilities in a safe and reliable manner and in accordance with this LGIA. Interconnection Customer shall operate the Large Generating Facility and Interconnection Customer's Interconnection Facilities in accordance with all applicable requirements of the Balancing Authority Area of which it is part, as such requirements are set forth in Appendix C, Interconnection Details, of this LGIA. Appendix C, Interconnection Details, will be modified to reflect changes to the requirements as they may

change from time to time. Either Party may request that the other Party provide copies of the requirements set forth in Appendix C, Interconnection Details, of this LGIA.

9.5 Start-Up and Synchronization. Consistent with the Parties' mutually acceptable procedures, Interconnection Customer is responsible for the proper synchronization of the Large Generating Facility to Transmission Provider's Transmission System.

9.6 Reactive Power and Primary Frequency Response.

9.6.1 Power Factor Design Criteria.

9.6.1.1 Synchronous Generation. Interconnection Customer shall design the Large Generating Facility to maintain a composite power delivery at continuous rated power output at the Point of Interconnection at a power factor within the range of 0.95 leading to 0.95 lagging, unless Transmission Provider has established different requirements that apply to all synchronous generators in the Balancing Authority Area on a comparable basis.

9.6.1.2 Non-Synchronous Generation. Interconnection Customer shall design the Large Generating Facility to maintain a composite power delivery at continuous rated power output at the high-side of the generator substation at a power factor within the range of 0.95 leading to 0.95 lagging, unless Transmission Provider has established a different power factor range that applies to all non-synchronous generators in the Balancing Authority Area on a comparable basis. This power factor range standard shall be dynamic and can be met using, for example, power electronics designed to supply this level of reactive capability (taking into account any limitations due to voltage level, real power output, etc.) or fixed and switched capacitors, or a combination of the two.

This requirement shall only apply to newly interconnecting non-synchronous generators that have not yet executed a Facilities Study Agreement as of the effective date of the Final Rule establishing this requirement (Order No. 827).

9.6.2 Voltage Schedules. Once Interconnection Customer has synchronized the Large Generating Facility with the Transmission System, Transmission Provider shall require Interconnection Customer to operate the Large Generating Facility to produce or absorb reactive power within the design limitations of the Large Generating Facility set forth in Article 9.6.1 (Power Factor Design Criteria). Transmission Provider's voltage schedules shall treat all sources of reactive power in the Balancing Authority Area in an equitable and not unduly discriminatory manner. Transmission Provider shall exercise Reasonable Efforts to provide Interconnection Customer with such schedules at least one (1) day in advance, and may make changes to such schedules as necessary to maintain the reliability of the Transmission System. Interconnection Customer shall operate the Large Generating Facility to maintain the specified output voltage or power factor at the Point of Interconnection within the design limitations of the Large Generating Facility set forth in Article 9.6.1 (Power Factor Design Criteria). If Interconnection Customer is unable to maintain the specified voltage or power factor, it shall promptly notify the System Operator.

9.6.2.1 Voltage Regulators. Whenever the Large Generating Facility is operated in parallel with the Transmission System and voltage regulators are capable of operation, Interconnection Customer shall operate the Large Generating Facility with its voltage regulators in automatic operation. If the Large Generating Facility's voltage regulators are not capable of such automatic operation, Interconnection Customer shall immediately notify Transmission Provider's system operator, or its designated representative, and ensure that such Large Generating Facility's reactive power production or absorption (measured in MVARs) are within the design capability of the Large Generating Facility's generating unit(s) and steady state stability limits. Interconnection Customer shall not cause its Large Generating Facility to disconnect automatically or instantaneously from the Transmission System or trip any

generating unit comprising the Large Generating Facility for an under or over frequency condition unless the abnormal frequency condition persists for a time period beyond the limits set forth in ANSI/IEEE Standard C37.106, or such other standard as applied to other generators in the Balancing Authority Area on a comparable basis.

9.6.3 Payment for Reactive Power. Transmission Provider is required to pay Interconnection Customer for reactive power that Interconnection Customer provides or absorbs from the Large Generating Facility when Transmission Provider requests Interconnection Customer to operate its Large Generating Facility outside the range specified in Article 9.6.1, provided that if Transmission Provider pays its own or affiliated generators for reactive power service within the specified range, it must also pay Interconnection Customer. Payments shall be pursuant to Article 11.6 or such other agreement to which the Parties have otherwise agreed.

9.6.4 Primary Frequency Response. Interconnection Customer shall ensure the primary frequency response capability of its Large Generating Facility by installing, maintaining, and operating a functioning governor or equivalent controls. The term “functioning governor or equivalent controls” as used herein shall mean the required hardware and/or software that provides frequency responsive real power control with the ability to sense changes in system frequency and autonomously adjust the Large Generating Facility’s real power output in accordance with the droop and deadband parameters and in the direction needed to correct frequency deviations. Interconnection Customer is required to install a governor or equivalent controls with the capability of operating: (1) with a maximum 5 percent droop and ± 0.036 Hz deadband; or (2) in accordance with the relevant droop, deadband, and timely and sustained response settings from an approved Electric Reliability Organization reliability standard providing for equivalent or more stringent parameters. The droop characteristic shall be: (1) based on the nameplate capacity of the Large Generating Facility, and shall be linear in the range of frequencies between 59 to 61 Hz that are outside of the deadband parameter; or (2) based on an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter. The deadband parameter shall be: the range of frequencies above and below nominal (60 Hz) in which the governor or equivalent controls is not expected to adjust the Large Generating Facility’s

real power output in response to frequency deviations. The deadband shall be implemented: (1) without a step to the droop curve, that is, once the frequency deviation exceeds the deadband parameter, the expected change in the Large Generating Facility's real power output in response to frequency deviations shall start from zero and then increase (for under-frequency deviations) or decrease (for over-frequency deviations) linearly in proportion to the magnitude of the frequency deviation; or (2) in accordance with an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter. Interconnection Customer shall notify Transmission Provider that the primary frequency response capability of the Large Generating Facility has been tested and confirmed during commissioning. Once Interconnection Customer has synchronized the Large Generating Facility with the Transmission system, Interconnection Customer shall operate the Large Generating Facility consistent with the provisions specified in articles 9.6.4.1 and 9.6.4.2 of this Agreement. The primary frequency response requirements contained herein shall apply to both synchronous and non-synchronous Large Generating Facilities.

9.6.4.1 Governor or Equivalent Controls. Whenever the Large Generating Facility is operated in parallel with the Transmission System, Interconnection Customer shall operate the Large Generating Facility with its governor or equivalent controls in service and responsive to frequency. Interconnection Customer shall: (1) in coordination with Transmission Provider and/or the relevant balancing authority, set the deadband parameter to: (1) a maximum of ± 0.036 Hz and set the droop parameter to a maximum of 5 percent; or (2) implement the relevant droop and deadband settings from an approved Electric Reliability Organization reliability standard that provides for equivalent or more stringent parameters. Interconnection Customer shall be required to provide the status and settings of the governor or equivalent controls to Transmission Provider and/or the relevant balancing authority upon request. If Interconnection Customer needs to operate the Large Generating Facility with its governor or equivalent controls not in service, Interconnection Customer shall immediately notify Transmission Provider and the relevant balancing authority, and provide both with the following information: (1) the

operating status of the governor or equivalent controls (i.e., whether it is currently out of service or when it will be taken out of service); (2) the reasons for removing the governor or equivalent controls from service; and (3) a reasonable estimate of when the governor or equivalent controls will be returned to service. Interconnection Customer shall make Reasonable Efforts to return its governor or equivalent controls into service as soon as practicable. Interconnection Customer shall make Reasonable Efforts to keep outages of the Large Generating Facility's governor or equivalent controls to a minimum whenever the Large Generating Facility is operated in parallel with the Transmission System.

9.6.4.2 Timely and Sustained Response. Interconnection Customer shall ensure that the Large Generating Facility's real power response to sustained frequency deviations outside of the deadband setting is automatically provided and shall begin immediately after frequency deviates outside of the deadband, and to the extent the Large Generating Facility has operating capability in the direction needed to correct the frequency deviation. Interconnection Customer shall not block or otherwise inhibit the ability of the governor or equivalent controls to respond and shall ensure that the response is not inhibited, except under certain operational constraints including, but not limited to, ambient temperature limitations, physical energy limitations, outages of mechanical equipment, or regulatory requirements. The Large Generating Facility shall sustain the real power response at least until system frequency returns to a value within the deadband setting of the governor or equivalent controls. A Commission-approved reliability standard with equivalent or more stringent requirements shall supersede the above requirements.

9.6.4.3 Exemptions. Large Generating Facilities that are regulated by the United States Nuclear Regulatory Commission shall be exempt from articles 9.6.4, 9.6.4.1, and 9.6.4.2 of this Agreement. Large Generating Facilities that are behind the meter generation that is sized-to-load (i.e., the thermal load

and the generation are near-balanced in real-time operation and the generation is primarily controlled to maintain the unique thermal, chemical, or mechanical output necessary for the operating requirements of its host facility) shall be required to install primary frequency response capability in accordance with the droop and deadband capability requirements specified in article 9.6.4, but shall be otherwise exempt from the operating requirements in articles 9.6.4, 9.6.4.1, 9.6.4.2, and 9.6.4.4 of this Agreement.

9.6.4.4 Electric Storage Resources. Interconnection Customer interconnecting a Generating Facility that contains an electric storage resource shall establish an operating range in Appendix C of its LGIA that specifies a minimum state of charge and a maximum state of charge between which the electric storage resource will be required to provide primary frequency response consistent with the conditions set forth in articles 9.6.4, 9.6.4.1, 9.6.4.2 and 9.6.4.3 of this Agreement. Appendix C shall specify whether the operating range is static or dynamic, and shall consider (1) the expected magnitude of frequency deviations in the interconnection; (2) the expected duration that system frequency will remain outside of the deadband parameter in the interconnection; (3) the expected incidence of frequency deviations outside of the deadband parameter in the interconnection; (4) the physical capabilities of the electric storage resource; (5) operational limitations of the electric storage resource due to manufacturer specifications; and (6) any other relevant factors agreed to by Transmission Provider and Interconnection Customer, and in consultation with the relevant transmission owner or balancing authority as appropriate. If the operating range is dynamic, then Appendix C must establish how frequently the operating range will be reevaluated and the factors that may be considered during its reevaluation.

Interconnection Customer's electric storage resource is required to provide timely and sustained primary frequency response consistent with article 9.6.4.2 of this Agreement when it is online and dispatched to inject electricity to the Transmission System and/or receive electricity from the

Transmission System. This excludes circumstances when the electric storage resource is not dispatched to inject electricity to the Transmission System and/or dispatched to receive electricity from the Transmission System. If Interconnection

Customer's electric storage resource is charging at the time of a frequency deviation outside of its deadband parameter, it is to increase (for over-frequency deviations) or decrease (for under-frequency deviations) the rate at which it is charging in accordance with its droop parameter. Interconnection Customer's electric storage resource is not required to change from charging to discharging, or vice versa, unless the response necessitated by the droop and deadband settings requires it to do so and it is technically capable of making such a transition.

9.7 Outages and Interruptions.

9.7.1 Outages.

9.7.1.1 Outage Authority and Coordination. Each Party may in accordance with Good Utility Practice in coordination with the other Party remove from service any of its respective Interconnection Facilities or Network Upgrades that may impact the other Party's facilities as necessary to perform maintenance or testing or to install or replace equipment. Absent an Emergency Condition, the Party scheduling a removal of such facility(ies) from service will use Reasonable Efforts to schedule such removal on a date and time mutually acceptable to the Parties. In all circumstances, any Party planning to remove such facility(ies) from service shall use Reasonable Efforts to minimize the effect on the other Party of such removal.

9.7.1.2 Outage Schedules. Transmission Provider shall post scheduled outages of its transmission facilities on the OASIS.

Interconnection Customer shall submit its planned maintenance schedules for the Large Generating Facility to Transmission Provider for a minimum of a rolling twenty-four month period. Interconnection Customer shall update its planned maintenance schedules as necessary. Transmission Provider may request Interconnection Customer to reschedule its maintenance as necessary to maintain the reliability of the Transmission System; provided, however, adequacy of generation supply shall not be a criterion in determining Transmission System reliability. Transmission Provider shall compensate Interconnection Customer for any additional direct costs that Interconnection Customer incurs as a result of having to reschedule maintenance, including any additional overtime, breaking of maintenance contracts or other costs above and beyond the cost Interconnection Customer would have incurred absent Transmission Provider's request to reschedule maintenance. Interconnection Customer will not be eligible to receive compensation, if during the twelve (12) months prior to the date of the scheduled maintenance, Interconnection Customer had modified its schedule of maintenance activities.

9.7.1.3 **Outage Restoration.** If an outage on a Party's Interconnection Facilities or Network Upgrades adversely affects the other Party's operations or facilities, the Party that owns or controls the facility that is out of service shall use Reasonable Efforts to promptly restore such facility(ies) to a normal operating condition consistent with the nature of the outage. The Party that owns or controls the facility that is out of service shall provide the other Party, to the extent such information is known, information on the nature of the Emergency Condition, an estimated time of restoration, and any corrective actions required. Initial verbal notice shall be followed up as soon as practicable with written notice explaining the nature of the outage.

9.7.2 Interruption of Service. If required by Good Utility Practice to do so, Transmission Provider may require Interconnection Customer to interrupt or reduce deliveries of electricity if such delivery of electricity could

adversely affect Transmission Provider's ability to perform such activities as are necessary to safely and reliably operate and maintain the Transmission System. The following provisions shall apply to any interruption or reduction permitted under this Article 9.7.2:

- 9.7.2.1** The interruption or reduction shall continue only for so long as reasonably necessary under Good Utility Practice;
- 9.7.2.2** Any such interruption or reduction shall be made on an equitable, non-discriminatory basis with respect to all generating facilities directly connected to the Transmission System;
- 9.7.2.3** When the interruption or reduction must be made under circumstances which do not allow for advance notice, Transmission Provider shall notify Interconnection Customer by telephone as soon as practicable of the reasons for the curtailment, interruption, or reduction, and, if known, its expected duration. Telephone notification shall be followed by written notification as soon as practicable;
- 9.7.2.4** Except during the existence of an Emergency Condition, when the interruption or reduction can be scheduled without advance notice, Transmission Provider shall notify Interconnection Customer in advance regarding the timing of such scheduling and further notify Interconnection Customer of the expected duration. Transmission Provider shall coordinate with Interconnection Customer using Good Utility Practice to schedule the interruption or reduction during periods of least impact to Interconnection Customer and Transmission Provider;
- 9.7.2.5** The Parties shall cooperate and coordinate with each other to the extent necessary in order to restore the Large Generating Facility, Interconnection Facilities, and the Transmission

System to their normal operating state, consistent with system conditions and Good Utility Practice.

9.7.3 Ride Through Capability and Performance. The Transmission System is designed to automatically activate a load-shed program as required by the Electric Reliability Organization in the event of an under-frequency system disturbance. Interconnection Customer shall implement under-frequency and over-frequency relay set points for the Large Generating Facility as required by the Electric Reliability Organization to ensure frequency “ride through” capability of the Transmission System. Large Generating Facility response to frequency deviations of pre-determined magnitudes, both under-frequency and over-frequency deviations, shall be studied and coordinated with Transmission Provider in accordance with Good Utility Practice. Interconnection Customer shall also implement under-voltage and over-voltage relay set points, or equivalent electronic controls, as required by the Electric Reliability Organization to ensure voltage “ride through” capability of the Transmission System. The term “ride through” as used herein shall mean the ability of a Generating Facility to stay connected to and synchronized with the Transmission System during system disturbances within a range of under-frequency, over-frequency, under-voltage, and over-voltage conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other Generating Facilities in the Balancing Authority Area on a comparable basis. For abnormal frequency conditions and voltage conditions within the “no trip zone” defined by Reliability Standard PRC-024-3 or successor mandatory ride through reliability standards, the non-synchronous Large Generating Facility must ensure that, within any physical limitations of the Large Generating Facility, its control and protection settings are configured or set to (1) continue active power production during disturbance and post disturbance periods at pre-disturbance levels, unless reactive power priority mode is enabled or unless providing primary frequency response or fast frequency response; (2) minimize reductions in active power and remain within dynamic voltage and current limits, if reactive power priority mode is enabled, unless providing primary frequency response or fast frequency response; (3) not artificially limit dynamic reactive power capability during disturbances; and (4) return to pre-disturbance active power levels without artificial ramp rate limits if active power is reduced, unless providing primary frequency response or fast frequency response.

9.7.4 System Protection and Other Control Requirements.

- 9.7.4.1** System Protection Facilities. Interconnection Customer shall, at its expense, install, operate and maintain System Protection Facilities as a part of the Large Generating Facility or Interconnection Customer's Interconnection Facilities. Transmission Provider shall install at Interconnection Customer's expense any System Protection Facilities that may be required on Transmission Provider's Interconnection Facilities or the Transmission System as a result of the interconnection of the Large Generating Facility and Interconnection Customer's Interconnection Facilities.
- 9.7.4.2** Each Party's protection facilities shall be designed and coordinated with other systems in accordance with Good Utility Practice.
- 9.7.4.3** Each Party shall be responsible for protection of its facilities consistent with Good Utility Practice.
- 9.7.4.4** Each Party's protective relay design shall incorporate the necessary test switches to perform the tests required in Article 6. The required test switches will be placed such that they allow operation of lockout relays while preventing breaker failure schemes from operating and causing unnecessary breaker operations and/or the tripping of Interconnection Customer's units.
- 9.7.4.5** Each Party will test, operate and maintain System Protection Facilities in accordance with Good Utility Practice.
- 9.7.4.6** Prior to the In-Service Date, and again prior to the Commercial Operation Date, each Party or its agent shall

perform a complete calibration test and functional trip test of the System Protection Facilities. At intervals suggested by Good Utility Practice and following any apparent malfunction of the System Protection Facilities, each Party shall perform both calibration and functional trip tests of its System Protection Facilities. These tests do not require the tripping of any in-service generation unit. These tests do, however, require that all protective relays and lockout contacts be activated.

9.7.5 Requirements for Protection. In compliance with Good Utility Practice, Interconnection Customer shall provide, install, own, and maintain relays, circuit breakers and all other devices necessary to remove any fault contribution of the Large Generating Facility to any short circuit occurring on the Transmission System not otherwise isolated by Transmission Provider's equipment, such that the removal of the fault contribution shall be coordinated with the protective requirements of the Transmission System. Such protective equipment shall include, without limitation, a disconnecting device or switch with load-interrupting capability located between the Large Generating Facility and the Transmission System at a site selected upon mutual agreement (not to be unreasonably withheld, conditioned or delayed) of the Parties. Interconnection Customer shall be responsible for protection of the Large Generating Facility and Interconnection Customer's other equipment from such conditions as negative sequence currents, over- or under-frequency, sudden load rejection, over- or under-voltage, and generator loss-of-field. Interconnection Customer shall be solely responsible to disconnect the Large Generating Facility and Interconnection Customer's other equipment if conditions on the Transmission System could adversely affect the Large Generating Facility.

9.7.6 Power Quality. Neither Party's facilities shall cause excessive voltage flicker nor introduce excessive distortion to the sinusoidal voltage or current waves as defined by ANSI Standard C84.1-1989, in accordance with IEEE Standard 519, or any applicable superseding electric industry standard. In the event of a conflict between ANSI Standard C84.1-1989, or any applicable superseding electric industry standard, ANSI Standard C84.1-1989, or the applicable superseding electric industry standard, shall control.

9.8 **Switching and Tagging Rules.** Each Party shall provide the other Party a copy of its switching and tagging rules that are applicable to the other Party's activities. Such switching and tagging rules shall be developed on a non-discriminatory basis. The Parties shall comply with applicable switching and tagging rules, as amended from time to time, in obtaining clearances for work or for switching operations on equipment.

9.9 **Use of Interconnection Facilities by Third Parties.**

9.9.1 Purpose of Interconnection Facilities. Except as may be required by Applicable Laws and Regulations, or as otherwise agreed to among the Parties, the Interconnection Facilities shall be constructed for the sole purpose of interconnecting the Large Generating Facility to the Transmission System and shall be used for no other purpose.

9.9.2 Third Party Users. If required by Applicable Laws and Regulations or if the Parties mutually agree, such agreement not to be unreasonably withheld, to allow one or more third parties to use Transmission Provider's Interconnection Facilities, or any part thereof, Interconnection Customer will be entitled to compensation for the capital expenses it incurred in connection with the Interconnection Facilities based upon the pro rata use of the Interconnection Facilities by Transmission Provider, all third party users, and Interconnection Customer, in accordance with Applicable Laws and Regulations or upon some other mutually-agreed upon methodology. In addition, cost responsibility for ongoing costs, including operation and maintenance costs associated with the Interconnection Facilities, will be allocated between Interconnection Customer and any third party users based upon the pro rata use of the Interconnection Facilities by Transmission Provider, all third party users, and Interconnection Customer, in accordance with Applicable Laws and Regulations or upon some other mutually agreed upon methodology. If the issue of such compensation or allocation cannot be resolved through such negotiations, it shall be submitted to FERC for resolution.

9.10 Disturbance Analysis Data Exchange. The Parties will cooperate with one another in the analysis of disturbances to either the Large Generating Facility or Transmission Provider's Transmission System by gathering and providing access to any information relating to any disturbance, including information from oscillography, protective relay targets, breaker operations and sequence of events records, and any disturbance information required by Good Utility Practice.

Article 10. Maintenance

10.1 Transmission Provider Obligations. Transmission Provider shall maintain the Transmission System and Transmission Provider's Interconnection Facilities in a safe and reliable manner and in accordance with this LGIA.

10.2 Interconnection Customer Obligations. Interconnection Customer shall maintain the Large Generating Facility and Interconnection Customer's Interconnection Facilities in a safe and reliable manner and in accordance with this LGIA.

10.3 Coordination. The Parties shall confer regularly to coordinate the planning, scheduling and performance of preventive and corrective maintenance on the Large Generating Facility and the Interconnection Facilities.

10.4 Secondary Systems. Each Party shall cooperate with the other in the inspection, maintenance, and testing of control or power circuits that operate below 600 volts, AC or DC, including, but not limited to, any hardware, control or protective devices, cables, conductors, electric raceways, secondary equipment panels, transducers, batteries, chargers, and voltage and current transformers that directly affect the operation of a Party's facilities and equipment which may reasonably be expected to impact the other Party. Each Party shall provide advance notice to the other Party before undertaking any work on such circuits, especially on electrical circuits involving circuit breaker trip and close contacts, current transformers, or potential transformers.

- 10.5 **Operating and Maintenance Expenses.** Subject to the provisions herein addressing the use of facilities by others, and except for operations and maintenance expenses associated with modifications made for providing interconnection or transmission service to a third party and such third party pays for such expenses, Interconnection Customer shall be responsible for all reasonable expenses including overheads, associated with: (1) owning, operating, maintaining, repairing, and replacing Interconnection Customer's Interconnection Facilities; and (2) operation, maintenance, repair and replacement of Transmission Provider's Interconnection Facilities.

Article 11. Performance Obligation

- 11.1 **Interconnection Customer Interconnection Facilities.** Interconnection Customer shall design, procure, construct, install, own and/or control Interconnection Customer Interconnection Facilities described in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades, at its sole expense.
- 11.2 **Transmission Provider's Interconnection Facilities.** Transmission Provider or Transmission Owner shall design, procure, construct, install, own and/or control Transmission Provider's Interconnection Facilities described in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades, at the sole expense of Interconnection Customer.
- 11.3 **Network Upgrades and Distribution Upgrades.** Transmission Provider or Transmission Owner shall design, procure, construct, install, and own the Network Upgrades and Distribution Upgrades described in Appendix A, Interconnection Facilities, Network Upgrades and Distribution Upgrades. Interconnection Customer shall be responsible for all costs related to Distribution Upgrades. Unless Transmission Provider or Transmission Owner elects to fund the capital for the Network Upgrades, they shall be solely funded by Interconnection Customer.
- 11.4 Transmission Credits.**

11.4.1 Repayment of Amounts Advanced for Network Upgrades. Interconnection Customer shall be entitled to a cash repayment, equal to the total amount paid to Transmission Provider and Affected System Operator, if any, for the Network Upgrades, including any tax gross-up or other tax-related payments associated with Network Upgrades, and not refunded to Interconnection Customer pursuant to Article 5.17.8 or otherwise, to be paid to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, as payments are made under Transmission Provider's Tariff and Affected System's Tariff for transmission services with respect to the Large Generating Facility. Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 C.F.R. § 35.19a(a)(2)(iii) from the date of any payment for Network Upgrades through the date on which Interconnection Customer receives a repayment of such payment pursuant to this subparagraph. Interconnection Customer may assign such repayment rights to any person.

Notwithstanding the foregoing, Interconnection Customer, Transmission Provider, and Affected System Operator may adopt any alternative payment schedule that is mutually agreeable so long as Transmission Provider and Affected System Operator take one of the following actions no later than five years from the Commercial Operation Date: (1) return to Interconnection Customer any amounts advanced for Network Upgrades not previously repaid, or (2) declare in writing that Transmission Provider or Affected System Operator will continue to provide payments to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, or develop an alternative schedule that is mutually agreeable and provides for the return of all amounts advanced for Network Upgrades not previously repaid; however, full reimbursement shall not extend beyond twenty (20) years from the Commercial Operation Date.

If the Large Generating Facility fails to achieve commercial operation, but it or another Generating Facility is later constructed and makes use of the Network Upgrades, Transmission Provider and Affected System Operator shall at that time reimburse

Interconnection Customer for the amounts advanced for the Network Upgrades. Before any such reimbursement can occur, Interconnection Customer, or the entity that ultimately constructs the Generating Facility, if different, is responsible for identifying the entity to which reimbursement must be made.

- 11.4.2 Special Provisions for Affected Systems. Unless Transmission Provider provides, under the LGIA, for the repayment of amounts advanced to Affected System Operator for Network Upgrades, Interconnection Customer and Affected System Operator shall enter into an agreement that provides for such repayment. The agreement shall specify the terms governing payments to be made by Interconnection Customer to the Affected System Operator as well as the repayment by the Affected System Operator.
- 11.4.3 Notwithstanding any other provision of this LGIA, nothing herein shall be construed as relinquishing or foreclosing any rights, including but not limited to firm transmission rights, capacity rights, transmission congestion rights, or transmission credits, that Interconnection Customer, shall be entitled to, now or in the future under any other agreement or tariff as a result of, or otherwise associated with, the transmission capacity, if any, created by the Network Upgrades, including the right to obtain cash reimbursements or transmission credits for transmission service that is not associated with the Large Generating Facility.
- 11.5 Provision of Security. At least thirty (30) Calendar Days prior to the commencement of the procurement, installation, or construction of a discrete portion of a Transmission Provider's Interconnection Facilities, Network Upgrades, or Distribution Upgrades, Interconnection Customer shall provide Transmission Provider, at Interconnection Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to Transmission Provider and is consistent with the Uniform Commercial Code of the jurisdiction identified in Article 14.2.1. Such security for payment, as specified in Appendix B of this LGIA, shall be in an amount sufficient to cover the costs for constructing, procuring and installing the applicable portion of

Transmission Provider's Interconnection Facilities, Network Upgrades, or Distribution Upgrades and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider for these purposes. Transmission Provider must use the LGIA Deposit required in Section 11.3 of the LGIP before requiring Interconnection Customer to submit security in addition to that LGIA Deposit. Transmission Provider must specify, in Appendix B of this LGIA, the dates for which Interconnection Customer must provide additional security for construction of each discrete portion of Transmission Provider's Interconnection Facilities, Network Upgrades, or Distribution Upgrades and Interconnection Customer must provide such additional security.

In addition:

- 11.5.1** The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider, and contain terms and conditions that guarantee payment of any amount that may be due from Interconnection Customer, up to an agreed-to maximum amount.
 - 11.5.2** The letter of credit must be issued by a financial institution reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.
 - 11.5.3** The surety bond must be issued by an insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.
- 11.6** Interconnection Customer Compensation. If Transmission Provider requests or directs Interconnection Customer to provide a service pursuant to Articles 9.6.3 (Payment for Reactive Power), or 13.5.1 of this LGIA, Transmission Provider shall compensate Interconnection Customer in accordance with Interconnection Customer's applicable rate schedule then in effect unless the provision of such service(s) is subject to an RTO or ISO FERC-approved rate schedule. Interconnection Customer shall serve Transmission Provider or RTO or ISO with any filing of a proposed rate schedule at the time of such filing with FERC. To the extent that no rate schedule is in effect at the time Interconnection Customer is

required to provide or absorb any Reactive Power under this LGIA, Transmission Provider agrees to compensate Interconnection Customer in such amount as would have been due Interconnection Customer had the rate schedule been in effect at the time service commenced; provided, however, that such rate schedule must be filed at FERC or other appropriate Governmental Authority within sixty (60) Calendar Days of the commencement of service.

- 11.6.1 Interconnection Customer Compensation for Actions During Emergency Condition. Transmission Provider or RTO or ISO shall compensate Interconnection Customer for its provision of real and reactive power and other Emergency Condition services that Interconnection Customer provides to support the Transmission System during an Emergency Condition in accordance with Article 11.6.

Article 12. Invoice

- 12.1 General. Each Party shall submit to the other Party, on a monthly basis, invoices of amounts due for the preceding month. Each invoice shall state the month to which the invoice applies and fully describe the services and equipment provided. The Parties may discharge mutual debts and payment obligations due and owing to each other on the same date through netting, in which case all amounts a Party owes to the other Party under this LGIA, including interest payments or credits, shall be netted so that only the net amount remaining due shall be paid by the owing Party.
- 12.2 Final Invoice. Within six months after completion of the construction of Transmission Provider's Interconnection Facilities and the Network Upgrades, Transmission Provider shall provide an invoice of the final cost of the construction of Transmission Provider's Interconnection Facilities and the Network Upgrades and shall set forth such costs in sufficient detail to enable Interconnection Customer to compare the actual costs with the estimates and to ascertain deviations, if any, from the cost estimates. Transmission Provider shall refund to Interconnection Customer any amount by which the actual payment by Interconnection Customer for estimated costs exceeds the actual costs of

construction within thirty (30) Calendar Days of the issuance of such final construction invoice.

- 12.3 **Payment.** Invoices shall be rendered to the paying Party at the address specified in Appendix F. The Party receiving the invoice shall pay the invoice within thirty (30) Calendar Days of receipt. All payments shall be made in immediately available funds payable to the other Party, or by wire transfer to a bank named and account designated by the invoicing Party. Payment of invoices by either Party will not constitute a waiver of any rights or claims either Party may have under this LGIA.
- 12.4 **Disputes.** In the event of a billing dispute between Transmission Provider and Interconnection Customer, Transmission Provider shall continue to provide Interconnection Service under this LGIA as long as Interconnection Customer: (i) continues to make all payments not in dispute; and (ii) pays to Transmission Provider or into an independent escrow account the portion of the invoice in dispute, pending resolution of such dispute. If Interconnection Customer fails to meet these two requirements for continuation of service, then Transmission Provider may provide notice to Interconnection Customer of a Default pursuant to Article 17. Within thirty (30) Calendar Days after the resolution of the dispute, the Party that owes money to the other Party shall pay the amount due with interest calculated in accord with the methodology set forth in FERC's regulations at 18 CFR § 35.19a(a)(2)(iii).

Article 13. Emergencies

13.1 Definition. "Emergency Condition" shall mean a condition or situation: (i) that in

the judgment of the Party making the claim is imminently likely to endanger life or property; or (ii) that, in the case of Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to the Transmission System, Transmission Provider's Interconnection Facilities or the Transmission Systems of others to which the Transmission System is directly connected; or (iii) that, in the case of Interconnection Customer, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Large Generating Facility or Interconnection Customer's

Interconnection Facilities' System restoration and black start shall be considered Emergency Conditions; provided, that Interconnection Customer is not obligated by this LGIA to possess black start capability.

- 13.2 **Obligations.** Each Party shall comply with the Emergency Condition procedures of the applicable ISO/RTO, the Electric Reliability Organization, Applicable Laws and Regulations, and any emergency procedures agreed to by the Joint Operating Committee.
- 13.3 **Notice.** Transmission Provider shall notify Interconnection Customer promptly when it becomes aware of an Emergency Condition that affects Transmission Provider's Interconnection Facilities or the Transmission System that may reasonably be expected to affect Interconnection Customer's operation of the Large Generating Facility or Interconnection Customer's Interconnection Facilities. Interconnection Customer shall notify Transmission Provider promptly when it becomes aware of an Emergency Condition that affects the Large Generating Facility or Interconnection Customer's Interconnection Facilities that may reasonably be expected to affect the Transmission System or Transmission Provider's Interconnection Facilities. To the extent information is known, the notification shall describe the Emergency Condition, the extent of the damage or deficiency, the expected effect on the operation of Interconnection Customer's or Transmission Provider's facilities and operations, its anticipated duration and the corrective action taken and/or to be taken. The initial notice shall be followed as soon as practicable with written notice.
- 13.4 **Immediate Action.** Unless, in Interconnection Customer's reasonable judgment, immediate action is required, Interconnection Customer shall obtain the consent of Transmission Provider, such consent to not be unreasonably withheld, prior to performing any manual switching operations at the Large Generating Facility or Interconnection Customer's Interconnection Facilities in response to an Emergency Condition either declared by Transmission Provider or otherwise regarding the Transmission System.
- 13.5 **Transmission Provider Authority.**

13.5.1 **General.** Transmission Provider may take whatever actions or inactions with regard to the Transmission System or Transmission Provider's Interconnection Facilities it deems necessary during an Emergency Condition in order to (i) preserve public health and safety, (ii) preserve the reliability of the Transmission System or Transmission Provider's Interconnection Facilities, (iii) limit or prevent damage, and (iv) expedite restoration of service.

Transmission Provider shall use Reasonable Efforts to minimize the effect of such actions or inactions on the Large Generating Facility or Interconnection Customer's Interconnection Facilities.

Transmission Provider may, on the basis of technical considerations, require the Large Generating Facility to mitigate an Emergency Condition by taking actions necessary and limited in scope to remedy the Emergency Condition, including, but not limited to, directing Interconnection Customer to shut-down, start-up, increase or decrease the real or reactive power output of the Large Generating Facility; implementing a reduction or disconnection pursuant to Article 13.5.2; directing Interconnection Customer to assist with blackstart (if available) or restoration efforts; or altering the outage schedules of the Large Generating Facility and Interconnection Customer's Interconnection Facilities. Interconnection Customer shall comply with all of Transmission Provider's operating instructions concerning Large Generating Facility real power and reactive power output within the manufacturer's design limitations of the Large Generating Facility's equipment that is in service and physically available for operation at the time, in compliance with Applicable Laws and Regulations.

13.5.2 Reduction and Disconnection. Transmission Provider may reduce Interconnection Service or disconnect the Large Generating Facility or Interconnection Customer's Interconnection Facilities, when such, reduction or disconnection is necessary under Good Utility Practice due to Emergency Conditions. These rights are separate and distinct from any right of curtailment of Transmission Provider pursuant to Transmission Provider's Tariff. When Transmission Provider can schedule the reduction or disconnection in advance, Transmission Provider shall notify Interconnection Customer of the reasons, timing and expected duration of the reduction or

disconnection. Transmission Provider shall coordinate with Interconnection Customer using Good Utility Practice to schedule the reduction or disconnection during periods of least impact to Interconnection Customer and Transmission Provider. Any reduction or disconnection shall continue only for so long as reasonably necessary under Good Utility Practice. The Parties shall cooperate with each other to restore the Large Generating Facility, the Interconnection Facilities, and the Transmission System to their normal operating state as soon as practicable consistent with Good Utility Practice.

- 13.6 Interconnection Customer Authority.** Consistent with Good Utility Practice and the LGIA and the LGIP, Interconnection Customer may take actions or inactions with regard to the Large Generating Facility or Interconnection Customer's Interconnection Facilities during an Emergency Condition in order to (i) preserve public health and safety, (ii) preserve the reliability of the Large Generating Facility or Interconnection Customer's Interconnection Facilities, (iii) limit or prevent damage, and (iv) expedite restoration of service. Interconnection Customer shall use Reasonable Efforts to minimize the effect of such actions or inactions on the Transmission System and Transmission Provider's Interconnection Facilities. Transmission Provider shall use Reasonable Efforts to assist Interconnection Customer in such actions.
- 13.7 Limited Liability. Except as otherwise provided in Article 11.6.1 of this LGIA, neither Party shall be liable to the other for any action it takes in responding to an Emergency Condition so long as such action is made in good faith and is consistent with Good Utility Practice.

Article 14. Regulatory Requirements and Governing Law

- 14.1 Regulatory Requirements. Each Party's obligations under this LGIA shall be subject to its receipt of any required approval or certificate from one or more Governmental Authorities in the form and substance satisfactory to the applying Party, or the Party making any required filings with, or providing notice to, such Governmental Authorities, and the expiration of any time period associated therewith. Each Party shall in good faith seek and use its Reasonable Efforts to obtain such other approvals. Nothing in this LGIA shall require Interconnection

Customer to take any action that could result in its inability to obtain, or its loss of, status or exemption under the Federal Power Act, the Public Utility Holding Company Act of 1935, as amended, or the Public Utility Regulatory Policies Act of 1978.

14.2 Governing Law.

- 14.2.1** The validity, interpretation and performance of this LGIA and each of its provisions shall be governed by the laws of the state where the Point of Interconnection is located, without regard to its conflicts of law principles.
- 14.2.2** This LGIA is subject to all Applicable Laws and Regulations.
- 14.2.3** Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, rules, or regulations of a Governmental Authority.

Article 15. Notices.

- 15.1 General. Unless otherwise provided in this LGIA, any notice, demand or request required or permitted to be given by either Party to the other and any instrument required or permitted to be tendered or delivered by either Party in writing to the other shall be effective when delivered and may be so given, tendered or delivered, by recognized national courier, or by depositing the same with the United States Postal Service with postage prepaid, for delivery by certified or registered mail, addressed to the Party, or personally delivered to the Party, at the address set out in Appendix F, Addresses for Delivery of Notices and Billings.

Either Party may change the notice information in this LGIA by giving five (5) Business Days written notice prior to the effective date of the change.

- 15.2 **Billings and Payments.** Billings and payments shall be sent to the addresses set out in Appendix F.
- 15.3 **Alternative Forms of Notice.** Any notice or request required or permitted to be given by a Party to the other and not required by this Agreement to be given in writing may be so given by telephone, facsimile or email to the telephone numbers and email addresses set out in Appendix F.
- 15.4 **Operations and Maintenance Notice.** Each Party shall notify the other Party in writing of the identity of the person(s) that it designates as the point(s) of contact with respect to the implementation of Articles 9 and 10.

Article 16. Force Majeure

16.1 Force Majeure.

16.1.1 Economic hardship is not considered a Force Majeure event.

16.1.2 Neither Party shall be considered to be in Default with respect to any obligation hereunder, (including obligations under Article 4), other than the obligation to pay money when due, if prevented from fulfilling such obligation by Force Majeure. A Party unable to fulfill any obligation hereunder (other than an obligation to pay money when due) by reason of Force Majeure shall give notice and the full particulars of such Force Majeure to the other Party in writing or by telephone as soon as reasonably possible after the occurrence of the cause relied upon. Telephone notices given pursuant to this article shall be confirmed in writing as soon as reasonably possible and shall specifically state full particulars of the Force Majeure, the time and date when the Force Majeure occurred and when the Force Majeure is reasonably expected to cease. The Party affected shall exercise due diligence to remove such disability with reasonable dispatch, but shall not be required to accede or agree to any provision not satisfactory to it in order to settle and terminate a strike or other labor disturbance.

Article 17. Default

17.1 Default

17.1.1 General. No Default shall exist where such failure to discharge an obligation (other than the payment of money) is the result of Force Majeure as defined in this LGIA or the result of an act of omission of the other Party. Upon a Breach, the non-breaching Party shall give written notice of such Breach to the breaching Party. Except as provided in Article 17.1.2, the breaching Party shall have thirty (30) Calendar Days from receipt of the Default notice within which to cure such Breach; provided however, if such Breach is not capable of cure within thirty (30) Calendar Days, the breaching Party shall commence such cure within thirty (30) Calendar Days after notice and continuously and diligently complete such cure within ninety (90) Calendar Days from receipt of the Default notice; and, if cured within such time, the Breach specified in such notice shall cease to exist.

17.1.2 Right to Terminate. If a Breach is not cured as provided in this article, or if a Breach is not capable of being cured within the period provided for herein, the non-breaching Party shall have the right to declare a Default and terminate this LGIA by written notice at any time until cure occurs, and be relieved of any further obligation hereunder and, whether or not that Party terminates this LGIA, to recover from the breaching Party all amounts due hereunder, plus all other damages and remedies to which it is entitled at law or in equity. The provisions of this article will survive termination of this LGIA.

17.2 Violation of Operating Assumptions for Generating Facilities. If Transmission Provider requires Interconnection Customer to memorialize the operating assumptions for the charging behavior of a Generating Facility that includes at least one electric storage resource in Appendix H of this LGIA, Transmission Provider may consider Interconnection Customer to be in Breach of

the LGIA if Interconnection Customer fails to operate the Generating Facility in accordance with those operating assumptions for charging behavior. However, if Interconnection Customer operates contrary to the operating assumptions for charging behavior specified in Appendix H of this LGIA at the direction of Transmission Provider, Transmission Provider shall not consider Interconnection Customer in Breach of this LGIA.

Article 18. Indemnity, Consequential Damages and Insurance

18.1 Indemnity. The Parties shall at all times indemnify, defend, and hold the other Party harmless from, any and all damages, losses, claims, including claims and actions relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's action or inactions of its obligations under this LGIA on behalf of the Indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the indemnified Party.

18.1.1 Indemnified Person. If an Indemnified Person is entitled to indemnification under this Article 18 as a result of a claim by a third party, and the Indemnifying Party fails, after notice and reasonable opportunity to proceed under Article 18.1, to assume the defense of such claim, such Indemnified Person may at the expense of the Indemnifying Party contest, settle or consent to the entry of any judgment with respect to, or pay in full, such claim.

18.1.2 Indemnifying Party. If an Indemnifying Party is obligated to indemnify and hold any Indemnified Person harmless under this Article 18, the amount owing to the Indemnified Person shall be the amount of such Indemnified Person's actual Loss, net of any insurance or other recovery.

18.1.3 Indemnity Procedures. Promptly after receipt by an Indemnified Person of any claim or notice of the commencement of any action or administrative or legal proceeding or investigation as to which the

indemnity provided for in Article 18.1 may apply, the Indemnified Person shall notify the Indemnifying Party of such fact. Any failure of or delay in such notification shall not affect a Party's indemnification obligation unless such failure or delay is materially prejudicial to the Indemnifying Party.

The Indemnifying Party shall have the right to assume the defense thereof with counsel designated by such Indemnifying Party and reasonably satisfactory to the Indemnified Person. If the defendants in any such action include one or more Indemnified Persons and the Indemnifying Party and if the Indemnified Person reasonably concludes that there may be legal defenses available to it and/or other Indemnified Persons which are different from or additional to those available to the Indemnifying Party, the Indemnified Person shall have the right to select separate counsel to assert such legal defenses and to otherwise participate in the defense of such action on its own behalf. In such instances, the Indemnifying Party shall only be required to pay the fees and expenses of one additional attorney to represent an Indemnified Person or Indemnified Persons having such differing or additional legal defenses.

The Indemnified Person shall be entitled, at its expense, to participate in any such action, suit or proceeding, the defense of which has been assumed by the Indemnifying Party. Notwithstanding the foregoing, the Indemnifying Party (i) shall not be entitled to assume and control the defense of any such action, suit or proceedings if and to the extent that, in the opinion of the Indemnified Person and its counsel, such action, suit or proceeding involves the potential imposition of criminal liability on the Indemnified Person, or there exists a conflict or adversity of interest between the Indemnified Person and the Indemnifying Party, in such event the Indemnifying Party shall pay the reasonable expenses of the Indemnified Person, and (ii) shall not settle or consent to the entry of any judgment in any action, suit or proceeding without the consent of the Indemnified Person, which shall not be reasonably withheld, conditioned or delayed.

- 18.2 Consequential Damages. Other than the Liquidated Damages heretofore described, in no event shall either Party be liable under any provision of this LGIA for any losses, damages, costs or expenses for any special, indirect, incidental, consequential, or punitive damages, including but not limited to loss of profit or revenue, loss of the use of equipment, cost of capital, cost of temporary equipment or services, whether based in whole or in part in contract, in tort, including negligence, strict liability, or any other theory of liability; provided, however, that damages for which a Party may be liable to the other Party under another agreement will not be considered to be special, indirect, incidental, or consequential damages hereunder.
- 18.3 Insurance. Each party shall, at its own expense, maintain in force throughout the period of this LGIA, and until released by the other Party, the following minimum insurance coverages, with insurers authorized to do business in the state where the Point of Interconnection is located:
- 18.3.1** Employers' Liability and Workers' Compensation Insurance providing statutory benefits in accordance with the laws and regulations of the state in which the Point of Interconnection is located.
- 18.3.2** Commercial General Liability Insurance including premises and operations, personal injury, broad form property damage, broad form blanket contractual liability coverage (including coverage for the contractual indemnification) products and completed operations coverage, coverage for explosion, collapse and underground hazards, independent contractors coverage, coverage for pollution to the extent normally available and punitive damages to the extent normally available and a cross liability endorsement, with minimum limits of One Million Dollars (\$1,000,000) per occurrence/One Million Dollars (\$1,000,000) aggregate combined single limit for personal injury, bodily injury, including death and property damage.
- 18.3.3** Comprehensive Automobile Liability Insurance for coverage of owned and non-owned and hired vehicles, trailers or semi-trailers designed for travel on public roads, with a minimum, combined

single limit of One Million Dollars (\$1,000,000) per occurrence for bodily injury, including death, and property damage.

- 18.3.4** Excess Public Liability Insurance over and above the Employers' Liability Commercial General Liability and Comprehensive Automobile Liability Insurance coverage, with a minimum combined single limit of Twenty Million Dollars (\$20,000,000) per occurrence/Twenty Million Dollars (\$20,000,000) aggregate.
- 18.3.5** The Commercial General Liability Insurance, Comprehensive Automobile Insurance and Excess Public Liability Insurance policies shall name the other Party, its parent, associated and Affiliate companies and their respective directors, officers, agents, servants and employees ("Other Party Group") as additional insured. All policies shall contain provisions whereby the insurers waive all rights of subrogation in accordance with the provisions of this LGIA against the Other Party Group and provide thirty (30) Calendar Days advance written notice to the Other Party Group prior to anniversary date of cancellation or any material change in coverage or condition.
- 18.3.6** The Commercial General Liability Insurance, Comprehensive Automobile Liability Insurance and Excess Public Liability Insurance policies shall contain provisions that specify that the policies are primary and shall apply to such extent without consideration for other policies separately carried and shall state that each insured is provided coverage as though a separate policy had been issued to each, except the insurer's liability shall not be increased beyond the amount for which the insurer would have been liable had only one insured been covered. Each Party shall be responsible for its respective deductibles or retentions.
- 18.3.7** The Commercial General Liability Insurance, Comprehensive Automobile Liability Insurance and Excess Public Liability Insurance policies, if written on a Claims First Made Basis, shall be maintained in full force and effect for two (2) years after termination of this LGIA, which coverage may be in the form of tail coverage or extended reporting period coverage if agreed by the Parties.

- 18.3.8** The requirements contained herein as to the types and limits of all insurance to be maintained by the Parties are not intended to and shall not in any manner, limit or qualify the liabilities and obligations assumed by the Parties under this LGIA.
- 18.3.9** Within ten (10) Business Days following execution of this LGIA, and as soon as practicable after the end of each fiscal year or at the renewal of the insurance policy and in any event within ninety (90) Calendar Days thereafter, each Party shall provide certification of all insurance required in this LGIA, executed by each insurer or by an authorized representative of each insurer.
- 18.3.10** Notwithstanding the foregoing, each Party may self-insure to meet the minimum insurance requirements of Articles 18.3.2 through 18.3.8 to the extent it maintains a self-insurance program; provided that, such Party's senior secured debt is rated at investment grade or better by Standard & Poor's and that its self-insurance program meets the minimum insurance requirements of Articles 18.3.2 through 18.3.8. For any period of time that a Party's senior secured debt is unrated by Standard & Poor's or is rated at less than investment grade by Standard & Poor's, such Party shall comply with the insurance requirements applicable to it under Articles 18.3.2 through 18.3.9. In the event that a Party is permitted to self-insure pursuant to this article, it shall notify the other Party that it meets the requirements to self-insure and that its self-insurance program meets the minimum insurance requirements in a manner consistent with that specified in Article 18.3.9.
- 18.3.11** The Parties agree to report to each other in writing as soon as practical all accidents or occurrences resulting in injuries to any person, including death, and any property damage arising out of this LGIA.

Article 19. Assignment

- 19.1 Assignment. This LGIA may be assigned by either Party only with the written consent of the other; provided that either Party may assign this LGIA without the consent of the other Party to any Affiliate of the assigning Party with an equal or greater credit rating and with the legal authority and operational ability to satisfy the obligations of the assigning Party under this LGIA; and provided further that Interconnection Customer shall have the right to assign this LGIA, without the consent of Transmission Provider, for collateral security purposes to aid in providing financing for the Large Generating Facility, provided that Interconnection Customer will promptly notify Transmission Provider of any such assignment. Any financing arrangement entered into by Interconnection Customer pursuant to this article will provide that prior to or upon the exercise of the secured party's, trustee's or mortgagee's assignment rights pursuant to said arrangement, the secured creditor, the trustee or mortgagee will notify Transmission Provider of the date and particulars of any such exercise of assignment right(s), including providing Transmission Provider with proof that it meets the requirements of Articles 11.5 and 18.3. Any attempted assignment that violates this article is void and ineffective. Any assignment under this LGIA shall not relieve a Party of its obligations, nor shall a Party's obligations be enlarged, in whole or in part, by reason thereof. Where required, consent to assignment will not be unreasonably withheld, conditioned or delayed.

Article 20. Severability

- 20.1 Severability. If any provision in this LGIA is finally determined to be invalid, void or unenforceable by any court or other Governmental Authority having jurisdiction, such determination shall not invalidate, void or make unenforceable any other provision, agreement or covenant of this LGIA; provided that if Interconnection Customer (or any third party, but only if such third party is not acting at the direction of Transmission Provider) seeks and obtains such a final determination with respect to any provision of the Alternate Option (Article 5.1.2), or the Negotiated Option (Article 5.1.4), then none of these provisions shall thereafter have any force or effect and the Parties' rights and obligations shall be governed solely by the Standard Option (Article 5.1.1).

Article 21. Comparability

21.1 Comparability. The Parties will comply with all applicable comparability and code of conduct laws, rules and regulations, as amended from time to time.

Article 22. Confidentiality

22.1 Confidentiality. Confidential Information shall include, without limitation, all information relating to a Party's technology, research and development, business affairs, and pricing, and any information supplied by either of the Parties to the other prior to the execution of this LGIA.

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document, or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential.

If requested by either Party, the other Party shall provide in writing, the basis for asserting that the information referred to in this Article 22 warrants confidential treatment, and the requesting Party may disclose such writing to the appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

22.1.1 Term. During the term of this LGIA, and for a period of three (3) years after the expiration or termination of this LGIA, except as otherwise provided in this Article 22, each Party shall hold in confidence and shall not disclose to any person Confidential Information.

22.1.2 Scope. Confidential Information shall not include information that the receiving Party can demonstrate: (1) is generally available to the public other than as a result of a disclosure by the receiving

Party; (2) was in the lawful possession of the receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a third party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party or Breach of this LGIA; or (6) is required, in accordance with Article 22.1.7 of the LGIA, Order of Disclosure, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena, or is necessary in any legal proceeding establishing rights and obligations under this LGIA. Information designated as Confidential Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the other Party that it no longer is confidential.

22.1.3 Release of Confidential Information. Neither Party shall release or disclose Confidential Information to any other person, except to its Affiliates (limited by the Standards of Conduct requirements), subcontractors, employees, consultants, or to parties who may be or considering providing financing to or equity participation with Interconnection Customer, or to potential purchasers or assignees of Interconnection Customer, on a need-to-know basis in connection with this LGIA, unless such person has first been advised of the confidentiality provisions of this Article 22 and has agreed to comply with such provisions. Notwithstanding the foregoing, a Party providing Confidential Information to any person shall remain primarily responsible for any release of Confidential Information in contravention of this Article 22.

22.1.4 Rights. Each Party retains all rights, title, and interest in the Confidential Information that each Party discloses to the other Party. The disclosure by each Party to the other Party of Confidential Information shall not be deemed a waiver by either Party or any other person or entity of the right to protect the Confidential Information from public disclosure.

- 22.1.5 No Warranties. By providing Confidential Information, neither Party makes any warranties or representations as to its accuracy or completeness. In addition, by supplying Confidential Information, neither Party obligates itself to provide any particular information or Confidential Information to the other Party nor to enter into any further agreements or proceed with any other relationship or joint venture.
- 22.1.6 Standard of Care. Each Party shall use at least the same standard of care to protect Confidential Information it receives as it uses to protect its own Confidential Information from unauthorized disclosure, publication or dissemination. Each Party may use Confidential Information solely to fulfill its obligations to the other Party under this LGIA or its regulatory requirements.
- 22.1.7 Order of Disclosure. If a court or a Government Authority or entity with the right, power, and apparent authority to do so requests or requires either Party, by subpoena, oral deposition, interrogatories, requests for production of documents, administrative order, or otherwise, to disclose Confidential Information, that Party shall provide the other Party with prompt notice of such request(s) or requirement(s) so that the other Party may seek an appropriate protective order or waive compliance with the terms of this LGIA. Notwithstanding the absence of a protective order or waiver, the Party may disclose such Confidential Information which, in the opinion of its counsel, the Party is legally compelled to disclose. Each Party will use Reasonable Efforts to obtain reliable assurance that confidential treatment will be accorded any Confidential Information so furnished.
- 22.1.8 Termination of Agreement. Upon termination of this LGIA for any reason, each Party shall, within ten (10) Calendar Days of receipt of a written request from the other Party, use Reasonable Efforts to destroy, erase, or delete (with such destruction, erasure, and deletion certified in writing to the other Party) or return to the other Party,

without retaining copies thereof, any and all written or electronic Confidential Information received from the other Party.

- 22.1.9 Remedies. The Parties agree that monetary damages would be inadequate to compensate a Party for the other Party's Breach of its obligations under this Article 22. Each Party accordingly agrees that the other Party shall be entitled to equitable relief, by way of injunction or otherwise, if the first Party Breaches or threatens to Breach its obligations under this Article 22, which equitable relief shall be granted without bond or proof of damages, and the receiving Party shall not plead in defense that there would be an adequate remedy at law. Such remedy shall not be deemed an exclusive remedy for the Breach of this Article 22, but shall be in addition to all other remedies available at law or in equity. The Parties further acknowledge and agree that the covenants contained herein are necessary for the protection of legitimate business interests and are reasonable in scope. No Party, however, shall be liable for indirect, incidental, or consequential or punitive damages of any nature or kind resulting from or arising in connection with this Article 22.
- 22.1.10 Disclosure to FERC, its Staff, or a State. Notwithstanding anything in this Article 22 to the contrary, and pursuant to 18 CFR section 1b.20, if FERC or its staff, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to this LGIA, the Party shall provide the requested information to FERC or its staff, within the time provided for in the request for information. In providing the information to FERC or its staff, the Party must, consistent with 18 CFR section 388.112, request that the information be treated as confidential and non-public by FERC and its staff and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party to this LGIA prior to the release of the Confidential Information to FERC or its staff. The Party shall notify the other Party to the LGIA when it is notified by FERC or its staff that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR section 388.112. Requests from a state regulatory body

conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

22.1.11 Subject to the exception in Article 22.1.10, any information that a Party claims is competitively sensitive, commercial or financial information under this LGIA (“Confidential Information”) shall not be disclosed by the other Party to any person not employed or retained by the other Party, except to the extent disclosure is (i) required by law; (ii) reasonably deemed by the disclosing Party to be required to be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (iii) otherwise permitted by consent of the other Party, such consent not to be unreasonably withheld; or (iv) necessary to fulfill its obligations under this LGIA or as a transmission service provider or a Balancing Authority Area operator including disclosing the Confidential Information to an RTO or ISO or to a regional or national reliability organization. The Party asserting confidentiality shall notify the other Party in writing of the information it claims is confidential. Prior to any disclosures of the other Party’s Confidential Information under this subparagraph, or if any third party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the disclosing Party agrees to promptly notify the other Party in writing and agrees to assert confidentiality and cooperate with the other Party in seeking to protect the Confidential Information from public disclosure by confidentiality agreement, protective order or other reasonable measures.

Article 23. Environmental Releases

23.1 Each Party shall notify the other Party, first orally and then in writing, of the release of any Hazardous Substances, any asbestos or lead abatement activities, or any type of remediation activities related to the Large Generating Facility or the Interconnection Facilities, each of which may reasonably be expected to affect the other Party. The notifying Party shall: (i) provide the notice as soon as practicable, provided such Party makes a good faith effort to provide the notice no later than twenty-four hours after such Party becomes aware of the occurrence;

and (ii) promptly furnish to the other Party copies of any publicly available reports filed with any Governmental Authorities addressing such events.

Article 24. Information Requirements

- 24.1 **Information Acquisition.** Transmission Provider and Interconnection Customer shall submit specific information regarding the electrical characteristics of their respective facilities to each other as described below and in accordance with Applicable Reliability Standards.
- 24.2 **Information Submission by Transmission Provider.** The initial information submission by Transmission Provider shall occur no later than one hundred eighty (180) Calendar Days prior to Trial Operation and shall include Transmission System information necessary to allow Interconnection Customer to select equipment and meet any system protection and stability requirements, unless otherwise agreed to by the Parties. On a monthly basis Transmission Provider shall provide Interconnection Customer a status report on the construction and installation of Transmission Provider's Interconnection Facilities and Network Upgrades, including, but not limited to, the following information: (1) progress to date; (2) a description of the activities since the last report (3) a description of the action items for the next period; and (4) the delivery status of equipment ordered.
- 24.3 **Updated Information Submission by Interconnection Customer.** The updated information submission by Interconnection Customer, including manufacturer information, shall occur no later than one hundred eighty (180) Calendar Days prior to the Trial Operation. Interconnection Customer shall submit a completed copy of the Large Generating Facility data requirements contained in Appendix 1 to the LGIP. It shall also include any additional information provided to Transmission Provider for the Cluster Study and Facilities Study. Information in this submission shall be the most current Large Generating Facility design or expected performance data. Information submitted for stability models shall be compatible with Transmission Provider standard models. If there is no compatible model, Interconnection Customer will work with a consultant mutually agreed to by the Parties to develop and supply a standard model and associated information.

If Interconnection Customer's data is materially different from what was originally provided to Transmission Provider pursuant to the Interconnection Study Agreement between Transmission Provider and Interconnection Customer, then Transmission Provider will conduct appropriate studies to determine the impact on Transmission Provider Transmission System based on the actual data submitted pursuant to this Article 24.3. Interconnection Customer shall not begin Trial Operation until such studies are completed.

- 24.4 Information Supplementation. Prior to the Operation Date, the Parties shall supplement their information submissions described above in this Article 24 with any and all "as-built" Large Generating Facility information or "as-tested" performance information that differs from the initial submissions or, alternatively, written confirmation that no such differences exist. Interconnection Customer shall conduct tests on the Large Generating Facility as required by Good Utility Practice such as an open circuit "step voltage" test on the Large Generating Facility to verify proper operation of the Large Generating Facility's automatic voltage regulator.

Unless otherwise agreed, the test conditions shall include: (1) Large Generating Facility at synchronous speed; (2) automatic voltage regulator on and in voltage control mode; and (3) a five percent change in Large Generating Facility terminal voltage initiated by a change in the voltage regulators reference voltage. Interconnection Customer shall provide validated test recordings showing the responses of Large Generating Facility terminal and field voltages. In the event that direct recordings of these voltages is impractical, recordings of other voltages or currents that mirror the response of the Large Generating Facility's terminal or field voltage are acceptable if information necessary to translate these alternate quantities to actual Large Generating Facility terminal or field voltages is provided. Large Generating Facility testing shall be conducted and results provided to Transmission Provider for each individual generating unit in a station.

Subsequent to the Operation Date, Interconnection Customer shall provide Transmission Provider any information changes due to equipment replacement, repair, or adjustment. Transmission Provider shall provide Interconnection Customer any information changes due to equipment replacement, repair or adjustment in the directly connected substation or any adjacent Transmission

Provider-owned substation that may affect Interconnection Customer's Interconnection Facilities equipment ratings, protection or operating requirements. The Parties shall provide such information no later than thirty (30) Calendar Days after the date of the equipment replacement, repair or adjustment.

Article 25. Information Access and Audit Rights

- 25.1 **Information Access.** Each Party (the “disclosing Party”) shall make available to the other Party information that is in the possession of the disclosing Party and is necessary in order for the other Party to: (i) verify the costs incurred by the disclosing Party for which the other Party is responsible under this LGIA; and (ii) carry out its obligations and responsibilities under this LGIA. The Parties shall not use such information for purposes other than those set forth in this Article 25.1 and to enforce their rights under this LGIA.
- 25.2 **Reporting of Non-Force Majeure Events.** Each Party (the “notifying Party”) shall notify the other Party when the notifying Party becomes aware of its inability to comply with the provisions of this LGIA for a reason other than a Force Majeure event. The Parties agree to cooperate with each other and provide necessary information regarding such inability to comply, including the date, duration, reason for the inability to comply, and corrective actions taken or planned to be taken with respect to such inability to comply. Notwithstanding the foregoing, notification, cooperation or information provided under this article shall not entitle the Party receiving such notification to allege a cause for anticipatory breach of this LGIA.
- 25.3 **Audit Rights.** Subject to the requirements of confidentiality under Article 22 of this LGIA, each Party shall have the right, during normal business hours, and upon prior reasonable notice to the other Party, to audit at its own expense the other Party's accounts and records pertaining to either Party's performance or either Party's satisfaction of obligations under this LGIA. Such audit rights shall include audits of the other Party's costs, calculation of invoiced amounts, Transmission Provider's efforts to allocate responsibility for the provision of reactive support to the Transmission System, Transmission Provider's efforts to allocate responsibility for interruption or reduction of generation on the

Transmission System, and each Party's actions in an Emergency Condition. Any audit authorized by this article shall be performed at the offices where such accounts and records are maintained and shall be limited to those portions of such accounts and records that relate to each Party's performance and satisfaction of obligations under this LGIA. Each Party shall keep such accounts and records for a period equivalent to the audit rights periods described in Article 25.4.

25.4 Audit Rights Periods.

25.4.1 Audit Rights Period for Construction-Related Accounts and Records. Accounts and records related to the design, engineering, procurement, and construction of Transmission Provider's Interconnection Facilities and Network Upgrades shall be subject to audit for a period of twenty-four months following Transmission Provider's issuance of a final invoice in accordance with Article 12.2.

25.4.2 Audit Rights Period for All Other Accounts and Records. Accounts and records related to either Party's performance or satisfaction of all obligations under this LGIA other than those described in Article 25.4.1 shall be subject to audit as follows: (i) for an audit relating to cost obligations, the applicable audit rights period shall be twenty-four months after the auditing Party's receipt of an invoice giving rise to such cost obligations; and (ii) for an audit relating to all other obligations, the applicable audit rights period shall be twenty-four months after the event for which the audit is sought.

25.5 Audit Results. If an audit by a Party determines that an overpayment or an underpayment has occurred, a notice of such overpayment or underpayment shall be given to the other Party together with those records from the audit which support such determination.

Article 26. Subcontractors

- 26.1 **General.** Nothing in this LGIA shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this LGIA; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this LGIA in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.
- 26.2 **Responsibility of Principal.** The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this LGIA. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under Article 5 of this LGIA. Any applicable obligation imposed by this LGIA upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.
- 26.3 **No Limitation by Insurance.** The obligations under this Article 26 will not be limited in any way by any limitation of subcontractor's insurance.

Article 27. Disputes

- 27.1 **Submission.** In the event either Party has a dispute, or asserts a claim, that arises out of or in connection with this LGIA or its performance, such Party (the "disputing Party") shall provide the other Party with written notice of the dispute or claim ("Notice of Dispute"). Such dispute or claim shall be referred to a designated senior representative of each Party for resolution on an informal basis as promptly as practicable after receipt of the Notice of Dispute by the other Party. In the event the designated representatives are unable to resolve the claim or dispute through unassisted or assisted negotiations within thirty (30) Calendar Days of the other Party's receipt of the Notice of Dispute, such claim or dispute may, upon mutual agreement of the Parties, be submitted to arbitration and resolved in accordance with the arbitration procedures set forth below. In the event the Parties do not agree to submit such claim or dispute to arbitration, each

Party may exercise whatever rights and remedies it may have in equity or at law consistent with the terms of this LGIA.

- 27.2 External Arbitration Procedures. Any arbitration initiated under this LGIA shall be conducted before a single neutral arbitrator appointed by the Parties. If the Parties fail to agree upon a single arbitrator within ten (10) Calendar Days of the submission of the dispute to arbitration, each Party shall choose one arbitrator who shall sit on a three-member arbitration panel. The two arbitrators so chosen shall within twenty (20) Calendar Days select a third arbitrator to chair the arbitration panel. In either case, the arbitrators shall be knowledgeable in electric utility matters, including electric transmission and bulk power issues, and shall not have any current or past substantial business or financial relationships with any party to the arbitration (except prior arbitration). The arbitrator(s) shall provide each of the Parties an opportunity to be heard and, except as otherwise provided herein, shall conduct the arbitration in accordance with the Commercial Arbitration Rules of the American Arbitration Association ("Arbitration Rules") and any applicable FERC regulations or RTO rules; provided, however, in the event of a conflict between the Arbitration Rules and the terms of this Article 27, the terms of this Article 27 shall prevail.
- 27.3 Arbitration Decisions. Unless otherwise agreed by the Parties, the arbitrator(s) shall render a decision within ninety (90) Calendar Days of appointment and shall notify the Parties in writing of such decision and the reasons therefor. The arbitrator(s) shall be authorized only to interpret and apply the provisions of this LGIA and shall have no power to modify or change any provision of this Agreement in any manner. The decision of the arbitrator(s) shall be final and binding upon the Parties, and judgment on the award may be entered in any court having jurisdiction. The decision of the arbitrator(s) may be appealed solely on the grounds that the conduct of the arbitrator(s), or the decision itself, violated the standards set forth in the Federal Arbitration Act or the Administrative Dispute Resolution Act. The final decision of the arbitrator must also be filed with FERC if it affects jurisdictional rates, terms and conditions of service, Interconnection Facilities, or Network Upgrades.
- 27.4 Costs. Each Party shall be responsible for its own costs incurred during the arbitration process and for the following costs, if applicable: (1) the cost of the arbitrator chosen by the Party to sit on the three member panel and one half of the

cost of the third arbitrator chosen; or (2) one half the cost of the single arbitrator jointly chosen by the Parties.

Article 28. Representations, Warranties, and Covenants

28.1 General. Each Party makes the following representations, warranties and covenants:

28.1.1 Good Standing. Such Party is duly organized, validly existing and in good standing under the laws of the state in which it is organized, formed, or incorporated, as applicable; that it is qualified to do business in the state or states in which the Large Generating Facility, Interconnection Facilities and Network Upgrades owned by such Party, as applicable, are located; and that it has the corporate power and authority to own its properties, to carry on its business as now being conducted and to enter into this LGIA and carry out the transactions contemplated hereby and perform and carry out all covenants and obligations on its part to be performed under and pursuant to this LGIA.

28.1.2 Authority. Such Party has the right, power and authority to enter into this LGIA, to become a Party hereto and to perform its obligations hereunder. This LGIA is a legal, valid and binding obligation of such Party, enforceable against such Party in accordance with its terms, except as the enforceability thereof may be limited by applicable bankruptcy, insolvency, reorganization or other similar laws affecting creditors' rights generally and by general equitable principles (regardless of whether enforceability is sought in a proceeding in equity or at law).

28.1.3 No Conflict. The execution, delivery and performance of this LGIA does not violate or conflict with the organizational or formation documents, or bylaws or operating agreement, of such

Party, or any judgment, license, permit, order, material agreement or instrument applicable to or binding upon such Party or any of its assets.

- 28.1.4 Consent and Approval. Such Party has sought or obtained, or, in accordance with this LGIA will seek or obtain, each consent, approval, authorization, order, or acceptance by any Governmental Authority in connection with the execution, delivery and performance of this LGIA, and it will provide to any Governmental Authority notice of any actions under this LGIA that are required by Applicable Laws and Regulations.

Article 29. Joint Operating Committee

- 29.1 Joint Operating Committee. Except in the case of ISOs and RTOs, Transmission Provider shall constitute a Joint Operating Committee to coordinate operating and technical considerations of Interconnection Service. At least six (6) months prior to the expected Initial Synchronization Date, Interconnection Customer and Transmission Provider shall each appoint one representative and one alternate to the Joint Operating Committee. Each Interconnection Customer shall notify Transmission Provider of its appointment in writing. Such appointments may be changed at any time by similar notice. The Joint Operating Committee shall meet as necessary, but not less than once each calendar year, to carry out the duties set forth herein. The Joint Operating Committee shall hold a meeting at the request of either Party, at a time and place agreed upon by the representatives. The Joint Operating Committee shall perform all of its duties consistent with the provisions of this LGIA. Each Party shall cooperate in providing to the Joint Operating Committee all information required in the performance of the Joint Operating Committee's duties. All decisions and agreements, if any, made by the Joint Operating Committee, shall be evidenced in writing. The duties of the Joint Operating Committee shall include the following:

- 29.1.1** Establish data requirements and operating record requirements.

- 29.1.2 Review the requirements, standards, and procedures for data acquisition equipment, protective equipment, and any other equipment or software.
- 29.1.3 Annually review the one (1) year forecast of maintenance and planned outage schedules of Transmission Provider's and Interconnection Customer's facilities at the Point of Interconnection.
- 29.1.4 Coordinate the scheduling of maintenance and planned outages on the Interconnection Facilities, the Large Generating Facility and other facilities that impact the normal operation of the interconnection of the Large Generating Facility to the Transmission System.
- 29.1.5 Ensure that information is being provided by each Party regarding equipment availability.
- 29.1.6 Perform such other duties as may be conferred upon it by mutual agreement of the Parties.

Article 30. Miscellaneous

- 30.1 **Binding Effect.** This LGIA and the rights and obligations hereof, shall be binding upon and shall inure to the benefit of the successors and assigns of the Parties hereto.
- 30.2 **Conflicts.** In the event of a conflict between the body of this LGIA and any attachment, appendices or exhibits hereto, the terms and provisions of the body of this LGIA shall prevail and be deemed the final intent of the Parties.
- 30.3 **Rules of Interpretation.** This LGIA, unless a clear contrary intention appears, shall be construed and interpreted as follows: (1) the singular number includes

the plural number and vice versa; (2) reference to any person includes such person's successors and assigns but, in the case of a Party, only if such successors and assigns are permitted by this LGIA, and reference to a person in a particular capacity excludes such person in any other capacity or individually; (3) reference to any agreement (including this LGIA), document, instrument or tariff means such agreement, document, instrument, or tariff as amended or modified and in effect from time to time in accordance with the terms thereof and, if applicable, the terms hereof; (4) reference to any Applicable Laws and Regulations means such Applicable Laws and Regulations as amended, modified, codified, or reenacted, in whole or in part, and in effect from time to time, including, if applicable, rules and regulations promulgated thereunder; (5) unless expressly stated otherwise, reference to any Article, Section or Appendix means such Article of this LGIA or such Appendix to this LGIA, or such Section to the LGIP or such Appendix to the LGIP, as the case may be; (6) "hereunder", "hereof", "herein", "hereto" and words of similar import shall be deemed references to this LGIA as a whole and not to any particular Article or other provision hereof or thereof; (7) "including" (and with correlative meaning "include") means including without limiting the generality of any description preceding such term; and (8) relative to the determination of any period of time, "from" means "from and including," "to" means "to but excluding" and "through" means "through and including."

- 30.4 Entire Agreement.** This LGIA, including all Appendices and Schedules attached hereto, constitutes the entire agreement between the Parties with reference to the subject matter hereof, and supersedes all prior and contemporaneous understandings or agreements, oral or written, between the Parties with respect to the subject matter of this LGIA. There are no other agreements, representations, warranties, or covenants which constitute any part of the consideration for, or any condition to, either Party's compliance with its obligations under this LGIA.
- 30.5 No Third Party Beneficiaries.** This LGIA is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and, where permitted, their assigns.

- 30.6 Waiver. The failure of a Party to this LGIA to insist, on any occasion, upon strict performance of any provision of this LGIA will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

Any waiver at any time by either Party of its rights with respect to this LGIA shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this LGIA. Termination or Default of this LGIA for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this LGIA shall, if requested, be provided in writing.

- 30.7 Headings. The descriptive headings of the various Articles of this LGIA have been inserted for convenience of reference only and are of no significance in the interpretation or construction of this LGIA.
- 30.8 Multiple Counterparts. This LGIA may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.
- 30.9 Amendment. The Parties may by mutual agreement amend this LGIA by a written instrument duly executed by the Parties.
- 30.10 Modification by the Parties. The Parties may by mutual agreement amend the Appendices to this LGIA by a written instrument duly executed by the Parties. Such amendment shall become effective and a part of this LGIA upon satisfaction of all Applicable Laws and Regulations.
- 30.11 Reservation of Rights. Transmission Provider shall have the right to make a unilateral filing with FERC to modify this LGIA with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this LGIA pursuant to section 206 or any other applicable provision of the Federal Power Act and FERC's rules and

regulations thereunder; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this LGIA shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations thereunder, except to the extent that the Parties otherwise mutually agree as provided herein.

- 30.12 No Partnership. This LGIA shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power, or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

IN WITNESS WHEREOF, the Parties have executed this LGIA in duplicate originals, each of which shall constitute and be an original effective Agreement between the Parties.

{Insert name of Transmission Provider or Transmission Owner, if applicable}

By: _____ By:

Title: _____ Title:

Date: _____ Date:

{Insert name of Interconnection Customer}

By: _____

Title: _____

Date: _____

Appendix A to LGIA
Interconnection Facilities, Network Upgrades and Distribution Upgrades

1. Interconnection Facilities:

(a) {insert Interconnection Customer's Interconnection Facilities}:

(b) {insert Transmission Provider's Interconnection Facilities}:

2. Network Upgrades:

(a) {insert Stand Alone Network Upgrades}:

(b) {insert Substation Network Upgrades}:

(c) {insert System Network Upgrades}:

3. Distribution Upgrades:

Appendix B to LGIA

Milestones

Site Control

Check box if applicable { }

Interconnection Customer with qualifying regulatory limitations must demonstrate 100% Site Control by {Transmission Provider to insert date one hundred eighty (180) Calendar Days from the effective date of this LGIA} or the LGIA may be terminated per Article 17 (Default) of this LGIA and Interconnection Customer may be subject to Withdrawal Penalties per Section 3.7.1.1 of Transmission Provider's LGIP (Calculation of the Withdrawal Penalty).

Appendix C to LGIA

Interconnection Details

Appendix D to LGIA

Security Arrangements Details

Infrastructure security of Transmission System equipment and operations and control hardware and software is essential to ensure day-to-day Transmission System reliability and operational security. FERC will expect all Transmission Providers, market participants, and Interconnection Customers interconnected to the Transmission System to comply with the recommendations offered by the President's Critical Infrastructure Protection Board and, eventually, best practice recommendations from the electric reliability authority. All public utilities will be expected to meet basic standards for system infrastructure and operational security, including physical, operational, and cyber-security practices.

**Appendix E to LGIA
Commercial Operation Date**

This Appendix E is a part of the LGIA between Transmission Provider and Interconnection Customer.

{Date}

{Transmission Provider Address}

Re: _____ Large Generating Facility

Dear _____:

On **{Date}** **{Interconnection Customer}** has completed Trial Operation of Unit No. _____. This letter confirms that **{Interconnection Customer}** commenced Commercial Operation of Unit No. ____ at the Large Generating Facility, effective as of **{Date plus one day}**.

Thank you.

{Signature}

{Interconnection Customer Representative}

Appendix F to LGIA
Addresses for Delivery of Notices and Billings

Notices:

Transmission Provider:

{To be supplied.}

Interconnection Customer:

{To be supplied.}

Billings and Payments:

Transmission Provider:

{To be supplied.}

Interconnection Customer:

{To be supplied.}

Alternative Forms of Delivery of Notices (telephone, facsimile or email):

Transmission Provider:

{To be supplied.}

Interconnection Customer:

{To be supplied.}

APPENDIX G

INTERCONNECTION REQUIREMENTS FOR A WIND GENERATING PLANT

Appendix G sets forth requirements and provisions specific to a wind generating plant or a Generating Facility that contains a wind generating plant. All other requirements of this LGIA continue to apply to wind generating plant interconnections.

A. Technical Standards Applicable to a Wind Generating Plant

i. Low Voltage Ride-Through (LVRT) Capability

A wind generating plant shall be able to remain online during voltage disturbances up to the time periods and associated voltage levels set forth in the standard below. The LVRT standard provides for a transition period standard and a post-transition period standard.

Transition Period LVRT Standard

The transition period standard applies to wind generating plants subject to FERC Order 661 that have either: (i) interconnection agreements signed and filed with the Commission, filed with the Commission in unexecuted form, or filed with the Commission as non-conforming agreements between January 1, 2006 and December 31, 2006, with a scheduled in-service date no later than December 31, 2007, or (ii) wind generating turbines subject to a wind turbine procurement contract executed prior to

December 31, 2005, for delivery through 2007.

1. Wind generating plants are required to remain in-service during three-phase faults with normal clearing (which is a time period of approximately 4 – 9 cycles) and single line to ground faults with delayed clearing, and subsequent post-fault voltage recovery to pre-fault voltage unless clearing the fault effectively disconnects the generator from the system. The clearing time requirement for a three-phase fault will be specific to the wind generating plant substation location, as determined by and documented by transmission provider. The maximum clearing time the wind generating plant shall be required to withstand for a three-phase fault shall be 9 cycles at a voltage as low as 0.15 p.u., as measured at the high side of the wind generating plant step-up transformer (i.e. the transformer that steps the voltage up to the transmission interconnection voltage or “GSU”), after which, if the fault remains following the location-specific normal clearing time for three-phase faults, the wind generating plant may disconnect from the transmission system.
2. This requirement does not apply to faults that would occur between the wind generator terminals and the high side of the GSU or to faults that would result in a voltage lower than 0.15 per unit on the high side of the GSU serving the facility.
3. Wind generating plants may be tripped after the fault period if this action is intended as part of a special protection system.
4. Wind generating plants may meet the LVRT requirements of this standard by the

performance of the generators or by installing additional equipment (e.g., Static VAr Compensator, etc.) within the wind generating plant or by a combination of generator performance and additional equipment.

5. Existing individual generator units that are, or have been, interconnected to the network at the same location at the effective date of the Appendix G LVRT Standard are exempt from meeting the Appendix G LVRT Standard for the remaining life of the existing generation equipment. Existing individual generator units that are replaced are required to meet the Appendix G LVRT Standard.

Post-transition Period LVRT Standard

All wind generating plants subject to FERC Order No. 661 and not covered by the transition period described above must meet the following requirements:

1. Wind generating plants are required to remain in-service during three-phase faults with normal clearing (which is a time period of approximately 4 – 9 cycles) and single line to ground faults with delayed clearing, and subsequent post-fault voltage recovery to prefault voltage unless clearing the fault effectively disconnects the generator from the system. The clearing time requirement for a three-phase fault will be specific to the wind generating plant substation location, as determined by and documented by transmission provider. The maximum clearing time the wind generating plant shall be required to withstand for a three-phase fault shall be 9 cycles after which, if the fault remains following the location-specific normal clearing time for three-phase faults, the wind generating plant may disconnect from the transmission system. A wind generating plant shall remain interconnected during

Record Content Description, Tariff Record Title, Record Version Number, Option Code:

OATT Attachment O, ATTACHMENT O Standard Small Generator Int. Procedures, 4.0.0, A

Record Narrative Name:

Tariff Record ID: 63

Tariff Record Collation Value: 63005 Tariff Record Parent Identifier: 0

Proposed Date: 2024-05-17

Priority Order: 501

Record Change Type: CHANGE

Record Content Type: 1

Associated Filing Identifier:

ATTACHMENT O

Small Generator Interconnection Procedures (SGIP)

SMALL GENERATOR INTERCONNECTION PROCEDURES (SGIP)

(For Generating Facilities No Larger Than 20 MW)

TABLE OF CONTENTS

	Page No.
<u>Section 1. Application.....</u>	<u>1</u>
1.1 Applicability.....	1
1.2 Pre-Application	2
1.3 Interconnection Request	5
1.4 Modification of the Interconnection Request	6
1.5 Site Control	6
1.6 Queue Position	6
1.7 Interconnection Requests Submitted Prior to the Effective Date of the SGIP	7
<u>Section 2. Fast Track Process</u>	<u>7</u>
2.1 Applicability.....	7
2.2 Initial Review	8
2.3 Customer Options Meeting.....	12
2.4 Supplemental Review	12

Section 3. Study Process..... 17

3.1 Applicability..... 17

3.2 Scoping Meeting 17

3.3 Feasibility Study..... 18

3.4 System Impact Study 19

3.5 Facilities Study..... 21

Section 4. Provisions that Apply to All Interconnection Requests 22

4.1 Reasonable Efforts 22

4.2 Disputes 22

4.3 Interconnection Metering..... 23

4.4 Commissioning..... 23

4.5 Confidentiality..... 23

4.6 Comparability..... 24

4.7 Record Retention..... 25

4.8 Interconnection Agreement..... 25

4.9 Coordination with Affected Systems 25

4.10 Capacity of the Small Generating Facility 25

Attachment 1 – Glossary of Terms

Attachment 2 – Small Generator Interconnection Request

Attachment 3 – Certification Codes and Standards

Attachment 4 – Certification of Small Generator Equipment Packages

Attachment 5 – Application, Procedures, and Terms and Conditions for Interconnecting a Certified Inverter-Based Small Generating Facility No Larger than 10 kW (“10 kW Inverter Process”).

Attachment 6 – Feasibility Study Agreement

Attachment 7 – System Impact Study Agreement

Attachment 8 – Facilities Study Agreement

Section 1. Application

1.1 Applicability

- 1.1.1 A request to interconnect a certified Small Generating Facility (See Attachments 3 and 4 for description of certification criteria) to Transmission Provider's Distribution System shall be evaluated under the section 2 Fast Track Process if the eligibility requirements of section 2.1 are met. A request to interconnect a certified inverter-based Small Generating Facility no larger than 10 kilowatts (kW) shall be evaluated under the Attachment 5 10 kW Inverter Process. A request to interconnect a Small Generating Facility no larger than 20 megawatts (MW) that does not meet the eligibility requirements of section 2.1, or does not pass the Fast Track Process or the 10 kW Inverter Process, shall be evaluated under the section 3 Study Process. If Interconnection Customer wishes to interconnect its Small Generating Facility using Network Resource Interconnection Service, it must do so under the Standard Large Generator Interconnection Procedures and execute the Standard Large Generator Interconnection Agreement.
- 1.1.2 Capitalized terms used herein shall have the meanings specified in the Glossary of Terms in Attachment 1 or the body of these procedures.
- 1.1.3 Neither these procedures nor the requirements included hereunder apply to Small Generating Facilities interconnected or approved for interconnection prior to sixty (60) Business Days after the effective date of these procedures.
- 1.1.4 Prior to submitting its Interconnection Request (Attachment 2), Interconnection Customer may ask Transmission Provider's interconnection contact employee or office whether the proposed interconnection is subject to these procedures. Transmission Provider shall respond within fifteen (15) Business Days.
- 1.1.5 Infrastructure security of electric system equipment and operations and control hardware and software is essential to ensure day-to-day reliability and operational security. The Federal Energy Regulatory Commission

expects all Transmission Providers, market participants, and Interconnection Customers interconnected with electric systems to comply with the recommendations offered by the President's Critical Infrastructure Protection Board and best practice recommendations from the electric reliability authority. All public utilities are expected to meet basic standards for electric system infrastructure and operational security, including physical, operational, and cyber-security practices.

- 1.1.6 References in these procedures to interconnection agreement are to the Small Generator Interconnection Agreement (SGIA).

1.2 Pre-Application

- 1.2.1 Transmission Provider shall designate an employee or office from which information on the application process and on an Affected System can be obtained through informal requests from Interconnection Customer presenting a proposed project for a specific site. The name, telephone number, and e-mail address of such contact employee or office shall be made available on Transmission Provider's Internet web site. Electric system information provided to Interconnection Customer should include relevant system studies, interconnection studies, and other materials useful to an understanding of an interconnection at a particular point on Transmission Provider's Transmission System, to the extent such provision does not violate confidentiality provisions of prior agreements or critical infrastructure requirements. Transmission Provider shall comply with reasonable requests for such information.
- 1.2.2 In addition to the information described in section 1.2.1, which may be provided in response to an informal request, an Interconnection Customer may submit a formal written request form along with a non-refundable fee of \$300 for a pre-application report on a proposed project at a specific site. Transmission Provider shall provide the pre-application data described in section 1.2.3 to Interconnection Customer within twenty (20) Business Days of receipt of the completed request form and payment of the \$300 fee. The pre-application report produced by Transmission Provider is non-binding, does not confer any rights, and Interconnection Customer

must still successfully apply to interconnect to Transmission Provider's system. The written pre-application report request form shall include the information in sections 1.2.2.1 through 1.2.2.8 below to clearly and sufficiently identify the location of the proposed Point of Interconnection.

- 1.2.2.1 Project contact information, including name, address, phone number, and email address.
 - 1.2.2.2 Project location (street address with nearby cross streets and town)
 - 1.2.2.3 Meter number, pole number, or other equivalent information identifying proposed Point of Interconnection, if available.
 - 1.2.2.4 Generator Type (e.g., solar, wind, combined heat and power, etc.)
 - 1.2.2.5 Size (alternating current kW)
 - 1.2.2.6 Single or three phase generator configuration
 - 1.2.2.7 Stand-alone generator (no onsite load, not including station service – Yes or No?)
 - 1.2.2.8 Is new service requested? Yes or No? If there is existing service, include the customer account number, site minimum and maximum current or proposed electric loads in kW (if available) and specify if the load is expected to change.
- 1.2.3. Using the information provided in the pre-application report request form in section 1.2.2, Transmission Provider will identify the substation/area bus, bank or circuit likely to serve the proposed Point of Interconnection. This selection by Transmission Provider does not necessarily indicate, after application of the screens and/or study, that this would be the circuit the project ultimately connects to. Interconnection Customer must request additional pre-application reports if information about multiple Points of Interconnection is requested. Subject to section 1.2.4, the pre-application report will include the following information:
- 1.2.3.1 Total capacity (in MW) of substation/area bus, bank or circuit based on normal or operating ratings likely to serve the proposed Point of Interconnection.

- 1.2.3.2 Existing aggregate generation capacity (in MW) interconnected to a substation/area bus, bank or circuit (i.e., amount of generation online) likely to serve the proposed Point of Interconnection.
- 1.2.3.3 Aggregate queued generation capacity (in MW) for a substation/area bus, bank or circuit (i.e., amount of generation in the queue) likely to serve the proposed Point of Interconnection.
- 1.2.3.4 Available capacity (in MW) of substation/area bus or bank and circuit likely to serve the proposed Point of Interconnection (i.e., total capacity less the sum of existing aggregate generation capacity and aggregate queued generation capacity).
- 1.2.3.5 Substation nominal distribution voltage and/or transmission nominal voltage if applicable.
- 1.2.3.6 Nominal distribution circuit voltage at the proposed Point of Interconnection.
- 1.2.3.7 Approximate circuit distance between the proposed Point of Interconnection and the substation.
- 1.2.3.8 Relevant line section(s) actual or estimated peak load and minimum load data, including daytime minimum load as described in section 2.4.4.1.1 below and absolute minimum load, when available.
- 1.2.3.9 Number and rating of protective devices and number and type (standard, bi-directional) of voltage regulating devices between the proposed Point of Interconnection and the substation/area. Identify whether the substation has a load tap changer.
- 1.2.3.10 Number of phases available at the proposed Point of Interconnection. If a single phase, distance from the three-phase circuit.
- 1.2.3.11 Limiting conductor ratings from the proposed Point of Interconnection to the distribution substation.

- 1.2.3.12 Whether the Point of Interconnection is located on a spot network, grid network, or radial supply.
- 1.2.3.13 Based on the proposed Point of Interconnection, existing or known constraints such as, but not limited to, electrical dependencies at that location, short circuit interrupting capacity issues, power quality or stability issues on the circuit, capacity constraints, or secondary networks.
- 1.2.4 The pre-application report need only include existing data. A pre-application report request does not obligate Transmission Provider to conduct a study or other analysis of the proposed generator in the event that data is not readily available. If Transmission Provider cannot complete all or some of a pre-application report due to lack of available data, the Transmission Provider shall provide Interconnection Customer with a pre-application report that includes the data that is available. The provision
- Of information on “available capacity” pursuant to section 1.2.3.4 does not imply that an interconnection up to this level may be completed without impacts since there are many variables studied as part of the interconnection review process, and data provided in the pre-application report may become outdated at the time of the submission of the complete Interconnection Request. Notwithstanding any of the provisions of this section, Transmission Provider shall, in good faith, include data in the pre-application report that represents the best available information at the time of reporting.

1.3 Interconnection Request

Interconnection Customer shall submit its Interconnection Request to Transmission Provider, together with the processing fee or deposit specified in the Interconnection Request. The Interconnection Request shall be date- and time-stamped upon receipt. The original date- and time-stamp applied to the Interconnection Request at the time of its original submission shall be accepted as the qualifying date- and time-stamp for the purposes of any timetable in these procedures. Interconnection Customer shall be notified of receipt by Transmission Provider within three (3) Business Days of receiving the Interconnection Request. Transmission Provider shall notify Interconnection Customer within ten (10) Business Days of the receipt of

the Interconnection Request as to whether the Interconnection Request is complete or incomplete. If the Interconnection Request is incomplete, Transmission Provider shall provide along with the notice that the Interconnection Request is incomplete, a written list detailing all information that must be provided to complete the Interconnection Request. Interconnection Customer will have ten (10) Business Days after receipt of the notice to submit the listed information or to request an extension of time to provide such information. If Interconnection Customer does not provide the listed information or a request for an extension of time within the deadline, the Interconnection Request will be deemed withdrawn. An Interconnection Request will be deemed complete upon submission of the listed information to Transmission Provider.

1.4 Modification of the Interconnection Request

Any modification to machine data or equipment configuration or to the interconnection site of the Small Generating Facility not agreed to in writing by Transmission Provider and Interconnection Customer may be deemed a withdrawal of the Interconnection Request and may require submission of a new Interconnection Request, unless proper notification of each Party by the other and a reasonable time to cure the problems created by the changes are undertaken. Any such modification of the Interconnection Request must be accompanied by any resulting updates to the models described in Attachment 2 of this SGIP.

1.5 Site Control

Documentation of site control must be submitted with the Interconnection Request. Site control may be demonstrated through:

- 1.5.1 Ownership of, a leasehold interest in, or a right to develop a site for the purpose of constructing the Small Generating Facility;
- 1.5.2 An option to purchase or acquire a leasehold site for such purpose; or
- 1.5.3 An exclusivity or other business relationship between Interconnection Customer and the entity having the right to sell, lease, or grant Interconnection Customer the right to possess or occupy a site for such purpose.

1.6 Queue Position

Transmission Provider shall assign a Queue Position based upon the date- and time-stamp of the Interconnection Request. The Queue Position of each Interconnection Request will be used to determine the cost responsibility for the Upgrades necessary to accommodate the interconnection. Transmission Provider shall maintain a single queue per geographic region. At Transmission Provider's option, Interconnection Requests may be studied serially or in clusters for the purpose of the system impact study.

1.7 Interconnection Requests Submitted Prior to the Effective Date of the SGIP

Nothing in this SGIP affects an Interconnection Customer's Queue Position assigned before the effective date of this SGIP. The Parties agree to complete work on any interconnection study agreement executed prior the effective date of this SGIP in accordance with the terms and conditions of that interconnection study agreement. Any new studies or other additional work will be completed pursuant to this SGIP.

Section 2. Fast Track Process

2.1 Applicability

The Fast Track Process is available to an Interconnection Customer proposing to interconnect its Small Generating Facility with Transmission Provider's Distribution System if the Small Generating Facility's capacity does not exceed the size limits identified in the table below. Small Generating Facilities below these limits are eligible for Fast Track review. However, Fast Track eligibility is distinct from the Fast Track Process itself, and eligibility does not imply or indicate that a Small Generating Facility will pass the Fast Track screens in section 2.2.1 below or the Supplemental Review screens in section 2.4.4 below.

Fast Track eligibility is determined based upon the generator type, the size of the generator, voltage of the line and the location of and the type of line at the Point of Interconnection. All Small Generating Facilities connecting to lines greater than 69 kilovolt (kV) are ineligible for the Fast Track Process regardless of size. All synchronous and induction machines must be no larger than 2 MW to be eligible for the Fast Track Process, regardless of location. For certified inverter-based systems, the size limit varies according to the voltage of the line at the proposed Point of Interconnection. Certified inverter-based Small Generating Facilities

located within 2.5 electrical circuit miles of a substation and on a mainline (as defined in the table below) are eligible for the Fast Track Process under the higher thresholds according to the table below. In addition to the size threshold, Interconnection Customer's proposed Small Generating Facility must meet the codes, standards, and certification requirements of Attachments 3 and 4 of these procedures, or Transmission Provider has to have reviewed the design or tested the proposed Small Generating Facility and is satisfied that it is safe to operate.

Fast Track Eligibility for Inverter-Based Systems		
Line Voltage	Fast Track Eligibility Regardless of Location	Fast Track Eligibility on a Mainline and ≤ 2.5 Electrical Circuit Miles from Substation
< 5 kV	≤ 500 kW	≤ 500 kW
≥ 5 kV and < 15 kV	≤ 2 MW	≤ 3 MW
≥ 15 kV and < 30 kV	≤ 3 MW	≤ 4 MW
≥ 30 kV and ≤ 69 kV	≤ 4 MW	≤ 5 MW

2.2 Initial Review

Within fifteen (15) Business Days after Transmission Provider notifies Interconnection Customer it has received a complete Interconnection Request, Transmission Provider shall perform an initial review using the screens set forth below, shall notify Interconnection Customer of the results, and include with the notification copies of the analysis and data underlying Transmission Provider's determinations under the screens.

2.2.1 Screens

2.2.1.1 The proposed Small Generating Facility's Point of Interconnection must be on a portion of Transmission Provider's Distribution System that is subject to the Tariff.

- 2.2.1.2 For interconnection of a proposed Small Generating Facility to a radial distribution circuit, the aggregated generation, including the proposed Small Generating Facility, on the circuit shall not exceed 15 % of the line section annual peak load as most recently measured at the substation. A line section is that portion of a Transmission Provider's electric system connected to a customer bounded by automatic sectionalizing devices or the end of the distribution line.
- 2.2.1.3 For interconnection of a proposed Small Generating Facility to the load side of spot network protectors, the proposed Small Generating Facility must utilize an inverter-based equipment package and, together with the aggregated other inverter-based generation, shall not exceed the smaller of 5 % of a spot network's maximum load or 50 kW.
- 2.2.1.4 The proposed Small Generating Facility, in aggregation with other generation on the distribution circuit, shall not contribute more than 10 % to the distribution circuit's maximum fault current at the point on the high voltage (primary) level nearest the proposed point of change of ownership.
- 2.2.1.5 The proposed Small Generating Facility, in aggregate with other generation on the distribution circuit, shall not cause any distribution protective devices and equipment (including, but not limited to, substation breakers, fuse cutouts, and line reclosers), or Interconnection Customer equipment on the system to exceed 87.5 % of the short circuit interrupting capability; nor shall the interconnection be proposed for a circuit that already exceeds 87.5 % of the short circuit interrupting capability.
- 2.2.1.6 Using the table below, determine the type of interconnection to a primary distribution line. This screen includes a review of the type of electrical service provided to the Interconnecting Customer, including line configuration and the transformer connection to limit the potential for creating over-voltages on Transmission Provider's electric power

system due to a loss of ground during the operating time of any anti-islanding function.

Primary Distribution Line Type	Type of Interconnection to Primary Distribution Line	Result/Criteria
Three-phase, three wire	3-phase or single phase, phase-to-phase	Pass screen
Three-phase, four wire	Effectively-grounded 3 phase or Single-phase, line-to-neutral	Pass screen

- 2.2.1.7 If the proposed Small Generating Facility is to be interconnected on single-phase shared secondary, the aggregate generation capacity on the shared secondary, including the proposed Small Generating Facility, shall not exceed 20 kW.
- 2.2.1.8 If the proposed Small Generating Facility is single-phase and is to be interconnected on a center tap neutral of a 240 volt service, its addition shall not create an imbalance between the two sides of the 240 volt service of more than 20 % of the nameplate rating of the service transformer.
- 2.2.1.9 The Small Generating Facility, in aggregate with other generation interconnected to the transmission side of a substation transformer feeding the circuit where the Small Generating Facility proposes to interconnect shall not exceed 10 MW in an area where there are known, or posted, transient stability limitations to generating units located in the general electrical vicinity (e.g., three or four transmission busses from the point of interconnection).
- 2.2.1.10 No construction of facilities by Transmission Provider on its own system shall be required to accommodate the Small Generating Facility.

- 2.2.2 If the proposed interconnection passes the screens, the Interconnection Request shall be approved and Transmission Provider will provide Interconnection Customer an executable interconnection agreement within five (5) Business Days after the determination.
- 2.2.3 If the proposed interconnection fails the screens, but Transmission Provider determines that the Small Generating Facility may nevertheless be interconnected consistent with safety, reliability, and power quality standards, Transmission Provider shall provide Interconnection Customer an executable interconnection agreement within five (5) Business Days after the determination.
- 2.2.4 If the proposed interconnection fails the screens, and Transmission Provider does not or cannot determine from the initial review that the Small Generating Facility may nevertheless be interconnected consistent with safety, reliability, and power quality standards unless Interconnection Customer is willing to consider minor modifications or further study, Transmission Provider shall provide Interconnection Customer with the opportunity to attend a customer options meeting.

2.3 Customer Options Meeting

If Transmission Provider determines the Interconnection Request cannot be approved without (1) minor modifications at minimal cost, (2) a supplemental study or other additional studies or actions, or (3) incurring significant cost to address safety, reliability, or power quality problems, Transmission Provider shall notify Interconnection Customer of that determination within five (5) Business Days after the determination and provide copies of all data and analyses underlying its conclusion. Within ten (10) Business Days of Transmission Provider's determination, Transmission Provider shall offer to convene a customer options meeting with Transmission Provider to review possible Interconnection Customer facility modifications or the screen analysis and related results, to determine what further steps are needed to permit the Small Generating Facility to be connected safely and reliably. At the time of notification of Transmission Provider's determination, or at the customer options meeting, Transmission Provider shall:

- 2.3.1 Offer to perform facility modifications or minor modifications to Transmission Provider's electric system (e.g., changing meters, fuses, relay settings) and provide a non-binding good faith estimate of the limited cost to make such modifications to Transmission Provider's electric system. If Interconnection Customer agrees to pay for the modifications to the Transmission Provider's electric system, the Transmission Provider will provide the Interconnection Customer with an executable interconnection agreement within ten (10) Business Days of the customer options meeting; or
- 2.3.2 Offer to perform a supplemental review in accordance with section 2.4 and provide a non-binding good faith estimate of the costs of such review; or
- 2.3.3 Obtain Interconnection Customer's agreement to continue evaluating the Interconnection Request under the section 3 Study Process.

2.4 Supplemental Review

- 2.4.1 To accept the offer of a supplemental review, Interconnection Customer shall agree in writing and submit a deposit for the estimated costs of the supplemental review in the amount of Transmission Provider's good faith estimate of the costs of such review, both within fifteen (15) Business Days of the offer. If the written agreement and deposit have not been received by Transmission Provider within that timeframe, the Interconnection Request shall continue to be evaluated under the section 3 Study Process unless it is withdrawn by Interconnection Customer. __
- 2.4.2 Interconnection Customer may specify the order in which Transmission Provider will complete the screens in section 2.4.4.
- 2.4.3 Interconnection Customer shall be responsible for Transmission Provider's actual costs for conducting the supplemental review. Interconnection Customer must pay any review costs that exceed the deposit within twenty (20) Business Days of receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced costs, Transmission Provider will return such excess within twenty (20) Business Days of the invoice without interest.

2.4.4 Within thirty (30) Business Days following receipt of the deposit for a supplemental review, Transmission Provider shall (1) perform a supplemental review using the screens set forth below; (2) notify in writing Interconnection Customer of the results; and (3) include with the notification copies of the analysis and data underlying Transmission Provider's determinations under the screens. Unless Interconnection Customer provided instructions for how to respond to the failure of any of the supplemental review screens below at the time Interconnection Customer accepted the offer of supplemental review, Transmission Provider shall notify Interconnection Customer following the failure of any of the screens, or if it is unable to perform the screen in section 2.4.4.1, within two (2) Business Days of making such determination to obtain Interconnection Customer's permission to: (1) continue evaluating the proposed interconnection under this section 2.4.4; (2) terminate the supplemental review and continue evaluating the Small Generating Facility under section 3; or (3) terminate the supplemental review upon withdrawal of the Interconnection Request by Interconnection Customer.

2.4.4.1 Minimum Load Screen: Where 12 months of line section minimum load data (including onsite load but not station service load served by the proposed Small Generating Facility) are available, can be calculated, can be estimated from existing data, or determined from a power flow model, the aggregate Generating Facility capacity on the line section is less than 100% of the minimum load for all line sections bounded by automatic sectionalizing devices upstream of the proposed Small Generating Facility. If minimum load data is not available, or cannot be calculated, estimated or determined, Transmission Provider shall include the reason(s) that it is unable to calculate, estimate or determine minimum load in its supplemental review results notification under section 2.4.4.

- 2.4.4.1.1 The type of generation used by the proposed Small Generating Facility will be taken into account when calculating, estimating, or determining circuit or line section minimum load relevant for the application of screen 2.4.4.1. Solar photovoltaic (PV) generation systems with no battery storage use daytime minimum load (i.e. 10 a.m. to 4 p.m. for fixed panel systems and 8 a.m. to 6 p.m. for PV_ systems utilizing tracking systems), while all other generation uses absolute minimum load.
- 2.4. 4.1.2 When this screen is being applied to a Small Generating Facility that serves some station service load, only the net injection into Transmission Provider's electric system will be considered as part of the aggregate generation.
- 2.4. 4.1.3 Transmission Provider will not consider as part of the aggregate generation for purposes of this screen generating facility capacity known to be already reflected in the minimum load data.
- 2.4.4.2 Voltage and Power Quality Screen: In aggregate with existing generation on the line section: (1) the voltage regulation on the line section can be maintained in compliance with relevant requirements under all system conditions; (2) the voltage fluctuation is within acceptable limits as defined by Institute of Electrical and Electronics Engineers (IEEE) Standard 1453, or utility practice similar to IEEE Standard 1453; and (3) the harmonic levels meet IEEE Standard 519 limits.
- 2.4.4.3 Safety and Reliability Screen: The location of the proposed Small Generating Facility and the aggregate generation capacity on the line section do not create impacts to safety or reliability that cannot be adequately addressed without application of the Study Process. Transmission Provider shall give due consideration to the following and other factors

in determining potential impacts to safety and reliability in applying this screen.

- 2.4.4.3.1 Whether the line section has significant minimum loading levels dominated by a small number of customers (e.g., several large commercial customers).
- 2.4.4.3.2 Whether the loading along the line section is uniform or even.
- 2.4.4.3.3 Whether the proposed Small Generating Facility is located in close proximity to the substation (i.e., less than 2.5 electrical circuit miles), and whether the line section from the substation to the Point of Interconnection is a Mainline rated for normal and emergency ampacity.
- 2.4.4.3.4 Whether the proposed Small Generating Facility incorporates a time delay function to prevent reconnection of the generator to the system until system voltage and frequency are within normal limits for a prescribed time.
- 2.4.4.3.5 Whether operational flexibility is reduced by the proposed Small Generating Facility, such that transfer of the line section(s) of the Small Generating Facility to a neighboring distribution circuit/substation may trigger overloads or voltage issues.
- 2.4.4.3.6 Whether the proposed Small Generating Facility employs equipment or systems certified by a recognized standards organization to address technical issues such as, but not limited to, islanding, reverse power flow, or voltage quality.

2.4.5 If the proposed interconnection passes the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above, the Interconnection Request shall be

approved and Transmission Provider will provide Interconnection Customer with an executable interconnection agreement within the timeframes established in sections 2.4.5.1 and 2.4.5.2 below. If the proposed interconnection fails any of the supplemental review screens and Interconnection Customer does not withdraw its Interconnection Request, it shall continue to be evaluated under the section 3 Study Process consistent with section 2.4.5.3 below.

- 2.4.5.1 If the proposed interconnection passes the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above and does not require construction of facilities by Transmission Provider on its own system, the interconnection agreement shall be provided within ten (10) Business Days after the notification of the supplemental review results.
- 2.4.5.2 If interconnection facilities or minor modifications to Transmission Provider's system are required for the proposed interconnection to pass the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above, and Interconnection Customer agrees to pay for the modifications to Transmission Provider's electric system, the interconnection agreement, along with a non-binding good faith estimate for the interconnection facilities and/or minor modifications, shall be provided to Interconnection Customer within fifteen (15) Business Days after receiving written notification of the supplemental review results.
- 2.4.5.3 If the proposed interconnection would require more than interconnection facilities or minor modifications to Transmission Provider's system to pass the supplemental screens in sections 2.4.4.1, 2.4.4.2, and 2.4.4.3 above, Transmission Provider shall notify Interconnection Customer, at the same time it notifies Interconnection Customer with the supplemental review results, that the Interconnection Request shall be evaluated under the section 3 Study Process unless Interconnection Customer withdraws its Small Generating Facility.

Section 3. Study Process

3.1 Applicability

The Study Process shall be used by an Interconnection Customer proposing to interconnect its Small Generating Facility with Transmission Provider's Transmission System or Distribution System if the Small Generating Facility (1) is larger than 2 MW but no larger than 20 MW, (2) is not certified, or (3) is certified but did not pass the Fast Track Process or the 10 kW Inverter Process.

3.2 Scoping Meeting

- 3.2.1 A scoping meeting will be held within ten (10) Business Days after the Interconnection Request is deemed complete, or as otherwise mutually agreed to by the Parties. Transmission Provider and Interconnection Customer will bring to the meeting personnel, including system engineers and other resources as may be reasonably required to accomplish the purpose of the meeting.
- 3.2.2 The purpose of the scoping meeting is to discuss the Interconnection Request and review existing studies relevant to the Interconnection Request. The Parties shall further discuss whether Transmission Provider should perform a feasibility study or proceed directly to a system impact study, or a facilities study, or an interconnection agreement. If the Parties agree that a feasibility study should be performed, Transmission Provider shall provide Interconnection Customer, as soon as possible, but not later than five (5) Business Days after the scoping meeting, a feasibility study agreement (Attachment 6) including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study.
- 3.2.3 The scoping meeting may be omitted by mutual agreement. In order to remain in consideration for interconnection, an Interconnection Customer who has requested a feasibility study must return the executed feasibility study agreement within fifteen (15) Business Days. If the Parties agree not to perform a feasibility study, Transmission Provider shall provide Interconnection Customer, no later than five (5) Business Days after the scoping meeting, a system impact study agreement (Attachment 7) including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study.

3.3 Feasibility Study

- 3.3.1 The feasibility study shall identify any potential adverse system impacts that would result from the interconnection of the Small Generating Facility.
- 3.3.2 A deposit of the lesser of 50 percent of the good faith estimated feasibility study costs or earnest money of \$1,000 may be required from Interconnection Customer.
- 3.3.3 The scope of and cost responsibilities for the feasibility study are described in the attached feasibility study agreement (Attachment 6).
- 3.3.4 If the feasibility study shows no potential for adverse system impacts, Transmission Provider shall send Interconnection Customer a facilities study agreement, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study. If no additional facilities are required, Transmission Provider shall send Interconnection Customer an executable interconnection agreement within five (5) Business Days.
- 3.3.5 If the feasibility study shows the potential for adverse system impacts, the review process shall proceed to the appropriate system impact study(s).
- 3.3.6 The feasibility study shall evaluate static synchronous compensators, static VAR compensators, advanced power flow control devices, transmission switching, synchronous condensers, voltage source converters, advanced conductors, and tower lifting. Transmission Provider shall evaluate each identified alternative transmission technology and determine whether it should be used, consistent with Good Utility Practice, Applicable Reliability Standards, and Applicable Laws and Regulations. Transmission Provider shall include an explanation of the results of Transmission Provider's evaluation for each technology in the feasibility study report.

3.4 System Impact Study

- 3.4.1 A system impact study shall identify and detail the electric system impacts that would result if the proposed Small Generating Facility were interconnected without project modifications or electric system modifications, focusing on the adverse system impacts identified in the feasibility study, or to study potential impacts, including but not limited to

those identified in the scoping meeting. A system impact study shall evaluate the impact of the proposed interconnection on the reliability of the electric system.

- 3.4.2 If no transmission system impact study is required, but potential electric power Distribution System adverse system impacts are identified in the scoping meeting or shown in the feasibility study, a distribution system impact study must be performed. Transmission Provider shall send Interconnection Customer a distribution system impact study agreement within fifteen (15) Business Days of transmittal of the feasibility study report, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study, or following the scoping meeting if no feasibility study is to be performed.
- 3.4.3 In instances where the feasibility study or the distribution system impact study shows potential for transmission system adverse system impacts, within five (5) Business Days following transmittal of the feasibility study report, Transmission Provider shall send Interconnection Customer a transmission system impact study agreement, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study, if such a study is required.
- 3.4.4 If a transmission system impact study is not required, but electric power Distribution System adverse system impacts are shown by the feasibility study to be possible and no distribution system impact study has been conducted, Transmission Provider shall send Interconnection Customer a distribution system impact study agreement.
- 3.4.5 If the feasibility study shows no potential for transmission system or Distribution System adverse system impacts, Transmission Provider shall send Interconnection Customer either a facilities study agreement (Attachment 8), including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study, or an executable interconnection agreement, as applicable.
- 3.4.6 In order to remain under consideration for interconnection, Interconnection Customer must return executed system impact study agreements, if applicable, within thirty (30) Business Days.

- 3.4.7 A deposit of the good faith estimated costs for each system impact study may be required from Interconnection Customer.
- 3.4.8 The scope of and cost responsibilities for a system impact study are described in the attached system impact study agreement.
- 3.4.9 Where transmission systems and Distribution Systems have separate owners, such as is the case with transmission-dependent utilities (“TDUs”) – whether investor-owned or not – Interconnection Customer may apply to the nearest Transmission Provider (Transmission Owner, Regional Transmission Operator, or Independent Transmission Provider) providing transmission service to the TDU to request project coordination. Affected Systems shall participate in the study and provide all information necessary to prepare the study.
- 3.4.10 The system impact study shall evaluate static synchronous compensators, static VAR compensators, advanced power flow control devices, transmission switching, synchronous condensers, voltage source converters, advanced conductors, and tower lifting. Transmission Provider shall evaluate each identified alternative transmission technology and determine whether it should be used, consistent with Good Utility Practice, Applicable Reliability Standards, and Applicable Laws and Regulations. Transmission Provider shall include an explanation of the results of Transmission Provider’s evaluation for each technology in the system impact study report.

3.5 Facilities Study

- 3.5.1 Once the required system impact study(s) is completed, a system impact study report shall be prepared and transmitted to Interconnection Customer along with a facilities study agreement within five (5) Business Days, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the facilities study. In the case where one or both impact studies are determined to be unnecessary, a notice of the fact shall be transmitted to Interconnection Customer within the same timeframe.
- 3.5.2 In order to remain under consideration for interconnection, or, as appropriate, in Transmission Provider’s interconnection queue, Interconnection Customer must return the executed facilities study

agreement or a request for an extension of time within thirty (30) Business Days.

- 3.5.3 The facilities study shall specify and estimate the cost of the equipment, engineering, procurement and construction work (including overheads) needed to implement the conclusions of the system impact study(s).
- 3.5.4 Design for any required Interconnection Facilities and/or Upgrades shall be performed under the facilities study agreement. Transmission Provider may contract with consultants to perform activities required under the facilities study agreement. Interconnection Customer and Transmission Provider may agree to allow Interconnection Customer to separately arrange for the design of some of the Interconnection Facilities. In such cases, facilities design will be reviewed and/or modified prior to acceptance by Transmission Provider, under the provisions of the facilities study agreement. If the Parties agree to separately arrange for design and construction, and provided security and confidentiality requirements can be met, Transmission Provider shall make sufficient information available to Interconnection Customer in accordance with confidentiality and critical infrastructure requirements to permit Interconnection Customer to obtain an independent design and cost estimate for any necessary facilities.
- 3.5.5 A deposit of the good faith estimated costs for the facilities study may be required from Interconnection Customer.
- 3.5.6 The scope of and cost responsibilities for the facilities study are described in the attached facilities study agreement.
- 3.5.7 Upon completion of the facilities study, and with the agreement of Interconnection Customer to pay for Interconnection Facilities and Upgrades identified in the facilities study, Transmission Provider shall provide Interconnection Customer an executable interconnection agreement within five (5) Business Days.

Section 4. Provisions that Apply to All Interconnection Requests

1.1 Reasonable Efforts

Transmission Provider shall make reasonable efforts to meet all time frames provided in these procedures unless Transmission Provider and Interconnection Customer agree to a different schedule. If Transmission Provider cannot meet a deadline provided herein, it shall notify Interconnection Customer, explain the reason for the failure to meet the deadline, and provide an estimated time by which it will complete the applicable interconnection procedure in the process.

4.2 Disputes

- 4.2.1 The Parties agree to attempt to resolve all disputes arising out of the interconnection process according to the provisions of this article.
- 4.2.2 In the event of a dispute, either Party shall provide the other Party with a written Notice of Dispute. Such Notice shall describe in detail the nature of the dispute.
- 4.2.3 If the dispute has not been resolved within two (2) Business Days after receipt of the Notice, either Party may contact FERC's Dispute Resolution Service (DRS) for assistance in resolving the dispute.
- 4.2.4 The DRS will assist the Parties in either resolving their dispute or in selecting an appropriate dispute resolution venue (e.g., mediation, settlement judge, early neutral evaluation, or technical expert) to assist the Parties in resolving their dispute. DRS can be reached at 1-877-337-2237 or via the internet at <http://www.ferc.gov/legal/adr.asp>.
- 4.2.5 Each Party agrees to conduct all negotiations in good faith and will be responsible for one-half of any costs paid to neutral third-parties.
- 4.2.6 If neither Party elects to seek assistance from the DRS, or if the attempted dispute resolution fails, then either Party may exercise whatever rights and remedies it may have in equity or law consistent with the terms of these procedures.

4.3 Interconnection Metering

Any metering necessitated by the use of the Small Generating Facility shall be installed at Interconnection Customer's expense in accordance with Federal Energy Regulatory Commission, state, or local regulatory requirements or Transmission Provider's specifications.

4.4 Commissioning

Commissioning tests of Interconnection Customer's installed equipment shall be performed pursuant to applicable codes and standards. Transmission Provider must be given at least five (5) Business Days written notice, or as otherwise mutually agreed to by the Parties, of the tests and may be present to witness the commissioning tests.

4.5. Confidentiality

4.5.1 Confidential information shall mean any confidential and/or proprietary information provided by one Party to the other Party that is clearly marked or otherwise designated "Confidential." For purposes of these procedures all design, operating specifications, and metering data provided by Interconnection Customer shall be deemed confidential information regardless of whether it is clearly marked or otherwise designated as such.

4.5.2 Confidential Information does not include information previously in the public domain, required to be publicly submitted or divulged by Governmental Authorities (after notice to the other Party and after exhausting any opportunity to oppose such publication or release), or necessary to be divulged in an action to enforce these procedures. Each Party receiving Confidential Information shall hold such information in confidence and shall not disclose it to any third party nor to the public without the prior written authorization from the Party providing that information, except to fulfill obligations under these procedures, or to fulfill legal or regulatory requirements.

4.5.2.1 Each Party shall employ at least the same standard of care to protect Confidential Information obtained from the other Party as it employs to protect its own Confidential Information.

4.5.2.2 Each Party is entitled to equitable relief, by injunction or otherwise, to enforce its rights under this provision to prevent the release of Confidential Information without bond or proof of damages, and may seek other remedies available at law or in equity for breach of this provision.

4.5.3 Notwithstanding anything in this article to the contrary, and pursuant to 18 CFR § 1b.20, if FERC, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to these procedures, the Party shall provide the requested information to FERC, within the time provided for in the request for information. In providing the information to FERC, the Party may, consistent with 18 CFR § 388.112, request that the information be treated as confidential and non-public by FERC and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party prior to the release of the Confidential Information to FERC. The Party shall notify the other Party when it is notified by FERC that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR § 388.112. Requests from a state regulatory body conducting a confidential investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

4.6 Comparability

Transmission Provider shall receive, process and analyze all Interconnection Requests in a timely manner as set forth in this document. Transmission Provider shall use the same reasonable efforts in processing and analyzing Interconnection Requests from all Interconnection Customers, whether the Small Generating Facility is owned or operated by Transmission Provider, its subsidiaries or affiliates, or others.

4.7 Record Retention

Transmission Provider shall maintain for three years records, subject to audit, of all Interconnection Requests received under these procedures, the times required to complete Interconnection Request approvals and disapprovals, and justification for the actions taken on the Interconnection Requests.

4.8 Interconnection Agreement

After receiving an interconnection agreement from Transmission Provider, Interconnection Customer shall have thirty (30) Business Days or another mutually agreeable timeframe to sign and return the interconnection agreement or request that Transmission Provider file an unexecuted interconnection agreement

with the Federal Energy Regulatory Commission. If Interconnection Customer does not sign the interconnection agreement, or ask that it be filed unexecuted by Transmission Provider within thirty (30) Business Days, the Interconnection Request shall be deemed withdrawn. After the interconnection agreement is signed by the Parties, the interconnection of the Small Generating Facility shall proceed under the provisions of the interconnection agreement.

4.9 Coordination with Affected Systems

Transmission Provider shall coordinate the conduct of any studies required to determine the impact of the Interconnection Request on Affected Systems with Affected System operators and, if possible, include those results (if available) in its applicable interconnection study within the time frame specified in these procedures. Transmission Provider will include such Affected System operators in all meetings held with Interconnection Customer as required by these procedures. Interconnection Customer will cooperate with Transmission Provider in all matters related to the conduct of studies and the determination of modifications to Affected Systems. A Transmission Provider which may be an Affected System shall cooperate with Transmission Provider with whom interconnection has been requested in all matters related to the conduct of studies and the determination of modifications to Affected Systems.

4.10 Capacity of the Small Generating Facility

4.10.1 If the Interconnection Request is for an increase in capacity for an existing Small Generating Facility, the Interconnection Request shall be evaluated on the basis of the new total capacity of the Small Generating Facility.

4.10.2 If the Interconnection Request is for a Small Generating Facility that includes multiple energy production devices at a site for which Interconnection Customer seeks a single Point of Interconnection, the Interconnection Request shall be evaluated on the basis of the aggregate capacity of the multiple devices.

4.10.3 The Interconnection Request shall be evaluated using the maximum capacity that the Small Generating Facility is capable of injecting into Transmission Provider's electric system. However, if the maximum capacity that the Small Generating Facility is capable of

injecting into Transmission Provider's electric system is limited (e.g., through use of a control system, power relay(s), or other similar device settings or adjustments), then Interconnection Customer must obtain Transmission Provider's agreement, with such agreement not to be unreasonably withheld, that the manner in which Interconnection Customer proposes to implement such a limit will not adversely affect the safety and reliability of Transmission Provider's system. If Transmission Provider does not so agree, then the Interconnection Request must be withdrawn or revised to specify the maximum capacity that the Small Generating Facility is capable of injecting into Transmission Provider's electric system without such limitations. Furthermore, nothing in this section shall prevent a Transmission Provider from considering an output higher than the limited output, if appropriate, when evaluating system protection impacts.

Attachment 1

Glossary of Terms

10 kW Inverter Process – The procedure for evaluating an Interconnection Request for a certified inverter-based Small Generating Facility no larger than 10 kW that uses the section 2 screens. The application process uses an all-in-one document that includes a simplified Interconnection Request, simplified procedures, and a brief set of terms and conditions. See SGIP Attachment 5.

Affected System – An electric system other than Transmission Provider's Transmission System that may be affected by the proposed interconnection.

Applicable Reliability Standards – The requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Applicable Laws and Regulations – All duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Business Day – Monday through Friday, excluding Federal Holidays.

Distribution System – Transmission Provider’s facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which Distribution Systems operate differ among areas.

Distribution Upgrades – The additions, modifications, and upgrades to Transmission Provider’s Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Small Generating Facility and render the transmission service necessary to effect Interconnection Customer’s wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Fast Track Process – The procedure for evaluating an Interconnection Request for a certified Small Generating Facility that meets the eligibility requirements of section 2.1_ and includes the section 2 screens, customer options meeting, and optional supplemental review.

Good Utility Practice – Any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and act which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Interconnection Customer – Any entity, including Transmission Provider, the Transmission Owner or any of the affiliates or subsidiaries of either, that proposes to interconnect its Small Generating Facility with Transmission Provider’s Transmission System.

Interconnection Facilities – Transmission Provider’s Interconnection Facilities and Interconnection Customer’s Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Small Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Small Generating Facility to Transmission Provider’s Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades or Network Upgrades.

Interconnection Request – Interconnection Customer’s request, in accordance with the Tariff, to interconnect a new Small Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Small Generating Facility that is interconnected with Transmission Provider’s Transmission System.

Material Modification – A modification that has a material impact on the cost or timing of any Interconnection Request with a later queue priority date.

Network Resource – Any designated generating resource owned, purchased, or leased by a Network Customer under the Network Integration Transmission Service Tariff. Network Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Network Customer’s Network Load on a non-interruptible basis.

Network Resource Interconnection Service – An Interconnection Service that allows Interconnection Customer to integrate its Generating Facility with Transmission Provider’s System (1) in a manner comparable to that in which Transmission Provider integrates its generating facilities to serve native load customers; or (2) in an RTO or ISO with market based congestion management, in the same manner as Network Resources. Network Resource Interconnection Service in and of itself does not convey transmission service.

Network Upgrades – Additions, modifications, and upgrades to Transmission Provider’s Transmission System required at or beyond the point at which the Small Generating Facility interconnects with Transmission Provider’s Transmission System to accommodate the interconnection with the Small Generating Facility to Transmission Provider’s Transmission System. Network Upgrades do not include Distribution Upgrades.

Party or Parties – Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Point of Interconnection – The point where the Interconnection Facilities connect with Transmission Provider’s Transmission System.

Queue Position – The order of a valid Interconnection Request, relative to all other pending valid Interconnection Requests, that is established based upon the date and time of receipt of the valid Interconnection Request by Transmission Provider.

Small Generating Facility – Interconnection Customer’s device for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer’s Interconnection Facilities.

Study Process – The procedure for evaluating an Interconnection Request that includes the section 3 scoping meeting, feasibility study, system impact study, and facilities study.

Transmission Owner – The entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Small Generator Interconnection Agreement to the extent necessary.

Transmission Provider – The public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission System – The facilities owned, controlled or operated by Transmission Provider or the Transmission Owner that are used to provide transmission service under the Tariff.

Upgrades – The required additions and modifications to Transmission Provider’s Transmission System at or beyond the Point of Interconnection. Upgrades may be Network Upgrades or Distribution Upgrades. Upgrades do not include Interconnection Facilities.

Attachment 2

SMALL GENERATOR INTERCONNECTION REQUEST

(Application Form)

Transmission Provider: _____

Designated Contact Person: _____

Address: _____

Telephone Number: _____

Fax: _____

E-Mail Address: _____

An Interconnection Request is considered complete when it provides all applicable and correct information required below. Per SGIP section 1.5, documentation of site control must be submitted with the Interconnection Request.

Preamble and Instructions

An Interconnection Customer who requests a Federal Energy Regulatory Commission jurisdictional interconnection must submit this Interconnection Request by hand delivery, mail, e-mail, or fax to Transmission Provider.

Processing Fee or Deposit:

If the Interconnection Request is submitted under the Fast Track Process, the non-refundable processing fee is \$500.

If the Interconnection Request is submitted under the Study Process, whether a new submission or an Interconnection Request that did not pass the Fast Track Process, Interconnection Customer shall submit to Transmission Provider a deposit not to exceed \$1,000 towards the cost of the feasibility study.

Interconnection Customer Information

Legal Name of Interconnection Customer (or, if an individual, individual's name)

Name: _____

Contact Person:

Mailing Address:

City: _____ State: _____ Zip: _____

Facility Location (if different from above):

Telephone (Day): _____ Telephone (Evening): _____

Fax: _____ E-Mail Address: _____

Alternative Contact Information (if different from Interconnection Customer)

Contact Name: _____

Title: _____

Address: _____

Telephone (Day): _____ Telephone

(Evening): _____

Fax: _____ E-Mail Address: _____

Application is for: _____ New Small Generating Facility

_____ Capacity addition to Existing Small Generating Facility

If capacity addition to existing facility, please describe: _____

Will the Small Generating Facility be used for any of the following?

Net Metering? Yes ___ No ___

To Supply Power to Interconnection Customer? Yes ___ No ___

To Supply Power to Others? Yes ___ No ___

For installations at locations with existing electric service to which the proposed Small Generating Facility will interconnect, provide:

(Local Electric Service Provider*)
Account Number*)

(Existing

{*To be provided by Interconnection Customer if the local electric service provider is different from Transmission Provider}

Contact Name:

Title:

Address:

Telephone (Day): _____ Telephone (Evening):

Fax: _____ E-Mail Address:

Requested Point of Interconnection:

Interconnection Customer's Requested In-Service Date:

Small Generating Facility Information

Data apply only to the Small Generating Facility, not the Interconnection Facilities.

Energy Source: ___ Solar ___ Wind ___ Hydro ___ Hydro Type (e.g.
Run-of-River): _____ ___ Diesel ___ Natural Gas ___ Fuel Oil ___ Other (state type)

Prime Mover: ___ Fuel Cell ___ Recip Engine ___ Gas Turb ___ Steam Turb
___ Microturbine ___ PV ___ Other

Type of Generator: ___ Synchronous ___ Induction ___ Inverter

Generator Nameplate Rating: _____ kW (Typical) Generator Nameplate kVAR:

Interconnection Customer or Customer-Site Load: _____ kW (if none, so
state)

Typical Reactive Load (if known): _____

Maximum Physical Export Capability Requested: _____ kW

List components of the Small Generating Facility equipment package that are currently certified:

	Equipment Type	Certifying Entity
1.	_____	_____
2.	_____	_____
3.	_____	_____
4.	_____	_____
5.	_____	_____

Is the prime mover compatible with the certified protective relay package? ___ Yes
___ No

Generator (or solar collector) Manufacturer, Model Name & Number:

Version Number: _____

Nameplate Output Power Rating in kW: (Summer) _____ (Winter)

Nameplate Output Power Rating in kVA: (Summer) _____ (Winter)

Individual Generator Power Factor

Rated Power Factor: Leading: _____ Lagging: _____

Total Number of Generators in wind farm to be interconnected pursuant to this

Interconnection Request: _____ Elevation: _____ ___ Single phase

___ Three phase

Inverter Manufacturer, Model Name & Number (if used): _____

List of adjustable set points for the protective equipment or software:

Note: A completed Power Systems Load Flow data sheet must be supplied with the Interconnection Request.

Small Generating Facility Characteristic Data (for inverter-based machines)

Max design fault contribution current: _____ Instantaneous or RMS _____ ?

Harmonics Characteristics:

Start-up requirements:

Small Generating Facility Characteristic Data (for rotating machines)

RPM Frequency: _____

(*) Neutral Grounding Resistor (If Applicable): _____

Synchronous Generators:

Direct Axis Synchronous Reactance, X_d : _____ P.U.

Direct Axis Transient Reactance, X'_d : _____ P.U.

Direct Axis Subtransient Reactance, X''_d : _____ P.U.

Negative Sequence Reactance, X_2 : _____ P.U.

Zero Sequence Reactance, X_0 : _____ P.U.

KVA Base: _____

Field Volts: _____

Field Amperes: _____

Induction Generators:

Motoring Power (kW): _____

I22t or K (Heating Time Constant): _____

Rotor Resistance, R_r : _____

Stator Resistance, R_s : _____

Stator Reactance, X_s : _____

Rotor Reactance, X_r : _____

Magnetizing Reactance, X_m : _____

Short Circuit Reactance, X_d'' : _____

Exciting Current: _____

Temperature Rise: _____

Frame Size: _____

Design Letter: _____

Reactive Power Required In Vars (No Load): _____

Reactive Power Required In Vars (Full Load): _____

Total Rotating Inertia, H : _____ Per Unit on kVA Base

Note: Please contact Transmission Provider prior to submitting the Interconnection Request to determine if the specified information above is required.

Excitation and Governor System Data for Synchronous Generators Only

Provide appropriate IEEE model block diagram of excitation system, governor system and power system stabilizer (PSS) in accordance with the regional reliability council criteria. A PSS may be determined to be required by applicable studies. A copy of the manufacturer's block diagram may not be substituted.

Models for Non-synchronous Small Generating Facilities

For a non-synchronous Small Generating Facility, Interconnection Customer shall provide (1) a validated user-defined root mean squared (RMS) positive sequence dynamics model; (2) an appropriately parameterized generic library RMS positive sequence dynamics model, including model block diagram of the inverter control and plant control systems, as defined by the selection in Table 1 or a model otherwise approved by the Western Electricity Coordinating Council, that corresponds to Interconnection Customer's Small Generating Facility; and (3) if applicable, a validated electromagnetic transient model if Transmission Provider performs an electromagnetic transient study as part of the interconnection study process. A user-defined model is a set of programming code created by equipment manufacturers or developers that captures the latest features of controllers that are mainly software based and represents the entities' control strategies but does not necessarily correspond to any generic library model. Interconnection Customer must also demonstrate that the model is validated by providing evidence that the equipment behavior is consistent with the model behavior (e.g., an attestation from Interconnection Customer that the model accurately represents the entire Small Generating Facility; attestations from each equipment manufacturer that the user defined model accurately represents the component of the Small Generating Facility; or test data).

Table 1: Acceptable Generic Library RMS Positive Sequence Dynamics Models

GE PSLF	Siemens PSS/E*	PowerWorld Simulator	Description
pvd1		PVD1	Distributed PV system model
der_a	DERAU1	DER_A	Distributed energy resource model
regc_a	REGCAU1, REGCA1	REGC_A	Generator/converter model
regc_b	REGCBU1	REGC_B	Generator/converter model
wt1g	WT1G1	WT1G and WT1G1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)
wt2g	WT2G1	WT2G and WT2G1	Generator model for generic Type-2 wind turbines
wt2e	WT2E1	WT2E and WT2E1	Rotor resistance control model for wound-rotor induction wind-turbine generator

			wt2g
reec_a	REECAU1, REECA1	REEC_A	Renewable energy electrical control model
reec_c	REECCU1	REEC_C	Electrical control model for battery energy storage system
reec_d	REECDU1	REEC_D	Renewable energy electrical control model
wt1t	WT12T1	WT1T and WT12T1	Wind turbine model for Type-1 wind turbines (conventional directly connected induction generator)
wtlp_b	wtlp_b	WT12A1U_ B	Generic wind turbine pitch controller for WTGs of Types 1 and 2
wt2t	WT12T1	WT2T	Wind turbine model for Type-2 wind turbines (directly connected induction generator wind turbines with an external rotor resistance)
wtgt_a	WTDTAU1, WTDTA1	WTGT_A	Wind turbine drive train model
wtga_a	WTARAU1, WTARA1	WTGA_A	Simple aerodynamic model
wtgp_a	WTPTAU1, WTPTA1	WTGPT_A	Wind Turbine Generator Pitch controller
wtgq_a	WTTQAU1, WTTQA1	WTGTRQ_ A	Wind Turbine Generator Torque controller
wtgwgo_a	WTGWGOAU	WTGWGO_ A	Supplementary control model for Weak Grids
wtigbfr_a	WTGIBFFRA	WTGIBFFR_ _A	Inertial-base fast frequency response control
wtgp_b	WTPTBU1	WTGPT_B	Wind Turbine Generator Pitch controller
wtgt_b	WTDTBU1	WTGT_B	Drive train model
repc_a	Type 4: REPCAU1	REPC_A	Power Plant Controller

	(v33), REPCA1 (v34) Type 3: REPCTAU1 (v33), REPCTA1 (v34)		
repc_b	PLNTBU1	REPC_B	Power Plant Level Controller for controlling several plants/devices In regard to Siemens PSS/E*: Names of other models for interface with other devices: REA3XBU1, REAX4BU1- for interface with Type 3 and 4 renewable machines SWSAXBU1- for interface with SVC (modeled as switched shunt in powerflow) SYNAXBU1- for interface with synchronous condenser FCTAXBUI- for interface with FACTS device
repc_c	REPCCU	REPC_C	Power plant controller

Interconnection Facilities Information

Will a transformer be used between the generator and the point of common coupling?

Yes No

Will the transformer be provided by Interconnection Customer? Yes No

Transformer Data (If Applicable, for Interconnection Customer-Owned Transformer):

Is the transformer: single phase three phase?

Size:

_____ kVA

Transformer Impedance: _____% on _____kVA Base

If Three Phase:

Transformer Primary: _____ Volts _____ Delta _____ Wye _____ Wye Grounded

Transformer Secondary: _____ Volts _____ Delta _____ Wye _____ Wye Grounded

Transformer Tertiary: _____ Volts _____ Delta _____ Wye _____ Wye Grounded

Transformer Fuse Data (If Applicable, for Interconnection Customer-Owned Fuse):

(Attach copy of fuse manufacturer’s Minimum Melt and Total Clearing Time-Current Curves)

Manufacturer: _____ Type: _____ Size: _____ Speed: _____

Interconnecting Circuit Breaker (if applicable):

Manufacturer: _____ Type: _____

Load Rating (Amps): _____ Interrupting Rating (Amps): _____ Trip Speed (Cycles): _____

Interconnection Protective Relays (If Applicable):

If Microprocessor-Controlled:

List of Functions and Adjustable Setpoints for the protective equipment or software:

	Setpoint Function	Minimum	Maximum
1.	_____	_____	_____
2.	_____	_____	_____
3.	_____	_____	_____
4.	_____	_____	_____
5.	_____	_____	_____
6.	_____	_____	_____

If Discrete Components:

(Enclose Copy of any Proposed Time-Overcurrent Coordination Curves)

Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____
Manufacturer: _____	Type: _____	Style/Catalog No.: _____	Proposed Setting: _____

Current Transformer Data (If Applicable):

(Enclose Copy of Manufacturer's Excitation and Ratio Correction Curves)

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection:

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection:

Potential Transformer Data (If Applicable):

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection:

Manufacturer:

Type: _____ Accuracy Class: _____ Proposed Ratio Connection:

General Information

Enclose copy of site electrical one-line diagram showing the configuration of all Small Generating Facility equipment, current and potential circuits, and protection and control schemes. This one-line diagram must be signed and stamped by a licensed Professional Engineer if the Small Generating Facility is larger than 50 kW. Is One-Line Diagram Enclosed? ___ Yes ___ No

Enclose copy of any site documentation that indicates the precise physical location of the proposed Small Generating Facility (e.g., USGS topographic map or other diagram or documentation).

Proposed location of protective interface equipment on property (include address if different from Interconnection Customer’s address) _____

Enclose copy of any site documentation that describes and details the operation of the protection and control schemes. Is Available Documentation Enclosed? ___ Yes ___ No

Enclose copies of schematic drawings for all protection and control circuits, relay current circuits, relay potential circuits, and alarm/monitoring circuits (if applicable).

Are Schematic Drawings Enclosed? ___ Yes ___ No

Applicant Signature

I hereby certify that, to the best of my knowledge, all the information provided in this Interconnection Request is true and correct.

For Interconnection Customer: _____ Date:

Attachment 3**Certification Codes and Standards**

IEEE1547 Standard for Interconnecting Distributed Resources with Electric Power Systems (including use of IEEE 1547.1 testing protocols to establish conformity)

UL 1741 Inverters, Converters, and Controllers for Use in Independent Power Systems

IEEE Std 929-2000 IEEE Recommended Practice for Utility Interface of Photovoltaic (PV) Systems

NFPA 70 (2002), National Electrical Code

IEEE Std C37.90.1-1989 (R1994), IEEE Standard Surge Withstand Capability (SWC) Tests for Protective Relays and Relay Systems

IEEE Std C37.90.2 (1995), IEEE Standard Withstand Capability of Relay Systems to Radiated Electromagnetic Interference from Transceivers

IEEE Std C37.108-1989 (R2002), IEEE Guide for the Protection of Network Transformers

IEEE Std C57.12.44-2000, IEEE Standard Requirements for Secondary Network Protectors

IEEE Std C62.41.2-2002, IEEE Recommended Practice on Characterization of Surges in Low Voltage (1000V and Less) AC Power Circuits

IEEE Std C62.45-1992 (R2002), IEEE Recommended Practice on Surge Testing for Equipment Connected to Low-Voltage (1000V and Less) AC Power Circuits

ANSI C84.1-1995 Electric Power Systems and Equipment – Voltage Ratings (60 Hertz)

IEEE Std 100-2000, IEEE Standard Dictionary of Electrical and Electronic Terms

NEMA MG 1-1998, Motors and Small Resources, Revision 3

IEEE Std 519-1992, IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems

NEMA MG 1-2003 (Rev 2004), Motors and Generators, Revision 1

Attachment 4

Certification of Small Generator Equipment Packages

- 1.0 Small Generating Facility equipment proposed for use separately or packaged with other equipment in an interconnection system shall be considered certified for interconnected operation if (1) it has been tested in accordance with industry standards for continuous utility interactive operation in compliance with the appropriate codes and standards referenced below by any Nationally Recognized Testing Laboratory (NRTL) recognized by the United States Occupational Safety and Health Administration to test and certify interconnection equipment pursuant to the relevant codes and standards listed in SGIP Attachment 3, (2) it has been labeled and is publicly listed by such NRTL at the time of the interconnection application, and (3) such NRTL makes readily available for verification all test standards and procedures it utilized in performing such equipment certification, and, with consumer approval, the test data itself. The NRTL may make such information available on its website and by encouraging such information to be included in the manufacturer's literature accompanying the equipment.
- 2.0 Interconnection Customer must verify that the intended use of the equipment falls within the use or uses for which the equipment was tested, labeled, and listed by the NRTL.
- 3.0 Certified equipment shall not require further type-test review, testing, or additional equipment to meet the requirements of this interconnection procedure; however, nothing herein shall preclude the need for an on-site commissioning test by the parties to the interconnection nor follow-up production testing by the NRTL.
- 4.0 If the certified equipment package includes only interface components (switchgear, inverters, or other interface devices), then an Interconnection Customer must show that the generator or other electric source being utilized with

the equipment package is compatible with the equipment package and is consistent with the testing and listing specified for this type of interconnection equipment.

- 5.0 Provided the generator or electric source, when combined with the equipment package, is within the range of capabilities for which it was tested by the NRTL, and does not violate the interface components' labeling and listing performed by the NRTL, no further design review, testing or additional equipment on the customer side of the point of common coupling shall be required to meet the requirements of this interconnection procedure.

- 6.0 An equipment package does not include equipment provided by the utility.

- 7.0 Any equipment package approved and listed in a state by that state's regulatory body for interconnected operation in that state prior to the effective date of these small generator interconnection procedures shall be considered certified under these procedures for use in that state.

Attachment 5

Application, Procedures, and Terms and Conditions for Interconnecting a Certified Inverter-Based Small Generating Facility No Larger than 10 kW ("10 kW Inverter Process")

- 1.0 Interconnection Customer ("Customer") completes the Interconnection Request ("Application") and submits it to Transmission Provider ("Company").
- 2.0 The Company acknowledges to the Customer receipt of the Application within three (3) Business Days of receipt.
- 3.0 The Company evaluates the Application for completeness and notifies the Customer within ten (10) Business Days of receipt that the Application is or is not complete and, if not, advises what material is missing.

- 4.0 The Company verifies that the Small Generating Facility can be interconnected safely and reliably using the screens contained in the Fast Track Process in the Small Generator Interconnection Procedures (SGIP). The Company has fifteen (15) Business Days to complete this process. Unless the Company determines and demonstrates that the Small Generating Facility cannot be interconnected safely and reliably, the Company approves the Application and returns it to the Customer. Note to Customer: Please check with the Company before submitting the Application if disconnection equipment is required.
- 5.0 After installation, the Customer returns the Certificate of Completion to the Company. Prior to parallel operation, the Company may inspect the Small Generating Facility for compliance with standards which may include a witness test, and may schedule appropriate metering replacement, if necessary.
- 6.0 The Company notifies the Customer in writing that interconnection of the Small Generating Facility is authorized. If the witness test is not satisfactory, the Company has the right to disconnect the Small Generating Facility. The Customer has no right to operate in parallel until a witness test has been performed, or previously waived on the Application. The Company is obligated to complete this witness test within ten (10) Business Days of the receipt of the Certificate of Completion. If the Company does not inspect within ten (10) Business Days or by mutual agreement of the Parties, the witness test is deemed waived.
- 7.0 Contact Information – The Customer must provide the contact information for the legal applicant (i.e., Interconnection Customer). If another entity is responsible for interfacing with the Company, that contact information must be provided on the Application.
- 8.0 Ownership Information – Enter the legal names of the owner(s) of the Small Generating Facility. Include the percentage ownership (if any) by any utility or public utility holding company, or by any entity owned by either.
- 9.0 UL1741 Listed – This standard (“Inverters, Converters, and Controllers for Use in Independent Power Systems”) addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL1741. This “listing” is then marked on the equipment and supporting documentation.

Application for Interconnecting a Certified Inverter-Based Small Generating Facility No Larger than 10kW

This Application is considered complete when it provides all applicable and correct information required below. Per SGIP section 1.5, documentation of site control must be submitted with the Interconnection Request. Additional information to evaluate the Application may be required.

Processing Fee

A non-refundable processing fee of \$100 must accompany this Application.

Interconnection Customer

Name:

Contact Person:

Address:

City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

Contact (if different from Interconnection Customer)

Name:

Contact Person:

Address:

City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

Owner of the facility (include % ownership by any electric utility):

____ Small Generating Facility Information

Location (if different from above):

Electric Service Company:

Account Number:

Inverter Manufacturer: _____ Model: _____
Nameplate Rating: _____ (kW) _____ (kVA) _____ (AC Volts)

Single Phase _____ Three Phase _____

System Design Capacity: _____ (kW) _____ (kVA)

Prime Mover: _____ Photovoltaic _____ Reciprocating Engine _____ Fuel Cell
_____ Turbine _____ Other (describe) _____

Energy Source: _____ Solar _____ Wind _____ Hydro _____ Diesel _____ Natural Gas
_____ Fuel Oil _____ Other (describe) _____

Is the equipment UL1741 Listed? _____ Yes _____ No

If Yes, attach manufacturer's cut-sheet showing UL1741 listing

Estimated Installation Date: _____ Estimated In-Service Date:

The 10 kW Inverter Process is available only for inverter-based Small Generating Facilities no larger than 10 kW that meet the codes, standards, and certification requirements of Attachments 3 and 4 of the Small Generator Interconnection Procedures (SGIP), or Transmission Provider has reviewed the design or tested the proposed Small Generating Facility and is satisfied that it is safe to operate.

List components of the Small Generating Facility equipment package that are currently certified:

	Equipment Type	Certifying Entity
1.	_____	_____
2.	_____	_____
3.	_____	_____
4.	_____	_____
5.	_____	_____

Interconnection Customer Signature

I hereby certify that, to the best of my knowledge, the information provided in this Application is true. I agree to abide by the Terms and Conditions for Interconnecting an Inverter-Based Small Generating Facility No Larger than 10kW and return the Certificate of Completion when the Small Generating Facility has been installed.

Signed:

Title: _____

Date:

.....
.....

Contingent Approval to Interconnect the Small Generating Facility

(For Company use only)

Interconnection of the Small Generating Facility is approved contingent upon the Terms and Conditions for Interconnecting an Inverter-Based Small Generating Facility No Larger than 10kW and return of the Certificate of Completion.

Company Signature:

Title: _____

Date:

Application ID number: _____

Company waives inspection/witness test? Yes___No___

Small Generating Facility Certificate of Completion

Is the Small Generating Facility owner-installed? Yes _____ No _____

Interconnection Customer:

Contact Person:

Address:

Location of the Small Generating Facility (if different from above):

_____ City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

Electrician:

Name:

Address:

Location of the Small Generating Facility (if different from above):

_____ City: _____ State: _____ Zip: _____

Telephone (Day): _____ (Evening): _____

Fax: _____ E-Mail Address: _____

License number: _____

Date Approval to Install Facility granted by the Company: _____

Application ID number: _____

Inspection:

The Small Generating Facility has been installed and inspected in compliance with the local

building/electrical code of:

Signed (Local electrical wiring inspector, or attach signed electrical inspection):

Print Name: _____

Date: _____

As a condition of interconnection, you are required to send/fax a copy of this form along with a copy of the signed electrical permit to (insert Company information below):

Name: _____

Company: _____

Address: _____

City, State ZIP: _____

Fax: _____

.....
.....

Approval to Energize the Small Generating Facility (For Company use only)

Energizing the Small Generating Facility is approved contingent upon the Terms and Conditions for Interconnecting an Inverter-Based Small Generating Facility No Larger than 10kW

Company Signature: _____

Title: _____ Date:

Terms and Conditions for Interconnecting an Inverter-Based Small Generating Facility No Larger than 10kW

1.0 Construction of the Facility

Interconnection Customer (the “Customer”) may proceed to construct (including operational testing not to exceed two hours) the Small Generating Facility when Transmission Provider (the “Company”) approves the Interconnection Request (the “Application”) and returns it to the Customer.

2.0 Interconnection and Operation

The Customer may operate Small Generating Facility and interconnect with the Company’s electric system once all of the following have occurred:

- 2.1 Upon completing construction, the Customer will cause the Small Generating Facility to be inspected or otherwise certified by the appropriate local electrical wiring inspector with jurisdiction, and
- 2.2 The Customer returns the Certificate of Completion to the Company, and
- 2.3 The Company has either:
 - 2.3.1 Completed its inspection of the Small Generating Facility to ensure that all equipment has been appropriately installed and that all electrical connections have been made in accordance with applicable codes. All inspections must be conducted by the Company, at its own expense, within ten (10) Business Days after receipt of the Certificate of Completion and shall take place at a time agreeable to the Parties. The Company shall provide a written statement that the Small Generating Facility has passed inspection or shall notify the Customer of what steps it must take to pass inspection as soon as practicable after the inspection takes place; or
 - 2.3.2 If the Company does not schedule an inspection of the Small Generating Facility within ten (10) Business Days after receiving the

Certificate of Completion, the witness test is deemed waived (unless the Parties agree otherwise); or

2.3.3 The Company waives the right to inspect the Small Generating Facility.

2.4 The Company has the right to disconnect the Small Generating Facility in the event of improper installation or failure to return the Certificate of Completion.

2.5 Revenue quality metering equipment must be installed and tested in accordance with applicable ANSI standards.

3.0 Safe Operations and Maintenance

The Customer shall be fully responsible to operate, maintain, and repair the Small Generating Facility as required to ensure that it complies at all times with the interconnection standards to which it has been certified.

4.0 Access

The Company shall have access to the disconnect switch (if the disconnect switch is required) and metering equipment of the Small Generating Facility at all times. The Company shall provide reasonable notice to the Customer when possible prior to using its right of access.

5.0 Disconnection

The Company may temporarily disconnect the Small Generating Facility upon the following conditions:

5.1 For scheduled outages upon reasonable notice.

5.2 For unscheduled outages or emergency conditions.

5.3 If the Small Generating Facility does not operate in the manner consistent with these Terms and Conditions.

5.4 The Company shall inform the Customer in advance of any scheduled disconnection, or as is reasonable after an unscheduled disconnection.

6.0 Indemnification

The Parties shall at all times indemnify, defend, and save the other Party harmless from, any and all damages, losses, claims, including claims and actions relating to

injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's action or inactions of its obligations under this agreement on behalf of the indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the indemnified Party.

7.0 Insurance

The Parties agree to follow all applicable insurance requirements imposed by the state in which the Point of Interconnection is located. All insurance policies must be maintained with insurers authorized to do business in that state.

8.0 Limitation of Liability

Each party's liability to the other party for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall either party be liable to the other party for any indirect, incidental, special, consequential, or punitive damages of any kind whatsoever, except as allowed under paragraph 6.0.

9.0 Termination

The agreement to operate in parallel may be terminated under the following conditions:

9.1 By the Customer

By providing written notice to the Company.

9.2 By the Company

If the Small Generating Facility fails to operate for any consecutive 12 month period or the Customer fails to remedy a violation of these Terms and Conditions.

9.3 Permanent Disconnection

In the event this Agreement is terminated, the Company shall have the right to disconnect its facilities or direct the Customer to disconnect its Small Generating Facility.

9.4 Survival Rights

This Agreement shall continue in effect after termination to the extent necessary to allow or require either Party to fulfill rights or obligations that arose under the Agreement.

10.0 Assignment/Transfer of Ownership of the Facility

This Agreement shall survive the transfer of ownership of the Small Generating Facility to a new owner when the new owner agrees in writing to comply with the terms of this Agreement and so notifies the Company.

Attachment 6

Feasibility Study Agreement

THIS AGREEMENT is made and entered into this ____ day of _____
20__ by and between _____,
a _____ organized and existing under the laws of the State of _____, (“Interconnection Customer,”) and _____, a _____ organized and existing under the laws of the State of _____, (“Transmission Provider”). Interconnection Customer and Transmission Provider each may be referred to as a “Party, ” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Small Generating Facility or generating capacity addition to an existing Small Generating Facility consistent with the Interconnection Request completed by Interconnection Customer on _____; and

WHEREAS, Interconnection Customer desires to interconnect the Small Generating Facility with Transmission Provider’s Transmission System; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform a feasibility study to assess the feasibility of interconnecting the proposed Small

Generating Facility with Transmission Provider's Transmission System, and of any Affected Systems;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall have the meanings indicated or the meanings specified in the standard Small Generator Interconnection Procedures.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be performed an interconnection feasibility study consistent the standard Small Generator Interconnection Procedures in accordance with the Open Access Transmission Tariff.
- 3.0 The scope of the feasibility study shall be subject to the assumptions set forth in Attachment A to this Agreement.
- 4.0 The feasibility study shall be based on the technical information provided by Interconnection Customer in the Interconnection Request, as may be modified as the result of the scoping meeting. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the feasibility study and as designated in accordance with the standard Small Generator Interconnection Procedures. If Interconnection Customer modifies its Interconnection Request, the time to complete the feasibility study may be extended by agreement of the Parties.
- 5.0 In performing the study, Transmission Provider shall rely, to the extent reasonably practicable, on existing studies of recent vintage. Interconnection Customer shall not be charged for such existing studies; however, Interconnection Customer shall be responsible for charges associated with any new study or modifications to existing studies that are reasonably necessary to perform the feasibility study.
- 6.0 The feasibility study report shall provide the following analyses for the purpose of identifying any potential adverse system impacts that would result from the interconnection of the Small Generating Facility as proposed:

- 6.1 Initial identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection;
 - 6.2 Initial identification of any thermal overload or voltage limit violations resulting from the interconnection;
 - 6.3 Initial review of grounding requirements and electric system protection;
- and
- 6.4 Description and non-binding estimated cost of facilities required to interconnect the proposed Small Generating Facility and to address the identified short circuit and power flow issues.
- 7.0 The feasibility study shall model the impact of the Small Generating Facility regardless of purpose in order to avoid the further expense and interruption of operation for reexamination of feasibility and impacts if Interconnection Customer later changes the purpose for which the Small Generating Facility is being installed.
 - 8.0 The study shall include the feasibility of any interconnection at a proposed project site where there could be multiple potential Points of Interconnection, as requested by Interconnection Customer and at Interconnection Customer's cost.
 - 9.0 A deposit of the lesser of 50 percent of good faith estimated feasibility study costs or earnest money of \$1,000 may be required from Interconnection Customer.
 - 10.0 Once the feasibility study is completed, a feasibility study report shall be prepared and transmitted to Interconnection Customer. Barring unusual circumstances, the feasibility study must be completed and the feasibility study report transmitted within thirty (30) Business Days of Interconnection Customer's agreement to conduct a feasibility study.
 - 11.0 Any study fees shall be based on Transmission Provider's actual costs and will be invoiced to Interconnection Customer after the study is completed and delivered and will include a summary of professional time.
 - 12.0 Interconnection Customer must pay any study costs that exceed the deposit without interest within thirty (30) Calendar Days on receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced fees, Transmission

Provider shall refund such excess within thirty (30) Calendar Days of the invoice without interest.

13.0 Governing Law, Regulatory Authority, and Rules

The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____ (where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.

14.0 Amendment

The Parties may amend this Agreement by a written instrument duly executed by both Parties.

15.0 No Third-Party Beneficiaries

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

16.0 Waiver

16.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

16.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

17.0 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

18.0 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

19.0 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

20.0 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

20.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this

Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

20.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

21.0 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement under any applicable provision of the Federal Power Act and FERC's rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider} {Insert name of Interconnection Customer}

Signed: _____

Signed: _____

Name (Printed):

Name (Printed):

Title: _____

Title: _____

Attachment A to
Feasibility Study Agreement
Assumptions Used in Conducting the Feasibility Study

The feasibility study will be based upon the information set forth in the Interconnection Request and agreed upon in the scoping meeting held on _____:

- 1) Designation of Point of Interconnection and configuration to be studied.

- 2) Designation of alternative Points of Interconnection and configuration.

1) and 2) are to be completed by the Interconnection Customer. Other assumptions (listed below) are to be provided by Interconnection Customer and Transmission Provider.

Attachment 7
System Impact Study Agreement

THIS AGREEMENT is made and entered into this ____ day of _____
 20__ by and between _____,
 a _____ organized and existing under the laws of the State of _____,
 _____, (“Interconnection Customer,”) and

_____, a _____,
organized and existing under the laws of the State
of _____,

(“Transmission Provider”). Interconnection Customer and Transmission Provider each
may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Small Generating
Facility or generating capacity addition to an existing Small Generating Facility
consistent with the Interconnection Request completed by Interconnection Customer
on _____; and

WHEREAS, Interconnection Customer desires to interconnect the Small Generating
Facility with Transmission Provider’s Transmission System;

WHEREAS, Transmission Provider has completed a feasibility study and provided the
results of said study to Interconnection Customer (This recital to be omitted if the Parties
have agreed to forego the feasibility study.); and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform
a system impact study(s) to assess the impact of interconnecting the Small Generating
Facility with Transmission Provider’s Transmission System, and of any Affected
Systems;

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained
herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall
have the meanings indicated or the meanings specified in the standard Small
Generator Interconnection Procedures.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause to be
performed a system impact study(s) consistent with the standard Small Generator
Interconnection Procedures in accordance with the Open Access Transmission
Tariff.
- 3.0 The scope of a system impact study shall be subject to the assumptions set forth in
Attachment A to this Agreement.

- 4.0 A system impact study will be based upon the results of the feasibility study and the technical information provided by Interconnection Customer in the Interconnection Request. Transmission Provider reserves the right to request additional technical information from Interconnection Customer as may reasonably become necessary consistent with Good Utility Practice during the course of the system impact study. If Interconnection Customer modifies its designated Point of Interconnection, Interconnection Request, or the technical information provided therein is modified, the time to complete the system impact study may be extended.
- 5.0 A system impact study shall consist of a short circuit analysis, a stability analysis, a power flow analysis, voltage drop and flicker studies, protection and set point coordination studies, and grounding reviews, as necessary. A system impact study shall state the assumptions upon which it is based, state the results of the analyses, and provide the requirement or potential impediments to providing the requested interconnection service, including a preliminary indication of the cost and length of time that would be necessary to correct any problems identified in those analyses and implement the interconnection. A system impact study shall provide a list of facilities that are required as a result of the Interconnection Request and non-binding good faith estimates of cost responsibility and time to construct.
- 6.0 A distribution system impact study shall incorporate a distribution load flow study, an analysis of equipment interrupting ratings, protection coordination study, voltage drop and flicker studies, protection and set point coordination studies, grounding reviews, and the impact on electric system operation, as necessary.
- 7.0 Affected Systems may participate in the preparation of a system impact study, with a division of costs among such entities as they may agree. All Affected Systems shall be afforded an opportunity to review and comment upon a system impact study that covers potential adverse system impacts on their electric systems, and Transmission Provider has twenty (20) additional Business Days to complete a system impact study requiring review by Affected Systems.

- 8.0 If Transmission Provider uses a queuing procedure for sorting or prioritizing projects and their associated cost responsibilities for any required Network Upgrades, the system impact study shall consider all generating facilities (and with respect to paragraph 8.3 below, any identified Upgrades associated with such higher queued interconnection) that, on the date the system impact study is commenced –
- 8.1 Are directly interconnected with Transmission Provider’s electric system;
- or
- 8.2 Are interconnected with Affected Systems and may have an impact on the proposed interconnection; and
- 8.3 Have a pending higher queued Interconnection Request to interconnect with Transmission Provider’s electric system.
- 9.0 A distribution system impact study, if required, shall be completed and the results transmitted to Interconnection Customer within thirty (30) Business Days after this Agreement is signed by the Parties. A transmission system impact study, if required, shall be completed and the results transmitted to Interconnection Customer within forty-five (45) Business Days after this Agreement is signed by the Parties, or in accordance with Transmission Provider’s queuing procedures.
- 10.0 A deposit of the equivalent of the good faith estimated cost of a distribution system impact study and the one half the good faith estimated cost of a transmission system impact study may be required from Interconnection Customer.
- 11.0 Any study fees shall be based on Transmission Provider’s actual costs and will be invoiced to Interconnection Customer after the study is completed and delivered and will include a summary of professional time.
- 12.0 Interconnection Customer must pay any study costs that exceed the deposit without interest within thirty (30) Calendar Days on receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced fees, Transmission Provider shall refund such excess within thirty (30) Calendar Days of the invoice without interest.

13.0 Governing Law, Regulatory Authority, and Rules

The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____ (where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.

14.0 Amendment

The Parties may amend this Agreement by a written instrument duly executed by both Parties.

15.0 No Third-Party Beneficiaries

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

16.0 Waiver

16.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

16.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

17.0 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

18.0 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

19.0 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

20.0 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

20.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

20.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

21.0 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations

thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement under any applicable provision of the Federal Power Act and FERC’s rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC’s rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

IN WITNESS THEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider} {Insert name of Interconnection Customer}

Signed: _____

Signed: _____

Name (Printed):

Name (Printed):

Title: _____

Title: _____

**Attachment A to System
Impact Study Agreement
Assumptions Used in Conducting the System Impact Study**

The system impact study shall be based upon the results of the feasibility study, subject to any modifications in accordance with the standard Small Generator Interconnection Procedures, and the following assumptions:

1) Designation of Point of Interconnection and configuration to be studied.

2) Designation of alternative Points of Interconnection and configuration.

1) and 2) are to be completed by Interconnection Customer. Other assumptions (listed below) are to be provided by Interconnection Customer and Transmission Provider.

**Attachment 8
Facilities Study Agreement**

THIS AGREEMENT is made and entered into this ____ day of _____
 20__ by and between _____,
 a _____ organized and existing under the laws of the State of _____,
 _____, (“Interconnection Customer,”) and

_____, a _____,
organized and existing under the laws of the State
of _____,

(“Transmission Provider”). Interconnection Customer and Transmission Provider each
may be referred to as a “Party,” or collectively as the “Parties.”

RECITALS

WHEREAS, Interconnection Customer is proposing to develop a Small Generating
Facility or generating capacity addition to an existing Small Generating Facility
consistent with the Interconnection Request completed by Interconnection Customer
on _____; and

WHEREAS, Interconnection Customer desires to interconnect the Small Generating
Facility with Transmission Provider’s Transmission System;

WHEREAS, Transmission Provider has completed a system impact study and provided
the results of said study to Interconnection Customer; and

WHEREAS, Interconnection Customer has requested Transmission Provider to perform
a facilities study to specify and estimate the cost of the equipment, engineering,
procurement and construction work needed to implement the conclusions of the system
impact study in accordance with Good Utility Practice to physically and electrically
connect the Small Generating Facility with Transmission Provider’s Transmission
System.

NOW, THEREFORE, in consideration of and subject to the mutual covenants contained
herein the Parties agreed as follows:

- 1.0 When used in this Agreement, with initial capitalization, the terms specified shall
have the meanings indicated or the meanings specified in the standard Small
Generator Interconnection Procedures.
- 2.0 Interconnection Customer elects and Transmission Provider shall cause a facilities
study consistent with the standard Small Generator Interconnection Procedures to
be performed in accordance with the Open Access Transmission Tariff.
- 3.0 The scope of the facilities study shall be subject to data provided in Attachment A
to this Agreement.

- 4.0 The facilities study shall specify and estimate the cost of the equipment, engineering, procurement and construction work (including overheads) needed to implement the conclusions of the system impact study(s). The facilities study shall also identify (1) the electrical switching configuration of the equipment, including, without limitation, transformer, switchgear, meters, and other station equipment, (2) the nature and estimated cost of Transmission Provider's Interconnection Facilities and Upgrades necessary to accomplish the interconnection, and (3) an estimate of the time required to complete the construction and installation of such facilities.
- 5.0 Transmission Provider may propose to group facilities required for more than one Interconnection Customer in order to minimize facilities costs through economies of scale, but any Interconnection Customer may require the installation of facilities required for its own Small Generating Facility if it is willing to pay the costs of those facilities.
- 6.0 A deposit of the good faith estimated facilities study costs may be required from Interconnection Customer.
- 7.0 In cases where Upgrades are required, the facilities study must be completed within forty-five (45) Business Days of the receipt of this Agreement. In cases where no Upgrades are necessary, and the required facilities are limited to Interconnection Facilities, the facilities study must be completed within thirty (30) Business Days.
- 8.0 Once the facilities study is completed, a "draft" facilities study report shall be prepared and transmitted to Interconnection Customer. Barring unusual circumstances, the facilities study must be completed and the "draft" facilities study report transmitted within thirty (30) Business Days of Interconnection Customer's agreement to conduct a facilities study.
- 9.0 Interconnection Customer may, within thirty (30) Calendar Days after receipt of the draft report, provide written comments to Transmission Provider, which Transmission Provider shall include in the final report. Transmission Provider shall issue the final Interconnection Facilities Study report within fifteen (15) Business Days of receiving Interconnection Customer's comments or promptly upon receiving Interconnection Customer's statement that it will not provide comments. Transmission Provider may reasonably extend such fifteen-day period upon notice to Interconnection Customer if Interconnection Customer's

comments require Transmission Provider to perform additional analyses or make other significant modifications prior to the issuance of the final Interconnection Facilities Report. Upon request, Transmission Provider shall provide Interconnection Customer supporting documentation, workpapers, and databases or data developed in the preparation of the Interconnection Facilities Study, subject to confidentiality arrangements consistent with Section 4.5 of the standard Small Generator Interconnection Procedures.

- 10.0 Within ten (10) Business Days of providing a draft Interconnection Facilities Study report to Interconnection Customer, Transmission Provider and Interconnection Customer shall meet to discuss the results of the Interconnection Facilities Study.
- 11.0 Any study fees shall be based on Transmission Provider's actual costs and will be invoiced to Interconnection Customer after the study is completed and delivered and will include a summary of professional time.
- 12.0 Interconnection Customer must pay any study costs that exceed the deposit without interest within thirty (30) Calendar Days on receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced fees, Transmission Provider shall refund such excess within thirty (30) Calendar Days of the invoice without interest.

13.0 Governing Law, Regulatory Authority, and Rules

The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____ (where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.

14.0 Amendment

The Parties may amend this Agreement by a written instrument duly executed by both Parties.

15.0 No Third-Party Beneficiaries

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or

entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

16.0 Waiver

16.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

16.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

17.0 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

18.0 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

19.0 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

20.0 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

20.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

20.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

21.0 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement under any applicable provision of the Federal Power Act and FERC's rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be duly executed by their duly authorized officers or agents on the day and year first above written.

{Insert name of Transmission Provider} {Insert name of Interconnection Customer}

Signed _____

Signed _____

Name (Printed):

Name (Printed):

Title _____

Title _____

**Attachment A to
Facilities Study Agreement
Data to Be Provided by Interconnection Customer
with the Facilities Study Agreement**

Provide location plan and simplified one-line diagram of the plant and station facilities. For staged projects, please indicate future generation, transmission circuits, etc.

On the one-line diagram, indicate the generation capacity attached at each metering location. (Maximum load on CT/PT)

On the one-line diagram, indicate the location of auxiliary power. (Minimum load on CT/PT) Amps

One set of metering is required for each generation connection to the new ring bus or existing Transmission Provider station. Number of generation connections:

Will an alternate source of auxiliary power be available during CT/PT maintenance?

Yes ____ No ____

Will a transfer bus on the generation side of the metering require that each meter set be designed for the total plant generation? Yes ____ No ____

(Please indicate on the one-line diagram).

What type of control system or PLC will be located at the Small Generating Facility?

What protocol does the control system or PLC use?

Please provide a 7.5-minute quadrangle map of the site. Indicate the plant, station, transmission line, and property lines.

Physical dimensions of the proposed interconnection station:

_____ Bus length from generation to interconnection station:

_____ Line length from interconnection station to Transmission Provider's Transmission System.

_____ Tower number observed in the field. (Painted on tower leg)*:

_____ Number of third party easements required for transmission lines*:

_____ Record Content Description, Tariff Record Title, Record Version

Number, Option Code:
 OATT Attachment P, ATTACHMENT P Small Generator Int. Agreement, 4.0.0, A

Record Narrative Name:
 Tariff Record ID: 64

Tariff Record Collation Value: 64005 Tariff Record Parent Identifier: 0

Proposed Date: 2024-05-17

Priority Order: 501

Record Change Type: CHANGE

Record Content Type: 1

Associated Filing Identifier:

ATTACHMENT P

Small Generator Interconnection Agreement

**SMALL GENERATOR
INTERCONNECTION AGREEMENT (SGIA)**

(For Generating Facilities No Larger Than 20 MW)

TABLE OF CONTENTS

	Page No.
<u>Article 1. Scope and Limitations of Agreement</u>	- 2 -
<u>1.5 Responsibilities of the Parties</u>	- 2 -
<u>1.6 Parallel Operation Obligations</u>	- 5 -
<u>1.7 Metering</u>	- 5 -
<u>1.8 Reactive Power and Primary Frequency Response</u>	- 5 -
<u>1.8.1 Power Factor Design Criteria</u>	- 5 -
<u>1.8.4 Primary Frequency Response</u>	- 7 -
<u>Article 2. Inspection, Testing, Authorization, and Right of Access</u>	- 10 -
<u>2.1 Equipment Testing and Inspection</u>	- 11 -
<u>2.2 Authorization Required Prior to Parallel Operation</u>	- 11 -
<u>2.3 Right of Access</u>	- 12 -
<u>Article 3. Effective Date, Term, Termination, and Disconnection</u>	- 12 -
<u>3.1 Effective Date</u>	- 12 -
<u>3.2 Term of Agreement</u>	- 13 -
<u>3.3 Termination</u>	- 13 -
<u>3.4 Temporary Disconnection</u>	- 14 -
<u>3.4.1 Emergency Conditions</u>	- 14 -
<u>3.4.2 Routine Maintenance, Construction, and Repair</u>	- 15 -
<u>3.4.3 Forced Outages</u>	- 15 -
<u>3.4.4 Adverse Operating Effects</u>	- 15 -
<u>3.4.5 Modification of the Small Generating Facility</u>	- 16 -
<u>3.4.6 Reconnection</u>	- 16 -

Article 4. Cost Responsibility for Interconnection Facilities and Distribution Upgrades - 16 -

 4.1 Interconnection Facilities - 16 -

 4.2 Distribution Upgrades - 17 -

Article 5. Cost Responsibility for Network Upgrades..... - 17 -

 5.1 Applicability - 17 -

 5.2 Network Upgrades - 17 -

 5.2.1 Repayment of Amounts Advanced for Network Upgrades..... - 17 -

 5.3 Special Provisions for Affected Systems - 19 -

 5.4 Rights Under Other Agreements - 19 -

Article 6. Billing, Payment, Milestones, and Financial Security - 19 -

 6.1 Billing and Payment Procedures and Final Accounting - 19 -

 6.2 Milestones - 20 -

 6.3 Financial Security Arrangements - 20 -

Article 7. Assignment, Liability, Indemnity, Force Majeure, Consequential Damages, and Default..... - 21 -

 7.1 Assignment - 21 -

 7.2 Limitation of Liability..... - 22 -

 7.3 Indemnity..... - 22 -

 7.4 Consequential Damages..... - 23 -

 7.5 Force Majeure..... - 24 -

 7.6 Default - 24 -

Article 8. Insurance..... - 25 -

Article 9. Confidentiality..... - 26 -

Article 10. Disputes..... - 27 -

Article 11. Taxes..... - 28 -

Article 12. Miscellaneous..... - 28 -

 12.1 Governing Law, Regulatory Authority, and Rules..... - 28 -

 12.2 Amendment - 28 -

 12.3 No Third-Party Beneficiaries..... - 29 -

 12.4 Waiver - 29 -

 12.5 Entire Agreement..... - 29 -

 12.6 Multiple Counterparts..... - 30 -

 12.7 No Partnership..... - 30 -

[12.8 Severability](#) - 30 -

[12.9 Security Arrangements](#)..... - 30 -

[12.10 Environmental Releases](#) - 30 -

[12.11 Subcontractors](#)..... - 31 -

[12.12 Reservation of Rights](#) - 31 -

[Article 13. Notices](#)..... - 32 -

[13.1 General](#) - 32 -

[13.2 Billing and Payment](#)..... - 33 -

[13.3 Alternative Forms of Notice](#) - 33 -

[13.4 Designated Operating Representative](#)..... - 34 -

[13.5 Changes to the Notice Information](#) - 35 -

[Article 14. Signatures](#)..... - 36 -

[Attachment 1](#) – Glossary of Terms

[Attachment 2](#) – Description and Costs of the Small Generating Facility, Interconnection Facilities, and Metering Equipment

[Attachment 3](#) – One-line Diagram Depicting the Small Generating Facility, Interconnection Facilities, Metering Equipment, and Upgrades

[Attachment 4](#) – Milestones

[Attachment 5](#) – Additional Operating Requirements for Transmission Provider’s Transmission System and Affected Systems Needed to Support Interconnection Customer’s Needs

[Attachment 6](#) – Transmission Provider’s Description of its Upgrades and Best Estimate of Upgrade Costs

This Interconnection Agreement (“Agreement”) is made and entered into this _____ day of _____, 20__, by

(“Transmission Provider”), and

(“Interconnection Customer”) each hereinafter sometimes referred to individually as “Party” or both referred to collectively as the “Parties.”

Transmission Provider Information

Transmission Provider: _____

Attention: _____

Address: _____

City: _____ State: _____ Zip: _____

Phone: _____ Fax: _____

Interconnection Customer Information

Interconnection Customer: _____

Attention: _____

Address: _____

City: _____ State: _____ Zip: _____

Phone: _____ Fax: _____

Interconnection Customer Application No: _____

In consideration of the mutual covenants set forth herein, the Parties agree as follows:

Article 1. Scope and Limitations of Agreement

1.1 Applicability

This Agreement shall be used for all Interconnection Requests submitted under the Small Generator Interconnection Procedures (SGIP) except for those submitted under the 10 kW Inverter Process contained in SGIP Attachment 5.

1.2 Purpose

This Agreement governs the terms and conditions under which Interconnection Customer's Small Generating Facility will interconnect with, and operate in parallel with, Transmission Provider's Transmission System.

1.3 No Agreement to Purchase or Deliver Power

This Agreement does not constitute an agreement to purchase or deliver Interconnection Customer's power. The purchase or delivery of power and other services that Interconnection Customer may require will be covered under separate agreements, if any. Interconnection Customer will be responsible for separately making all necessary arrangements (including scheduling) for delivery of electricity with the applicable Transmission Provider.

1.4 Limitations

Nothing in this Agreement is intended to affect any other agreement between Transmission Provider and Interconnection Customer.

1.5 Responsibilities of the Parties

1.5.1 The Parties shall perform all obligations of this Agreement in accordance with all Applicable Laws and Regulations, Operating Requirements, and Good Utility Practice.

1.5.2 Interconnection Customer shall construct, interconnect, operate and maintain its Small Generating Facility and construct, operate, and maintain its Interconnection Facilities in accordance with the applicable manufacturer's recommended maintenance schedule, and in accordance with this Agreement, and with Good Utility Practice.

- 1.5.3 Transmission Provider shall construct, operate, and maintain its Transmission System and Interconnection Facilities in accordance with this Agreement, and with Good Utility Practice.
- 1.5.4 Interconnection Customer agrees to construct its facilities or systems in accordance with applicable specifications that meet or exceed those provided by the National Electrical Safety Code, the American National Standards Institute, IEEE, Underwriter's Laboratory, and Operating Requirements in effect at the time of construction and other applicable national and state codes and standards. Interconnection Customer agrees to design, install, maintain, and operate its Small Generating Facility so as to reasonably minimize the likelihood of a disturbance adversely affecting or impairing the system or equipment of Transmission Provider and any Affected Systems.
- 1.5.5 Each Party shall operate, maintain, repair, and inspect, and shall be fully responsible for the facilities that it now or subsequently may own unless otherwise specified in the Attachments to this Agreement. Each Party shall be responsible for the safe installation, maintenance, repair and condition of their respective lines and appurtenances on their respective sides of the point of change of ownership. Transmission Provider and Interconnection Customer, as appropriate, shall provide Interconnection Facilities that adequately protect Transmission Provider's Transmission System, personnel, and other persons from damage and injury. The allocation of responsibility for the design, installation, operation, maintenance and ownership of Interconnection Facilities shall be delineated in the Attachments to this Agreement.
- 1.5.6 Transmission Provider shall coordinate with all Affected Systems to support the interconnection.
- 1.5.7 Interconnection Customer shall ensure "frequency ride through" capability and "voltage ride through" capability of its Small Generating Facility. Interconnection Customer shall enable these capabilities such that its Small Generating Facility shall not disconnect automatically or instantaneously from the system or equipment of Transmission Provider and any Affected Systems for a defined under-frequency or over-frequency condition, or an

under-voltage or over-voltage condition, as tested pursuant to Section 2.1 of this agreement. The defined conditions shall be in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. The Small Generating Facility's protective equipment settings shall comply with Transmission Provider's automatic load-shed program. Transmission Provider shall review the protective equipment settings to confirm compliance with the automatic load-shed program. The term "ride through" as used herein shall mean the ability of a Small Generating Facility to stay connected to and synchronized with the system or equipment of Transmission Provider and any Affected Systems during system disturbances within a range of conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. The term "frequency ride through" as used herein shall mean the ability of a Small Generating Facility to stay connected to and synchronized with the system or equipment of Transmission Provider and any Affected Systems during system disturbances within a range of under-frequency and over-frequency conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. The term "voltage ride through" as used herein shall mean the ability of a Small Generating Facility to stay connected to and synchronized with the system or equipment of Transmission Provider and any Affected Systems during system disturbances within a range of under-voltage and over-voltage conditions, in accordance with Good Utility Practice and consistent with any standards and guidelines that are applied to other generating facilities in the Balancing Authority Area on a comparable basis. For abnormal frequency conditions and voltage conditions within the "no trip zone" defined by Reliability Standard PRC-024-3 or successor mandatory ride through Applicable Reliability Standards, the non-synchronous Small Generating Facility must ensure that, within any physical limitations of the Small Generating Facility, its control and protection settings are configured or set to (1) continue active power production during disturbance and post disturbance periods at pre-disturbance levels unless reactive power priority mode is enabled or unless providing primary frequency response or fast frequency response; (2) minimize reductions in active power and remain within dynamic voltage and current limits, if reactive power priority mode is enabled, unless providing primary frequency response or fast frequency response; (3) not artificially limit dynamic reactive power capability during disturbances; and

(4) return to pre-disturbance active power levels without artificial ramp rate limits if active power is reduced, unless providing primary frequency response or fast frequency response.

1.6 Parallel Operation Obligations

Once the Small Generating Facility has been authorized to commence parallel operation, Interconnection Customer shall abide by all rules and procedures pertaining to the parallel operation of the Small Generating Facility in the applicable Balancing Authority Area, including, but not limited to; 1) the rules and procedures concerning the operation of generation set forth in the Tariff or by the applicable system operator(s) for Transmission Provider's Transmission System and; 2) the Operating Requirements set forth in Attachment 5 of this Agreement.

1.7 Metering

Interconnection Customer shall be responsible for Transmission Provider's reasonable and necessary cost for the purchase, installation, operation, maintenance, testing, repair, and replacement of metering and data acquisition equipment specified in Attachments 2 and 3 of this Agreement. Interconnection Customer's metering (and data acquisition, as required) equipment shall conform to applicable industry rules and Operating Requirements.

1.8 Reactive Power and Primary Frequency Response

1.8.1 Power Factor Design Criteria

1.8.1.1 Synchronous Generation. Interconnection Customer shall design its Small Generating Facility to maintain a composite power delivery at continuous rated power output at the Point of Interconnection at a power factor within the range of 0.95 leading to 0.95 lagging, unless Transmission Provider has established different requirements that apply to all similarly situated synchronous generators in the Balancing Authority Area on a comparable basis.

1.8.1.2 Non-Synchronous Generation. Interconnection Customer shall design its Small Generating Facility to maintain a composite power delivery at continuous rated power output at the high-side of the

generator substation at a power factor within the range of 0.95 leading to 0.95 lagging, unless Transmission Provider has established a different power factor range that applies to all similarly situated non-synchronous generators in the Balancing Authority Area on a comparable basis. This power factor range standard shall be dynamic and can be met using, for example, power electronics designed to supply this level of reactive capability (taking into account any limitations due to voltage level, real power output, etc.) or fixed and switched capacitors, or a combination of the two. This requirement shall only apply to newly interconnecting non-synchronous generators that have not yet executed a Facilities Study Agreement as of the effective date of the Final Rule establishing this requirement (Order No. 827).

- 1.8.2 Transmission Provider is required to pay Interconnection Customer for reactive power that Interconnection Customer provides or absorbs from the Small Generating Facility when Transmission Provider requests Interconnection Customer to operate its Small Generating Facility outside the range specified in Article 1.8.1. In addition, if Transmission Provider pays its own or affiliated generators for reactive power service within the specified range, it must also pay Interconnection Customer.
- 1.8.3 Payments shall be in accordance with Interconnection Customer's applicable rate schedule then in effect unless the provision of such service(s) is subject to a regional transmission organization or independent system operator FERC-approved rate schedule. To the extent that no rate schedule is in effect at the time Interconnection Customer is required to provide or absorb reactive power under this Agreement, the Parties agree to expeditiously file such rate schedule and agree to support any request for waiver of the Commission's prior notice requirement in order to compensate Interconnection Customer from the time service commenced.
- 1.8.4 Primary Frequency Response. Interconnection Customer shall ensure the primary frequency response capability of its Small Generating Facility by installing, maintaining, and operating a functioning governor or equivalent controls. The term "functioning governor or equivalent controls" as used herein shall mean the required hardware and/or software that provides frequency responsive real power control with the ability to sense changes in

system frequency and autonomously adjust the Small Generating Facility's real power output in accordance with the droop and deadband parameters and in the direction needed to correct frequency deviations. Interconnection Customer is required to install a governor or equivalent controls with the capability of operating: (1) with a maximum 5 percent droop and ± 0.036 Hz deadband; or (2) in accordance with the relevant droop, deadband, and timely and sustained response settings from an approved Electric Reliability Organization reliability standard providing for equivalent or more stringent parameters. The droop characteristic shall be: (1) based on the nameplate capacity of the Small Generating Facility, and shall be linear in the range of frequencies between 59 to 61 Hz that are outside of the deadband parameter; or (2) based on an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter. The deadband parameter shall be: the range of frequencies above and below nominal (60 Hz) in which the governor or equivalent controls is not expected to adjust the Small Generating Facility's real power output in response to frequency deviations. The deadband shall be implemented: (1) without a step to the droop curve, that is, once the frequency deviation exceeds the deadband parameter, the expected change in the Small Generating Facility's real power output in response to frequency deviations shall start from zero and then increase (for under-frequency deviations) or decrease (for over-frequency deviations) linearly in proportion to the magnitude of the frequency deviation; or (2) in accordance with an approved Electric Reliability Organization reliability standard providing for an equivalent or more stringent parameter. Interconnection Customer shall notify Transmission Provider that the primary frequency response capability of the Small Generating Facility has been tested and confirmed during commissioning. Once Interconnection Customer has synchronized the Small Generating Facility with the Transmission System, Interconnection Customer shall operate the Small Generating Facility consistent with the provisions specified in Sections 1.8.4.1 and 1.8.4.2 of this Agreement. The primary frequency response requirements contained herein shall apply to both synchronous and non-synchronous Small Generating Facilities.

1.8.4.1 Governor or Equivalent Controls. Whenever the Small Generating Facility is operated in parallel with the Transmission System, Interconnection Customer shall operate the Small Generating Facility with its governor or equivalent controls in service and responsive to frequency. Interconnection Customer

shall: (1) in coordination with Transmission Provider and/or the relevant Balancing Authority, set the deadband parameter to: (1) a maximum of ± 0.036 Hz and set the droop parameter to a maximum of 5 percent; or (2) implement the relevant droop and deadband settings from an approved Electric Reliability Organization reliability standard that provides for equivalent or more stringent parameters. Interconnection Customer shall be required to provide the status and settings of the governor or equivalent controls to Transmission Provider and/or the relevant Balancing Authority upon request. If Interconnection Customer needs to operate the Small Generating Facility with its governor or equivalent controls not in service, Interconnection Customer shall immediately notify Transmission Provider and the relevant Balancing Authority, and provide both with the following information: (1) the operating status of the governor or equivalent controls (i.e., whether it is currently out of service or when it will be taken out of service); (2) the reasons for removing the governor or equivalent controls from service; and (3) a reasonable estimate of when the governor or equivalent controls will be returned to service. Interconnection Customer shall make Reasonable Efforts to return its governor or equivalent controls into service as soon as practicable. Interconnection Customer shall make Reasonable Efforts to keep outages of the Small Generating Facility's governor or equivalent controls to a minimum whenever the Small Generating Facility is operated in parallel with the Transmission System.

1.8.4.2 Timely and Sustained Response. Interconnection Customer shall ensure that the Small Generating Facility's real power response to sustained frequency deviations outside of the deadband setting is automatically provided and shall begin immediately after frequency deviates outside of the deadband, and to the extent the Small Generating Facility has operating capability in the direction needed to correct the frequency deviation. Interconnection Customer shall not block or otherwise inhibit the ability of the governor or equivalent controls to respond and shall ensure that the response is not inhibited, except under certain operational constraints including, but not limited to, ambient temperature limitations, physical energy limitations, outages of mechanical equipment, or regulatory requirements. The Small

Generating Facility shall sustain the real power response at least until system frequency returns to a value within the deadband setting of the governor or equivalent controls. A Commission-approved Reliability Standard with equivalent or more stringent requirements shall supersede the above requirements.

- 1.8.4.3 Exemptions. Small Generating Facilities that are regulated by the United States Nuclear Regulatory Commission shall be exempt from Sections 1.8.4, 1.8.4.1, and 1.8.4.2 of this Agreement. Small Generating Facilities that are behind the meter generation that is sized-to-load (i.e., the thermal load and the generation are near-balanced in real-time operation and the generation is primarily controlled to maintain the unique thermal, chemical, or mechanical output necessary for the operating requirements of its host facility) shall be required to install primary frequency response capability in accordance with the droop and deadband capability requirements specified in Section 1.8.4, but shall be otherwise exempt from the operating requirements in Sections 1.8.4, 1.8.4.1, 1.8.4.2, and 1.8.4.4 of this Agreement.
- 1.8.4.4 Electric Storage Resources. Interconnection Customer interconnecting an electric storage resource shall establish an operating range in Attachment 5 of its SGIA that specifies a minimum state of charge and a maximum state of charge between which the electric storage resource will be required to provide primary frequency response consistent with the conditions set forth in Sections 1.8.4, 1.8.4.1, 1.8.4.2 and 1.8.4.3 of this Agreement. Attachment 5 shall specify whether the operating range is static or dynamic, and shall consider: (1) the expected magnitude of frequency deviations in the interconnection; (2) the expected duration that system frequency will remain outside of the deadband parameter in the interconnection; (3) the expected incidence of frequency deviations outside of the deadband parameter in the interconnection; (4) the physical capabilities of the electric storage resource; (5) operational limitations of the electric storage resource due to manufacturer specifications; and (6) any other relevant factors agreed to by Transmission Provider and Interconnection Customer, and in consultation with the relevant transmission owner or Balancing Authority as appropriate. If the operating range is dynamic, then Attachment 5 must establish how

frequently the operating range will be reevaluated and the factors that may be considered during its reevaluation.

Interconnection Customer's electric storage resource is required to provide timely and sustained primary frequency response consistent with Section 1.8.4.2 of this Agreement when it is online and dispatched to inject electricity to the Transmission System and/or receive electricity from the Transmission System. This excludes circumstances when the electric storage resource is not dispatched to inject electricity to the Transmission System and/or dispatched to receive electricity from the Transmission System. If Interconnection Customer's electric storage resource is charging at the time of a frequency deviation outside of its deadband parameter, it is to increase (for over-frequency deviations) or decrease (for under-frequency deviations) the rate at which it is charging in accordance with its droop parameter. Interconnection Customer's electric storage resource is not required to change from charging to discharging, or vice versa, unless the response necessitated by the droop and deadband settings requires it to do so and it is technically capable of making such a transition.

- 1.9 Capitalized terms used herein shall have the meanings specified in the Glossary of Terms in Attachment 1 or the body of this Agreement.

Article 2. Inspection, Testing, Authorization, and Right of Access

2.1 Equipment Testing and Inspection

- 2.1.1 Interconnection Customer shall test and inspect its Small Generating Facility and Interconnection Facilities prior to interconnection. Interconnection Customer shall notify Transmission Provider of such activities no fewer than five (5) Business Days (or as may be agreed to by the Parties) prior to such testing and inspection. Testing and inspection shall occur on a Business Day. Transmission Provider may, at its own expense, send qualified personnel to the Small Generating Facility site to inspect the interconnection and observe the testing. Interconnection Customer shall provide Transmission Provider a written test report when such testing and inspection is completed.

2.1.2 Transmission Provider shall provide Interconnection Customer written acknowledgment that it has received Interconnection Customer's written test report. Such written acknowledgment shall not be deemed to be or construed as any representation, assurance, guarantee, or warranty by Transmission Provider of the safety, durability, suitability, or reliability of the Small Generating Facility or any associated control, protective, and safety devices owned or controlled by Interconnection Customer or the quality of power produced by the Small Generating Facility.

2.2 Authorization Required Prior to Parallel Operation

2.2.1 Transmission Provider shall use Reasonable Efforts to list applicable parallel operation requirements in Attachment 5 of this Agreement. Additionally, Transmission Provider shall notify Interconnection Customer of any changes to these requirements as soon as they are known. Transmission Provider shall make Reasonable Efforts to cooperate with Interconnection Customer in meeting requirements necessary for Interconnection Customer to commence parallel operations by the in-service date.

2.2.2 Interconnection Customer shall not operate its Small Generating Facility in parallel with Transmission Provider's Transmission System without prior written authorization of Transmission Provider. Transmission Provider will provide such authorization once Transmission Provider receives notification that Interconnection Customer has complied with all applicable parallel operation requirements. Such authorization shall not be unreasonably withheld, conditioned, or delayed.

2.3 Right of Access

2.3.1 Upon reasonable notice, Transmission Provider may send a qualified person to the premises of Interconnection Customer at or immediately before the time the Small Generating Facility first produces energy to inspect the interconnection, and observe the commissioning of the Small Generating Facility (including any required testing), startup, and operation

for a period of up to three (3) Business Days after initial start-up of the unit. In addition, Interconnection Customer shall notify Transmission Provider at least five (5) Business Days prior to conducting any on-site verification testing of the Small Generating Facility.

2.3.2 Following the initial inspection process described above, at reasonable hours, and upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition, Transmission Provider shall have access to Interconnection Customer's premises for any reasonable purpose in connection with the performance of the obligations imposed on it by this Agreement or if necessary to meet its legal obligation to provide service to its customers.

2.3.3 Each Party shall be responsible for its own costs associated with following this article.

Article 3. Effective Date, Term, Termination, and Disconnection

3.1 Effective Date

This Agreement shall become effective upon execution by the Parties subject to acceptance by FERC (if applicable), or if filed unexecuted, upon the date specified by the FERC. Transmission Provider shall promptly file this Agreement with the FERC upon execution, if required.

3.2 Term of Agreement

This Agreement shall become effective on the Effective Date and shall remain in effect for a period of ten years from the Effective Date or such other longer period as Interconnection Customer may request and shall be automatically renewed for each successive one-year period thereafter, unless terminated earlier in accordance with article 3.3 of this Agreement.

3.3 Termination

No termination shall become effective until the Parties have complied with all Applicable Laws and Regulations applicable to such termination, including the filing with FERC of a notice of termination of this Agreement (if required), which notice has been accepted for filing by FERC.

- 3.3.1 Interconnection Customer may terminate this Agreement at any time by giving Transmission Provider twenty (20) Business Days written notice.
 - 3.3.2 Either Party may terminate this Agreement after Default pursuant to article 7.6.
 - 3.3.3 Upon termination of this Agreement, the Small Generating Facility will be disconnected from Transmission Provider's Transmission System. All costs required to effectuate such disconnection shall be borne by the terminating Party, unless such termination resulted from the non-terminating Party's Default of this SGIA or such non-terminating Party otherwise is responsible for these costs under this SGIA.
 - 3.3.4 The termination of this Agreement shall not relieve either Party of its liabilities and obligations, owed or continuing at the time of the termination.
 - 3.3.5 The provisions of this article shall survive termination or expiration of this Agreement.
- 3.4 Temporary Disconnection
- Temporary disconnection shall continue only for so long as reasonably necessary under Good Utility Practice.
- 3.4.1 Emergency Conditions – “Emergency Condition” shall mean a condition or situation: (1) that in the judgment of the Party making the claim is imminently likely to endanger life or property; or (2) that, in the case of Transmission Provider, is imminently likely (as determined in a non-discriminatory manner) to cause a material adverse effect on the security of, or damage to the Transmission System, Transmission Provider's Interconnection Facilities or the Transmission Systems of others to which the Transmission System is directly connected; or (3) that, in the case of Interconnection Customer, is imminently likely (as determined in a

non-discriminatory manner) to cause a material adverse effect on the security of, or damage to, the Small Generating Facility or Interconnection Customer's Interconnection Facilities. Under Emergency Conditions, Transmission Provider may immediately suspend interconnection service and temporarily disconnect the Small Generating Facility. Transmission Provider shall notify Interconnection Customer promptly when it becomes aware of an Emergency Condition that may reasonably be expected to affect Interconnection Customer's operation of the Small Generating Facility. Interconnection Customer shall notify Transmission Provider promptly when it becomes aware of an Emergency Condition that may reasonably be expected to affect Transmission Provider's Transmission System or any Affected Systems. To the extent information is known, the notification shall describe the Emergency Condition, the extent of the damage or deficiency, the expected effect on the operation of both Parties' facilities and operations, its anticipated duration, and the necessary corrective action.

3.4.2 Routine Maintenance, Construction, and Repair

Transmission Provider may interrupt interconnection service or curtail the output of the Small Generating Facility and temporarily disconnect the Small Generating Facility from Transmission Provider's Transmission System when necessary for routine maintenance, construction, and repairs on Transmission Provider's Transmission System. Transmission Provider shall provide Interconnection Customer with five (5) Business Days notice prior to such interruption. Transmission Provider shall use Reasonable Efforts to coordinate such reduction or temporary disconnection with Interconnection Customer.

3.4.3 Forced Outages

During any forced outage, Transmission Provider may suspend interconnection service to effect immediate repairs on Transmission Provider's Transmission System. Transmission Provider shall use Reasonable Efforts to provide Interconnection Customer with prior notice. If prior notice is not given, Transmission Provider shall, upon request, provide Interconnection Customer written documentation after the fact explaining the circumstances of the disconnection.

3.4.4 Adverse Operating Effects

Transmission Provider shall notify Interconnection Customer as soon as practicable if, based on Good Utility Practice, operation of the Small Generating Facility may cause disruption or deterioration of service to other customers served from the same electric system, or if operating the Small Generating Facility could cause damage to Transmission Provider's Transmission System or Affected Systems. Supporting documentation used to reach the decision to disconnect shall be provided to Interconnection Customer upon request. If, after notice, Interconnection Customer fails to remedy the adverse operating effect within a reasonable time, Transmission Provider may disconnect the Small Generating Facility. Transmission Provider shall provide Interconnection Customer with five Business Day notice of such disconnection, unless the provisions of article 3.4.1 apply.

3.4.5 Modification of the Small Generating Facility

Interconnection Customer must receive written authorization from Transmission Provider before making any change to the Small Generating Facility that may have a material impact on the safety or reliability of the Transmission System. Such authorization shall not be unreasonably withheld. Modifications shall be done in accordance with Good Utility Practice. If Interconnection Customer makes such modification without Transmission Provider's prior written authorization, the latter shall have the right to temporarily disconnect the Small Generating Facility.

3.4.6 Reconnection

The Parties shall cooperate with each other to restore the Small Generating Facility, Interconnection Facilities, and Transmission Provider's Transmission System to their normal operating state as soon as reasonably practicable following a temporary disconnection.

Article 4. Cost Responsibility for Interconnection Facilities and Distribution Upgrades

4.1 Interconnection Facilities

4.1.1 Interconnection Customer shall pay for the cost of the Interconnection Facilities itemized in Attachment 2 of this Agreement. Transmission Provider shall provide a best estimate cost, including overheads, for the

purchase and construction of its Interconnection Facilities and provide a detailed itemization of such costs. Costs associated with Interconnection Facilities may be shared with other entities that may benefit from such facilities by agreement of Interconnection Customer, such other entities, and Transmission Provider.

4.1.2 Interconnection Customer shall be responsible for its share of all reasonable expenses, including overheads, associated with (1) owning, operating, maintaining, repairing, and replacing its own Interconnection Facilities, and (2) operating, maintaining, repairing, and replacing Transmission Provider's Interconnection Facilities.

4.2 Distribution Upgrades

Transmission Provider shall design, procure, construct, install, and own the Distribution Upgrades described in Attachment 6 of this Agreement. If Transmission Provider and Interconnection Customer agree, Interconnection Customer may construct Distribution Upgrades that are located on land owned by Interconnection Customer. The actual cost of the Distribution Upgrades, including overheads, shall be directly assigned to Interconnection Customer.

Article 5. Cost Responsibility for Network Upgrades

5.1 Applicability

No portion of this article 5 shall apply unless the interconnection of the Small Generating Facility requires Network Upgrades.

5.2 Network Upgrades

Transmission Provider or the Transmission Owner shall design, procure, construct, install, and own the Network Upgrades described in Attachment 6 of this Agreement. If Transmission Provider and Interconnection Customer agree, Interconnection Customer may construct Network Upgrades that are located on land owned by Interconnection Customer. Unless Transmission Provider elects to pay for Network Upgrades, the actual cost of the Network Upgrades, including overheads, shall be borne initially by Interconnection Customer.

5.2.1 Repayment of Amounts Advanced for Network Upgrades
Interconnection Customer shall be entitled to a cash repayment, equal to the total amount paid to Transmission Provider and Affected System operator, if any, for Network Upgrades, including any tax gross-up or other tax-related payments associated with the Network Upgrades, and not otherwise refunded to Interconnection Customer, to be paid to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, as payments are made under Transmission Provider's Tariff and Affected System's Tariff for transmission services with respect to the Small Generating Facility. Any repayment shall include interest calculated in accordance with the methodology set forth in FERC's regulations at 18 C.F.R. § 35.19a(a)(2)(iii) from the date of any payment for Network Upgrades through the date on which Interconnection Customer receives a repayment of such payment pursuant to this subparagraph. Interconnection Customer may assign such repayment rights to any person.

5.2.1.1 Notwithstanding the foregoing, Interconnection Customer, Transmission Provider, and any applicable Affected System operators may adopt any alternative payment schedule that is mutually agreeable so long as Transmission Provider and said Affected System operators take one of the following actions no later than five years from the Commercial Operation Date: (1) return to Interconnection Customer any amounts advanced for Network Upgrades not previously repaid, or (2) declare in writing that Transmission Provider or any applicable Affected System operators will continue to provide payments to Interconnection Customer on a dollar-for-dollar basis for the non-usage sensitive portion of transmission charges, or develop an alternative schedule that is mutually agreeable and provides for the return of all amounts advanced for Network Upgrades not previously repaid; however, full reimbursement shall not extend beyond twenty (20) years from the commercial operation date.

5.2.1.2 If the Small Generating Facility fails to achieve commercial operation, but it or another generating facility is later constructed and requires use of the Network Upgrades, Transmission Provider and Affected System operator shall at that time reimburse Interconnection Customer for the amounts advanced for the Network

Upgrades. Before any such reimbursement can occur, Interconnection Customer, or the entity that ultimately constructs the generating facility, if different, is responsible for identifying the entity to which reimbursement must be made.

5.3 Special Provisions for Affected Systems

Unless Transmission Provider provides, under this Agreement, for the repayment of amounts advanced to any applicable Affected System operators for Network Upgrades, Interconnection Customer and Affected System operator shall enter into an agreement that provides for such repayment. The agreement shall specify the terms governing payments to be made by Interconnection Customer to Affected System operator as well as the repayment by Affected System operator.

5.4 Rights Under Other Agreements

Notwithstanding any other provision of this Agreement, nothing herein shall be construed as relinquishing or foreclosing any rights, including but not limited to firm transmission rights, capacity rights, transmission congestion rights, or transmission credits, that Interconnection Customer shall be entitled to, now or in the future, under any other agreement or tariff as a result of, or otherwise associated with, the transmission capacity, if any, created by the Network Upgrades, including the right to obtain cash reimbursements or transmission credits for transmission service that is not associated with the Small Generating Facility.

Article 6. Billing, Payment, Milestones, and Financial Security

6.1 Billing and Payment Procedures and Final Accounting

6.1.1 Transmission Provider shall bill Interconnection Customer for the design, engineering, construction, and procurement costs of Interconnection Facilities and Upgrades contemplated by this Agreement on a monthly basis, or as otherwise agreed by the Parties. Interconnection Customer shall pay each bill within thirty (30) Calendar Days of receipt, or as otherwise agreed to by the Parties.

6.1.2 Within three months of completing the construction and installation of Transmission Provider's Interconnection Facilities and/or Upgrades described in the Attachments to this Agreement, Transmission Provider shall provide Interconnection Customer with a final accounting report of any difference between (1) Interconnection Customer's cost responsibility for the actual cost of such facilities or Upgrades, and (2) Interconnection Customer's previous aggregate payments to Transmission Provider for such facilities or Upgrades. If Interconnection Customer's cost responsibility exceeds its previous aggregate payments, Transmission Provider shall invoice Interconnection Customer for the amount due and Interconnection Customer shall make payment to Transmission Provider within thirty (30) Calendar Days. If Interconnection Customer's previous aggregate payments exceed its cost responsibility under this Agreement, Transmission Provider shall refund to Interconnection Customer an amount equal to the difference within thirty (30) Calendar Days of the final accounting report.

6.2 Milestones

The Parties shall agree on milestones for which each Party is responsible and list them in Attachment 4 of this Agreement. A Party's obligations under this provision may be extended by agreement. If a Party anticipates that it will be unable to meet a milestone for any reason other than a Force Majeure Event, it shall immediately notify the other Party of the reason(s) for not meeting the milestone and (1) propose the earliest reasonable alternate date by which it can attain this and future milestones, and (2) requesting appropriate amendments to Attachment 4. The Party affected by the failure to meet a milestone shall not unreasonably withhold agreement to such an amendment unless it will suffer significant uncompensated economic or operational harm from the delay, (2) attainment of the same milestone has previously been delayed, or (3) it has reason to believe that the delay in meeting the milestone is intentional or unwarranted notwithstanding the circumstances explained by the Party proposing the amendment.

6.3 Financial Security Arrangements

At least twenty (20) Business Days prior to the commencement of the design, procurement, installation, or construction of a discrete portion of Transmission Provider's Interconnection Facilities and Upgrades, Interconnection Customer shall provide Transmission Provider, at Interconnection Customer's option, a guarantee, a surety bond, letter of credit or other form of security that is reasonably acceptable to Transmission Provider and is consistent with the Uniform

Commercial Code of the jurisdiction where the Point of Interconnection is located. Such security for payment shall be in an amount sufficient to cover the costs for constructing, designing, procuring, and installing the applicable portion of Transmission Provider's Interconnection Facilities and Upgrades and shall be reduced on a dollar-for-dollar basis for payments made to Transmission Provider under this Agreement during its term. In addition:

6.3.1 The guarantee must be made by an entity that meets the creditworthiness requirements of Transmission Provider, and contain terms and conditions that guarantee payment of any amount that may be due from Interconnection Customer, up to an agreed-to maximum amount.

1.3.2 The letter of credit or surety bond must be issued by a financial institution or insurer reasonably acceptable to Transmission Provider and must specify a reasonable expiration date.

Article 7. Assignment, Liability, Indemnity, Force Majeure, Consequential Damages, and Default

7.1 Assignment

This Agreement may be assigned by either Party upon fifteen (15) Business Days prior written notice and opportunity to object by the other Party; provided that:

7.1.1 Either Party may assign this Agreement without the consent of the other Party to any affiliate of the assigning Party with an equal or greater credit rating and with the legal authority and operational ability to satisfy the obligations of the assigning Party under this Agreement, provided that Interconnection Customer promptly notifies Transmission Provider of any such assignment;

7.1.2 Interconnection Customer shall have the right to assign this Agreement, without the consent of Transmission Provider, for collateral security purposes to aid in providing financing for the Small Generating Facility, provided that Interconnection Customer will promptly notify Transmission Provider of any such assignment.

7.1.3 Any attempted assignment that violates this article is void and ineffective. Assignment shall not relieve a Party of its obligations, nor shall a Party's obligations be enlarged, in whole or in part, by reason thereof. An assignee is responsible for meeting the same financial, credit, and insurance obligations as Interconnection Customer. Where required, consent to assignment will not be unreasonably withheld, conditioned or delayed.

7.2 Limitation of Liability

Each Party's liability to the other Party for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of this Agreement, shall be limited to the amount of direct damage actually incurred. In no event shall either Party be liable to the other Party for any indirect, special, consequential, or punitive damages, except as authorized by this Agreement.

7.3 Indemnity

7.3.1 This provision protects each Party from liability incurred to third parties as a result of carrying out the provisions of this Agreement. Liability under this provision is exempt from the general limitations on liability found in article 7.2.

7.3.2 The Parties shall at all times indemnify, defend, and hold the other Party harmless from, any and all damages, losses, claims, including claims and actions relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other Party's action or failure to meet its obligations under this Agreement on behalf of the indemnifying Party, except in cases of gross negligence or intentional wrongdoing by the indemnified Party.

7.3.3 If an indemnified person is entitled to indemnification under this article as a result of a claim by a third party, and the indemnifying Party fails, after notice and reasonable opportunity to proceed under this article, to assume the defense of such claim, such indemnified person may at the expense of

the indemnifying Party contest, settle or consent to the entry of any judgment with respect to, or pay in full, such claim.

7.3.4 If an indemnifying party is obligated to indemnify and hold any indemnified person harmless under this article, the amount owing to the indemnified person shall be the amount of such indemnified person's actual loss, net of any insurance or other recovery.

7.3.5 Promptly after receipt by an indemnified person of any claim or notice of the commencement of any action or administrative or legal proceeding or investigation as to which the indemnity provided for in this article may apply, the indemnified person shall notify the indemnifying party of such fact. Any failure of or delay in such notification shall not affect a Party's indemnification obligation unless such failure or delay is materially prejudicial to the indemnifying party.

7.4 Consequential Damages

Other than as expressly provided for in this Agreement, neither Party shall be liable under any provision of this Agreement for any losses, damages, costs or expenses for any special, indirect, incidental, consequential, or punitive damages, including but not limited to loss of profit or revenue, loss of the use of equipment, cost of capital, cost of temporary equipment or services, whether based in whole or in part in contract, in tort, including negligence, strict liability, or any other theory of liability; provided, however, that damages for which a Party may be liable to the other Party under another agreement will not be considered to be special, indirect, incidental, or consequential damages hereunder.

7.5 Force Majeure

7.5.1 As used in this article, a Force Majeure Event shall mean "any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, breakage or accident to machinery or equipment, any order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, or any other cause beyond a Party's control. A Force Majeure Event does not include an act of negligence or intentional wrongdoing."

7.5.2 If a Force Majeure Event prevents a Party from fulfilling any obligations under this Agreement, the Party affected by the Force Majeure Event (Affected Party) shall promptly notify the other Party, either in writing or via the telephone, of the existence of the Force Majeure Event. The notification must specify in reasonable detail the circumstances of the Force Majeure Event, its expected duration, and the steps that the Affected Party is taking to mitigate the effects of the event on its performance. The Affected Party shall keep the other Party informed on a continuing basis of developments relating to the Force Majeure Event until the event ends. The Affected Party will be entitled to suspend or modify its performance of obligations under this Agreement (other than the obligation to make payments) only to the extent that the effect of the Force Majeure Event cannot be mitigated by the use of Reasonable Efforts. The Affected Party will use Reasonable Efforts to resume its performance as soon as possible.

7.6 Default

7.6.1 No Default shall exist where such failure to discharge an obligation (other than the payment of money) is the result of a Force Majeure Event as defined in this Agreement or the result of an act or omission of the other Party. Upon a Default, the non-defaulting Party shall give written notice of such Default to the defaulting Party. Except as provided in article 7.6.2, the defaulting Party shall have sixty (60) Calendar Days from receipt of the Default notice within which to cure such Default; provided however, if such Default is not capable of cure within sixty (60) Calendar Days, the defaulting Party shall commence such cure within twenty (20) Calendar Days after notice and continuously and diligently complete such cure within six months from receipt of the Default notice; and, if cured within such time, the Default specified in such notice shall cease to exist.

7.6.2 If a Default is not cured as provided in this article, or if a Default is not capable of being cured within the period provided for herein, the non-defaulting Party shall have the right to terminate this Agreement by written notice at any time until cure occurs, and be relieved of any further obligation hereunder and, whether or not that Party terminates this Agreement, to recover from the defaulting Party all amounts due hereunder, plus all other damages and remedies to which it is entitled at law or in

equity. The provisions of this article will survive termination of this Agreement.

Article 8. Insurance

- 8.1 Interconnection Customer shall, at its own expense, maintain in force general liability insurance without any exclusion for liabilities related to the interconnection undertaken pursuant to this Agreement. The amount of such insurance shall be sufficient to insure against all reasonably foreseeable direct liabilities given the size and nature of the generating equipment being interconnected, the interconnection itself, and the characteristics of the system to which the interconnection is made. Interconnection Customer shall obtain additional insurance only if necessary as a function of owning and operating a generating facility. Such insurance shall be obtained from an insurance provider authorized to do business in the State where the interconnection is located. Certification that such insurance is in effect shall be provided upon request of Transmission Provider, except that Interconnection Customer shall show proof of insurance to Transmission Provider no later than ten (10) Business Days prior to the anticipated commercial operation date. An Interconnection Customer of sufficient credit-worthiness may propose to self-insure for such liabilities, and such a proposal shall not be unreasonably rejected.
- 8.2 Transmission Provider agrees to maintain general liability insurance or self-insurance consistent with Transmission Provider's commercial practice. Such insurance or self-insurance shall not exclude coverage for Transmission Provider's liabilities undertaken pursuant to this Agreement.
- 8.3 The Parties further agree to notify each other whenever an accident or incident occurs resulting in any injuries or damages that are included within the scope of coverage of such insurance, whether or not such coverage is sought.

Article 9. Confidentiality

- 9.1 Confidential Information shall mean any confidential and/or proprietary information provided by one Party to the other Party that is clearly marked or otherwise designated "Confidential." For purposes of this Agreement all design,

operating specifications, and metering data provided by Interconnection Customer shall be deemed Confidential Information regardless of whether it is clearly marked or otherwise designated as such.

9.2 Confidential Information does not include information previously in the public domain, required to be publicly submitted or divulged by Governmental Authorities (after notice to the other Party and after exhausting any opportunity to oppose such publication or release), or necessary to be divulged in an action to enforce this Agreement. Each Party receiving Confidential Information shall hold such information in confidence and shall not disclose it to any third party nor to the public without the prior written authorization from the Party providing that information, except to fulfill obligations under this Agreement, or to fulfill legal or regulatory requirements.

9.2.1 Each Party shall employ at least the same standard of care to protect Confidential Information obtained from the other Party as it employs to protect its own Confidential Information.

9.2.2 Each Party is entitled to equitable relief, by injunction or otherwise, to enforce its rights under this provision to prevent the release of Confidential Information without bond or proof of damages, and may seek other remedies available at law or in equity for breach of this provision.

9.3 Notwithstanding anything in this article to the contrary, and pursuant to 18 CFR § 1b.20, if FERC, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to this Agreement, the Party shall provide the requested information to FERC, within the time provided for in the request for information. In providing the information to FERC, the Party may, consistent with 18 CFR § 388.112, request that the information be treated as confidential and non-public by FERC and that the information be withheld from public disclosure. Parties are prohibited from notifying the other Party to this Agreement prior to the release of the Confidential Information to FERC. The Party shall notify the other Party to this Agreement when it is notified by FERC that a request to release Confidential Information has been received by FERC, at which time either of the Parties may respond before such information would be made public, pursuant to 18 CFR § 388.112. Requests from a state regulatory body conducting a confidential

investigation shall be treated in a similar manner if consistent with the applicable state rules and regulations.

Article 10. Disputes

- 10.1 The Parties agree to attempt to resolve all disputes arising out of the interconnection process according to the provisions of this article.
- 10.2 In the event of a dispute, either Party shall provide the other Party with a written Notice of Dispute. Such Notice shall describe in detail the nature of the dispute.
- 10.3 If the dispute has not been resolved within two (2) Business Days after receipt of the Notice, either Party may contact FERC's Dispute Resolution Service (DRS) for assistance in resolving the dispute.
- 10.4 The DRS will assist the Parties in either resolving their dispute or in selecting an appropriate dispute resolution venue (e.g., mediation, settlement judge, early neutral evaluation, or technical expert) to assist the Parties in resolving their dispute. DRS can be reached at 1-877-337-2237 or via the internet at <http://www.ferc.gov/legal/adr.asp>.
- 10.5 Each Party agrees to conduct all negotiations in good faith and will be responsible for one-half of any costs paid to neutral third-parties.
- 10.6 If neither Party elects to seek assistance from the DRS, or if the attempted dispute resolution fails, then either Party may exercise whatever rights and remedies it may have in equity or law consistent with the terms of this Agreement.

Article 11. Taxes

- 11.1 The Parties agree to follow all applicable tax laws and regulations, consistent with FERC policy and Internal Revenue Service requirements.

- 11.2 Each Party shall cooperate with the other to maintain the other Party's tax status. Nothing in this Agreement is intended to adversely affect Transmission Provider's tax exempt status with respect to the issuance of bonds including, but not limited to, local furnishing bonds.

Article 12. Miscellaneous

12.1 Governing Law, Regulatory Authority, and Rules

The validity, interpretation and enforcement of this Agreement and each of its provisions shall be governed by the laws of the state of _____ (where the Point of Interconnection is located), without regard to its conflicts of law principles. This Agreement is subject to all Applicable Laws and Regulations. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a Governmental Authority.

12.2 Amendment

The Parties may amend this Agreement by a written instrument duly executed by both Parties, or under article 12.12 of this Agreement.

12.3 No Third-Party Beneficiaries

This Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

12.4 Waiver

12.4.1 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of any provision of this Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

12.4.2 Any waiver at any time by either Party of its rights with respect to this Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, duty of this Agreement. Termination or default of this Agreement for any reason by Interconnection Customer shall not constitute a waiver of Interconnection Customer's legal rights to obtain an interconnection from Transmission Provider. Any waiver of this Agreement shall, if requested, be provided in writing.

12.5 Entire Agreement

This Agreement, including all Attachments, constitutes the entire agreement between the Parties with reference to the subject matter hereof, and supersedes all prior and contemporaneous understandings or agreements, oral or written, between the Parties with respect to the subject matter of this Agreement. There are no other agreements, representations, warranties, or covenants which constitute any part of the consideration for, or any condition to, either Party's compliance with its obligations under this Agreement.

12.6 Multiple Counterparts

This Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

12.7 No Partnership

This Agreement shall not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

12.8 Severability

If any provision or portion of this Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other Governmental Authority, (1) such portion or provision shall be deemed separate and independent, (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such

ruling, and (3) the remainder of this Agreement shall remain in full force and effect.

12.9 Security Arrangements

Infrastructure security of electric system equipment and operations and control hardware and software is essential to ensure day-to-day reliability and operational security. FERC expects all Transmission Providers, market participants, and Interconnection Customers interconnected to electric systems to comply with the recommendations offered by the President's Critical Infrastructure Protection Board and, eventually, best practice recommendations from the electric reliability authority. All public utilities are expected to meet basic standards for system infrastructure and operational security, including physical, operational, and cyber-security practices.

12.10 Environmental Releases

Each Party shall notify the other Party, first orally and then in writing, of the release of any hazardous substances, any asbestos or lead abatement activities, or any type of remediation activities related to the Small Generating Facility or the Interconnection Facilities, each of which may reasonably be expected to affect the other Party. The notifying Party shall (1) provide the notice as soon as practicable, provided such Party makes a good faith effort to provide the notice no later than 24 hours after such Party becomes aware of the occurrence, and (2) promptly furnish to the other Party copies of any publicly available reports filed with any governmental authorities addressing such events.

12.11 Subcontractors

Nothing in this Agreement shall prevent a Party from utilizing the services of any subcontractor as it deems appropriate to perform its obligations under this Agreement; provided, however, that each Party shall require its subcontractors to comply with all applicable terms and conditions of this Agreement in providing such services and each Party shall remain primarily liable to the other Party for the performance of such subcontractor.

12.11.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under this Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no

subcontract had been made; provided, however, that in no event shall Transmission Provider be liable for the actions or inactions of Interconnection Customer or its subcontractors with respect to obligations of Interconnection Customer under this Agreement. Any applicable obligation imposed by this Agreement upon the hiring Party shall be equally binding upon, and shall be construed as having application to, any subcontractor of such Party.

12.11.2 The obligations under this article will not be limited in any way by any limitation of subcontractor's insurance.

12.12 Reservation of Rights

Transmission Provider shall have the right to make a unilateral filing with FERC to modify this Agreement with respect to any rates, terms and conditions, charges, classifications of service, rule or regulation under section 205 or any other applicable provision of the Federal Power Act and FERC's rules and regulations thereunder, and Interconnection Customer shall have the right to make a unilateral filing with FERC to modify this Agreement under any applicable provision of the Federal Power Act and FERC's rules and regulations; provided that each Party shall have the right to protest any such filing by the other Party and to participate fully in any proceeding before FERC in which such modifications may be considered. Nothing in this Agreement shall limit the rights of the Parties or of FERC under sections 205 or 206 of the Federal Power Act and FERC's rules and regulations, except to the extent that the Parties otherwise agree as provided herein.

Article 13. Notices

13.1 General

Unless otherwise provided in this Agreement, any written notice, demand, or request required or authorized in connection with this Agreement ("Notice") shall be deemed properly given if delivered in person, delivered by recognized national courier service, or sent by first class mail, postage prepaid, to the person specified below:

If to Interconnection Customer:

Interconnection Customer:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

If to Transmission Provider:

Transmission Provider:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

13.2 Billing and Payment

Billings and payments shall be sent to the addresses set out below:

Interconnection Customer: _____

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Transmission Provider:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

13.3 Alternative Forms of Notice

Any notice or request required or permitted to be given by either Party to the other and not required by this Agreement to be given in writing may be so given by telephone, facsimile or e-mail to the telephone numbers and e-mail addresses set out below:

If to Interconnection Customer:

Interconnection Customer:

Attention: _____

Address:

City: _____ State: _____

Zip: _____

Phone: _____ Fax: _____

If to Transmission Provider:

Transmission Provider:

Attention: _____

Address:

City: _____ State: _____
Zip: _____
Phone: _____ Fax: _____

13.4 Designated Operating Representative

The Parties may also designate operating representatives to conduct the communications which may be necessary or convenient for the administration of this Agreement. This person will also serve as the point of contact with respect to operations and maintenance of the Party's facilities.

Interconnection Customer's Operating Representative:

Interconnection Customer:

Attention: _____
Address:

City: _____ State: _____
Zip: _____
Phone: _____ Fax: _____

Transmission Provider's Operating Representative:

Transmission Provider:

Attention: _____
Address:

City: _____ State: _____
Zip: _____
Phone: _____ Fax: _____

13.5 Changes to the Notice Information

Either Party may change this information by giving five (5) Business Days written notice prior to the effective date of the change.

Article 14. Signatures

IN WITNESS WHEREOF, the Parties have caused this Agreement to be executed by their respective duly authorized representatives.

For Transmission Provider

Name: _____

Title: _____

Date: _____

For Interconnection Customer

Name: _____

Title: _____

Date: _____

Attachment 1

Glossary of Terms

Affected System – An electric system other than Transmission Provider’s Transmission System that may be affected by the proposed interconnection.

Applicable Laws and Regulations – All duly promulgated applicable federal, state and local laws, regulations, rules, ordinances, codes, decrees, judgments, directives, or judicial or administrative orders, permits and other duly authorized actions of any Governmental Authority.

Applicable Reliability Standards - The requirements and guidelines of the Electric Reliability Organization and the Balancing Authority Area of the Transmission System to which the Generating Facility is directly interconnected.

Balancing Authority – An entity that integrates resource plans ahead of time, maintains demand and resource balance within a Balancing Authority Area, and supports interconnection frequency in real time.

Balancing Authority Area – The collection of generation, transmission, and loads within the metered boundaries of the Balancing Authority. The Balancing Authority maintains load-resource balance within this area.

Business Day – Monday through Friday, excluding Federal Holidays.

Default – The failure of a breaching Party to cure its breach under the Small Generator Interconnection Agreement.

Distribution System – Transmission Provider’s facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby generators or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which Distribution Systems operate differ among areas.

Distribution Upgrades – The additions, modifications, and upgrades to Transmission Provider’s Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Small Generating Facility and render the transmission service

necessary to effect Interconnection Customer's wholesale sale of electricity in interstate commerce. Distribution Upgrades do not include Interconnection Facilities.

Good Utility Practice – Any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Governmental Authority – Any federal, state, local or other governmental regulatory or administrative agency, court, commission, department, board, or other governmental subdivision, legislature, rulemaking board, tribunal, or other governmental authority having jurisdiction over the Parties, their respective facilities, or the respective services they provide, and exercising or entitled to exercise any administrative, executive, police, or taxing authority or power; provided, however, that such term does not include Interconnection Customer, the Interconnection Provider, or any Affiliate thereof.

Interconnection Customer – Any entity, including Transmission Provider, the Transmission Owner or any of the affiliates or subsidiaries of either, that proposes to interconnect its Small Generating Facility with Transmission Provider's Transmission System.

Interconnection Facilities – Transmission Provider's Interconnection Facilities and Interconnection Customer's Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Small Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the Small Generating Facility to Transmission Provider's Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades or Network Upgrades.

Interconnection Request – Interconnection Customer's request, in accordance with the Tariff, to interconnect a new Small Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Small Generating Facility that is interconnected with Transmission Provider's Transmission System.

Material Modification – A modification that has a material impact on the cost or timing of any Interconnection Request with a later queue priority date.

Network Upgrades – Additions, modifications, and upgrades to Transmission Provider's Transmission System required at or beyond the point at which the Small Generating

Facility interconnects with Transmission Provider's Transmission System to accommodate the interconnection of the Small Generating Facility with Transmission Provider's Transmission System. Network Upgrades do not include Distribution Upgrades.

Operating Requirements – Any operating and technical requirements that may be applicable due to Regional Transmission Organization, Independent System Operator, Balancing Authority Area, or Transmission Provider's requirements, including those set forth in the Small Generator Interconnection Agreement.

Party or Parties – Transmission Provider, Transmission Owner, Interconnection Customer or any combination of the above.

Point of Interconnection – The point where the Interconnection Facilities connect with Transmission Provider's Transmission System.

Reasonable Efforts – With respect to an action required to be attempted or taken by a Party under the Small Generator Interconnection Agreement, efforts that are timely and consistent with Good Utility Practice and are otherwise substantially equivalent to those a Party would use to protect its own interests.

Small Generating Facility – Interconnection Customer's device for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include Interconnection Customer's Interconnection Facilities.

Tariff – Transmission Provider or Affected System's Tariff through which open access transmission service and Interconnection Service are offered, as filed with the FERC, and as amended or supplemented from time to time, or any successor tariff.

Transmission Owner – The entity that owns, leases or otherwise possesses an interest in the portion of the Transmission System at the Point of Interconnection and may be a Party to the Small Generator Interconnection Agreement to the extent necessary.

Transmission Provider – The public utility (or its designated agent) that owns, controls, or operates transmission or distribution facilities used for the transmission of electricity in interstate commerce and provides transmission service under the Tariff. The term Transmission Provider should be read to include the Transmission Owner when the Transmission Owner is separate from Transmission Provider.

Transmission System – The facilities owned, controlled or operated by Transmission Provider or the Transmission Owner that are used to provide transmission service under the Tariff.

Upgrades – The required additions and modifications to Transmission Provider's Transmission System at or beyond the Point of Interconnection. Upgrades may be

Network Upgrades or Distribution Upgrades. Upgrades do not include Interconnection Facilities.

Attachment 2

Description and Costs of the Small Generating Facility, Interconnection Facilities, and Metering Equipment

Equipment, including the Small Generating Facility, Interconnection Facilities, and metering equipment shall be itemized and identified as being owned by Interconnection Customer, Transmission Provider, or the Transmission Owner. Transmission Provider will provide a best estimate itemized cost, including overheads, of its Interconnection Facilities and metering equipment, and a best estimate itemized cost of the annual operation and maintenance expenses associated with its Interconnection Facilities and metering equipment.

Attachment 3

**One-line Diagram Depicting the Small Generating Facility, Interconnection
Facilities, Metering Equipment, and Upgrades**

Attachment 4

Milestones

In-Service Date: _____

Critical milestones and responsibility as agreed to by the Parties:

	Milestone/Date	Responsible Party
(1)	_____	_____
(2)	_____	_____
(3)	_____	_____
(4)	_____	_____
(5)	_____	_____
(6)	_____	_____
(7)	_____	_____
(8)	_____	_____

(9) _____

(10) _____

Agreed to by:

For Transmission Provider _____ Date _____

For Transmission Owner (If Applicable) _____
Date _____

For Interconnection Customer _____ Date _____

Attachment 5

**Additional Operating Requirements for Transmission Provider's
Transmission System and Affected Systems Needed to Support
Interconnection Customer's Needs**

Transmission Provider shall also provide requirements that must be met by Interconnection Customer prior to initiating parallel operation with Transmission Provider's Transmission System.

Attachment 6

**Transmission Provider’s Description of its Upgrades
and Best Estimate of Upgrade Costs**

Transmission Provider shall describe Upgrades and provide an itemized best estimate of the cost, including overheads, of the Upgrades and annual operation and maintenance expenses associated with such Upgrades. Transmission Provider shall functionalize Upgrade costs and annual expenses as either transmission or distribution related.

_____ * To be completed in
coordination with Transmission Provider.

Is the Small Generating Facility located in Transmission Provider’s service area?

Yes _____ No _____ If No, please provide name of local provider:

Please provide the following proposed schedule dates:

Begin Construction Date: _____

Generator step-up transformers Date: _____

receive back feed power

Generation Testing

Date: _____

Commercial Operation

Date: _____

such a fault on the transmission system for a voltage level as low as zero volts, as measured at the high voltage side of the wind GSU.

2. This requirement does not apply to faults that would occur between the wind generator terminals and the high side of the GSU.
3. Wind generating plants may be tripped after the fault period if this action is intended as part of a special protection system.
4. Wind generating plants may meet the LVRT requirements of this standard by the performance of the generators or by installing additional equipment (e.g., Static VAR Compensator) within the wind generating plant or by a combination of generator performance and additional equipment.

Existing individual generator units that are, or have been, interconnected to the network at the same location at the effective date of the Appendix G LVRT Standard are exempt from meeting the Appendix G LVRT Standard for the remaining life of the existing generation equipment. Existing individual generator units that are replaced are required to meet the Appendix G LVRT Standard.

ii. Power Factor Design Criteria (Reactive Power)

The following reactive power requirements apply only to a newly interconnecting wind generating plant that has executed a Facilities Study Agreement as of the effective date of the Final Rule establishing the reactive power requirements for non-synchronous generators in article 9.6.1 of this LGIA (Order No. 827). A wind generating plant to which this provision applies shall maintain a power factor within the range of 0.95 leading to 0.95 lagging, measured at the Point of Interconnection as defined in this LGIA, if Transmission Provider's Cluster Study shows that such a requirement is necessary to ensure safety or reliability. The power factor range standard can be met by using, for example, power electronics designed to supply this level of reactive capability (taking into account any limitations due to voltage level, real power output, etc.) or fixed and switched capacitors if agreed to by Transmission Provider, or a combination of the two. Interconnection Customer shall not disable power factor equipment while the wind plant is in operation. Wind plants shall also be able to provide sufficient dynamic voltage support in lieu of the power system stabilizer and automatic voltage regulation at the generator excitation system if the Cluster Study shows this to be required for system safety or reliability.

iii. Supervisory Control and Data Acquisition (SCADA) Capability

The wind plant shall provide SCADA capability to transmit data and receive instructions from Transmission Provider to protect system reliability. Transmission Provider and the wind plant Interconnection Customer shall determine what SCADA

information is essential for the proposed wind plant, taking into account the size of the plant and its characteristics, location, and importance in maintaining generation resource adequacy and transmission system reliability in its area.

Appendix H to LGIA

Operating Assumptions for Generating Facility

Check box if applicable { }

Operating Assumptions:

{insert operating assumptions that reflect the charging behavior of the Generating Facility that includes at least one electric storage resource}

..

tion of Affected System Network Upgrade(s)

Dear {Name or Title}:

This letter is sent pursuant to the Multiparty Affected System Facilities Construction Agreement among {Transmission Provider} and {Affected System Interconnection Customers}, dated _____, 20__.

On {Date}, Transmission Provider completed to its satisfaction all work on the Affected System Network Upgrade(s) required to facilitate the safe and reliable interconnection and operation of Affected System Interconnection Customer's generating facilities. Transmission Provider confirms that the Affected System Network Upgrade(s) are in place.

Thank you.

{Signature}

{Transmission Provider Representative}

**Attachment C to Appendix 12
Multiparty Affected System Facilities Construction Agreement**

EXHIBITS

This Appendix C is a part of the Multiparty Affected System Facilities Construction Agreement among Affected System Interconnection Customers and Transmission Provider.

Exhibit A1

Transmission Provider Site Map

Exhibit A2

Site Plan

Exhibit A3

Affected System Network Upgrade(s) Plan & Profile

Exhibit A4

Estimated Cost of Affected System Network Upgrade(s)

	Location	Facilities to Be Constructed by Transmission Provider	Estimate in Dollars

		Total:	
--	--	---------------	--

Document Content(s)

Transmittal Letter.PDF.....1
Attachment A1.rtf.....10
Attachment A2.rtf.....241
Attachment A3.rtf.....369
Attachment A4.rtf.....458
Attachment B1.rtf.....507
Attachment B2.rtf.....738
Attachment B3.rtf.....866
Attachment B4.rtf.....955
FERC GENERATED TARIFF FILING.rtf.....1004